

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps A Ø	0.0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps B Ø	0.0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps C Ø	0.0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushing Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	9 Month Operations	5	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	General Comments		
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations A Ø	0	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations B Ø	0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations C Ø	0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations Ground	0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Follow-up Action Required?	n	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Foundation Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	General Comments		
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	General Comments		
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Grounds in Place?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Maintenance Operations	0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AF	264	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AL	0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations This Read Vac	0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Switching Operations	0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Unknown Operations	0	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Regulator As Left Counter	194812	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	General Comments		
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Vegetation	None	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Regulator As Left Counter	77775	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushing Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps C Ø	27.0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps B Ø	28.0	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	9 Month Operations	24	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps A Ø	56.0	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps B Ø	64.0	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps C Ø	48.0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	General Comments		
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps A Ø	30.0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Battery Overall Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	All Connections OK?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	General Comments		
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Foundation Condition	Good	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Follow-up Action Required?	n	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Follow-up Action Required?	n	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations Ground	0	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CVVT Properly Grounded?	y	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations A Ø	0	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations C Ø	3	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations B Ø	0	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations C Ø	0	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CVVT Visible Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	General Comments	Counter not working	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	General Comments	LTC is a little low	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations Ground	0	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	9 Month Operations	7	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps A Ø	3.0	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Found Counter	54479	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Left Counter	54479	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps B Ø	7.0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps C Ø	2.0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushing Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations A Ø	0	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Current Tap Position	11L	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Max Tap Position	5L	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Min Tap Position	15L	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Follow-up Action Required?	n	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Regulator As Left Counter	74021	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations B Ø	3	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations A Ø	3	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps C Phase V	2.15	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	General Comments		
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Unknown Operations	0	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Switching Operations	1	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations This Read Vac	9	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AL	222	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AF	222	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Maintenance Operations	8	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps A Phase V	2.15	
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps B Phase V	2.15	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	General Comments		
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Regulator As Left Counter	356996	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	General Comments		
4/15/2022 10:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	General Comments		
4/15/2022 10:48	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Grounds in Place?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Grounds in Place?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	General Comments	BFTC	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	General Comments		
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Foundation Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Follow-up Action Required?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations Ground	0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations C Ø	0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations B Ø	0	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	General Comments		
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/15/2022 15:08	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	General Comments	BFTC	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	General Comments		
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Foundation Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Follow-up Action Required?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations Ground	0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations C Ø	0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations B Ø	0	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	General Comments		
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps C Ø	0	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	General Comments		
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps B Ø	7	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Operations Counter	217	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	General Comments	BFTC	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Operations Counter	38	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	General Comments		
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Unknown Operations	0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Switching Operations	1	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations This Read Vac	1	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AL	200	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AF	199	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	General Comments	counter read wrong last qtr	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	548	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.0	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Regulator As Left Counter	45442	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.0	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps C Ø	18.0	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	388	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	449	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Maintenance Operations	0	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Maintenance Operations	0	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	General Comments		
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps A Ø	0	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Regulator As Left Counter	100096	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/15/2022 15:18	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/15/2022 10:24	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/15/2022 13:33	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations A Ø	0	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	General Comments		
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
4/15/2022 11:55	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/15/2022 15:08	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/15/2022 10:51	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/14/2022 13:33	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakersSF6	830-618	GCB Patrol Inspection	Ambient Temperature	52	°F
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BCH001545	Charger	812-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations Counter AL	166	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations Counter AF	166	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Maintenance Operations	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Operations Since Last Insp	953	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/14/2022 13:33	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	General Comments	y	
4/14/2022 13:33	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 13:33	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:33	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:33	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	General Comments		
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/14/2022 13:33	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 13:33	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations C Ø	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	General Comments		
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations B Ø	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations A Ø	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps C Ø	107	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps B Ø	92	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps A Ø	108	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	9 Month Operations	1	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations Ground	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations C Ø	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations B Ø	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations A Ø	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BAT001625	Battery	812-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps C Ø	6	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps B Ø	15	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps A Ø	13	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	9 Month Operations	2	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Unknown Operations	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Switching Operations	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations This Read Vac	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations Counter AL	183	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations Counter AF	183	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Maintenance Operations	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations Ground	0	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations A Ø	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations B Ø	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations C Ø	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations Ground	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	General Comments	counter readingentered wrong last qtr inspection	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Maintenance Operations	0	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations Counter AF	182	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations Counter AL	182	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations This Read Vac	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Switching Operations	0	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	9 Month Operations	4	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations This Read Vac	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Switching Operations	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Unknown Operations	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	LTC Totalizer Reading	5457.60	kw
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Min Tap Position	9L	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Max Tap Position	3R	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Current Tap Position	2L	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Left Counter	55540	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Found Counter	55533	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	General Comments	counter reading entered wrong last qtr check	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations A ∅	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations B ∅	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations C Ø	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations Ground	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Max	40	°C
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Vegetation	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Reading	.3790	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Max	40	°C
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Present	30	°C
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	9 Month Operations	2	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty A Ph V	1.18	%
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty B Ph V	1.18	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps A Phase V	26.75	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps B Phase V	26.75	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps C Phase V	26.75	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations A Ø	0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps A Ø	151.0	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps B Ø	139.0	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps C Ø	157.0	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Vegetation	None	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	General Comments		
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 13:47	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/14/2022 13:29	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations This Read Vac	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Switching Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	LTC Totalizer Reading	9378.00	kw
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AL	53	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AF	53	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Switching Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations This Read Vac	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3330.24	kw
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations Ground	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations C Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations B Ø	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations A Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Regulator As Left Counter	49539	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	34	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	34	°C
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Maintenance Operations	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations Ground	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Regulator As Left Counter	51335	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Min Tap Position	9L	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8592	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Max	60	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Present	42	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Unknown Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps A Ø	140.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	9 Month Operations	2	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Switching Operations	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations This Read Vac	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AL	224	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AF	222	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps B Ø	135.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps C Ø	145.0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Grounds in Place?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps A Ø	150.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps B Ø	150.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps C Ø	150.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Maintenance Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AF	236	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AL	238	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations This Read Vac	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Regulator As Left Counter	42780	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Unknown Operations	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Switching Operations	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Max Tap Position	2R	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Current Tap Position	6L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Present	36	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	8248.32	kw
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Maintenance Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	9 Month Operations	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Maintenance Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps A Ø	40.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps B Ø	45.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps C Ø	45.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushing Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Regulator As Left Counter	134014	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	9 Month Operations	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	LTC Operation Checked?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Base Voltage AF	124	VAC
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Base Voltage AL	124	VAC
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Time Delay	30	Seconds
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty C Ph V	.7	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps A Ø	180	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps B Ø	180	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps C Ø	180	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps A Ø	30	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps B Ø	30	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps C Ø	35	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Present	35	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Max	40	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Reading	.5210	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Unknown Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Switching Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty C Ph V	.41	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations Ground	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty A Ph V	1.22	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	9 Month Operations	2	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations This Read Vac	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AL	680	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AF	680	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Operations Counter	940	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	General Comments	fort knox test	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Maintenance Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AF	71	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AL	71	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations This Read Vac	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Switching Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Maintenance Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AF	296	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AL	298	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3469	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.3	VDC
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations This Read Vac	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Switching Operations	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Unknown Operations	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.1	VDC
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Vegetation	None	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps A Ø	0.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps B Ø	0.0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps C Ø	0.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations B Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps C Ø	20	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps B Ø	20	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps A Ø	20	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty C Ph V	13.46	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty B Ph V	15.84	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty A Ph V	14.26	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	9 Month Operations	10	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps A Ø	105.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps B Ø	130.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps C Ø	105.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Maintenance Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AF	380	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AL	383	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations This Read Vac	3	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Switching Operations	3	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Unknown Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Regulator As Left Counter	118217	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations C Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AL	140	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AF	140	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Maintenance Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Unknown Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Max	35	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Present	30	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	LTC000618	LTCControl	642-1 B	LTC Control Insp	All Connections OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2160	kw
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	9 Month Operations	3	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Min Tap Position	4R	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	9 Month Operations	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps C Ø	0.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps B Ø	0.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps A Ø	0.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty C Ph V	7.2	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty B Ph V	7.2	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty A Ph V	7.2	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	9 Month Operations	9	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Unknown Operations	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Switching Operations	1	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations This Read Vac	1	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AL	220	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AF	219	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Maintenance Operations	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations Ground	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations C Ø	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations B Ø	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations A Ø	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps C Ø	25	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	9 Month Operations	1	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps B Ø	25	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps A Ø	24	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps A Ø	1.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps B Ø	1.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps C Ø	1.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations B Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations A Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps C Ø	50	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps B Ø	60	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps A Ø	60	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	9 Month Operations	10	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	9 Month Operations	8	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty A Ph V	23.04	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty B Ph V	34.56	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty C Ph V	10.08	%
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Switching Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations This Read Vac	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AL	69	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Operations Counter AF	69	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Maintenance Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps A Ø	5.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps B Ø	5.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps C Ø	5.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations Ground	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations Ground	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	General Comments	fort knox test	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Maintenance Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Foundation Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Maintenance Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AF	400	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AL	402	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations This Read Vac	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Switching Operations	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Unknown Operations	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Ambient Temp	72	F
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Vegetation	None	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Unknown Operations	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Switching Operations	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations This Read Vac	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AL	296	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AF	296	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Maintenance Operations	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations Ground	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations Ground	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps C Ø	0.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps B Ø	0.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps A Ø	0.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	87.84	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.1	VDC
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.2	VDC
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	87.84	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	87.84	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	9 Month Operations	1	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Vegetation	None	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Unknown Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Switching Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	All Connections OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Operation Checked?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps C Ø	36.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps B Ø	36.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps A Ø	40.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	2.88	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	2.88	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AF	105	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AL	105	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations This Read Vac	1	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	2.88	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	9 Month Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Switching Operations	1	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps C Ø	80.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps B Ø	85.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps A Ø	70.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	9 Month Operations	2	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Switching Operations	1	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations This Read Vac	1	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AL	289	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AF	289	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Maintenance Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Unknown Operations	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	General Comments	fort knox test	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations Ground	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps B Ø	125.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps C Ø	125.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations A Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations B Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations C Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	9 Month Operations	4	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps A Ø	125.0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Maintenance Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AF	275	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AL	275	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations This Read Vac	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Switching Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps A Ø	15	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps B Ø	15	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps C Ø	19	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps C Ø	335.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps B Ø	355.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps A Ø	300.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	9 Month Operations	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps B Ø	155.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps C Ø	160.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	49134	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	49134	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	1L	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations A Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations B Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations C Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations Ground	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Maintenance Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AF	673	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AL	673	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations This Read Vac	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Switching Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Unknown Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Operations Counter	106	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps C Ø	40	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps B Ø	43	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps A Ø	50	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9828	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps C Ø	10	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps B Ø	15	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps A Ø	10	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	9 Month Operations	11	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	9 Month Operations	7	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps A Ø	150.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps B Ø	150.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps C Ø	150.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Switching Operations	1	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations This Read Vac	1	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AL	119	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AF	119	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Maintenance Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	General Comments	fort knox test	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	9 Month Operations	8	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty A Ph V	15.36	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty B Ph V	17.2	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty C Ph V	15.97	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps A Ø	1.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps B Ø	1.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps C Ø	0.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations Ground	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7076.16	kw
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Operations Since Last Insp	666	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Min Tap Position	6L	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Max Tap Position	1R	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Current Tap Position	6R	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Left Counter	65685	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Found Counter	65685	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	215	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	Neutral	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Left Counter	55370	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Found Counter	55370	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps A Ø	40	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty C Ph V	8.71	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty B Ph V	13.47	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty A Ph V	9.51	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	9 Month Operations	8	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Operations Since Last Insp	924	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Min Tap Position	11L	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Current Tap Position	7L	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Left Counter	217918	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Found Counter	217914	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	LTC Totalizer Reading	13852.80	kw
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Max	45	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Present	45	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Reading	.9620	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Max	50	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Present	45	°C
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Regulator Patrol Inspection	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations This Read Vac	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AL	668	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AF	668	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Maintenance Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations A Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps A Ø	400.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps B Ø	400.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps C Ø	400.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Maintenance Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AF	223	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AL	223	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Switching Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Unknown Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps C Ø	50	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps B Ø	50	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Regulator As Left Counter	54525	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Vegetation	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Unknown Operations	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Switching Operations	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations This Read Vac	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AL	224	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AF	224	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Maintenance Operations	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations Ground	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations C Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations B Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations A Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Vegetation	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Current Tap Position	4L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Max Tap Position	8L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Min Tap Position	3R	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Regulator As Left Counter	52721	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Switching Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations This Read Vac	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AL	125	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AF	125	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Maintenance Operations	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations Ground	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations B Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations A Ø	0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps C Ø	34.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps B Ø	34.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps A Ø	37.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty C Ph V	27.36	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty B Ph V	31.68	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty A Ph V	31.68	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	9 Month Operations	5	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Max Tap Position	5R	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	All Connections OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Operation Checked?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Operation Checked?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	All Connections OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations Ground	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations C Ø	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations A Ø	1	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps A Phase V	5.46	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Grounds in Place?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Foundation Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Bushing Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Grounds in Place?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Foundation Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Unknown Operations	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Switching Operations	1	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations This Read Vac	2	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AL	178	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AF	177	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Maintenance Operations	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Operations Counter	1835	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Vegetation	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Found Counter	82979	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Left Counter	82984	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Current Tap Position	4L	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Max Tap Position	1R	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Min Tap Position	11L	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Operations Since Last Insp	774	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	LTC Totalizer Reading	5955.84	kw
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Regulator As Left Counter	123193	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Min Tap Position	5R	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps C Ø	144	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps B Ø	135	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps A Ø	137	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty C Ph V	.81	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty A Ph V	2.03	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	9 Month Operations	2	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Reading	.6204	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Present	38	°C
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Max	38	°C
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	LTC Operation Checked?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	All Connections OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps A Ø	80	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps B Ø	80	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps C Ø	80	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations	3	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty A Ph V	.22	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Maintenance Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Regulator As Left Counter	118071	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AF	350	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AL	350	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations This Read Vac	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Switching Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Unknown Operations	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty C Ph V	.88	%
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps A Ø	130	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps B Ø	132	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps C Ø	130	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations A Ø	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations B Ø	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations C Ø	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations Ground	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Unknown Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Switching Operations	1	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations This Read Vac	5	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AL	191	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AF	186	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Maintenance Operations	4	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Maintenance Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AF	82	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AL	82	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations This Read Vac	1	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Switching Operations	1	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Unknown Operations	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.8	VDC
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26	VDC
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	9 Month Operations	2	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty A Ph V	.74	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty B Ph V	.74	%
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty C Ph V	.74	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps A Ø	258	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps B Ø	230	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps C Ø	245	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations B Ø	0	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Max Tap Position	9L	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Min Tap Position	3R	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations C Ø	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Regulator As Left Counter	31809	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Regulator As Left Counter	127353	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations Ground	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations C Ø	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Maintenance Operations	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations B Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AF	222	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AL	222	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations This Read Vac	1	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Switching Operations	1	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Unknown Operations	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps C Ø	320.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps B Ø	290.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps A Ø	295.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	9 Month Operations	6	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	General Comments		
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Vegetation	None	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTC000626	LTCControl	408-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	61	°F
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Reading	.4543	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Regulator As Left Counter	127625	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	General Comments		
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Present	40	°C
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Max	40	°C
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Reading	.315	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Present	38	°C
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Max	40	°C
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	LTC Totalizer Reading	4361.28	kw
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps C Ø	115.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps B Ø	90.0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps A Ø	100.0	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations A Ø	0	
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations B Ø	0	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	All Connections OK?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Follow-up Action Required?	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	General Comments		
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Operation Checked?	y	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:48	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Switching Operations	1	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/13/2022 14:08	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	9 Month Operations	2	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	7.200	millivolts
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	General Comments		
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.2	VDC
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.1	VDC
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	9 Month Operations	2	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	9 Month Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty A Ph V	.74	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty B Ph V	.74	%
4/13/2022 14:50	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty C Ph V	.74	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	9 Month Operations	4	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty A Ph V	4.38	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty B Ph V	5.25	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty C Ph V	2.63	%
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps A Ø	20	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps B Ø	20	
4/14/2022 5:29	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 13:44	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps C Ø	20	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 11:22	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Present	28	°C
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Max	34	°C
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4	psi
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	LTC Totalizer Reading	5670	kw
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	General Comments		
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 10:17	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 16:04	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Unknown Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Switching Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations This Read Vac	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Switching Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	9 Month Operations	21	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AF	95	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AL	95	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations This Read Vac	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Switching Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Unknown Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	115	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Maintenance Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Operations Counter AF	63	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	9 Month Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations This Read AM	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	409	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	409	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	TV Winding Temp Max	0	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	TV Winding Temp Present	0	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Winding Temp Max	0	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Winding Temp Present	0	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	41	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	41	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Switching Operations	1	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Operations Counter AL	63	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Operations This Read Vac	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	297	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	3	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	3	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	General Comments	vacuum monitor self-check and vacuum monitor antenna needs to be checked	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	267	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	267	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AF	57	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AL	57	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Operations Counter AF	94	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Operations Counter AL	94	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Operations This Read Vac	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	115	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Unknown Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps A Ø	112.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps B Ø	95.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps C Ø	103.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	41	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Present	0	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Max	0	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Present	0	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Amps A Ø	280.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AF	194	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AL	194	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Amps B Ø	265.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Readings	Amps C Ø	308.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps B Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps A Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	9 Month Operations	1	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps A Ø	249.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps B Ø	249.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps C Ø	250.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	9 Months Operations	5	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Left Counter	21344	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Found Counter	21344	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps C Ø	56.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	9 Month Operations	1	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	9 Month Operations	6	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps A Ø	294.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps B Ø	305.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps C Ø	301.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Maintenance Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations Counter AF	202	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations Counter AL	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations This Read Vac	4	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Switching Operations	4	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Unknown Operations	0	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	249	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps C Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps B Ø	51.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Min Tap Position	11L	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps A Ø	51.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Max Tap Position	5L	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	General Comments	only oil x1, x2, and x3 readings	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H1 Winding Temp Max	41	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H1 Winding Temp Present	30	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	41	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	9 Month Operations	3	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps A Ø	58.0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps B Ø	56.0	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Current Tap Position	10L	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	41	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	HV Winding Temp Max	41	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations A Ø	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations B Ø	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations C Ø	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations Ground	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	HV Winding Temp Present	30	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	41	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	30	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	General Comments	OK	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Maintenance Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AF	195	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Oil Temp Max	38	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AL	195	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations This Read Vac	1	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Switching Operations	1	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AF	124	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AL	124	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations This Read Vac	4	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Switching Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Unknown Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Vacuum Monitor Self-Check OK?	na	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001931	BreakerVacuum	TA-12KV BUS TIE SEC 4	VCB Patrol Inspection	Vacuum Monitor Antenna Paint	NA	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Switching Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	0	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	0	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Operations This Read Vac	3	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	9 Month Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Operations Counter AL	69	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Operations Counter AF	69	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	9 Month Operations	5	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps A Ø	119.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps B Ø	141.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps C Ø	123.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Operations Counter AF	75	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Operations Counter AL	75	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Operations This Read Vac	1	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Switching Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations This Read AM	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AL	123	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AF	123	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Maintenance Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	9	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations A Ø	2	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations B Ø	2	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	General Comments	A and B phase IOC	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	29	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Switching Operations	1	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Operations This Read Vac	8	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Operations Counter AL	86	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Operations Counter AF	86	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Maintenance Operations	7	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	General Comments	vacuum monitor self- check and vacuum monitor antenna needs to be looked into	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Switching Operations	1	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Unknown Operations	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.4	VDC
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.3	VDC
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	General Comments	ok	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Operations Counter AF	70	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Operations Counter AL	70	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Operations This Read Vac	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Switching Operations	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Unknown Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Maintenance Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AF	187	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AL	187	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations This Read Vac	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Switching Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	LTC Operation Checked?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	All Connections OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps A Ø	40.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps B Ø	39.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps C Ø	39.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Vacuum Monitor Self-Check OK?	na	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Vacuum Monitor Antenna Paint	NA	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AF	127	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AL	127	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations This Read Vac	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Switching Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Operations Counter AF	83	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Operations Counter AL	83	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AL	183	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations This Read Vac	1	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Switching Operations	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Operations This Read Vac	1	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Amps C Ø	0.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Amps B Ø	0.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	9 Months Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Amps A Ø	0.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	9 Month Operations	29	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	58.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	59.0	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Amps A Ø	108.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Amps B Ø	107.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	56.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Amps C Ø	164.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Switching Operations	2	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Vacuum Monitor Antenna Paint	NA	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Vacuum Monitor Self-Check OK?	na	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	9 Month Operations	17	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Switching Operations	2	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations This Read Vac	2	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AL	255	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AF	255	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Maintenance Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001930	BreakerVacuum	TA-1134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Negative DC Ground	0.0	VDC
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AF	236	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AL	236	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Switching Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	9 Month Operations	3	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF001262	PowerFuse	SW-B 14KV GND RLY POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF001262	PowerFuse	SW-B 14KV GND RLY POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Operations Counter AL	70	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Operations This Read Vac	2	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	570	*F
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps A Ø	108.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps B Ø	126.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps C Ø	99.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	All Connections OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Operation Checked?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	9 Month Operations	22	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Amps A Ø	143.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Amps B Ø	129.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Amps C Ø	131.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	VRR Time Delay	0	Seconds
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	General Comments		water in front door cleaned seals area. Seal looks good
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Maintenance Operations	1	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Moisture and Leak Free?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AF	183	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Fault Operations Ground	0	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	165	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	165	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	General Comments		Need to check into vacuum monitor self check and vacuum monitor antenna needs to be looked into
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	General Comments		Racked out
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC As Found Counter	2803	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC As Left Counter	2803	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	29	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	391	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Amps C Ø	367.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Amps B Ø	348.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Amps A Ø	350.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001940	BreakerVacuum	TA-1131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	9 Month Operations	27	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001929	BreakerVacuum	TA-1133	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	9 Month Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	9 Month Operations	25	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	LTC Operation Checked?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001938	BreakerVacuum	TA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	4	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Amps A Ø	128.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Amps B Ø	136.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Operations C Ø	1	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Operations B Ø	2	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps C Ø	0.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps B Ø	0.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps A Ø	0.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001941	BreakerVacuum	TA-1130	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	61	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	140.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	145.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	131.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	9 Month Operations	30	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001939	BreakerVacuum	TA-1105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK001942	BreakerVacuum	TA-1172	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	29	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	General Comments		
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	1219	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	50	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	13L	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Left Counter	252500	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Found Counter	252500	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	804	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.1	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.9	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.1	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	877	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Present	40	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Max	45	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Reading	.5156	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Regulator As Left Counter	66124	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Max	35	°C
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	LTC Totalizer Reading	6570.72	kw
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	28	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	29	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	29	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	28	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Unknown Operations	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Switching Operations	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AL	161	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AF	161	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Maintenance Operations	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations B Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	1	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	1	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	99	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	99	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	27	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Present	40	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Max	65	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	General Comments	fan in control house not working	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	LTC Totalizer Reading	7424.64	kw
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Operations Counter	485	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	General Comments		
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.5	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps B Ø	19.9	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps A Ø	16.8	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2100	psi
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	General Comments		
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	269	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.1	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps B Ø	4.2	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.5	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	196	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	236	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	General Comments		
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AL	156	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AF	156	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	General Comments	DNO	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	General Comments	Whole station needs wildlife protection and fiberglass is exposed on all xfmr fuse barrels including spare.	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations C Ø	0	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps B Ø	16.1	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.9	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	210	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	195	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	General Comments		
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Switching Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations This Read AM	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AL	59	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AF	59	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	General Comments	OK	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps C Ø	115.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps B Ø	105.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps A Ø	126.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	383	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	9 Month Operations	1	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	General Comments	ok	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps C Ø	340.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps B Ø	312.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps A Ø	326.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	9 Months Operations	0	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	General Comments	need 3 8ft single pin lights replaced to LED	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Present	30	°C
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Max	40	°C
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Reading	.4563	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps C Ø	0.0	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps B Ø	0.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps A Ø	0.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations	0	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	General Comments		
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Broom on Site?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	General Comments	There are several places where rain has leaked into house where wall meets the floor.	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Moisture and Leak Free?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Present	51	*C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	General Comments	ok	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Ambient Temp	79	*F
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	*C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Max	28	*C
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	52	*C
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	46	*C
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	*C
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	47	*C
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	45	*C
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	*C
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Max	41	*C
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Present	41	*C
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	General Comments		
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.6	VDC
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Max	56	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps C Ø	573.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps B Ø	567.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps A Ø	550.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Months Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.6	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.9	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.3	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Operations Counter	252	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Unknown Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	REMOVED ONE FAN FOR REPAIR	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Switching Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations This Read Vac	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AL	1167	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AF	1167	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Maintenance Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	General Comments	DNO	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations Ground	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations C Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations B Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.3	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.9	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.5	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	General Comments		
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	General Comments	ok	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations This Read AM	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AL	577	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AF	577	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.3	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.5	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	307	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	254	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	9 Months Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps A Ø	74.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps B Ø	66.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps C Ø	74.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	General Comments	OK	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Maintenance Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AF	189	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AL	189	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps C Ø	222.0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps B Ø	240.0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps A Ø	216.0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	1	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	9 Month Operations	5	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	183	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps A Ø	16.2	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Max	36	°C
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Present	36	°C
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	General Comments		
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations This Read AM	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Switching Operations	0	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	General Comments	ok	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Max	77	°C
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations A Ø	0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations B Ø	0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations C Ø	0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations Ground	0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	General Comments	2 switching ops	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	General Comments	ok	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Maintenance Operations	0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AF	250	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AL	250	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations This Read Vac	2	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Switching Operations	2	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Unknown Operations	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps A Phase V	2.12	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps B Phase V	6.36	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps C Phase V	4.24	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations A Ø	1	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations B Ø	3	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations C Ø	2	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations Ground	0	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	General Comments	1 AB 50, 2 BC 50 ops	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	General Comments	ok	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Maintenance Operations	0	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AF	241	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AL	241	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations This Read Vac	6	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Switching Operations	0	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Unknown Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps A Ø	200.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps C Ø	250.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AF	86	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AL	86	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Switching Operations	0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	9 Month Operations	6	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps A Ø	46.0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps B Ø	32.0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps C Ø	37.0	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Undetermined	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	LTC Totalizer Reading	7200.00	kw
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	60	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Found Counter	73754	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Left Counter	73754	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Current Tap Position	3L	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Min Tap Position	9L	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	General Comments		
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1090.80	kw
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	361.67	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	335.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Max	35	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Reading	.5000	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Max	40	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Present	30	°C
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Regulator As Left Counter	56683	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Current Tap Position	5R	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	462	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	9 Month Operations	8	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	9 Months Operations	11	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	512	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	42	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Min Tap Position	16L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Max Tap Position	10L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Current Tap Position	13L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Left Counter	234190	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Found Counter	234190	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Found Counter	81262	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Left Counter	81262	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	288	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Found Counter	70772	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Left Counter	70772	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	9L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	6L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	14L	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	250	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Found Counter	28202	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Left Counter	28202	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	383	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	9 Months Operations	4	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Current Tap Position	8R	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps A Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps B Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps C Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AF	422	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AL	422	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations This Read AM	2	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Switching Operations	2	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Present	42	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Max	42	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	General Comments	needs nitro	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	General Comments	No door alarm on swgr doors. There is lots of rust on the lower walls and edges of the floor in the swgr. Holes are developing in the wal	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	2	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	53.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	43.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	32.0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	General Comments	ok	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	General Comments		
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Unknown Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Switching Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations This Read Vac	0	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AL	99980	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AF	99980	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Maintenance Operations	0	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	177	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations Ground	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations C Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations B Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations A Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.9	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Regulator As Left Counter	46230	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	52	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4008	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	General Comments		Wild-life protection needed
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	318	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	101.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	80.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	98.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Vegetation	None	Need size info and qty

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Operations Since Last Insp	204	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	General Comments	ok	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations This Read AM	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	318	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps A Ø	280.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps B Ø	265.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps C Ø	308.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AF	94	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AL	94	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations This Read Vac	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Switching Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	37	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	480.96	kw
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Max	30	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	42	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	35	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	42	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	40	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	45	°C
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 12:21	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3030	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	9 Month Operations	4	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps A Ø	45.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps B Ø	65.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps C Ø	49.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations A Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations B Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations C Ø	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations Ground	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Maintenance Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AF	156	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AL	156	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations This Read Vac	4	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Switching Operations	4	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Unknown Operations	0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	9 Month Operations	2	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.6	VDC
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.6	VDC
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps B Ø	300.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps A Ø	290.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	9 Month Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Tank Oil Level	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	PT Free of Leaks?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations This Read AM	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AL	212	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AF	212	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Maintenance Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations C Ø	0	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	416	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	416	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	230.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	241.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	258.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations This Read AM	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	81	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	81	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Found Counter	21902	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Left Counter	21902	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Current Tap Position	2L	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Max Tap Position	1L	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Min Tap Position	8L	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	131.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	148.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	137.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Vegetation	None	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	4	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	9 Month Operations	2	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Present	25	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Max	25	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1280	psi
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.1	psi
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	20	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	122.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	122.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	117.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AL	396	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AF	396	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	1	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	20	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps A Ø	70.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps B Ø	50.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps C Ø	50.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Unknown Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Switching Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps C Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps B Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps A Ø	50.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	306	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	35	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	35	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	29	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	29	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	22	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	22	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	9 Months Operations	19	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	619	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	619	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	41	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	61	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	58	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	60	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	64	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Current Tap Position	Neutral	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Left Counter	81685	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Found Counter	81685	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Present	40	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Max	50	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps C Ø	275.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Maintenance Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Maintenance Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AF	506	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AL	506	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Unknown Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	116.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	110.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	3	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5382	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	9 Months Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	353	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	353	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments	open	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations Ground	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Ambient Temp	62	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	General Comments	Standing water behind TR1	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	General Comments		
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1291.68	kw
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	145.00	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Max	36	°C
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	111.0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps B Ø	0.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps C Ø	0.0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	3	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	General Comments		
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps C Ø	169.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps B Ø	149.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps A Ø	159.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	9 Months Operations	0	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	General Comments	ok	
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Negative DC Ground	133.0	VDC
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/12/2022 15:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Regulator As Left Counter	293457	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps A Ø	0.0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	9 Months Operations	1	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	General Comments		
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	495.84	kw
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6198	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	2	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps C Ø	96.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps B Ø	95.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps A Ø	97.0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	General Comments		
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Regulator As Left Counter	281200	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Switching Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations This Read AM	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AL	536	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AF	536	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations This Read AM	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	620	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	620	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Operations Since Last Insp	274	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Maintenance Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AF	602	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AL	602	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Switching Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Unknown Operations	0	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	87.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	94.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	93.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	49	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	49	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations This Read AM	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Regulator As Left Counter	312960	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	9 Month Operations	2	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps A Ø	75.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps B Ø	70.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps C Ø	75.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations This Read AM	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AL	367	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AF	367	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Maintenance Operations	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations C Ø	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Ambient Temp	63	*F
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	580	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	580	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Unknown Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Switching Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations This Read Vac	0	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Regulator As Left Counter	66688	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AL	525	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AF	525	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Regulator As Left Counter	60383	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Maintenance Operations	0	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	General Comments	No door alarm on swgr.	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	General Comments	Bottom insulators for B&C phase fuse holders have broken skirts.	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	598.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	621.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	661.0	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	49	
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	221	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Switching Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AL	510	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AF	510	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Maintenance Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps C Ø	100.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushing Condition	Good	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps C Ø	0.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps B Ø	0.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps A Ø	0.0	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	9 Month Operations	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps C Ø	50.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps B Ø	45.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps A Ø	50.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Current Tap Position	4L	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Max Tap Position	2L	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps B Ø	130.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps A Ø	95.0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	9 Month Operations	2	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Min Tap Position	8L	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Operations Since Last Insp	200	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	9 Month Operations	2	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	General Comments	ok	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations C Ø	0	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Found Counter	147791	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Unknown Operations	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Found Counter	83620	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Left Counter	83620	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Left Counter	147791	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations B Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations This Read Vac	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	General Comments		
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	General Comments	Needs new nitrogen gauge.	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	General Comments	ok	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Regulator As Left Counter	63446	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	General Comments		
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	General Comments		
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	184.0	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/13/2022 9:43	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	General Comments		
4/12/2022 16:11	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 13:29	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	164.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	176.0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	390	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	390	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Maintenance Operations	0	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AF	235	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AL	235	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations This Read AM	3	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Switching Operations	3	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	General Comments		
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations Ground	0	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/12/2022 10:09	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	General Comments		
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:31	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1634.40	kw
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	1	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	General Comments		
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/13/2022 5:02	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Operations Counter	421	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/12/2022 14:50	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 10:58	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	General Comments		
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6810	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
4/12/2022 13:13	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 13:20	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/12/2022 13:31	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	243	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	243	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations Counter AF	136	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Unknown Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations This Read Vac	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations Counter AL	136	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations This Read AM	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps C Ø	130.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps A Ø	127.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps B Ø	106.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps A Ø	20.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps B Ø	20.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5506.56	kw
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps C Ø	20.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AF	999	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AL	999	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations This Read AM	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Unknown Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5736	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Switching Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations Counter AL	165	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations Counter AF	165	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Maintenance Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations This Read Vac	1	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps B Ø	95.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps C Ø	85.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Present	45	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Max	52	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Switching Operations	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations This Read Vac	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations Counter AL	142	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	9 Month Operations	16	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Present	45	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Max	60	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Max	40	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Present	40	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	LTC Totalizer Reading	7296.00	kw
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Regulator As Left Counter	186781	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Maintenance Operations	10	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	44	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	27	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations Counter AF	68	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations Counter AL	68	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations This Read Vac	11	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Switching Operations	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Unknown Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps A Ø	61.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps B Ø	55.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps C Ø	62.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Present	25	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	37	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	55	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	47	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	42	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	42	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	4	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	4	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	27	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	9 Months Operations	16	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Switching Operations	1	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Switching Operations	1	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Unknown Operations	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	5	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	55	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	48	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	55	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	48	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Reading	.3040	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	LTC Totalizer Reading	6300.00	kw
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Max	45	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Present	40	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Reading	.3500	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Unknown Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	47	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	27	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	48	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	21	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps A Ø	132.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps B Ø	116.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps C Ø	126.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations B Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Present	46	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Max	60	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	42	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	52	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Operations Since Last Insp	756	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Min Tap Position	10L	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Current Tap Position	4L	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Left Counter	43134	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Found Counter	43134	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.130	millivolts
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.4	psi
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Nitro cylinder needs to be filled	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps A Ø	100.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Fans are operational but one fan on Bank 1 located at bottom row outside position is turning backwards. Fans are 3 Phase , rotated red	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	155	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	155	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations This Read Vac	10	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Switching Operations	2	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	1	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	78.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	76.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	6.000	millivolts
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.0	amps
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Maintenance Operations	8	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AF	225	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AL	225	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Maintenance Operations	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations Counter AF	370	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations Counter AL	371	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations A Ø	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations This Read Vac	1	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps C Ø	11.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps C Ø	123.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Switching Operations	1	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps B Ø	122.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	General Comments	Dead tree has fallen onto the West fence bending the top rail. Repairs have been made.	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations Ground	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations C Ø	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations B Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations A Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations B Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations C Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Maintenance Operations	5	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations Ground	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations Ground	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations C Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations B Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations A Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps C Ø	105.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps B Ø	95.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps A Ø	127.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps B Ø	14.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps A Ø	4.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	9 Month Operations	8	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	9 Month Operations	11	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps A Ø	0.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps B Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	9 Month Operations	26	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Amps C Ø	0.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Unknown Operations	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Switching Operations	1	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations This Read Vac	6	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AL	238	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	25	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AF	238	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations A Ø	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations B Ø	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations C Ø	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations Ground	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Maintenance Operations	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AF	336	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AL	337	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AF	1484	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AL	1484	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations This Read AM	1	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Switching Operations	1	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Unknown Operations	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Switching Operations	1	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	9 Month Operations	1	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps A Ø	57.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps B Ø	51.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps C Ø	50.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Regulator As Left Counter	39792	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Foundation Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	9 Months Operations	2	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations Ground	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Found Counter	32512	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Left Counter	32512	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6L	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1L	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Min Tap Position	7L	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	131	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations Counter AF	53	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations Counter AL	53	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations This Read Vac	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Switching Operations	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations Counter AF	142	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	9 Month Operations	2	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps A Ø	96.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps B Ø	87.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps C Ø	122.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Tank Oil Level	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	PT Free of Leaks?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Foundation Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Tank Oil Level	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	PT Free of Leaks?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	9 Month Operations	1	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Operations A Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Operations B Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Operations C Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Fault Operations Ground	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Maintenance Operations	16	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Operations Counter AF	153	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Operations Counter AL	153	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Operations This Read Vac	17	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps A Ø	75.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps A Ø	41.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps B Ø	48.0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps C Ø	65.0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations Ground	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Maintenance Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Found Counter	18877	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Left Counter	18877	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	440	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Trash Emptied?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Panels Dusted?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Floor Swept?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	9 Month Operations	20	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Amps A Ø	0.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Amps B Ø	0.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Readings	Amps C Ø	0.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Broom on Site?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BK001171	BreakerVacuum	896-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Found Counter	72186	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Left Counter	72186	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	210	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	48	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	48	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIND	Position
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Found Counter	33422	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Left Counter	33422	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	490.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	466.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	480.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps C Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps B Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps A Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	9 Months Operations	0	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	320	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	320	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	73.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	71.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	85.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps C Ø	46.0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations A Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations B Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations C Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations Ground	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Maintenance Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations Counter AF	195	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations Counter AL	195	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations This Read Vac	1	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Switching Operations	1	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Unknown Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	9 Month Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps C Ø	38.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps B Ø	34.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps A Ø	13.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	9 Month Operations	2	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Unknown Operations	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Switching Operations	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations This Read Vac	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AL	154	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AF	154	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Maintenance Operations	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	19	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Switching Operations	1	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations Counter AL	219	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations Counter AF	219	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Maintenance Operations	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	9 Month Operations	1	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps A Ø	46.0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps B Ø	70.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps C Ø	249.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps B Ø	248.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps A Ø	255.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	9 Month Operations	2	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	9 Month Operations	18	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Switching Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Unknown Operations	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps A Ø	350.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps B Ø	375.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps C Ø	375.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations A Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	LTC Totalizer Reading	2646.00	kw
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Max	35	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Present	30	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations Counter AL	23	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations Counter AF	23	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps C Ø	59.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps B Ø	69.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps A Ø	73.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	9 Month Operations	2	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations Counter AL	21	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations Counter AF	21	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCCControl	BR-TRANS 3	LTC Control Insp	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCCControl	BR-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCCControl	KE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations This Read AM	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AL	41	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AF	41	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Reading	.1470	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	General Comments	ok	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	LTC Totalizer Reading	3355.20	kw
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Max	54	°C
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Present	38	°C
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Reading	.4660	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Max	30	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Present	30	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations C Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations Ground	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Maintenance Operations	6	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AF	551	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AL	551	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations This Read Vac	8	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Switching Operations	2	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Min Tap Position	12L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	100.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Maintenance Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations Counter AF	160	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations Counter AL	160	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Switching Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	100.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	100.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	9 Month Operations	2	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps A Ø	90.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps B Ø	60.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps C Ø	50.0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Operations Since Last Insp	243	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Maintenance Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations Counter AF	160	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations Counter AL	160	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Switching Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Unknown Operations	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	1	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations This Read Vac	1	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	262	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	262	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	9 Month Operations	6	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps A Ø	94.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps B Ø	77.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps C Ø	87.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations C Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps B Ø	555.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps A Ø	543.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	9 Month Operations	17	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	228	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	228	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Found Counter	55800	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Left Counter	55800	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Current Tap Position	9L	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Max Tap Position	2L	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Operations Since Last Insp	214	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Min Tap Position	12L	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Max Tap Position	2R	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Current Tap Position	3L	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Left Counter	49139	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Found Counter	49139	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Reading	.1404	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	9 Months Operations	25	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps A Ø	266.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps B Ø	283.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps C Ø	276.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AF	586	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AL	586	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Unknown Operations	0	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Present	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Maintenance Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations Counter AF	171	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations Counter AL	171	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations This Read Vac	4	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Switching Operations	4	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Unknown Operations	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps B Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps A Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	9 Month Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations C Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AF	233	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AL	233	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations This Read Vac	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	1	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	225	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	225	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	1	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Unknown Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations This Read AM	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AL	724	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AF	724	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Removed blanks	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps C Ø	23.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps B Ø	16.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps A Ø	20.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	9 Months Operations	31	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Unknown Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Switching Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations This Read Vac	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AL	279	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AF	279	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Maintenance Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Unknown Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AL	132	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AF	132	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Unknown Operations	0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	LTC Operation Checked?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	LTCC000932	LTCControl	475-1	LTC Control Insp	All Connections OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations This Read Vac	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AL	338	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AF	338	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	406	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Min Tap Position	6L	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Operation Checked?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	All Connections OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Unknown Operations	0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Leaks	None	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Switching Operations	0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations This Read Oil	0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AL	31	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AF	31	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Number of Ops last 9 Months	1	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	40	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	41	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	41	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	40	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	41	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Max	46	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	General Comments	NEEDS NITROGEN	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Time Delay	30	Seconds
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Maintenance Operations	0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Leaks	None	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Fault Operations	0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3980	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	9 Month Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps A Ø	0.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps B Ø	0.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps C Ø	0.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Maintenance Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AF	276	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AL	276	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Switching Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Unknown Operations	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Found Counter	20371	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Left Counter	20371	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Current Tap Position	8L	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Max Tap Position	4L	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Min Tap Position	12L	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Operations Since Last Insp	262	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Found Counter	432732	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Left Counter	432740	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Current Tap Position	8L	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Max Tap Position	4L	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Min Tap Position	13L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Operations Since Last Insp	470	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Found Counter	68703	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Left Counter	68703	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Current Tap Position	7L	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Max Tap Position	4L	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Min Tap Position	14L	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps C Ø	242.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps B Ø	233.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps A Ø	244.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Operations Since Last Insp	716	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	9 Month Operations	5	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	146	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Left Counter	28495	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Found Counter	28495	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3355.20	kw
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Max	27	°C
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Present	27	°C
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	LTC Totalizer Reading	7699.20	kw
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Max	60	°C
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Present	35	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Reading	.8020	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Max	70	°C
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AL	179	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AF	179	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps C Ø	238.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps B Ø	233.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps A Ø	244.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	9 Month Operations	4	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	341	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Min Tap Position	4L	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Max Tap Position	15R	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Current Tap Position	4L	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Left Counter	184332	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Found Counter	184332	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	602	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Left Counter	66529	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Found Counter	66529	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Maintenance Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AF	197	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AL	197	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	9 Month Operations	2	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps A Ø	125.0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps B Ø	138.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps C Ø	141.0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	9 Month Operations	1	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps A Ø	179.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps B Ø	163.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps C Ø	146.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Follow-up Action Required?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	General Comments	No change in operation counter after recorder C phase TOC on 2/22/22, counter will need to be checked for proper operation.	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Maintenance Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AF	67	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AL	67	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations This Read Vac	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Switching Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	240126	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Left Counter	240126	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	9 Months Operations	22	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps A Ø	46.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps B Ø	48.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps C Ø	50.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations B Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations C Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AF	705	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AL	705	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations This Read AM	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	563	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Found Counter	101618	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Left Counter	101618	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8R	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	9 Months Operations	29	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps A Ø	80.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps B Ø	101.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps C Ø	90.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations B Ø	2	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations C Ø	2	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	General Comments	B,C Phase IOC	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AF	1239	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AL	1239	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations This Read AM	4	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	307	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	2	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3240	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3110.40	kw
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5790	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Found Counter	23238	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Left Counter	23238	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Current Tap Position	2L	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Max Tap Position	1R	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Min Tap Position	8L	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Operations Since Last Insp	357	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Maintenance Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AF	129	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AL	129	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations This Read Vac	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps C Ø	79.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps B Ø	78.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps A Ø	76.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	9 Month Operations	2	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Found Counter	273473	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Left Counter	273473	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations Counter AL	51	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations Counter AF	51	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1074	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps C Ø	99.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps B Ø	86.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps A Ø	86.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	9 Month Operations	4	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations Counter AL	29	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations Counter AF	29	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps C Ø	450.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps B Ø	460.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps A Ø	450.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	9 Month Operations	4	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	34	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	314	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	314	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations Counter AL	79	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations Counter AF	79	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	322	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	547	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	33	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Max Tap Position	8R	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Left Counter	49105	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Found Counter	49105	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	2.01	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps A Ø	560.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps B Ø	551.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps C Ø	608.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Maintenance Operations	0	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AF	31	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AL	35	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations This Read Vac	4	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Switching Operations	4	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Unknown Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	General Comments	ok	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Found Counter	113360	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Left Counter	113360	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	680	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Found Counter	201608	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Left Counter	201608	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	5	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	2	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	2	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	132	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	132	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1389.60	kw
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Positive DC Ground	53.5	VDC
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Negative DC Ground	53.5	VDC
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	525	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations	7	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps A Ø	21.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps B Ø	19.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps C Ø	21.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	General Comments	Last Operation count on 1/12/22 was 169 with one IOC on B phase, AF & AL reading was the same @ 169 operations	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Maintenance Operations	5	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AF	177	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AL	177	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations This Read Vac	6	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Switching Operations	1	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	154	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	154	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Trash Emptied?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Regulator As Left Counter	84199	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations B Ø	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	121568	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	General Comments	Vacuum bottle failure is lit annunciator is turned off. No information tag at annunciator. See completed W.O. #2022-4719723	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Follow-up Action Required?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	138	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	138	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	General Comments	ok	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AF	184	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AL	184	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations This Read Vac	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Unknown Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps B Ø	0.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps C Ø	0.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Regulator As Left Counter	3287	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	180.0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	164.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	159.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Maintenance Operations	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations Counter AF	179	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations Counter AL	179	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Switching Operations	1	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	2	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	12.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	12.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	12.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	285	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	285	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps B Ø	9.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps A Ø	12.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	9 Month Operations	3	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	100.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	100.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	100.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Vegetation	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps A Ø	61.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps B Ø	99.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps C Ø	94.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations B Ø	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	2	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps C Ø	12.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	63.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	9 Month Operations	2	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	59.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	58.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations C Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AF	363	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AL	363	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations This Read Vac	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps A Ø	0.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Left Counter	26362	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Found Counter	26362	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations Ground	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	354	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	354	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations This Read Vac	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Regulator As Left Counter	70122	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Present	30	°C
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Max	45	°C
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	LTC Totalizer Reading	13694.40	kw
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps A Ø	18.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps B Ø	30.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps C Ø	22.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations B Ø	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AF	294	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AL	295	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations This Read Vac	1	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Switching Operations	1	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Unknown Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	9 Month Operations	1	Position
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	All Connections OK?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	General Comments		
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	LTC Operation Checked?	y	
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
4/11/2022 12:13	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Time Delay	60	Seconds
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Present	40	°C
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Max	50	°C
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Reading	.9510	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations C Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations Ground	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Maintenance Operations	5	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AF	253	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AL	253	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations This Read Vac	6	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Switching Operations	1	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Unknown Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.7	amps
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Operations Counter AL	336	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Operations Counter AF	336	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	35	°C
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	9 Month Operations	7	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	32	°C
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	32	°C
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	35	°C
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	32	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps A Ø	400.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps B Ø	400.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps C Ø	400.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations A Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	14L	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	11R	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	9 Month Operations	7	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps A Ø	52.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps B Ø	48.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps C Ø	48.0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	42	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	47	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	42	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	48	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	General Comments	NO. 2 HEATER STAYS RUNNING	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	6	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Operation Checked?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	All Connections OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	All Lights Functioning?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations B Ø	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations C Ø	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations Ground	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Maintenance Operations	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	240	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	240	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	9 Months Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps A Ø	140.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps B Ø	170.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps C Ø	160.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Retired Distribution	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	354	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	354	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	40	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	40	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	20	°C
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Regulator As Left Counter	127309	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	104409	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Switching Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Operations This Read Vac	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Operations Counter AL	53	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Operations Counter AF	53	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Operations Ground	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	10	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	100.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	100.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Operations A Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Amps C Ø	14.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Amps B Ø	14.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Amps A Ø	15.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001981	BreakerVacuum	HC-1432	VCB Readings	9 Month Operations	31	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	100.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	9 Month Operations	24	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Switching Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Operations This Read Vac	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Operations Counter AL	50	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Operations Counter AF	50	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Operations Ground	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Amps C Ø	218.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Amps B Ø	223.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Amps A Ø	219.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	158	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	General Comments	Has spiders	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps C Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps B Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps A Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	9 Month Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	40	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	40	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	158	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Operations A Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Amps C Ø	0.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Amps B Ø	0.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Amps A Ø	0.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	9 Month Operations	14	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations Counter AF	54	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations Counter AL	54	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001983	BreakerVacuum	HC-1434	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001985	BreakerVacuum	HC-14KV TR 1	VCB Readings	9 Month Operations	16	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Switching Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Operations This Read Vac	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Operations Counter AL	32	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Operations Counter AF	32	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Operations Ground	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001984	BreakerVacuum	HC-GND TR 1	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	442	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Regulator As Left Counter	199003	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Operations Since Last Insp	236	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	9 Months Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps A Ø	0.0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Unknown Operations	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	108225	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Maintenance Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AF	429	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AL	429	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations This Read AM	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AF	174	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AL	174	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations This Read Vac	4	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	LTC Operation Checked?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	All Connections OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Switching Operations	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations Counter AL	17	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations Counter AF	17	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	General Comments	Needs Two 4 foot double pin bulbs	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps B Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps C Ø	0.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	4	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	70.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	70.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	70.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	2	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations B Ø	2	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Regulator As Left Counter	30430	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Num Operations Last 9 Months	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AF	52	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Switching Operations	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AL	52	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations This Read SF6	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Operations This Read Vac	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Operations Counter AL	28	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Operations Counter AF	28	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Operations Ground	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Operations B Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Operations A Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Amps C Ø	84.0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Ambient Temperature	62	*F
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Fault Operations	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushing Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	230.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	230.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	230.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	180	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	180	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations This Read Vac	1	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	1	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Amps B Ø	84.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Amps A Ø	84.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK001980	BreakerVacuum	HC-1431	VCB Readings	9 Month Operations	18	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Switching Operations	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	4	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Follow-up Action Required?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps C Ø	166.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps B Ø	157.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps A Ø	168.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	9 Month Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps C Ø	62.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps B Ø	63.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	75	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	45	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	45	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps A Ø	13.0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	324	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	324	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations This Read AM	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AL	178	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AF	178	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Maintenance Operations	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	9 Month Operations	3	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Time Delay	60	Seconds
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations This Read Vac	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	General Comments	position indicator not ledgible	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	9 Month Operations	5	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps A Ø	123.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps B Ø	116.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps C Ø	117.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	9 Month Operations	7	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	50	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Present	45	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps A Ø	56.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps C Ø	282.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps C Ø	50.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps B Ø	50.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps A Ø	50.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	9 Month Operations	15	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCCControl	444-3	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations Ground	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	9 Month Operations	3	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations A Ø	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Unknown Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Switching Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AL	350	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AF	350	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Operation Checked?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Maintenance Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations A Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations B Ø	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps C Ø	6.0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps B Ø	4.0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations A Ø	0	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Regulator As Left Counter	104936	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	9 Months Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps A Ø	0.0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps B Ø	0.0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments	ok	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps C Ø	0.0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Operations Counter	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	General Comments		
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.7	amps
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.4	VDC
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AF	323	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AL	323	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations This Read Vac	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	All Connections OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Operation Checked?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Switching Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Unknown Operations	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	needs 3, 4 foot 2 pine led bulbs installed	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps B Ø	88.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps C Ø	83.0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Fault Operations Ground	0	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Battery Charger Current	9.7	amps
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	9 Month Operations	3	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps A Ø	79.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations Ground	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Maintenance Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AF	1342	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AL	1342	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations This Read AM	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Switching Operations	0	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Unknown Operations	0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Oil Temp Max	40	°C
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AF	224	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AL	224	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Unknown Operations	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Unknown Operations	0	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps A Ø	29.0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps C Ø	27.0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	LTC Totalizer Reading	8164.80	kw
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	General Comments		
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Regulator As Left Counter	209404	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Operations Counter AL	44	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Operations Counter AF	44	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	2	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	5	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	120.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	120.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	120.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	General Comments		
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps A Ø	175.0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	84	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	84	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	2	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	9 Month Operations	14	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Unknown Operations	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations Ground	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Switching Operations	1	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	General Comments		
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 9:29	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	All Connections OK?	y	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps A Ø	315.0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps B Ø	301.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Unknown Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps B Ø	205.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps C Ø	212.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	9 Month Operations	24	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps C Ø	73.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps B Ø	70.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps A Ø	73.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Unknown Operations	2	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations This Read Vac	2	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations Counter AL	52	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations Counter AF	52	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	General Comments		
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Maintenance Operations	0	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Present	32	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AL	397	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Max	34	°C
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Switching Operations	1	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	9 Month Operations	3	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/12/2022 11:16	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.320	millivolts
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/11/2022 11:29	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AF	397	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Present	30	°C
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	18	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	130.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	129.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	132.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AF	237	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	General Comments	position indicater not ledible	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Follow-up Action Required?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	LTC Operation Checked?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	All Connections OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations Counter AL	55	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations This Read Vac	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Unknown Operations	0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6336.00	kw
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	9 Month Operations	3	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Unknown Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Switching Operations	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AL	237	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Amps B Ø	50.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Amps A Ø	50.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	9 Month Operations	21	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Unknown Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Maintenance Operations	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AF	261	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AL	261	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Switching Operations	8	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Operations This Read Vac	8	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Operations Counter AL	363	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Operations Counter AF	363	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Maintenance Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	General Comments		
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations This Read Vac	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Switching Operations	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations C Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations B Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations A Ø	0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps C Ø	160.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps B Ø	155.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps A Ø	160.0	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Regulator As Left Counter	41295	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	9 Month Operations	4	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps A Ø	54.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps B Ø	55.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps C Ø	53.0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations A Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations B Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations C Ø	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations Ground	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Follow-up Action Required?	n	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	Amps C Ø	50.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Maintenance Operations	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AF	171	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Vegetation	None	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Regulator As Left Counter	110473	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps C Ø	27.0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Oil Temp Max	45	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations This Read Vac	1	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AL	171	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Max	45	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:28	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Reading	.3402	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Left Counter	37006	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Current Tap Position	6L	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Max Tap Position	2L	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations A Ø	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Min Tap Position	12L	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations B Ø	0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations This Read Vac	1	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AL	302	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AF	302	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Maintenance Operations	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	General Comments		
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	General Comments		
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6600	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Follow-up Action Required?	n	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations Ground	0	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations C Ø	1	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations B Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations A Ø	0	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	LTC Totalizer Reading	10200.00	kw
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 10:36	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	288	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	288	
4/11/2022 11:02	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/11/2022 13:02	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:23	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	General Comments	ok	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps C Ø	112.0	
4/11/2022 11:56	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	9 Month Operations	29	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations Counter AF	55	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps B Ø	109.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps A Ø	79.0	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AF	225	
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AL	225	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	General Comments		
4/11/2022 14:45	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps A Ø	30.0	
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	General Comments		
4/11/2022 13:06	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Found Counter	37006	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Present	35	°C
4/12/2022 9:17	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps B Ø	35.0	
4/11/2022 12:41	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	General Comments		
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Max	50	°C
4/11/2022 10:56	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Reading	.4250	
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	General Comments		
4/11/2022 13:21	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	65.0	VDC
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	64.0	VDC
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	35	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	61	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	3	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	27.0	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.0	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	19.0	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	General Comments		
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Found Counter	88176	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Left Counter	88176	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps C Ø	44.0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1581	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	General Comments	ok	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	All Connections OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Maintenance Operations	0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	All Connections OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AF	476	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AL	476	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations This Read Vac	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.3	VDC
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Negative DC Ground	29.7	VDC
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	LTC Operation Checked?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps B Ø	44.0	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	General Comments	Trip Cks	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Operations Counter	15	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps A Ø	41.6	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Max Tap Position	7L	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Time Delay	30	Seconds
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Time Delay	30	Seconds
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	LTC Operation Checked?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Switching Operations	0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Unknown Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Operation Checked?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	19	°C
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Regulator As Left Counter	49880	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCCControl	195-5	LTC Control Insp	All Connections OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCCControl	195-5	LTC Control Insp	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	41	°F
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Maintenance Operations	1	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AF	274	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AL	274	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations This Read Vac	1	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Switching Operations	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Unknown Operations	0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Max	44	°C
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations A Ø	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations B Ø	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations C Ø	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations Ground	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	General Comments		
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Oil Status	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	721	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	721	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Operations Counter	268	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	General Comments	ok	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	807.84	kw
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4488	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Regulator As Left Counter	165564	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	General Comments	Berm needs some gravel. Needs new ODL.	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	General Comments	Washout under fence back left.	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28980	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1864.08	kw
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5178	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Negative DC Ground	29.3	VDC
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.1	VDC
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24519	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations Ground	0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations C Ø	0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations B Ø	0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations A Ø	0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps C Ø	132.0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps B Ø	121.0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps A Ø	122.0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	9 Month Operations	4	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	General Comments	Station needs additional wildlife protection. 1715T2 handle needs ground strap. Fiberglass is starting to fray on xfmr fuse barrels.	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps A Ø	100.0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps B Ø	120.0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Pressure OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Present	27	°C
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Max	27	°C
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Broken skirts	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Present	21	°C
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Max	38	°C
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	General Comments	ok	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Regulator As Left Counter	59789	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps C Ø	110.0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Regulator As Left Counter	208708	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Unknown Operations	0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Leaks	None	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 3 Oil Level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 2 Oil level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 1 Oil Level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Switching Operations	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	9 Month Operations	3	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pressure Vessel Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pop-off Valve Tested Date	2022-04-08 00:00:00.000000	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations This Read Oil	0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AL	99991	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AF	99991	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Number of Ops last 9 Months	0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Maintenance Operations	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Fault Operations	0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Unknown Operations	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Switching Operations	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations This Read Vac	1	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AL	242	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AF	242	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Maintenance Operations	1	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations Ground	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations C Ø	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations B Ø	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations A Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	284	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	9 Month Operations	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps A Ø	165.0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps B Ø	180.0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps C Ø	200.0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Regulator As Left Counter	67414	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Operations Counter	231	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps C Ø	79.0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps B Ø	66.0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps A Ø	73.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps C Ø	110.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps B Ø	106.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps A Ø	104.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	9 Months Operations	6	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations B Ø	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations C Ø	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations Ground	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Maintenance Operations	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AF	139	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AL	139	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations This Read Vac	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Switching Operations	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Unknown Operations	0	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	30.5	amps
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Unknown Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Switching Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations This Read AM	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AL	1327	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Operations Counter	115	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AF	1327	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Maintenance Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations Ground	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations C Ø	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations A Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations B Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations A Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Maintenance Operations	0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.500	millivolts
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	if no, which cells in comments
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations Ground	0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations C Ø	0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations B Ø	0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations A Ø	0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Operations Counter	120	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Switching Operations	1	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations This Read Vac	1	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations Counter AL	169	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations Counter AF	168	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps A Ø	53.0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps B Ø	49.0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps C Ø	41.0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations A Ø	0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations B Ø	0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations C Ø	0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations Ground	0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Maintenance Operations	1	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AF	220	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AL	220	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps C Ø	29.0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	General Comments	had to change out board	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps A Ø	38.0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps C Ø	6.0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps B Ø	2.0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps A Ø	2.0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	9 Month Operations	3	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps C Ø	44.0	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Regulator As Left Counter	116925	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations This Read Vac	1	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Switching Operations	0	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Unknown Operations	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	psi
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	General Comments		
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Max	40	°C
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps C Ø	0.0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps B Ø	0.0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps A Ø	0.0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AF	177	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AL	177	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations This Read Vac	0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Switching Operations	0	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	General Comments	Temp gauge cover needs replacing-hard to see through	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	LTC Totalizer Reading	2982.40	kw
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Max	0	°C
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Present	0	°C
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Unknown Operations	0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Reading	.9320	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	9 Month Operations	1	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps A Ø	110.0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps B Ø	134.0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps C Ø	107.0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations A Ø	0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations B Ø	0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations C Ø	0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations Ground	0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Maintenance Operations	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Max	42	°C
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Regulator As Left Counter	98206	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Max Tap Position	6L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	LTC Totalizer Reading	1779.84	kw
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	General Comments		
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Reading	.3708	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Oil Temp Max	35	°C
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Oil Temp Present	25	°C
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Totalizer Meter Reading	.0949	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Regulator As Left Counter	265728	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	284	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37829	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	LTC Totalizer Reading	2023.68	kw
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Max	60	°C
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Present	45	°C
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Reading	.6324	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	LTC Totalizer Reading	683.28	kw
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps B Ø	94.0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps A Ø	98.0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	9 Month Operations	5	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	General Comments		
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3031.20	kw
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4210	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Unknown Operations	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Switching Operations	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations This Read Vac	2	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AL	294	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AF	294	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Maintenance Operations	1	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations Ground	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations C Ø	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations B Ø	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations A Ø	1	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.1	VDC
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps A Phase V	2.83	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps C Ø	85.0	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1142	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	299	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	300	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	177	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	9 Month Operations	1	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps A Ø	62.0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps C Ø	43.0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	274.08	kw
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	170.00	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	155.00	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Max	90	°C
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	All Connections OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Regulator As Left Counter	47537	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Operation Checked?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	All Connections OK?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Time Delay	40	Seconds
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Found Counter	23746	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Left Counter	23762	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Current Tap Position	1L	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Max Tap Position	1R	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Min Tap Position	8L	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Operations Since Last Insp	409	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	General Comments	Fiberglass is started to be exposed on xfmr fuse barrel. Bus needs wildlife protection.	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Regulator As Left Counter	116519	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Regulator As Left Counter	46894	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Regulator As Left Counter	72619	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0816	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps A Phase V	8.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Operations Since Last Insp	233	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Min Tap Position	2L	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Max Tap Position	5R	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Current Tap Position	3R	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC As Left Counter	78239	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC As Found Counter	78235	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AL	53	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AF	53	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Maintenance Operations	1	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	General Comments	TC	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations Ground	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations C Ø	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations B Ø	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations A Ø	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AL	127	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AF	127	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Maintenance Operations	0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations Ground	0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations C Ø	0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations B Ø	0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations A Ø	1	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps C Ø	112.0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps B Ø	105.0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps A Ø	82.0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	9 Month Operations	6	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Current Tap Position	8R	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.0	VDC
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	9 Month Operations	2	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Unknown Operations	0	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Reading	.7236	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Present	37	°C
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Max	37	°C
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	LTC Totalizer Reading	1736.64	kw
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Present	55	°C
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	9 Month Operations	18	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments	Not in service	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	0.0	VDC
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	0.0	VDC
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	General Comments	Under frequency has been disabled	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Operations Counter	157	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	General Comments	good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	195.84	kw
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Max	38	°C
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Present	27	°C
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	General Comments	Both transfer switches on top bus needs wildlife protection disks	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Unknown Operations	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Switching Operations	0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations B Ø	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations C Ø	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations Ground	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Maintenance Operations	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AF	181	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AL	181	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations This Read Vac	2	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Switching Operations	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Unknown Operations	2	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Maintenance Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AF	540	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AL	540	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations This Read AM	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Switching Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Unknown Operations	0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Unknown Operations	0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Switching Operations	1	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations This Read Vac	2	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations This Read Vac	1	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	9 Months Operations	2	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	9 Month Operations	2	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps A Ø	29.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps B Ø	18.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps C Ø	13.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps A Phase V	5.66	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps B Phase V	5.66	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps C Phase V	5.66	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations A Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps A Ø	250.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps B Ø	238.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps C Ø	271.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps A Ø	65.0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps B Ø	67.0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps C Ø	68.0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps A Phase V	5.66	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations A Ø	2	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	9 Month Operations	2	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps A Ø	105.0	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps B Ø	106.0	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	General Comments		Draghands follow lead hand
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Regulator As Left Counter	18642	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Regulator As Left Counter	19765	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Operations Counter	40	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	General Comments	27.6/25.1 BFTC	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps C Ø	54.0	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps B Ø	54.0	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	9 Month Operations	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Regulator As Left Counter	188973	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps C Ø	109.0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations B Ø	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations C Ø	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations Ground	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	General Comments	TC/ Ice Storm x 2 ops	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Maintenance Operations	1	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AF	213	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AL	213	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations This Read Vac	3	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Switching Operations	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Unknown Operations	0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	34	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Min Tap Position	7L	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Operations Since Last Insp	165	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Found Counter	9399	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Left Counter	9408	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Current Tap Position	2L	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Min Tap Position	10L	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Operations Since Last Insp	359	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps C Ø	7.0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps B Ø	5.0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps A Ø	10.0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	9 Month Operations	5	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18276	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Found Counter	190	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Left Counter	198	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Current Tap Position	1R	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Max Tap Position	5R	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	62	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	58.0	VDC
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	58.0	VDC
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	9 Month Operations	15	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Regulator As Left Counter	51450	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	62	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Maintenance Operations	0	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AF	191	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AL	191	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Follow-up Actlon Required?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	General Comments	Right gate needs attention.	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	General Comments	Bus could use additional wildlife protection.	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	General Comments	ok	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Found Counter	76598	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Left Counter	76605	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Current Tap Position	7L	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Max Tap Position	10R	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Min Tap Position	2L	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	General Comments	SPR has been removed	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Operations Since Last Insp	116	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations C Ø	0	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations Ground	0	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gates Aligned?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Regulator As Left Counter	34561	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8325	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations This Read Vac	0	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Regulator As Left Counter	190879	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Switching Operations	0	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Unknown Operations	0	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Left Counter	2550	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Current Tap Position	8L	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Max Tap Position	5L	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Min Tap Position	12L	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Operations Since Last Insp	11	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps A Ø	105.0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps B Ø	130.0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps C Ø	105.0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations A Ø	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations B Ø	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations C Ø	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations Ground	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	General Comments	Counter is not working consistently.	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	General Comments	Top rail is rusty and fabric	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Found Counter	2550	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	All Connections OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Operation Checked?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8965	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations A Ø	0	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations B Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Ambient Temp	43	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Present	32	°C
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Max	41	°C
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	658.80	kw
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	9 Months Operations	42	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps A Ø	88.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps B Ø	72.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps C Ø	76.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	100.62	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	100.62	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations A Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations B Ø	9	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations C Ø	9	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	issues turned into P&C	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Min Tap Position	2L	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	General Comments	Drag hands do not work	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.5490	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Regulator As Left Counter	157295	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	33	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations Ground	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Maintenance Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AF	935	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AL	935	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations This Read AM	18	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Switching Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Unknown Operations	0	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Switching Operations	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Unknown Operations	1	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	General Comments	Error on totalizer	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Max	60	°C
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Present	50	°C
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Multiplier	0	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations C Ø	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations B Ø	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations A Ø	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps B Phase V	2.83	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps A Phase V	2.83	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations Ground	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Maintenance Operations	1	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps C Ø	20.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps B Ø	15.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps A Ø	12.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	9.0	VDC
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	9.0	VDC
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	9 Month Operations	3	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AF	164	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AL	164	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations This Read Vac	2	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	15.700	millivolts
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Structuring Horns Good Condition?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Operations Counter	95	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	75.04	kw
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3752	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Regulator As Left Counter	346127	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Regulator As Left Counter	308593	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.0	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	General Comments		
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Operations Counter	256	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Negative DC Ground	5.4	VDC
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Positive DC Ground	8.2	VDC
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Unknown Operations	1	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Switching Operations	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations This Read Vac	2	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AL	173	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AF	173	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Maintenance Operations	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	General Comments	1 CG op, 1 unknown op	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations Ground	0	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Unknown Operations	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Switching Operations	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations This Read Vac	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AL	220	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AF	220	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Maintenance Operations	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations Ground	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations C Ø	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations B Ø	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations A Ø	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps C Ø	35.0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps B Ø	27.0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps A Ø	45.0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	9 Month Operations	9	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	256	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	23.2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	RC001321	RecloserHydraulic	635-1707 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations This Read Vac	1	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AL	157	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AF	157	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Maintenance Operations	1	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	General Comments	TC	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations Ground	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations C Ø	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations B Ø	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations A Ø	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	105	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps A Ø	9.0	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.7	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.6	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	87	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	94	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations C Ø	1	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations B Ø	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations A Ø	0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps C Phase V	3.31	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps B Phase V	1.66	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps A Phase V	1.66	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	*F
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps C Ø	43.0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps B Ø	49.0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps A Ø	32.0	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	9 Month Operations	5	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Unknown Operations	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Switching Operations	0	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 9:15	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.8	VDC
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Reading	.6228	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	31	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Max	42	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Present	34	°C
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 11:34	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1688	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Present	0	°C
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	135.04	kw
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	General Comments	temp gauge does not work	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Present	32	°C
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Max	42	°C
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	LTC Totalizer Reading	5978.88	kw
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	General Comments	ok	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Regulator As Left Counter	234344	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Regulator As Left Counter	243535	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	9 Month Operations	3	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Regulator As Left Counter	59671	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Min Tap Position	2L	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	General Comments		
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:17	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	General Comments		
4/8/2022 12:06	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations A Ø	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations B Ø	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Present	20	°C
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Switching Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations This Read AM	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AL	896	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AF	896	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Maintenance Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations Ground	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations C Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations B Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations A Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps C Ø	25.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps B Ø	23.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps A Ø	38.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps A Ø	130.0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps B Ø	120.0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps C Ø	136.0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	9 Month Operations	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps A Ø	168.0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps B Ø	108.0	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 12:54	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps C Ø	108.0	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37922	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Max Tap Position	9R	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	General Comments	Top of containment is exposed by the control house.	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Operations Counter	20	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	General Comments	27.8/25	BFTC
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Operations Counter	166	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 12:12	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Current Tap Position	8R	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	9 Months Operations	3	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps A Ø	21.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps B Ø	38.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps C Ø	55.0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations A Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations B Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations C Ø	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations Ground	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Maintenance Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AF	865	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AL	865	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations This Read AM	1	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CVVT Visible Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CVVT Properly Grounded?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	General Comments	ok	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AF	189	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AL	189	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations This Read Vac	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Switching Operations	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Unknown Operations	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.5	VDC
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.5	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 12:45	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 10:45	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	840	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	840	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Regulator As Left Counter	100776	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 15:16	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:19	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Switching Operations	1	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Unknown Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Structure Patrol Inspection	Good	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 12:32	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	*F
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Vegetation	None	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Maintenance Operations	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35190	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	9 Months Operations	8	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Regulator As Left Counter	168005	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	General Comments		
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Current Tap Position	12L	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations C Ø	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations Ground	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Follow-up Action Required?	n	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	General Comments	ok	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	General Comments	ok	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Present	30	°C
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Max	40	°C
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Reading	.4580	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Switching Operations	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Present	30	°C
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Unknown Operations	0	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Max	40	°C
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	LTC Totalizer Reading	10992.00	kw
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	All Temp Gauges MAX Reset	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/8/2022 10:56	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 11:15	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations A Ø	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations B Ø	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations C Ø	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations Ground	0	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Maintenance Operations	1	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AF	190	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AL	190	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations This Read Vac	1	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	General Comments		Whole station needs wildlife protection.
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Maintenance Operations	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AF	173	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AL	173	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations This Read Vac	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Unknown Operations	0	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	General Comments		Tap gauge leaking
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Found Counter	295927	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Left Counter	295936	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Operations Since Last Insp	271	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Min Tap Position	7L	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Current Tap Position	1R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Max Tap Position	5R	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Min Tap Position	16L	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Operations Since Last Insp	164	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Switching Operations	0	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	General Comments		
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	General Comments	ok	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Regulator As Left Counter	166362	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	679	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	310	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/11/2022 7:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	9 Month Operations	3	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps A Ø	312.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps B Ø	288.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps C Ø	312.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations Ground	0	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations C Ø	0	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations B Ø	0	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps A Phase V	5.66	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps B Phase V	5.66	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps C Phase V	5.66	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations A Ø	0	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations A Ø	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations B Ø	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations C Ø	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations Ground	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Follow-up Action Required?	n	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	General Comments		
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/8/2022 18:29	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	General Comments		
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Maintenance Operations	1	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AF	218	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Unknown Operations	2	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Switching Operations	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations This Read Vac	3	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AL	218	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Current Tap Position	2L	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations This Read Vac	3	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AL	126	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Left Counter	155261	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	General Comments		
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AF	126	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	All Connections OK?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Maintenance Operations	3	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Operation Checked?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Output Voltage Level	115.2	VAC
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AF	115.0	VAC
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Grounds in Place?	y	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AL	115.0	VAC
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 7:12	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Time Delay	30	Seconds
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Foundation Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	500.00	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	517.50	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Switching Operations	0	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 13:59	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Unknown Operations	0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	9 Month Operations	4	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps A Ø	87.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps B Ø	70.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps C Ø	66.0	
4/8/2022 13:26	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushing Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 9:42	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Regulator As Left Counter	67820	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	41	*F
4/8/2022 10:48	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Wood Structures OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.4	VDC
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.4	VDC
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/8/2022 14:10	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	General Comments		
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Max Tap Position	7L	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2664.00	kw
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
4/8/2022 10:20	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/8/2022 11:47	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/8/2022 14:04	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations Ground	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	59	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	20	°C
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	9 Months Operations	5	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Switching Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps A Ø	110.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps C Ø	80.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps B Ø	105.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	*C
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	*C
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Unknown Operations	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Switching Operations	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations This Read AM	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AL	546	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AF	546	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Maintenance Operations	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations C Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations Ground	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	*C
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	*C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	18	*C
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	*C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Unknown Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	9 Months Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Maintenance Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations Counter AF	181	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations Counter AL	183	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations This Read Vac	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Switching Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Unknown Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	127	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps C Ø	110.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps B Ø	50.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps A Ø	50.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	9 Month Operations	4	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Unknown Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Switching Operations	3	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	LTC Filter is leaking	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Found Counter	60427	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Left Counter	60427	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Left Counter	405186	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Found Counter	405186	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	32	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations A Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations B Ø	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		Oil leak on TR still active
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps A Ø	60.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps B Ø	70.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps C Ø	100.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations Ground	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Maintenance Operations	2	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AF	367	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AL	367	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations This Read AM	2	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Switching Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Unknown Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	*C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations This Read Vac	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations This Read Vac	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AL	386	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AF	386	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	*C
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	*C
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AL	326	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Unknown Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Switching Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations This Read Vac	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AL	497	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AF	497	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Maintenance Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations Ground	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations C Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations B Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations A Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps C Ø	50.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps B Ø	50.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps A Ø	50.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	9 Month Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AF	326	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations Ground	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Maintenance Operations	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AF	505	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AL	505	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations This Read AM	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Switching Operations	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Unknown Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps B Ø	70.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps A Ø	75.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Switching Operations	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Unknown Operations	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	9 Months Operations	1	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	408	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	408	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations C Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Found Counter	44239	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Left Counter	44239	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Current Tap Position	4L	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Max Tap Position	3L	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Min Tap Position	12L	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Operations Since Last Insp	480	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations A Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Maintenance Operations	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AL	193	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AF	193	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Maintenance Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps A Ø	114.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps B Ø	93.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations This Read AM	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps C Ø	95.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps C Ø	60.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Max	40	°C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Present	30	°C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	set for summer	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations Ground	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps C Ø	240.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations This Read Vac	6	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AL	510	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AF	504	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Maintenance Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Oil Temp Max	45	°C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Oil Temp Present	35	°C
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	20	°C
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	30	°C
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	60.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	60.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Reading	.7540	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Found Counter	163514	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps C Ø	185.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps B Ø	183.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps A Ø	220.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Present	35	°C
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	9 Month Operations	5	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	9 Month Operations	7	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Max	50	°C
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	LTC Totalizer Reading	7651.20	kw
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps B Ø	240.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps A Ø	240.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Operations Since Last Insp	602	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Min Tap Position	6L	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Max Tap Position	3R	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Current Tap Position	1L	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Switching Operations	6	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Unknown Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Left Counter	200290	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Found Counter	200290	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Reading	.9564	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Operations Since Last Insp	482	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Min Tap Position	12L	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Max Tap Position	1L	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Current Tap Position	4L	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Left Counter	163514	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations This Read Vac	3	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AL	248	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	All Connections OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Operation Checked?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	All Connections OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Operation Checked?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AF	248	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Maintenance Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps C Ø	381.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps B Ø	406.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps A Ø	393.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Present	17	°C
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	All Connections OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Operation Checked?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Found Counter	10187	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Left Counter	10187	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Current Tap Position	3L	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Min Tap Position	8L	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	70.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Operations Since Last Insp	206	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	LTC Totalizer Reading	10857.60	kw
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	9 Month Operations	2	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	-60	°C
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	-60	°C
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	9 Month Operations	5	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	19	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Left Counter	69691	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Found Counter	69691	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Amps C Ø	93.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Operations This Read Vac	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Operations Counter AL	17	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Operations Counter AF	17	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Readings	Maintenance Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001950	BreakerVacuum	HB-1147	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Follow-up Action Required?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations Ground	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps C Ø	150.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps B Ø	150.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps A Ø	150.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	9 Months Operations	5	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	9 Months Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps A Ø	50.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps B Ø	50.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps C Ø	40.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Fault Operations Ground	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Maintenance Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AF	545	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations Counter AL	545	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Operations This Read AM	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Switching Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Unknown Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Amps C Ø	94.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Amps B Ø	92.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Amps A Ø	91.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001949	BreakerVacuum	HB-1150	VCB Readings	9 Month Operations	7	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PF001309	PowerFuse	GI-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	PF001309	PowerFuse	GI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AF	336	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AL	336	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Unknown Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Switching Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations This Read AM	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AL	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AF	16	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Maintenance Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	General Comments	c phase ioc, target wouldn't reset, photos sent to Isreal	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Amps C Ø	678.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Amps B Ø	660.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Amps A Ø	670.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	9 Month Operations	13	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations A Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations B Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations C Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations Ground	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Maintenance Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AF	559	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AL	559	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations This Read Vac	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Switching Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Unknown Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	9 Month Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps A Ø	0.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps B Ø	0.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps C Ø	0.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Unknown Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Switching Operations	1	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Operations Counter AL	10	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Operations Counter AF	10	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Maintenance Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	General Comments	The Last O.C. was at 9 on 2/11/22	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001954	BreakerVacuum	HB-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Operations Counter AL	15	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Operations Counter AF	15	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Maintenance Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Amps C Ø	161.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Amps B Ø	168.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Amps A Ø	163.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	9 Month Operations	13	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	74	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	74	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Unknown Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Switching Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Operations This Read Vac	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Operations Counter AL	18	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Operations Counter AF	18	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	Maintenance Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Readings	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001951	BreakerVacuum	HB-1146	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	*F
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Unknown Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Switching Operations	1	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Operations This Read Vac	1	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Operations Counter AL	27	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Operations Counter AF	27	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Maintenance Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Grounds in Place?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	General Comments	There were 4 fault operations on 2/22/22 with the AF & AL count remaining at 22 operations today the count is 27 operations.	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	General Comments		
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Foundation Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Follow-up Action Required?	n	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Operations Ground	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Operations C Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Operations B Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Operations A Ø	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Patrol Inspection	Bushing Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Amps C Ø	114.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Amps B Ø	113.0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Amps A Ø	110.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001953	BreakerVacuum	HB-1144	VCB Readings	9 Month Operations	18	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Unknown Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Tank Paint Condition	Good	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Switching Operations	0	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/11/2022 11:45	Distribution	Hurstbourne Quarterly Inspection	BK001952	BreakerVacuum	HB-1145	VCB Readings	Operations This Read Vac	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps C Ø	120.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps B Ø	120.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps A Ø	100.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	9 Month Operations	6	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Present	45	°C
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Max	60	°C
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Reading	.8852	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Present	40	°C
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Max	60	°C
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	LTC Totalizer Reading	12746.88	kw
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations Ground	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Unknown Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Switching Operations	2	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps C Ø	250.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps B Ø	170.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps A Ø	160.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty B Ph AM	2.14	%
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty A Ph AM	8.54	%
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Months Operations	1	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations This Read Vac	2	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AL	412	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AF	412	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Maintenance Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	All Connections OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Operation Checked?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Unknown Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Found Counter	116407	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Left Counter	116407	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Current Tap Position	4L	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Max Tap Position	2L	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Min Tap Position	9L	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Operations Since Last Insp	349	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	145.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Present	45	°C
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Max	65	°C
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	795	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	795	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Reading	1.3750	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	General Comments	neighbors fence within 6 inches of station fence (on the right side of fence). Noted in previous insp.	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Ambient Temp	52	F
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	9 Month Operations	4	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps A Ø	120.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps B Ø	100.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps C Ø	200.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Maintenance Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AF	97	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AL	97	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations This Read Vac	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Switching Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	All Connections OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Operation Checked?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Reading	.9480	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Present	30	°C
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Max	60	°C
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	LTC Totalizer Reading	5688.00	kw
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	9 Month Operations	6	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps A Ø	80.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps B Ø	120.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps C Ø	120.0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Found Counter	41066	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Left Counter	41066	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Current Tap Position	1R	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Max Tap Position	5R	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Min Tap Position	7L	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Operations Since Last Insp	646	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Maintenance Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AF	467	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AL	467	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations This Read Vac	2	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Switching Operations	2	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Unknown Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations A Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations B Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations C Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations Ground	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	40.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	50.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	50.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Maintenance Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AF	685	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AL	685	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations This Read Vac	4	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Switching Operations	4	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Unknown Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PF001297	PowerFuse	CB-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PF001297	PowerFuse	CB-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Unknown Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Switching Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations This Read AM	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AL	276	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AF	276	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Maintenance Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Unknown Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Switching Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations This Read AM	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AL	410	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AF	410	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Maintenance Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	General Comments	ok	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations Ground	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations This Read AM	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	326	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	326	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps C Ø	20.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps B Ø	40.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps A Ø	20.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty C Ph AM	7.47	%
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty B Ph AM	8.54	%
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty A Ph AM	8.54	%
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Months Operations	3	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	9 Month Operations	5	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps A Ø	60.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps B Ø	120.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps C Ø	120.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps A Ø	146.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	9 Month Operations	8	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Unknown Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Switching Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations This Read AM	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AL	591	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AF	591	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Maintenance Operations	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations Ground	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	*C
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	*C
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	40	*C
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	75	*C
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	General Comments	couldnt get to reset	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Maintenance Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AF	157	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AL	157	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations This Read Vac	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Switching Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Unknown Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps C Ø	100.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps B Ø	100.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps A Ø	100.0	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	9 Months Operations	1	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations A Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations B Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations C Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations Ground	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Maintenance Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AF	327	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AL	327	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations This Read Vac	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Switching Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Unknown Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	9 Month Operations	9	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps A Ø	635.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps B Ø	665.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps C Ø	635.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations A Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations B Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations C Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations Ground	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AF	536	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AL	536	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations This Read AM	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Switching Operations	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Unknown Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Unknown Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Switching Operations	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations This Read Vac	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AL	286	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AF	284	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Maintenance Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Operation Checked?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	All Connections OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Switching Operations	2	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations This Read Vac	2	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AL	199	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AF	199	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Maintenance Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations Ground	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations C Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations B Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations A Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps C Ø	190.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps B Ø	235.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps A Ø	255.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	9 Month Operations	3	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Present	30	*C
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Reading	.6170	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Unknown Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Switching Operations	2	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations This Read Vac	2	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AL	218	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AF	218	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Maintenance Operations	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations Ground	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations C Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations B Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations A Ø	0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps C Ø	150.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps B Ø	100.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps A Ø	110.0	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	9 Month Operations	6	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	LTC Totalizer Reading	4936.00	kw
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Max	60	*C
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Unknown Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Unknown Operations	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	9 Months Operations	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps A Ø	50.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps B Ø	40.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps C Ø	40.0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations Ground	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Maintenance Operations	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AF	460	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AL	460	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations This Read AM	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Unknown Operations	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	9 Month Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps A Ø	0.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps B Ø	0.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps C Ø	0.0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations A Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations B Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations C Ø	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations Ground	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Follow-up Action Required?	n	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	General Comments		
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Maintenance Operations	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AF	234	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AL	234	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations This Read Vac	0	
4/19/2022 11:56	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Months Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps A Ø	20.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps B Ø	20.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps C Ø	20.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations Ground	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Maintenance Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AF	1302	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AL	1302	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations This Read AM	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Switching Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Unknown Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	LTC Totalizer Reading	3600.00	kw
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Max	60	°C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Present	40	°C
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Months Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps A Ø	40.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps B Ø	50.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps C Ø	50.0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations Ground	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Maintenance Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AF	34895	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AL	34895	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations This Read AM	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Switching Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Unknown Operations	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	General Comments	substation gate post on the right has been hit, post is leaning over to the left	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps A Ø	100.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps B Ø	100.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps C Ø	100.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Unknown Operations	0	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	El-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Unknown Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Switching Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations This Read Vac	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Maintenance Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AF	510	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AL	514	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations This Read Vac	4	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Switching Operations	4	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Unknown Operations	0	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AL	186	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AF	186	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Maintenance Operations	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13116	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps B Ø	120.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Operations Since Last Insp	447	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Min Tap Position	6L	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Max Tap Position	2R	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Current Tap Position	1L	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Left Counter	67534	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Found Counter	67534	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps A Ø	120.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Maintenance Operations	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AF	248	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AL	248	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations This Read Vac	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	9 Month Operations	4	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Switching Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	9 Month Operations	5	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Maintenance Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations Ground	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations C Ø	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations B Ø	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations A Ø	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	9 Month Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps A Ø	140.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps B Ø	145.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps C Ø	120.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps C Ø	120.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps B Ø	135.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Amps A Ø	115.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	9 Month Operations	2	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Left Counter	22119	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Found Counter	22119	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Switching Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations Ground	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations C Ø	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations B Ø	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations A Ø	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps C Ø	60.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps B Ø	105.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps A Ø	80.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	9 Month Operations	2	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Unknown Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Switching Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations This Read Vac	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations Counter AL	178	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations Counter AF	178	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps C Ø	137.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps B Ø	141.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps A Ø	126.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	9 Month Operations	2	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4620	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Equipment Properly Labeled?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps C Ø	200.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	268	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1108.80	kw
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	9 Month Operations	4	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Maintenance Operations	0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps A Ø	23.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps B Ø	32.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps C Ø	40.0	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations Counter AF	171	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations Counter AL	173	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations This Read Vac	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Switching Operations	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Unknown Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Regulator As Left Counter	11251	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	9	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	10	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Left Counter	76686	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Found Counter	76686	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	General Comments		
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	141	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Left Counter	419873	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12985	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	General Comments		
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:18	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations B Ø	0	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Found Counter	419873	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	General Comments		
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	General Comments		
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Maintenance Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AF	516	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AL	516	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations This Read Vac	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	General Comments		
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 10:50	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Maintenance Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AF	504	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AL	504	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations This Read AM	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Switching Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Unknown Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Switching Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations This Read Vac	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations Counter AL	175	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations Counter AF	173	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Maintenance Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations Ground	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations C Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations B Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations A Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	General Comments		
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	LTC Totalizer Reading	24750.00	kw
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Oil Temp Max	60	°C
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Oil Temp Present	40	°C
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations Counter AF	141	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Maintenance Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations Ground	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations C Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations B Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations A Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps C Ø	485.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps B Ø	500.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps A Ø	520.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	9 Month Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Unknown Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty B Ph AM	4.27	%
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps A Ø	80.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps B Ø	100.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps C Ø	120.0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations A Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations B Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations C Ø	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations Ground	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps C Ø	0.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps B Ø	0.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps A Ø	0.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Vegetation	None	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations A Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations B Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations Ground	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Maintenance Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	9 Month Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Unknown Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Switching Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations This Read Vac	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations Counter AL	203	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations Counter AF	201	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	General Comments		
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 8:49	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	All Connections OK?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	Follow-up Action Required?	n	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Maintenance Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations Counter AF	175	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Operation Checked?	y	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations Counter AL	177	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations This Read Vac	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Switching Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Unknown Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	9 Month Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps A Ø	125.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps B Ø	110.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps C Ø	100.0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/7/2022 13:00	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations C Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations Ground	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	General Comments		
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Maintenance Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	9 Months Operations	4	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty A Ph AM	8.54	%
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations Counter AF	181	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations Counter AL	183	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations This Read Vac	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Switching Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Unknown Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps C Ø	90.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps B Ø	95.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps A Ø	95.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	9 Month Operations	2	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	110	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Left Counter	537258	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Found Counter	537258	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Unknown Operations	0	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:37	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Unknown Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Unknown Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Switching Operations	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations This Read Vac	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations Counter AL	144	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations Counter AF	142	
4/7/2022 14:28	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	110	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3	
4/7/2022 12:52	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Maintenance Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	9 Month Operations	2	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Unknown Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations A Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations B Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations C Ø	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations Ground	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Switching Operations	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations This Read Vac	0	
4/7/2022 10:27	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations Counter AL	141	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Switching Operations	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations This Read Vac	0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations Counter AL	229	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations Counter AF	229	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps C Ø	0.0	
4/7/2022 12:28	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Maintenance Operations	0	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps B Ø	0.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps A Ø	0.0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	9 Month Operations	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Unknown Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Tank Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Switching Operations	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations This Read Vac	2	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations Counter AL	158	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations Counter AF	156	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Maintenance Operations	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Grounds in Place?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	General Comments		
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Foundation Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Follow-up Action Required?	n	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations Ground	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations C Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations B Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations A Ø	0	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Bushing Condition	Good	
4/7/2022 7:09	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Amps C Ø	110.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	729	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	729	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Ambient Temperature	50	*F
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Pressure Indicator	good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations Ground	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations C Ø	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations B Ø	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations A Ø	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps C Ø	15.0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps B Ø	18.0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps A Ø	20.0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	9 Month Operations	4	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Unknown Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Switching Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations This Read AM	2	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AL	376	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AF	376	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Maintenance Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	General Comments	A,B Phase IOC	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Maintenance Operations	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AF	177	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AL	179	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations This Read Vac	2	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Switching Operations	2	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Unknown Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Operation Checked?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	All Connections OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	9 Month Operations	5	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps A Ø	120.0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps B Ø	100.0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps C Ø	105.0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Fault Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations A Ø	1	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations B Ø	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations C Ø	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations Ground	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Maintenance Operations	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AF	195	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AL	196	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations This Read Vac	2	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Switching Operations	1	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Unknown Operations	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 3	90	psi
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Switching Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Unknown Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Switching Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations This Read AM	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AL	297	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AF	297	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Maintenance Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations Ground	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Unknown Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations Ground	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Maintenance Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AF	525	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AL	525	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations This Read AM	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Switching Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Unknown Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Max	0	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps C Ø	50.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps B Ø	50.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps A Ø	50.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	9 Months Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	TV Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	TV Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	9 Month Operations	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps A Ø	330.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps B Ø	350.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps C Ø	367.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations A Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations B Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations C Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations Ground	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	General Comments	CHAINLINK DOWN BACKSIDE OF STATION AND WITHIN 6" ON LEFTSIDE OF STATION	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Maintenance Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations Counter AF	173	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations Counter AL	173	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations This Read Vac	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Switching Operations	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Unknown Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	General Comments	OK	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Maintenance Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Num Operations Last 9 Months	18	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations Counter AF	194	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations Counter AL	194	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations This Read SF6	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 1	90	psi
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 2	90	psi
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD0000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AL	469	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations This Read Vac	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Switching Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AL	328	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AF	328	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Maintenance Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD0000629	Yard	CK-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations Ground	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Maintenance Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AF	327	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AL	327	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations This Read AM	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Switching Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Unknown Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations Ground	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	9 Months Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps A Ø	250.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps B Ø	250.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps C Ø	250.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Unknown Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Switching Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations This Read AM	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	9 Months Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps A Ø	10.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps B Ø	10.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps C Ø	50.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Maintenance Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AF	469	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Present	35	°C
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Max	55	°C
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps C Ø	98.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Fault Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	General Comments	OK	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Maintenance Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Num Operations Last 9 Months	74	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	LTC Totalizer Reading	3603.84	kw
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations Counter AF	121	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations Counter AL	121	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations This Read SF6	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 1	90	psi
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 2	90	psi
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 3	90	psi
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Switching Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Unknown Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations A Ø	1	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations B Ø	1	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Ambient Temperature	52	*F
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps A Ø	50.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps B Ø	56.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps C Ø	50.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Time Delay	0	Seconds
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	14	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	*C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	*C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC As Left Counter	2544	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC As Found Counter	2544	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	9 Months Operations	11	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Reading	.7508	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps A Ø	100.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps B Ø	100.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps C Ø	100.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Ambient Temperature	52	*F
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps A Ø	90.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps B Ø	100.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations Ground	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations C Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations B Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations A Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps C Ø	960.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps B Ø	910.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps A Ø	880.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	9 Month Operations	5	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	9 Months Operations	5	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps A Ø	70.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	9 Months Operations	4	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps A Ø	25.0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps B Ø	100.0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps C Ø	100.0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps B Ø	50.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps C Ø	50.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations C Ø	1	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations Ground	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations Ground	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Unknown Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Switching Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Vegetation	None	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	General Comments		WOODEN FARM FENCE AROUND SUSTATION
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Unknown Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Switching Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations This Read AM	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AL	619	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AF	619	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Maintenance Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations Ground	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps C Ø	80.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps B Ø	50.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps A Ø	120.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	9 Months Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Unknown Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Switching Operations	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations This Read Vac	5	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AL	171	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AF	171	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Maintenance Operations	4	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps C Ø	100.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps B Ø	100.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps A Ø	100.0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	9 Month Operations	2	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	9 Months Operations	2	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps A Ø	400.0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps B Ø	400.0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Unknown Operations	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Switching Operations	2	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations This Read Vac	2	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AL	244	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AF	242	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Maintenance Operations	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations Ground	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations C Ø	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps C Ø	400.0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations B Ø	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations A Ø	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Reading	.6260	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Present	35	°C
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Max	50	°C
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	LTC Totalizer Reading	6009.60	kw
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Maintenance Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AF	454	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	General Comments	C Phase IOC	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Maintenance Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AF	99977	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AL	99977	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations This Read AM	1	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Switching Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Unknown Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Unknown Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Switching Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations This Read AM	10	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AL	99999	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AF	99999	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Maintenance Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	General Comments	B,C Phase IOC / 5 ops since last inspection	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations Ground	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations C Ø	5	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations B Ø	5	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	55.90	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	55.90	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps C Ø	100.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps B Ø	110.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps A Ø	100.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	9 Months Operations	13	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AL	454	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations This Read AM	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AL	379	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AF	379	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Maintenance Operations	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations This Read AM	4	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Switching Operations	4	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Unknown Operations	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations Ground	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	OK	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Found Counter	427268	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Left Counter	427268	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	99	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Found Counter	502756	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Left Counter	502756	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	56	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Found Counter	492420	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Left Counter	492420	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	16L	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	63	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Found Counter	25938	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Found Counter	335962	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Left Counter	335962	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2L	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	74	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Oil Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Oil Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	HV Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	HV Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	0	°C
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H1 Winding Temp Present	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H1 Winding Temp Max	0	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	General Comments	New transformer could not get the max/min data.Instruction sheet is incorrect.	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Maintenance Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	need entry forms for Section 2 switchgear and breakers 12 KV bus tie sec 2, CF-1210, CF-1209, CF-1208, CF-1207, CF-1206, 12KV TR2,	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AF	272	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AL	272	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations This Read AM	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Maintenance Operations	2	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations Counter AF	189	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations Counter AL	189	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations This Read Vac	3	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Switching Operations	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Unknown Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Switching Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Unknown Operations	1	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Left Counter	25938	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	337	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps C Ø	90.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps B Ø	100.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps A Ø	0.0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Operations Since Last Insp	456	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	9 Month Operations	3	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps A Ø	90.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps B Ø	60.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps C Ø	50.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Min Tap Position	6L	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Max Tap Position	4R	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Left Counter	115992	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Found Counter	115992	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	9 Months Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	9 Months Operations	12	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps A Ø	280.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps B Ø	300.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps C Ø	280.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations Ground	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations A Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations B Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations C Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations Ground	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps C Ø	100.0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Operations Ground	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Maintenance Operations	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AF	413	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations Counter AL	413	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Operations This Read AM	1	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Switching Operations	1	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Unknown Operations	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	9 Months Operations	38	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Unknown Operations	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Operation Checked?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	All Connections OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Time Delay	30	Seconds
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Operation Checked?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	All Connections OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Vegetation	None	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps B Ø	50.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps A Ø	50.0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	9 Months Operations	1	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps A Ø	10.0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps B Ø	100.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Unknown Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Switching Operations	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations This Read Vac	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AL	209	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AF	209	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Maintenance Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PF001296	PowerFuse	CB-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/7/2022 9:27	Distribution	Crop Quarterly Inspection	PF001296	PowerFuse	CB-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Switching Operations	1	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations This Read AM	1	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AL	679	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AF	679	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Maintenance Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Found Counter	52197	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Left Counter	52197	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Current Tap Position	6R	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Max Tap Position	12R	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Min Tap Position	6L	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Operations Since Last Insp	759	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations Ground	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps C Ø	130.0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps B Ø	50.0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Vegetation	None	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	9 Months Operations	3	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PF001290	PowerFuse	CK-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	PF001290	PowerFuse	CK-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PF001288	PowerFuse	BK-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PF001288	PowerFuse	BK-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps C Ø	90.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps B Ø	150.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps A Ø	130.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Vegetation	None	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations Ground	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Maintenance Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AF	320	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AL	320	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations This Read AM	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Switching Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Unknown Operations	0	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	9 Months Operations	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/6/2022 12:01	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/6/2022 12:01	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 12:01	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	111.80	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Present	40	°C
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Max	60	°C
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Reading	1.2000	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Present	40	°C
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Max	60	°C
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	LTC Totalizer Reading	21600.00	kw
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps C Ø	50.0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Unknown Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Switching Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations This Read AM	30	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps A Ø	500.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps B Ø	600.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps C Ø	600.0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Maintenance Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AF	99785	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AL	99785	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations This Read AM	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Switching Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Unknown Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AL	104	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AF	104	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Maintenance Operations	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	General Comments	Found ABC Phase targets. Breaker had 10 ops since last inspection.	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations Ground	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations C Ø	10	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations B Ø	10	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations A Ø	10	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	111.80	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	111.80	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Min Tap Position	4L	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Operations Since Last Insp	338	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Unknown Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Switching Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations This Read AM	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AL	280	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AF	280	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Maintenance Operations	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Current Tap Position	4L	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Max Tap Position	2L	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	40	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	40	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	40	%
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps C Ø	90.0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps B Ø	95.0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps A Ø	90.0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	9 Month Operations	2	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps C Ø	25.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps B Ø	150.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps A Ø	50.0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	9 Months Operations	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	9 Month Operations	1	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps A Ø	335.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps B Ø	330.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps C Ø	350.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations A Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations B Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations C Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations Ground	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Vegetation	None	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	General Comments		
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations Ground	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 15:27	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Unknown Operations	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Switching Operations	2	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations This Read Vac	2	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AL	243	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AF	241	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Maintenance Operations	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Foundation Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations Ground	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations C Ø	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations B Ø	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations A Ø	0	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	9 Months Operations	1	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Found Counter	14382	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Left Counter	14382	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations A Ø	0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps C Ø	210.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps B Ø	200.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps A Ø	190.0	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	9 Month Operations	1	
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/6/2022 12:35	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps A Ø	50.0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations B Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	General Comments		
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations C Ø	0	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	General Comments		
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:33	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/6/2022 11:54	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations Ground	0	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 13:09	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 17:42	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	All Connections OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	42	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	62	°C
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9216	kw
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Present	52	°C
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Max	46	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Present	36	°C
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	48	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AL	125	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations This Read AM	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Switching Operations	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps A Ø	350.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	9 Months Operations	1	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Present	38	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Max	52	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Unknown Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Switching Operations	1	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations This Read Vac	1	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations Counter AL	156	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations Counter AF	156	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Maintenance Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AF	125	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps A Ø	14.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps B Ø	10.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps C Ø	25.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Bushing Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps C Ø	350.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps B Ø	350.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	9 Month Operations	2	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Switching Operations	1	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Glass for the oil temp is cracked	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AF	859	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AL	859	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations This Read AM	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Switching Operations	0	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	needs nitrogen bottle	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Current Tap Position	6L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Max Tap Position	12R	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Min Tap Position	11L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Regulator As Left Counter	30297	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps A Ø	103.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps B Ø	110.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps C Ø	95.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations Ground	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Maintenance Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Tank Leaks	None	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Whips Correctly Engaged?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Operations Counter AF	168	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Operations Counter AL	168	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Operations This Read Vac	1	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps A Ø	100.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps B Ø	100.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps C Ø	100.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	9 Month Operations	2	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	9 Months Operations	3	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	46	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	38	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	52	°C
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Reading	.96	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Unknown Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	LTC Totalizer Reading	4625.28	kw
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Max	62	°C
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Present	36	°C
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Current Tap Position	6L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	All Connections OK?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Max Tap Position	5R	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	9 Month Operations	2	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps A Ø	50.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps B Ø	50.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps C Ø	50.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps C Ø	60	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps B Ø	60	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps A Ø	60	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty C Ph V	.69	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty A Ph V	1.38	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	9 Month Operations	5	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Operations Counter	183	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps C Ø	300.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps B Ø	300.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps A Ø	300.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	9 Month Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Regulator As Left Counter	34223	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Min Tap Position	11L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations A Ø	2	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations B Ø	2	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	General Comments	a, b phase ioc	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations Counter AF	341	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations Counter AL	341	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations This Read Vac	4	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Switching Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Unknown Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations Counter AF	346	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations Counter AL	346	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations This Read Vac	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Switching Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Unknown Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	9 Month Operations	6	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps A Ø	50.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps B Ø	50.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps C Ø	50.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Regulator As Left Counter	16680	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Glass for the oil Temp is cracked	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Unknown Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Switching Operations	4	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations This Read Vac	4	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AL	91	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AF	87	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Maintenance Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations Ground	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations C Ø	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations B Ø	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations A Ø	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6906.24	kw
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Oil Temp Max	36	°C
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7194	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Max	42	°C
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Found Counter	276739	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Left Counter	276739	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Current Tap Position	7L	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Max Tap Position	2L	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Min Tap Position	7L	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Operations Since Last Insp	156	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Reading	.4818	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Switching Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations This Read Vac	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations Counter AL	362	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations Counter AF	362	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps C Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps B Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps A Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	9 Month Operations	9	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Unknown Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Switching Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations Counter AL	333	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations Counter AF	333	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Found Counter	13819	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Left Counter	13819	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Current Tap Position	6L	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Max Tap Position	3L	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Min Tap Position	10L	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Operations Since Last Insp	389	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations	3	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps A Ø	125	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps B Ø	118	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps C Ø	133	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Maintenance Operations	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AF	281	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AL	282	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations This Read Vac	1	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Switching Operations	1	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Unknown Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Regulator As Left Counter	81133	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps C Ø	25.0	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AF	153	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	General Comments	B Phase IOC/TOC	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations B Ø	3	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps C Ø	150.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps B Ø	150.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps A Ø	150.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Switching Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Max Tap Position	2L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Min Tap Position	12L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Regulator As Left Counter	20031	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Found Counter	29437	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Left Counter	29437	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Current Tap Position	3L	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Max Tap Position	2L	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Min Tap Position	7L	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-5	psi
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Operations Since Last Insp	147	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	All Connections OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Time Delay	30	Seconds
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	9 Months Operations	6	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	All Connections OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	9 Month Operations	4	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty A Ph V	23.57	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty B Ph V	22.75	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty C Ph V	23.57	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps A Ø	297	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps B Ø	313	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps C Ø	311	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	General Comments		
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations This Read AM	3	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AL	901	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AF	901	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Maintenance Operations	0	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	General Comments	ABC Phase IOC	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations C Ø	1	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations B Ø	1	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations A Ø	1	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps C Ø	100.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps B Ø	100.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps A Ø	100.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	9 Months Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	General Comments	27.2/25	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Operations Counter	20	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Regulator As Left Counter	92816	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps A Ø	70.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps B Ø	70.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps C Ø	70.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Reading	.1944	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Switching Operations	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations This Read SF6	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AL	71	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AF	70	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Num Operations Last 9 Months	3	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Maintenance Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	General Comments	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Fault Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Ambient Temperature	54	°F
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Busted Glass	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	CO283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	Filter Dirty	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Regulator As Left Counter	29834	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Min Tap Position	14L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	9 Month Operations	4	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Current Tap Position	7L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	General Comments		
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	LTC Totalizer Reading	1399.68	kw
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Max	46	°C
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Present	34	°C
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	9 Month Operations	2	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps A Ø	57	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps B Ø	48	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps C Ø	50	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps A Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Maintenance Operations	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations Counter AF	182	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations Counter AL	183	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations This Read Vac	1	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Switching Operations	1	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Switching Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations This Read AM	3	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AL	153	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	12	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	18	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	20	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	20	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Left Counter	16369	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Found Counter	16369	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	General Comments		
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	105	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AF	641	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AL	641	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations This Read Vac	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Switching Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Left Counter	96195	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Found Counter	96195	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	139	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Left Counter	189075	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Found Counter	189075	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Operations Counter	17	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	General Comments	27.3/25.1	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	General Comments		
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.8	VDC
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Base Voltage AF	123.3	VAC
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Time Delay	60	Seconds
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	General Comments	nitrogen bottle needs refilled	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Max	50	*C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	*C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load X2 Max	60	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load Y2 Max	60	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Reading	.3812	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Time Delay	40	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	50	°C
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	General Comments		
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	All Connections OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Regulator As Left Counter	135403	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	40	°C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Max	50	°C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Present	30	°C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	°C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	45	°C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Max	50	°C
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Present	40	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0	amps
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Maintenance Operations	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AF	339	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AL	340	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations This Read Vac	2	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Cracked Glass	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Switching Operations	2	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Unknown Operations	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	General Comments		
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	9 Month Operations	16	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps A Ø	120.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps B Ø	120.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps C Ø	120.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Maintenance Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AF	252	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AL	253	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations This Read Vac	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Switching Operations	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Unknown Operations	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	LTC Output Voltage Level	125	VAC
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	LTC000696	LTCControl	874-1	LTC Control Insp	All Connections OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Regulator As Left Counter	86992	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Regulator As Left Counter	30542	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	9 Month Operations	4	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty A Ph V	1.36	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty B Ph V	1.02	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty C Ph V	1.36	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps A Ø	208	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps B Ø	213	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps C Ø	236	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Operations Counter	2336	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AF	341	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AL	341	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations This Read Vac	4	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Switching Operations	1	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Unknown Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	9 Month Operations	3	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty C Ph V	.34	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps A Ø	82	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps B Ø	85	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps C Ø	88	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Maintenance Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AF	240	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AL	241	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Regulator As Left Counter	142733	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations This Read Vac	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Switching Operations	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Unknown Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	LTC000894	LTCControl	032-6	LTC Control Insp	All Connections OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Reading	.4080	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Present	35	°C
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Max	50	°C
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	LTC Totalizer Reading	3264.00	kw
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	LTC Totalizer Reading	2744.64	kw
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Max	50	°C
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations Ground	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Maintenance Operations	3	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCCControl	116-6	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCCControl	116-6	LTC Control Insp	VRR Base Voltage AL	124.2	VAC
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCCControl	116-6	LTC Control Insp	VRR Base Voltage AF	124.2	VAC
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCCControl	116-6	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCCControl	116-6	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCCControl	116-6	LTC Control Insp	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCCControl	116-6	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCCControl	116-6	LTC Control Insp	All Connections OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Operations Since Last Insp	287	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Min Tap Position	14L	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Max Tap Position	8L	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Current Tap Position	9L	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Left Counter	29351	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Found Counter	29351	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Ambient Temperature	54	°F
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Fault Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	General Comments	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Maintenance Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Num Operations Last 9 Months	1	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations Counter AF	68	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations Counter AL	68	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations This Read SF6	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Pressure	90	psi
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Switching Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	402	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	402	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps A Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty C Ph V	2.46	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty B Ph V	3.18	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty A Ph V	6.75	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	9 Month Operations	4	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	All Connections OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Eyewash Solution	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	General Comments	Not on site yet.	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations This Read AM	2	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AL	326	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AF	326	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	General Comments	B Phase TOC / C Phase IOC	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations C Ø	1	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations B Ø	1	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps C Ø	140.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps B Ø	140.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001624	Battery	116-Battery Bank Control House	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001552	Charger	116-Battery Charger Control House	Battery Charger Patrol Insp	General Comments	Not on site yet.	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps A Ø	150.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	9 Months Operations	2	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	9 Month Operations	11	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps A Ø	260.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps B Ø	230.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps C Ø	250.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations A Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations B Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations Ground	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Maintenance Operations	0	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	9 Month Operations	10	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	General Comments		
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/6/2022 8:51	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	300.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	300.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	300.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Unknown Operations	0	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps A Ø	21.0	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	General Comments		
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Operations Counter	42	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	*F
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Unknown Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Switching Operations	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations This Read Vac	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AL	292	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AF	291	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Maintenance Operations	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps C Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps B Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps C Ø	480.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps B Ø	480.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps A Ø	480.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	9 Month Operations	10	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	9 Month Operations	2	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps A Ø	73.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps B Ø	57.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps C Ø	59.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Maintenance Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AF	237	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AL	237	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations This Read Vac	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Switching Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps C Ø	31	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps B Ø	42	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps A Ø	35	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty C Ph V	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	9 Month Operations	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	9 Month Operations	6	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps A Ø	70.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps B Ø	70.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps C Ø	80.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps A Phase V	25.80	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps B Phase V	25.80	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations A Ø	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations B Ø	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations Ground	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Present	50	°C
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Max	65	°C
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Reading	1.1360	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Maintenance Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AF	203	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AL	205	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations This Read Vac	6	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Switching Operations	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Unknown Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	9 Month Operations	9	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations A Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations B Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations Ground	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Maintenance Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AF	204	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AL	206	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations This Read Vac	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Switching Operations	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Unknown Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Unknown Operations	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Switching Operations	1	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations This Read Vac	1	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations Counter AL	174	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Maintenance Operations	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AF	209	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AL	211	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations This Read Vac	1	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Switching Operations	1	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Unknown Operations	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	9 Month Operations	4	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps A Ø	0.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps B Ø	0.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps C Ø	0.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps A Ø	90.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps B Ø	80.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps C Ø	85.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations A Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations B Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations Ground	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Present	55	°C
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Max	120	°C
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	LTC Totalizer Reading	20448.00	kw
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9792	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1175.04	kw
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	General Comments		
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Regulator As Left Counter	92299	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	General Comments	counter doesn't work	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AF	980	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AL	980	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations This Read AM	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Switching Operations	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Switching Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations This Read Vac	0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AL	255	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AF	255	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	9 Month Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps A Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps B Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps C Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AF	158	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AL	158	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations This Read Vac	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Switching Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	General Comments	OPEN	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Maintenance Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AF	352	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AL	352	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations This Read Vac	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Switching Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	9 Months Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Unknown Operations	0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps A Ø	50.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps B Ø	50.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps C Ø	50.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	*F
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	9 Month Operations	8	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps A Ø	60.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps B Ø	59.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps C Ø	58.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations Ground	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Maintenance Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AF	242	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AL	242	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations This Read Vac	2	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Switching Operations	2	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Unknown Operations	0	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps C Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps B Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps A Ø	0.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	9 Month Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Unknown Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	74	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	6	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Left Counter	59358	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Found Counter	59358	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Operations Since Last Insp	453	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Min Tap Position	11L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Max Tap Position	1L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Current Tap Position	7L	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Left Counter	142720	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Found Counter	142712	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:39	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Maintenance Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AF	237	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AL	241	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations This Read Vac	4	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Switching Operations	4	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Water coming in from Exhaust fan	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AF	154	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AL	154	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations This Read AM	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps C Ø	50.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps B Ø	50.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps A Ø	50.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Switching Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Unknown Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Found Counter	172502	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Left Counter	172505	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Current Tap Position	2L	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Max Tap Position	2R	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	9 Months Operations	3	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Min Tap Position	5L	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Operations Since Last Insp	258	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	9 Month Operations	7	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty A Ph V	2.07	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty B Ph V	.69	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty C Ph V	3.46	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps A Ø	30	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps B Ø	30	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps C Ø	30	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	9 Month Operations	5	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	LTC Totalizer Reading	26442.00	kw
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Max	70	°C
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Present	40	°C
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty A Ph V	13	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty B Ph V	10.56	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty C Ph V	14.63	%
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps A Ø	19	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps B Ø	24	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps C Ø	20	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Reading	1.4690	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Max	85	°C
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Present	45	°C
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Maintenance Operations	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AF	515	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AL	515	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations This Read Vac	1	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Switching Operations	1	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Unknown Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	9 Month Operations	4	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps A Ø	93.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps B Ø	116.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps C Ø	82.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations Ground	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Maintenance Operations	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AF	180	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AL	181	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations This Read Vac	1	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Switching Operations	1	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Unknown Operations	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	9 Month Operations	8	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps A Ø	210.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps B Ø	200.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps C Ø	210.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Maintenance Operations	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AF	409	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AL	413	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations This Read Vac	4	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Switching Operations	4	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Unknown Operations	0	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	20.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	*F
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	if no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations This Read Vac	1	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AL	191	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AF	191	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Maintenance Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations Ground	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps C Ø	128.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps B Ø	123.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps A Ø	127.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	9 Month Operations	1	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Switching Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations This Read AM	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AL	67	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AF	67	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps C Ø	0.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps B Ø	0.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps A Ø	0.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	9 Months Operations	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	9 Month Operations	16	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps A Ø	380.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps B Ø	350.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps C Ø	360.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	2	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Found Counter	440836	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Left Counter	440838	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Max Tap Position	3R	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Min Tap Position	7L	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Operations Since Last Insp	562	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Regulator As Left Counter	128727	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	388	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	388	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.1	psi
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7516.8	kw
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Oil Temp Max	52	°C
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Oil Temp Present	44	°C
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Totalizer Meter Reading	.783	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	All Connections OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	General Comments	above breaker 4427 on line side, insulator has a large chip in skirt on bottom of line side disconnect	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	4	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	4	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps C Ø	90.0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps B Ø	60.0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps A Ø	70.0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Reading	.2120	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Present	35	°C
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Max	50	°C
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	LTC Totalizer Reading	678.40	kw
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Unknown Operations	0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Switching Operations	2	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations This Read Vac	2	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AL	188	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AF	186	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Maintenance Operations	0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations Ground	0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations C Ø	0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations B Ø	0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations A Ø	0	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Reading	.2406	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Present	35	°C
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Max	36	°C
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	LTC Totalizer Reading	2309.76	kw
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Present	27	°C
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Max	32	°C
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Reading	.3876	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Present	30	°C
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Max	30	°C
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	LTC Totalizer Reading	3720.96	kw
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Maintenance Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps C Ø	12.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps B Ø	12.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps A Ø	12.0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	9 Month Operations	4	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Unknown Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Switching Operations	1	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	9 Month Operations	3	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	9 Month Operations	7	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps A Ø	75.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps B Ø	80.0	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Regulator As Left Counter	124620	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	General Comments		
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps C Ø	80.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations Ground	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Maintenance Operations	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AF	240	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AL	240	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations This Read Vac	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Switching Operations	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Unknown Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Unknown Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Switching Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations This Read Vac	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AL	461	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AF	461	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	General Comments		
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	9 Month Operations	8	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty B Ph V	.64	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps A Ø	180	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps B Ø	130	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps C Ø	130	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Negative DC Ground	66.9	VDC
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.8	VDC
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	General Comments		
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps C Ø	6.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps B Ø	6.0	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	Bushing oil on A and C phases turning red	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Found Counter	126726	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Left Counter	126726	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Current Tap Position	6L	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Min Tap Position	14L	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Operations Since Last Insp	545	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Vegetation	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Max Tap Position	3R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	General Comments		
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations A Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations B Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations Ground	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	leaking from top of transformer	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations B Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Operations Ground	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	General Comments		
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Maintenance Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AF	165	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AL	166	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations This Read Vac	1	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Switching Operations	1	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Unknown Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	9 Month Operations	8	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps A Ø	0.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps B Ø	0.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps C Ø	0.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	General Comments		
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Maintenance Operations	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AF	740	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AL	740	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations This Read Vac	0	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Switching Operations	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Unknown Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Switching Operations	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations This Read Vac	0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AL	72	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AF	72	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations Ground	0	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65	VDC
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68	VDC
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Maintenance Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AF	200	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AL	201	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations This Read Vac	1	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Switching Operations	1	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Unknown Operations	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Found Counter	160500	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Left Counter	160500	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Current Tap Position	7L	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Min Tap Position	15L	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Operations Since Last Insp	369	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Switching Operations	2	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations This Read Vac	2	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AL	234	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AF	234	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps C Ø	350.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps B Ø	350.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps A Ø	350.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	9 Months Operations	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Max	32	°C
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Reading	.6336	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Present	32	°C
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Max	32	°C
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AF	265	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AL	266	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations This Read Vac	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Switching Operations	1	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	LTC Totalizer Reading	6082.56	kw
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Unknown Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.6	VDC
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Present	27	°C
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.6	amps
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 14:24	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Counter Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Counter Readings	LTC As Found Counter	157209	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Counter Readings	LTC As Left Counter	157215	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	00231	LTCMechanism	116-6	LTC Counter Readings	LTC Current Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Max Tap Position	2R	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Min Tap Position	6L	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Operations Since Last Insp	416	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	General Comments	upper fence post washing out, large tree limbs growing into station over fence	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	9 Month Operations	14	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	9 Month Operations	4	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty A Ph V	1.19	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps A Ø	287	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps B Ø	305	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps C Ø	296	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations A Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations B Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations C Ø	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations Ground	0	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Follow-up Action Required?	n	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Maintenance Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps A Ø	6.0	
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 11:17	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations A Ø	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations B Ø	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations C Ø	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations Ground	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Maintenance Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AF	21	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AL	26	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations This Read Vac	5	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Switching Operations	5	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Unknown Operations	0	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 11:13	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	General Comments		
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.2	VDC
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.2	VDC
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	General Comments	Counter not working	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Found Counter	3300	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Left Counter	3300	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Current Tap Position	10L	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Max Tap Position	4L	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Min Tap Position	15L	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Unknown Operations	0	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 11:43	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Neighboring Fence within 6'	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	General Comments	vegetation needs cut back from the fence	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps A Ø	185.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	9 Month Operations	1	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations This Read Vac	1	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AL	238	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AF	238	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Maintenance Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	General Comments		
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AF	197	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps B Ø	175.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps C Ø	190.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps A Ø	96.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps B Ø	111.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps C Ø	99.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Switching Operations	2	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	9 Month Operations	8	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	9 Month Operations	7	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps A Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps A Ø	120.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps B Ø	100.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps C Ø	90.0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	9 Month Operations	6	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Unknown Operations	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Switching Operations	1	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations B Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Unknown Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Switching Operations	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations This Read Vac	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AL	199	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Unknown Operations	0	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations Ground	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations B Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations A Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps C Ø	120.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps B Ø	100.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps A Ø	100.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	9 Month Operations	17	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AF	202	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Maintenance Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Present	36	*C
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Max	50	*C
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations Ground	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	9 Month Operations	12	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	LTC Totalizer Reading	7689.6	kw
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations B Ø	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	General Comments		
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations A Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations B Ø	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Unknown Operations	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Switching Operations	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations This Read Vac	0	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AL	202	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Reading	.801	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 12:18	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations C Ø	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations Ground	0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Maintenance Operations	0	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 16:05	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	General Comments		
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	79	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	56	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.1	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	.2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	.2	
4/5/2022 14:41	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	52	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Present	30	°C
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Max	34	°C
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AF	687	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps A Ø	235.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.0624	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Present	31	°C
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Max	31	°C
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	9 Month Operations	7	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Unknown Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Switching Operations	1	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations This Read Vac	1	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AL	163	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AF	162	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations A Ø	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations B Ø	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations C Ø	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations Ground	0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Follow-up Action Required?	n	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps C Ø	270.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps B Ø	230.0	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	All Connections OK?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	General Comments		
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
4/5/2022 13:11	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 12:33	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps C Ø	355.0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AL	687	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps A Ø	100	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps B Ø	90	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations This Read AM	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps B Ø	365.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps A Ø	355.0	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AF	209	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AL	211	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations This Read Vac	2	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Switching Operations	0	
4/6/2022 4:59	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Unknown Operations	0	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 12:00	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Maintenance Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations Ground	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations C Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations B Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations A Ø	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	7649.28	kw
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	General Comments		
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Maintenance Operations	0	
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	General Comments		
4/5/2022 15:11	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 15:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps C Ø	90	
4/5/2022 15:55	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty A Ph V	3.14	%
4/5/2022 15:41	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallePAR	Position
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps A Phase V	30.40	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps B Phase V	30.40	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps C Phase V	30.40	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations A Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations B Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations C Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.7	amps
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.000	millivolts
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Unknown Operations	6	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Switching Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations This Read Vac	6	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations Counter AL	181	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations Counter AF	181	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Maintenance Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	General Comments	BFTC 3-30-22	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Time Delay	60	Seconds
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AF	124.4	VAC
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Operation Checked?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	All Connections OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Vegetation	None	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps C Ø	150.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps B Ø	150.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps A Ø	140.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	9 Month Operations	16	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Regulator As Left Counter	153365	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Operations Since Last Insp	301	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Min Tap Position	4L	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Current Tap Position	9L	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Left Counter	63495	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Found Counter	63495	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Switching Operations	2	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations This Read Vac	2	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AL	259	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AF	257	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations Ground	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps C Ø	0.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps B Ø	0.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps A Ø	0.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	9 Month Operations	10	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	43	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	43	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations Ground	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Trash Emptied?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Trash Emptied?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Switching Operations	2	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations This Read Vac	2	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AL	261	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AF	261	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Oil Temp Present	24	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	103.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	71.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	91.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Oil Temp Max	33	°C
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Vegetation	None	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Max	40	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	LTC Totalizer Reading	10392.00	kw
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	General Comments	Multiple insulators have chipped and broken skirts above transformers	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	General Comments	barbed wire rusty	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	178	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	178	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B & C phase IOC	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps C Ø	200.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps B Ø	200.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps A Ø	200.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	9 Month Operations	17	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	43.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	51.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	53.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Switching Operations	4	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations This Read Vac	4	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AL	469	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AF	469	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AF	90500	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AL	90500	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations This Read Vac	2	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Switching Operations	2	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Unknown Operations	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	76	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps C Ø	109.0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps B Ø	148.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps A Ø	151.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	9 Month Operations	12	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	76	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	9 Month Operations	14	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps A Ø	130.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps B Ø	140.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps C Ø	140.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Current Tap Position	1R	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Max Tap Position	8R	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Min Tap Position	16L	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Breaker is open / not in use.	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations C Ø	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations B Ø	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations A Ø	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps C Ø	12.0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps B Ø	11.0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps A Ø	10.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	9 Month Operations	5	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps C Ø	0.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps B Ø	0.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps A Ø	0.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	9 Month Operations	14	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Ambient Temp	57	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Vegetation	None	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1425	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1425	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	No change in counter, check counter.	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	General Comments	2 arrestors blown on cir 414 and one blown on cir 415, center bushing on transfer buss has chipped skirt	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Present	30	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Max	40	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Reading	.4330	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Switching Operations	3	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations This Read Vac	3	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AL	288	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AF	287	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	LTC Totalizer Reading	1982.40	kw
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Max	42	°C
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Present	19	°C
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Reading	.4130	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	9 Month Operations	9	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	General Comments		
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	General Comments	added one pound of nitrogen, tank seeping	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	LTC Totalizer Reading	4108.80	kw
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Present	30	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Max	40	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Reading	.6018	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Present	30	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Max	45	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	LTC Totalizer Reading	8665.92	kw
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	General Comments		
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	1839.36	kw
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Max	52	°C
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Present	33	°C
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Reading	.3832	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AF	261	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AL	261	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations This Read Vac	2	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Switching Operations	2	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Unknown Operations	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Time Delay	30	Seconds
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	General Comments		
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Unknown Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Switching Operations	0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Max	66	°C
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Present	34	°C
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps A Ø	110.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps B Ø	110.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps C Ø	90.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations B Ø	0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Reading	.8560	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	General Comments	Fabric is rusty and barb wire.	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	All Connections OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	LTC Operation Checked?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AF	204	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AL	205	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations This Read Vac	1	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Switching Operations	1	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Unknown Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Found Counter	10118	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Left Counter	10118	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Current Tap Position	5L	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Max Tap Position	3L	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Min Tap Position	10L	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Operations Since Last Insp	179	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7918.56	kw
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Max	59	°C
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	LTC Totalizer Reading	7747.20	kw
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Oil Temp Max	35	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Oil Temp Present	30	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Totalizer Meter Reading	.3228	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Winding Temp Max	35	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Winding Temp Present	30	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	9 Month Operations	7	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps A Ø	245.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps B Ø	250.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps C Ø	255.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AF	1316	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AL	1316	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations This Read Vac	1	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Switching Operations	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Unknown Operations	1	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	81	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps A Ø	4.2	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps B Ø	4.0	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps C Ø	4.9	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	92	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	462	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	All Connections OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Operation Checked?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Present	25	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Max	50	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Reading	.5502	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Present	40	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Max	45	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	LTC Totalizer Reading	7922.88	kw
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0998	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Negative DC Ground	9.0	VDC
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Switching Operations	4	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations This Read Vac	4	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	9 Month Operations	7	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps A Ø	10.0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps B Ø	10.0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps C Ø	11.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AL	401	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AF	401	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps A Phase V	3.04	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps B Phase V	3.04	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps C Phase V	3.04	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations A Ø	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations B Ø	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations C Ø	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations Ground	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Maintenance Operations	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	LTC Totalizer Reading	3163.20	kw
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Max	49	°C
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Present	29	°C
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Reading	.6590	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Present	30	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Max	45	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Reading	.6370	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Current Tap Position	3R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	All Connections OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Operation Checked?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AF	125.3	VAC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AL	124.5	VAC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Time Delay	60	Seconds
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Regulator As Left Counter	161849	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Min Tap Position	7L	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Max Tap Position	6R	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps B Ø	9.0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps C Ø	21.0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	General Comments	BFTC	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Operations Counter	18	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Max Tap Position	4L	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Min Tap Position	14L	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Operations Since Last Insp	688	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	49	°F
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	All Connections OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Current Tap Position	13L	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Max Tap Position	7L	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Current Tap Position	6L	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	General Comments		
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Max Tap Position	2R	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Regulator As Left Counter	68767	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Present	30	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Max	40	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	LTC Totalizer Reading	9172.80	kw
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Regulator As Left Counter	61422	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Current Tap Position	13L	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	General Comments		
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	General Comments	LTC below normal level	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Found Counter	284189	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Left Counter	284196	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Current Tap Position	12L	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	General Comments	corner of foundation next to house is crumbling, multiple insulators are cracked and chipped in the steel	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Regulator As Left Counter	145168	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Min Tap Position	6L	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Max Tap Position	6R	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Switching Operations	4	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations This Read Vac	4	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AL	404	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Current Tap Position	1R	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations This Read Vac	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AL	583	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AF	583	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Maintenance Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps C Ø	194.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps B Ø	212.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps A Ø	203.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	9 Month Operations	5	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Operations Counter	88	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	General Comments	open	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Operations Since Last Insp	719	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Min Tap Position	5L	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Max Tap Position	5R	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Current Tap Position	2L	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Left Counter	32556	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Found Counter	32456	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	General Comments	Tank level slightly below normal level	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps C Ø	100.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps B Ø	100.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps A Ø	100.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	9 Month Operations	8	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	350	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Left Counter	210127	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Found Counter	210127	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	256	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Left Counter	102134	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Found Counter	102134	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Found Counter	211089	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Left Counter	211089	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Current Tap Position	9L	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Max Tap Position	5L	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Min Tap Position	12L	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Operations Since Last Insp	428	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AF	404	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps C Ø	25.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps B Ø	25.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps A Ø	25.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	9 Month Operations	7	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Current Tap Position	2R	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Max Tap Position	4R	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Regulator As Left Counter	822270	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Vegetation	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Max	48	°C
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Present	22	°C
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC00662	LTCControl	549-3	LTC Control Insp	VRR Time Delay	30	Seconds
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC00662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC00662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Left Counter	111985	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Found Counter	111985	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	68.40	kw
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Oil Temp Present	22	°C
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1140	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	General Comments		
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	General Comments		
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Unknown Operations	45	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Switching Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCCControl	549-3	LTC Control Insp	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCCControl	549-3	LTC Control Insp	All Connections OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Switching Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations This Read Vac	45	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations Counter AL	241	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations Counter AF	241	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations This Read Vac	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AL	397	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AF	397	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations B Ø	0	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	General Comments		
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 11:03	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCCControl	549-3	LTC Control Insp	LTC Output Voltage Level	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	LTC Operation Checked?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Max	88	°C
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/4/2022 12:07	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps C Ø	376.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps B Ø	397.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps A Ø	392.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	9 Month Operations	7	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	42	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	38	°C
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Current Tap Position	16L	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Regulator As Left Counter	65051	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	General Comments	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Grounds in Place?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Maintenance Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Num Operations Last 9 Months	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Found Counter	374751	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	General Comments	raise drag hand is stuck on the moving drag hand.	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	General Comments	oil level below normal fill level	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	All Connections OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations Counter AF	113	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations Counter AL	113	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	General Comments	nitrogen bottle is empty	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Operations Since Last Insp	627	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Min Tap Position	8L	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Max Tap Position	1L	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Current Tap Position	1L	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Left Counter	374758	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Unknown Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Switching Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations This Read Vac	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AL	291	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AF	291	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Maintenance Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99895	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99895	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	General Comments		
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 2	59	psi
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 3	60	psi
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Switching Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Operations Since Last Insp	349	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Min Tap Position	7L	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Max Tap Position	4R	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	38	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations This Read SF6	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 1	59	psi
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	7508	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	7508	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations A Ø	0	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	General Comments		
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	1456.80	kw
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Max	51	°C
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Present	34	°C
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Reading	.6070	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Max	56	°C
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Switching Operations	1	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations This Read Vac	1	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AL	165	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AF	164	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Leaks	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Regulator As Left Counter	161087	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Min Tap Position	12L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Max Tap Position	1R	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	General Comments		
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Current Tap Position	9L	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	42	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	38	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	42	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	9 Month Operations	6	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps A Ø	210.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps B Ø	200.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps C Ø	215.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Max	34	°C
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Present	21	°C
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Regulator As Left Counter	150033	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	General Comments		
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	32	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	38	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	42	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Vegetation	None	
4/4/2022 12:07	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AF	237	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AL	240	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations This Read Vac	3	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Switching Operations	3	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Unknown Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	General Comments	BFTC 3-31-22	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	9 Month Operations	12	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps A Ø	0.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps B Ø	0.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps C Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1200.0	psi
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2	psi
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Max	38	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	32	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	33	°C
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	9 Month Operations	66	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	General Comments		
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Max	49	°C
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Unknown Operations	0	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps C Ø	75.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps B Ø	60.0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Present	38	°C
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations Ground	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations C Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations B Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps A Ø	85.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps C Phase V	228.01	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps B Phase V	228.01	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps A Phase V	228.01	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	9 Month Operations	7	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps C Ø	15.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps B Ø	20.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps A Ø	14.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NITROGEN CYLINER NEEDS TO BE FILLED. THERE IS ONE RADIATOR THAT IS SEEPING OIL. THERE ARE TWO FANS ON THE TRANSFORME	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	7.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	8.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	8.0	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	General Comments	BFTC	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps A Ø	360.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps B Ø	365.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	9 Month Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps A Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps B Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps C Ø	0.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Follow-up Action Required?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	General Comments	Amps not working for this breaker, Breaker is closed and all indication is showing the same but on the switzer 351S the lock out light is	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Maintenance Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AF	151	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AL	151	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations This Read Vac	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Switching Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Unknown Operations	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	135	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations A Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations B Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Operations Since Last Insp	395	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Min Tap Position	7L	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Max Tap Position	2R	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Current Tap Position	2L	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Left Counter	40210	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Found Counter	40210	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	9 Month Operations	3	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Vegetation	None	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps A Ø	0.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps B Ø	0.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps C Ø	0.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	General Comments		
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	9 Month Operations	9	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Operations Counter	13	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Vegetation	None	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	General Comments		
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations C Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations Ground	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	General Comments	BFTC 2-27-22	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Maintenance Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AF	210	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AL	210	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations This Read Vac	1	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Maintenance Operations	0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AF	45	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AL	46	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations This Read Vac	1	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Switching Operations	1	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Unknown Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Switching Operations	1	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Unknown Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Unknown Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Switching Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations This Read Vac	1	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations Counter AL	183	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Maintenance Operations	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AF	9	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AL	9	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations This Read Vac	0	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Switching Operations	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations Counter AF	183	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Maintenance Operations	1	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	General Comments	BFTC Breaker open	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 12:01	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Unknown Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	148.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	128.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	143.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps C Ø	375.0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Left Counter	74402	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Found Counter	74402	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	FOUND OIL LEAK IN PUMP FILTER HOUSING. FIXED LEAK AND ADDED OIL TO TAP CHANGER. OIL LEVEL IS GOOD AND THERE ARE NO LE	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations Ground	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	All Connections OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Operation Checked?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps C Ø	75.0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps A Ø	62.0	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	9 Month Operations	1	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps A Ø	137.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps B Ø	90.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps C Ø	96.0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushing Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations A Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	General Comments		
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations A Ø	0	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations B Ø	0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Vegetation	None	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	General Comments		
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	9 Month Operations	2	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps A Ø	68.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps B Ø	62.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps C Ø	65.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Maintenance Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Tank Paint Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Unknown Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AF	150	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AL	150	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations This Read Vac	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Switching Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Unknown Operations	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Ambient Temperature	53	*F
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps C Ø	125.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps B Ø	140.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps A Ø	143.0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	9 Month Operations	1	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCCControl	499-1	LTC Control Insp	VRR Base Voltage AF	123.2	VAC
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Fault Operations	0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCCControl	499-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AL	261	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Grounds in Place?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations This Read Vac	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Switching Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Unknown Operations	0	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCCControl	499-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCCControl	499-1	LTC Control Insp	VRR Time Delay	60	Seconds
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	General Comments		
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Vegetation	None	
4/4/2022 13:09	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	General Comments	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Foundation Condition	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AF	261	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Maintenance Operations	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	General Comments		
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations Ground	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations C Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations B Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations A Ø	0	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Fault Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Ambient Temperature	53	*F
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Maintenance Operations	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Num Operations Last 9 Months	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations Counter AF	81	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations Counter AL	81	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations This Read SF6	0	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Broom on Site?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 1	60	psi
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 2	60	psi
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 3	62	psi
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Switching Operations	0	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	All Connections OK?	y	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	Follow-up Action Required?	n	
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	General Comments		
4/4/2022 13:13	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Operation Checked?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	General Comments		
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/4/2022 13:25	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/4/2022 14:46	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Follow-up Action Required?	n	
4/5/2022 7:13	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Foundation Condition	Good	
4/4/2022 14:00	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/4/2022 11:07	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	113817	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	General Comments	ok	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	General Comments		small tree on fence. I removed
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations Ground	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11032	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Found Counter	276602	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Left Counter	276605	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Current Tap Position	4L	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Max Tap Position	7R	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Min Tap Position	5L	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Operations Since Last Insp	303	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations C Ø	0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	General Comments		
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Found Counter	529502	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Left Counter	529511	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Current Tap Position	1L	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Max Tap Position	2R	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Min Tap Position	2L	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Operations Since Last Insp	196	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	General Comments	Small washout under fence behind xfms.	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations B Ø	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations A Ø	0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Regulator As Left Counter	9255	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Maintenance Operations	1	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AF	252	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AL	252	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations This Read Vac	1	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Switching Operations	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Unknown Operations	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Found Counter	130570	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Ambient Temperature	48	*F
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Fault Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Pressure	66	psi
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Switching Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Maintenance Operations	1	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	General Comments		
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	General Comments	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Maintenance Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Num Operations Last 9 Months	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AF	84	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations Ground	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations C Ø	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations B Ø	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations A Ø	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AL	84	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations This Read SF6	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Compressor Belt Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Pressure	64	psi
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Switching Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Unknown Operations	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Switching Operations	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations This Read Vac	1	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AL	166	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AF	166	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Ambient Temperature	48	*F
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Fault Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Maintenance Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Operations Since Last Insp	283	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Min Tap Position	5L	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Max Tap Position	7R	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Current Tap Position	4R	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Left Counter	130573	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Num Operations Last 9 Months	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AF	72	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AL	72	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations This Read SF6	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6570	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	General Comments	Old OCB needs to be removed	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55761	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	General Comments	barbed wire top broke in places	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Min Tap Position	2L	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Unknown Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Evidence of Insects	None	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Swept?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panels Dusted?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	9 Month Operations	4	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps A Ø	6.0	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps B Ø	4.0	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps C Ø	21.0	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations A Ø	0	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations B Ø	0	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations C Ø	0	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations Ground	0	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	General Comments	1 trip check	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Maintenance Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32649	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	9 Month Operations	6	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2102.40	kw
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps B Ø	90.0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps C Ø	120.0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	General Comments	Could use a new spare fuse barrel for xfmr. Need additional wildlife protection in bus.	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.6	VDC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.6	VDC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	General Comments	Neighboring fence 43 inches.	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AF	198	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AL	198	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations This Read Vac	1	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Switching Operations	0	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Unknown Operations	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10854	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps A Ø	84.0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps C Ø	104.0	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps A Ø	84.0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Present	35	°C
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Max	45	°C
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	LTC Totalizer Reading	11433.6	kw
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations A Ø	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations B Ø	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations C Ø	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations Ground	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	General Comments	1 trip check	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	General Comments	ok	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	General Comments	Small washout under fence behind xfmr.	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	General Comments		
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Current Tap Position	6R	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	9 Month Operations	4	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps A Ø	20.0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps B Ø	35.0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps C Ø	20.0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Reading	1.191	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	51	*F
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Negative DC Ground	8.4	VDC
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Positive DC Ground	8.4	VDC
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Operations Counter	21	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	General Comments	2 small washouts under fence. One to the left of gate entrance and one in back	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Switching Operations	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Unknown Operations	0	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Maintenance Operations	1	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AF	217	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AL	217	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations This Read Vac	1	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28905	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	General Comments		
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46831	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Max Tap Position	2R	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	General Comments	Bus and transfer switches need wildlife protection.	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Regulator As Left Counter	70680	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Vegetation	None	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Present	35	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Max	35	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Regulator As Left Counter	23343	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Present	25	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Max	35	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	General Comments		
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Ambient Temp	45	°F
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Min Tap Position	1R	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Max Tap Position	12R	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BAT001608	Battery	803-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	803-Battery Charger Current	2.0	amps
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Ambient Temp	51	*F
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Vegetation	None	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	BCH001535	Charger	803-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Regulator As Left Counter	62139	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Maintenance Operations	1	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AF	193	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AL	193	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations This Read Vac	4	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Switching Operations	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Unknown Operations	3	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Regulator As Left Counter	84552	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	General Comments		
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Foundation Condition	Crumbling	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	18.3	VDC
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	18.3	VDC
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.5	VDC
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	9 Month Operations	3	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Present	30	*C
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Max	44	*C
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	9 Month Operations	8	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps A Ø	54.0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps B Ø	44.0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps C Ø	32.0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps A Phase V	3.94	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps B Phase V	3.94	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps C Phase V	3.94	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations A Ø	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations B Ø	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations C Ø	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations Ground	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	General Comments	3 ops unknown	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Maintenance Operations	1	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AF	169	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AL	169	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations This Read Vac	1	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Switching Operations	0	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Unknown Operations	0	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	General Comments		
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Foundation Condition	Crumbling	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Regulator As Left Counter	177996	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps B Ø	55.0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps C Ø	34.0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	General Comments	1 trip check	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AF	227	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AL	227	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations This Read Vac	13	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Switching Operations	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Unknown Operations	12	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.1	VDC
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.3	VDC
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Regulator As Left Counter	34466	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	9 Month Operations	17	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps A Ø	79.0	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps B Ø	49.0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps C Ø	69.0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps A Phase V	15.77	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps B Phase V	15.77	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps C Phase V	15.77	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations A Ø	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations B Ø	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations C Ø	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations Ground	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	General Comments	12 ops unknown	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Maintenance Operations	1	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	140.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	28.44	kw
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusty and drooping in areas.	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27749	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	General Comments		
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4740	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	60	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2384.64	kw
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	General Comments	ok	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Operations Counter	41	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	General Comments		
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.3	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Max	34	°C
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Present	34	°C
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6624	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	281974	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	813.60	kw
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	210.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	37	°C
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	23	°C
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	General Comments	No spare xfmr fuses.	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Fault Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Ambient Temperature	48	*F
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	All Connections OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	LTC Operation Checked?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	LTCC000938	LTCControl	737-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.6780	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Found Counter	39962	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Left Counter	39965	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Current Tap Position	5R	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Max Tap Position	7R	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Min Tap Position	5L	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Operations Since Last Insp	301	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Unknown Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Switching Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Pressure	67	psi
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations This Read SF6	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AL	52	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AF	52	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Num Operations Last 9 Months	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Maintenance Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	General Comments	Bus needs wildlife protection.	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	General Comments	Containment berm is washed out behind xfmr.	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.2	VDC
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations This Read Vac	1	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AL	205	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AF	205	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Maintenance Operations	1	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations Ground	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations C Ø	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations B Ø	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations A Ø	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps C Ø	84.0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps B Ø	78.0	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	General Comments		
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Regulator As Left Counter	483121	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps A Ø	120.0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	9 Month Operations	2	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Operations Counter	61	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.0	VDC
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.0	VDC
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.9	VDC
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.2	VDC
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	°F
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	18	°C
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Reading	.6444	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	410.00	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	60	°C
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	24	°C
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	All Connections OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Operation Checked?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Output Voltage Level	1135.0	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Time Delay	45	Seconds
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	General Comments	one fan not working	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3168.00	kw
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3200	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	General Comments		
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	General Comments		
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	LTC Totalizer Reading	3093.12	kw
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Max	52	°C
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Present	22	°C
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4098	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	9 Month Operations	5	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps A Ø	49.0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps B Ø	71.0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps C Ø	51.0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations A Ø	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations B Ø	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations C Ø	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations Ground	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AF	193	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AL	193	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations This Read Vac	1	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Switching Operations	1	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	All Connections OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Operation Checked?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Output Voltage Level	113.5	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Time Delay	45	Seconds
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	All Connections OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Operation Checked?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Output Voltage Level	113.4	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Time Delay	45	Seconds
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2950.56	kw
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Max	38	°C
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Present	27	°C
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Regulator As Left Counter	90036	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Regulator As Left Counter	29453	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Regulator As Left Counter	17584	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Unknown Operations	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Switching Operations	2	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations This Read Vac	6	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations Counter AL	194	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations Counter AF	194	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Maintenance Operations	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	General Comments	storm	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations Ground	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations C Ø	1	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations B Ø	1	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations A Ø	2	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps C Phase V	1.93	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps B Phase V	1.93	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps A Phase V	3.86	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps C Ø	34.0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps B Ø	28.0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps A Ø	31.0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	9 Month Operations	9	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.5	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	30.1	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	56.5	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	11 ops	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	699	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations A Ø	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations B Ø	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations C Ø	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations Ground	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Maintenance Operations	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AF	214	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AL	214	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations This Read Vac	2	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Switching Operations	2	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Unknown Operations	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Crumbling	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Broken	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	General Comments		
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	General Comments	Temp gauge needs replacing, moisture inside, difficult to read.	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1051.20	kw
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4380	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 10:07	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 10:07	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 10:07	Distribution	Clinton 12KV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	321977	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	9 Month Operations	3	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps A Ø	17.0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps B Ø	35.0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps C Ø	38.0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	General Comments		
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	140.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	General Comments		
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	General Comments	Needs new nitro gauge.	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Switching Operations	0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations This Read Vac	1	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AL	172	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AF	172	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Maintenance Operations	1	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	416.16	kw
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Max	39	°C
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Present	15	°C
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2544.00	kw
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Oil Temp Max	52	°C
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0600	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	51	°F
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Unknown Operations	0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps A Ø	50.0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	9 Month Operations	2	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	General Comments	Metering equipment conduit in ned of repair	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3468	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	General Comments		
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	General Comments		
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations Ground	0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations C Ø	0	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	28	°C
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations B Ø	0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations A Ø	0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps C Ø	50.0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps B Ø	50.0	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	General Comments		
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Max	60	°C
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	9 Month Operations	6	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps A Ø	162.0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps B Ø	119.0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps C Ø	123.0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps A Phase V	5.59	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps B Phase V	5.59	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps C Phase V	5.59	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations A Ø	0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations B Ø	0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations C Ø	0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations Ground	0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Maintenance Operations	0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AF	183	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AL	183	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations This Read Vac	1	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Switching Operations	0	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Unknown Operations	1	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	General Comments		
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	General Comments	Nitro guage broke	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	General Comments		
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Operations Counter	798	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	General Comments		
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps B Ø	79.0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps C Ø	68.0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	General Comments	TC	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Operations Counter	101	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8562	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Max	20	°C
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3082.32	kw
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	General Comments	installed new guage	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	204	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps A Ø	9.0	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps B Ø	8.1	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps C Ø	6.1	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	236	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	194	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33823	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps A Ø	61.0	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps C Ø	23.0	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Unknown Operations	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Switching Operations	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations This Read Vac	1	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AL	358	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AF	358	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Operations Counter	75	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Leaks	None	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Maintenance Operations	1	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	General Comments	ok	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	General Comments	1 trip check	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations Ground	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations C Ø	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations B Ø	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations A Ø	0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps C Ø	65.0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps B Ø	60.0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Found Counter	155141	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Left Counter	155141	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Current Tap Position	3L	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Max Tap Position	1L	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Min Tap Position	7L	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Operations Since Last Insp	245	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2822.40	kw
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Max	22	°C
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5880	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Max	34	°C
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Present	24	°C
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations A Ø	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations B Ø	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations C Ø	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations Ground	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Max	55	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Present	55	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Max	45	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Present	45	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Maintenance Operations	1	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AF	93	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AL	93	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations This Read Vac	1	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Switching Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Unknown Operations	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Unknown Operations	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Switching Operations	0	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps A Ø	55.0	
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 15:24	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	9 Month Operations	4	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	General Comments		
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	79922	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Found Counter	12575	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Left Counter	12575	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Current Tap Position	2L	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Max Tap Position	6R	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Min Tap Position	10L	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Operations Since Last Insp	1026	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33269	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	General Comments		
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:59	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Unknown Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Switching Operations	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations This Read Vac	1	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AL	78	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AF	78	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Maintenance Operations	1	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations Ground	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32978	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34629	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	9 Month Operations	2	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps A Ø	500.0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps B Ø	500.0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps C Ø	500.0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations C Ø	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations B Ø	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations A Ø	0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps C Ø	100.0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps B Ø	100.0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps A Ø	100.0	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	9 Month Operations	2	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	142550	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 10:50	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Max	47	°C
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Regulator As Left Counter	71384	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	General Comments		
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Foundation Condition	Crumbling	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Max Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	no stable reading	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps C Ø	5.0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps B Ø	40.0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps A Ø	40.0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	9 Month Operations	5	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	*F
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Unknown Operations	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.5	VDC
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.6	VDC
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	9 Month Operations	2	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps A Ø	90.0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps B Ø	110.0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps C Ø	125.0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	General Comments	Needs new nitro gauge.	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	General Comments	ok	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	General Comments	meter has an error	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.0	psi
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	General Comments		
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Maintenance Operations	2	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AF	99945	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AL	99945	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations This Read Vac	2	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Switching Operations	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Unknown Operations	0	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Unknown Operations	0	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	General Comments		
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	General Comments		
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	231.45	kw
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations A Ø	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations B Ø	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations C Ø	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations Ground	0	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Follow-up Action Required?	n	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:14	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations A Ø	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations B Ø	0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Unknown Operations	0	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Operations Counter	99	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	General Comments	1 trip check	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps C Ø	26.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Regulator As Left Counter	75437	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps A Ø	55	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps B Ø	20	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	General Comments	Fiberglass is exposed on two xfmr fuses. Metering equip needs additional wildlife protection and so does bus.	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps C Ø	60	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Switching Operations	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Regulator As Left Counter	76300	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Foundation Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Vegetation	None	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	General Comments	yard light broke. needs replaced	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Trash?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	General Comments		
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	11.9	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	General Comments		
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations	4	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Regulator As Left Counter	131672	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Regulator As Left Counter	212327	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	General Comments		
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:55	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps A Ø	77.0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps B Ø	87.0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps C Ø	95.0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps C Phase V	4.56	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations A Ø	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations B Ø	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations C Ø	1	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations Ground	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations This Read Vac	1	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AL	289	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AF	289	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Maintenance Operations	1	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Follow-up Action Required?	n	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	General Comments		
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Maintenance Operations	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AF	291	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	General Comments	ok	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations Ground	0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations C Ø	0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations B Ø	0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations A Ø	0	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 9:38	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AL	291	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations This Read Vac	1	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Switching Operations	0	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Operations Counter	296	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 14:39	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Follow-up Action Required?	n	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	General Comments		
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Max	70	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Present	40	°C
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
4/1/2022 12:16	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	9 Month Operations	2	
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 7:46	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Maintenance Operations	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	General Comments		
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Regulator As Left Counter	96069	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Min Tap Position	3R	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	General Comments		
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations Ground	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations C Ø	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations B Ø	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations A Ø	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	General Comments		
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	General Comments	Gate side fence is not grounded. Every other side is just grounded in one spot.	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	General Comments	ok	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
4/1/2022 11:52	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps C Ø	50	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps B Ø	30	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps A Ø	35	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty C Ph V	0	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	9 Month Operations	4	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Unknown Operations	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Switching Operations	2	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations This Read Vac	2	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AL	216	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AF	214	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Regulator As Left Counter	24347	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AL	133	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AF	133	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Maintenance Operations	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33185	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	9 Month Operations	1	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 12:19	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps A Ø	68.0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps B Ø	81.0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps C Ø	70.0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	General Comments		
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations Ground	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations C Ø	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations B Ø	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations A Ø	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Unknown Operations	0	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Regulator As Left Counter	47960	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 11:51	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushing Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps C Ø	160	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps B Ø	140	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps A Ø	145	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty C Ph V	.32	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty B Ph V	0	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty A Ph V	0	%
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations	4	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Maintenance Operations	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AF	247	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AL	249	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations This Read Vac	2	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Switching Operations	2	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Unknown Operations	0	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	General Comments		
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:53	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Unknown Operations	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Switching Operations	0	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
4/1/2022 13:26	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations This Read Vac	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	General Comments		
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations Ground	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations C Ø	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations B Ø	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations A Ø	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Current Tap Position	7R	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	General Comments	ok	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Regulator As Left Counter	120541	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Regulator As Left Counter	40928	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AL	224	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AF	222	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Maintenance Operations	0	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Time Delay	30	Seconds
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Operation Checked?	y	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	Follow-up Action Required?	n	
4/1/2022 10:07	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	All Connections OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Foundation Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations C Ø	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations Ground	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Min Tap Position	2R	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Max Tap Position	10R	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Switching Operations	2	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations This Read Vac	2	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps A Phase V	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps B Phase V	0	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps C Phase V	0	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	General Comments		
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
4/1/2022 10:43	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7715	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 10:04	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Leaks	None	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
4/1/2022 13:44	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
4/1/2022 9:48	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
4/1/2022 13:17	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations Ground	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations B Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations C Ø	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations C Ø	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations Ground	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty A Ph V	1.05	%
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty B Ph V	1.05	%
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations A Ø	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps A Ø	330	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations A Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations B Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Maintenance Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AF	224	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AL	224	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations This Read Vac	2	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations C Ø	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations Ground	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Operations Since Last Insp	911	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Left Counter	4320	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Found Counter	4320	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Switching Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations This Read Vac	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Unknown Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AL	172	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	LTC Totalizer Reading	8956.8	kw
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Unknown Operations	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Switching Operations	2	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Max	44	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Present	32	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations This Read Vac	2	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AL	110	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps C Ø	60.0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps B Ø	55.0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps A Ø	66.0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations	4	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AF	108	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Maintenance Operations	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Reading	.4976	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Max	44	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Present	34	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty A Ph V	4.41	%
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty A Ph V	.38	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations	4	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Unknown Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations B Ø	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations C Ø	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations Ground	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Maintenance Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AF	214	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AL	214	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	9 Months Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps A Ø	25.0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps B Ø	50.0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps C Ø	25.0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Current Tap Position	4R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Max Tap Position	6R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Switching Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations This Read Vac	0	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Leaks	None	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations A Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations B Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Unknown Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Switching Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations This Read AM	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AL	472	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AF	472	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations C Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations Ground	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Maintenance Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps B Ø	311	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps C Ø	306	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations A Ø	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AF	172	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Maintenance Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations Ground	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations C Ø	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations B Ø	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations A Ø	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Switching Operations	2	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Unknown Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps C Ø	320	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps B Ø	320	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps A Ø	320	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps C Ø	48	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps B Ø	50	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps A Ø	51	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty C Ph V	.38	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty C Ph V	4.41	%
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty B Ph V	14.35	%
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	LTC Totalizer Reading	3398.40	kw
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Reading	.3540	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Vegetation	None	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Found Counter	15121	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Left Counter	15121	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Current Tap Position	6L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Max Tap Position	3L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Operations Since Last Insp	160	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Unknown Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations This Read Vac	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Switching Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Operations Since Last Insp	1123	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3	psi
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Max Tap Position	3R	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Left Counter	70307	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Found Counter	70304	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations	1	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty A Ph V	.76	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty B Ph V	.76	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty C Ph V	.76	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps A Ø	425	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps B Ø	433	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps C Ø	428	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AF	360	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AL	360	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations This Read AM	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Switching Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Unknown Operations	0	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Vegetation	None	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations A Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations B Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations C Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations Ground	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Maintenance Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AF	246	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AL	246	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps A Ø	100.0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps B Ø	90.0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps C Ø	90.0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations A Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations B Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations C Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations Ground	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Maintenance Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AF	386	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AL	386	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations This Read AM	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Switching Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Unknown Operations	0	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Found Counter	32538	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Left Counter	32538	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Current Tap Position	5L	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Min Tap Position	9L	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Operations Since Last Insp	10	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Min Tap Position	13L	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Left Counter	166149	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Found Counter	166146	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Maintenance Operations	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AF	196	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AL	198	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations This Read Vac	2	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Switching Operations	2	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Unknown Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.7	AMPS
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	9 Months Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCCControl	423-1	LTC Control Insp	LTC Operation Checked?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCCControl	423-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCCControl	423-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCCControl	423-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCCControl	423-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Reading	.5922	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Max	40	°C
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Present	35	°C
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCCControl	593-1	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Operation Checked?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AF	123.8	VAC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AL	123.8	VAC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	General Comments	Gauge disconnected	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Max	0	°C
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Present	0	°C
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	General Comments	Pump leaking	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	LTC Totalizer Reading	10659.60	kw
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Max	30	°C
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Present	30	°C
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Leaks	None	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Months Operations	3	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps A Ø	100.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps B Ø	100.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps C Ø	100.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Regulator As Left Counter	31225	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations A Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations B Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations C Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations Ground	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Min Tap Position	1R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Max Tap Position	6R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Current Tap Position	4R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Maintenance Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCCControl	423-1	LTC Control Insp	All Connections OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCCControl	423-1	LTC Control Insp	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCCControl	423-1	LTC Control Insp	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Max Tap Position	12R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Min Tap Position	5R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Regulator As Left Counter	121623	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Leaks	None	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2023-06-23 00:00:00.000000000	Need size info and qty
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Current Tap Position	7R	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PF001332	PowerFuse	PI-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PF001332	PowerFuse	PI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations	4	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps A Ø	114.0	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps B Ø	120.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Months Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps A Ø	20.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps B Ø	20.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps C Ø	20.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations A Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations B Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations Ground	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	General Comments		
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations	4	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3	VAC
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Min Tap Position	5R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Max Tap Position	12R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Current Tap Position	7R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	All Connections OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	All Connections OK?	y	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	General Comments		
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	LTC Operation Checked?	y	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Fault Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AL	121623	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AF	121621	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AL	125	VAC
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AF	125	VAC
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3	VAC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Maintenance Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Num Operations Last 9 Months	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AF	51	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AL	51	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations This Read SF6	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Bushing Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Pressure	88	psi
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Switching Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Vegetation	None	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Vegetation	None	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	LTCC000941	LTCControl	819-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	General Comments	fence under construction	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Max	40	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Present	30	°C
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LBO393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps A Ø	80.0	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PF001319	PowerFuse	GO-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PF001319	PowerFuse	GO-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PF001319	PowerFuse	GO-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/31/2022 13:06	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps A Ø	11.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps B Ø	14.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps C Ø	16.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations Ground	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations C Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations B Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations A Ø	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps C Ø	50.0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps B Ø	25.0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	73	*F
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	LTC Totalizer Reading	8395.2	kw
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AF	42	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AL	42	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Switching Operations	1	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations This Read Vac	1	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AL	1067	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AF	1067	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Maintenance Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations This Read Vac	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Switching Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Unknown Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations Ground	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations C Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations B Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations A Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps C Ø	101.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps B Ø	109.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps A Ø	121.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations	8	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations A Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations B Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations C Ø	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Reading	.4664	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Max	42	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Present	38	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations Ground	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	9 Months Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Unknown Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Maintenance Operations	0	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AL	124.1	VAC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AF	124.1	VAC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Output Voltage Level	124	VAC
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Operation Checked?	y	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	All Connections OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AL	284	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AF	284	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Unknown Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Switching Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations This Read Vac	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AL	456	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AF	456	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Maintenance Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations Ground	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations C Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations B Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations A Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Maintenance Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AF	99966	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AL	99966	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations This Read AM	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Switching Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Unknown Operations	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps C Ø	111.0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations A Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	91	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Left Counter	411510	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Found Counter	411510	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations B Ø	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations C Ø	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations Ground	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps A Ø	209.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps B Ø	254.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps C Ø	221.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations A Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations B Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations C Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations Ground	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Maintenance Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AF	231	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AL	231	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations This Read Vac	1	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Switching Operations	1	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Unknown Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Unknown Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Switching Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations This Read AM	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AL	446	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AF	446	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Maintenance Operations	0	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps C Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps B Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps A Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations	2	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Maintenance Operations	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AF	169	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AL	171	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations This Read Vac	2	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Switching Operations	2	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Unknown Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations	4	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Found Counter	8865	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Left Counter	8865	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	160	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Present	29	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Max	20	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Reading	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Present	20	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	LTC Totalizer Reading	0	kw
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	60	°F
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Max	22	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Maintenance Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AF	73	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AL	73	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations This Read Vac	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Switching Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Unknown Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Vegetation	None	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Leaks	None	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Regulator As Left Counter	14435	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps A Ø	470	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps B Ø	480	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps C Ø	477	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations A Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations B Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations C Ø	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations Ground	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Reading	.3960	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
3/31/2022 7:33	Distribution	Paris 12KV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	63.33	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Operations Since Last Insp	1201	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	44	°C
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Min Tap Position	13L	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Current Tap Position	5L	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Left Counter	75148	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Found Counter	75145	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	General Comments		
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	3801.60	kw
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations B Ø	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations A Ø	0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps C Ø	49.0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps B Ø	57.0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps A Ø	43.0	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations	5	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3	psi
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	LTC Totalizer Reading	10435.2	kw
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Vegetation	None	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Found Counter	341996	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Left Counter	341996	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	52	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/31/2022 10:14	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AL	0	VAC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AF	0	VAC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Output Voltage Level	0	VAC
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Operation Checked?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	General Comments		
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Follow-up Action Required?	n	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	All Connections OK?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Present	36	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Max	42	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Reading	1.087	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Present	32	°C
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Maintenance Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AF	168	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AL	168	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations This Read Vac	1	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG00053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Current Tap Position	10L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Unknown Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Switching Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Max Tap Position	5L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Min Tap Position	15L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Regulator As Left Counter	14576	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.5	VDC
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Leaks	None	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.5	VDC
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Switching Operations	1	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Unknown Operations	0	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AL	124	VAC
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations This Read Vac	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AL	99856	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AF	99856	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Maintenance Operations	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations A Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations B Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Unknown Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Switching Operations	2	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations This Read Vac	2	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations Counter AL	188	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Operations Counter AF	188	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Maintenance Operations	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations Ground	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations C Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations B Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Operations A Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps C Ø	366.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps B Ø	387.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps A Ø	393.0	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Ambient Temperature	47	*F
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 10:42	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps C Ø	60.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps B Ø	56.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Amps A Ø	69.0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	BK001827	BreakerVacuum	743-0883	VCB Readings	9 Month Operations	31	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations C Ø	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations Ground	0	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Min Tap Position	Neutral	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Max Tap Position	6R	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	General Comments		
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Current Tap Position	4L	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	All Connections OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/31/2022 12:50	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Operation Checked?	y	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	General Comments		
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Follow-up Action Required?	n	
3/31/2022 7:15	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	All Connections OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Max Tap Position	2L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Min Tap Position	14L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Regulator As Left Counter	16334	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Leaks	None	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Current Tap Position	9L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	General Comments		
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Min Tap Position	14L	
3/31/2022 7:33	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations	2	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AF	124.1	VAC
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3	VAC
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps A Ø	93.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps B Ø	87.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps C Ø	93.0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Follow-up Action Required?	n	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Foundation Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	General Comments		
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3	VAC
3/31/2022 9:34	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Unable to Reset	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations A Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations B Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations C Ø	0	
3/31/2022 12:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations Ground	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps B Ø	4	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps A Ø	9	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps C Ø	13	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushing Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations A Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Found Counter	88038	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Left Counter	88041	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Current Tap Position	7L	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Max Tap Position	3L	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Min Tap Position	11L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps A Ø	166	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps B Ø	158	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps C Ø	172	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushing Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations Ground	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations	1	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations C Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations B Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations A Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations C Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Foundation Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Grounds in Place?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Maintenance Operations	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AF	175	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AL	175	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations This Read Vac	3	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Switching Operations	3	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations Ground	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Unknown Operations	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Foundation Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushing Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps C Ø	69	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps B Ø	68	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps A Ø	61	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations	5	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Grounds in Place?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Maintenance Operations	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Vegetation	None	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations	6	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps C Ø	20	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps B Ø	25	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps A Ø	25	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Vegetation	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Operations Since Last Insp	403	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations A Ø	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations C Ø	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations Ground	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AF	170	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AL	170	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations This Read Vac	3	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Switching Operations	3	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Unknown Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Maintenance Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AF	24	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AL	24	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations This Read Vac	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Switching Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Operations Since Last Insp	314	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Max Tap Position	1R	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Left Counter	86304	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Found Counter	86300	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Unknown Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Ambient Temp	76	F
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Operations Counter	236	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Regulator As Left Counter	39193	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Unknown Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Switching Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations This Read Vac	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AL	32	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AF	32	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Maintenance Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations Ground	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations C Ø	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations B Ø	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations A Ø	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Reading	.9222	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Leaks	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushing Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6639.84	kw
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps C Ø	138	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps B Ø	158	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps A Ø	128	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps A Ø	130	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps B Ø	132	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps C Ø	148	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Operations Counter	12	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	All Connections OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Operation Checked?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AF	124.2	VAC
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AL	124.4	VAC
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Current Tap Position	8L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Min Tap Position	11L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations	7	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations	8	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty A Ph V	5.48	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty B Ph V	2.74	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty C Ph V	5.94	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps A Ø	60	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps B Ø	120	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps C Ø	100	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushing Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations A Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations B Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations C Ø	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations Ground	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Foundation Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Grounds in Place?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Maintenance Operations	0	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AF	229	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AL	229	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations This Read Vac	4	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Switching Operations	4	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Unknown Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps A Ø	22	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushing Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps C Ø	33	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps B Ø	38	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps A Ø	37	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Current Tap Position	7L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Leaks	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	LTC Operation Checked?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	LTCC000931	LTCControl	605-1	LTC Control Insp	All Connections OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Reading	.822	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BCH001474	Charger	774-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Negative DC Ground	23.1	VDC
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	BAT001544	Battery	774-Battery Bank	Battery Patrol Inspection	Positive DC Ground	30.1	VDC
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	LTC Totalizer Reading	2630.4	kw
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Max	70	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	LTC Totalizer Reading	9216	kw
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Present	38	°C
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Regulator As Left Counter	88606	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Leaks	None	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Reading	.512	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Max	40	°C
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Present	35	°C
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Regulator As Left Counter	81571	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Max Tap Position	3L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	General Comments		
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	General Comments		
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.58	%
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/30/2022 10:28	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
3/30/2022 13:44	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.5	VDC
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	.5	AMPS
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations	1	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps A Ø	480	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps B Ø	480	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps C Ø	540	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Found Counter	122092	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Left Counter	122096	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations C Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Vegetation	None	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	95	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27	VDC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations This Read Vac	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Switching Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Unknown Operations	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AF	320	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AL	320	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations This Read Vac	1	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Switching Operations	1	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Unknown Operations	0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BAT001562	Battery	767-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Max Tap Position	3R	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Min Tap Position	8L	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Operations Since Last Insp	617	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations C Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps A Ø	320	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty C Ph V	.79	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations	1	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Vegetation	None	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AF	213	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AL	213	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AF	2	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AL	2	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations This Read Vac	3	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Switching Operations	3	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Unknown Operations	0	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	General Comments		
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Found Counter	169955	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Left Counter	169955	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	61	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Unknown Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations This Read Vac	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AL	283	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AF	283	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	General Comments		
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations	10	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty A Ph V	10.95	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty B Ph V	7.67	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty C Ph V	9.86	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps A Ø	127	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps B Ø	144	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps C Ø	167	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations C Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AF	25	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AL	25	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations This Read Vac	3	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Switching Operations	3	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Unknown Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations	10	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty A Ph V	24.58	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty B Ph V	18.68	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty C Ph V	21.63	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps A Ø	55	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps B Ø	48	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps C Ø	58	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations C Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps A Phase V	18.39	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps B Phase V	18.39	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps C Phase V	18.39	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations C Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Maintenance Operations	3	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AF	203	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AL	203	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations This Read Vac	6	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AF	150	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AL	150	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations This Read Vac	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Switching Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Unknown Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps A Ø	320	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Switching Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Unknown Operations	3	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty C Ph V	1.02	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty A Ph V	.51	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations	2	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations	5	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty A Ph V	1.02	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty B Ph V	1.02	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty C Ph V	1.53	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps A Ø	98	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps B Ø	99	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps C Ø	90	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations C Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps C Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps C Ø	313	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps B Ø	315	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	9 Month Operations	2	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps A Ø	220	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps B Ø	225	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps C Ø	207	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations C Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations	7	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps A Ø	97	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps B Ø	99	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps C Ø	91	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Operations Since Last Insp	455	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Max Tap Position	1L	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Current Tap Position	3L	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Left Counter	13852	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Found Counter	13848	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	LTC Totalizer Reading	8467.2	kw
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Max	42	°C
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Unknown Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Present	20	°C
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Reading	.4704	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Max	45	°C
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Present	30	°C
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Present	38	°C
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Max	40	°C
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Reading	.8004	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations C Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations B Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations A Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps C Phase V	8.15	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps B Phase V	8.15	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps A Phase V	8.15	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps C Ø	85	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps B Ø	88	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps A Ø	90	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty C Ph V	4.86	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty B Ph V	7.9	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty A Ph V	6.68	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations	3	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Unknown Operations	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Switching Operations	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations This Read Vac	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AL	180	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AF	180	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Maintenance Operations	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations Ground	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations C Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations B Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations A Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTC000009	LTCControl	767-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations Ground	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations C Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations B Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations A Ø	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps C Ø	280	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps B Ø	270	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps A Ø	275	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty C Ph V	.07	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty B Ph V	.07	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps C Ø	155	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps B Ø	155	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps A Ø	150	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations	1	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Switching Operations	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations This Read Vac	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AL	183	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AF	183	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	All Connections OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Operation Checked?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AF	124.2	VAC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AL	124.5	VAC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Vegetation	None	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	All Connections OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Operation Checked?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AF	124.6	VAC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AL	124.6	VAC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.3	amps
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps C Ø	492	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps B Ø	497	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps A Ø	490	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	LTC Totalizer Reading	14407.2	kw
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Max	30	*C
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Present	30	*C
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Present	27	°C
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Reading	.9438	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Max	28	°C
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Present	28	°C
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Operations Since Last Insp	2571	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	22	°C
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	VRR Base Voltage AL	124.2	VAC
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	VRR Base Voltage AF	124.2	VAC
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations A Ø	0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations B Ø	0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations C Ø	0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations Ground	0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	General Comments		
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Maintenance Operations	0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AF	236	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AL	236	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations This Read Vac	2	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Switching Operations	2	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Unknown Operations	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	LTC Operation Checked?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCCControl	455-1	LTC Control Insp	All Connections OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Max	27	°C
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AF	915	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Ambient Temperature	40	°F
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AL	65	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AF	65	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Maintenance Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Grounds in Place?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	General Comments		
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Foundation Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps C Ø	1	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps B Ø	1	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps A Ø	3	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations	1	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	General Comments		
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Found Counter	215727	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps C Ø	320	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps B Ø	320	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Left Counter	215727	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Vegetation	None	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	General Comments		
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3	psi
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Max Tap Position	7R	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Current Tap Position	3R	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Left Counter	37616	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Found Counter	37610	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/29/2022 9:27	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations Ground	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations C Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations B Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations A Ø	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Unknown Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Switching Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations This Read Vac	0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushing Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps C Ø	49.0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps B Ø	42.0	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps A Ø	41.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	9 Month Operations	4	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AL	915	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations This Read Vac	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Switching Operations	0	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Tank Paint Condition	Good	
3/29/2022 14:49	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Unknown Operations	0	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2	amps
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Positive DC Ground	64.6	VDC
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Negative DC Ground	67.6	VDC
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations	1	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty A Ph V	.15	%
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/29/2022 9:18	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	General Comments		
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	LTC Totalizer Reading	13590.72	kw
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/29/2022 11:18	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	163	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Max	65	°C
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Present	50	°C
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	General Comments		
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	General Comments		
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations	8	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps A Ø	220.0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps B Ø	220.0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps C Ø	240.0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushing Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Ambient Temperature	40	°F
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Max Tap Position	3R	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Operations Since Last Insp	597	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	if no, which cells in comments
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	265.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Present	55	°C
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Max	65	°C
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Reading	.9140	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	if no, which cells in comments
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	if no, which cells in comments
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	if no, which cells in comments
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	if low,note cell #'s
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	if no, which cells in comments
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Left Counter	234579	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Found Counter	234579	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	LTC Totalizer Reading	13161.60	kw
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Fault Operations	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Operations Since Last Insp	836	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Min Tap Position	14L	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Max Tap Position	3R	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC Current Tap Position	2L	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC As Left Counter	57088	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	LTC As Found Counter	57088	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Vegetation	None	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Ambient Temp	45	F
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Max Tap Position	12R	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	All Connections OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Operation Checked?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	General Comments		
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29624	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	All Connections OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Operation Checked?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps A Ø	195.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps B Ø	240.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps C Ø	215.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Bushing Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations A Ø	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations B Ø	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations C Ø	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations Ground	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Maintenance Operations	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations Counter AF	174	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations Counter AL	176	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations This Read Vac	2	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Switching Operations	2	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Unknown Operations	0	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Vegetation	None	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	General Comments		
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	LTC000842	LTCControl	433-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations	8	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Regulator As Left Counter	88769	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps A Ø	350.0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps B Ø	350.0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps C Ø	350.0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushing Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations A Ø	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations B Ø	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations C Ø	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations Ground	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Maintenance Operations	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AF	297	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AL	301	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations This Read Vac	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	General Comments		
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	General Comments		
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	LTC Totalizer Reading	5330.88	kw
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Present	45	°C
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Reading	.7404	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps C Ø	61.0	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	9 Month Operations	4	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps A Ø	65.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps B Ø	75.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps C Ø	40.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushing Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations A Ø	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations B Ø	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations A Ø	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations B Ø	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations C Ø	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Fault Operations Ground	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Foundation Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Grounds in Place?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Maintenance Operations	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations Counter AF	174	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations Counter AL	174	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Operations This Read Vac	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Switching Operations	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001618	BreakerVacuum	663-2	VCB Readings	Unknown Operations	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	9 Month Operations	7	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps A Ø	0.0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps B Ø	0.0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Operation Checked?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	All Connections OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Operation Checked?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	General Comments		
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	Follow-up Action Required?	n	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	All Connections OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Readings	Amps C Ø	0.0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001619	BreakerVacuum	663-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerInspection	728-0645	VCB Readings	Operations Counter AL	184	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Operations This Read Vac	2	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Switching Operations	2	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BK001794	BreakerVacuum	728-0645	VCB Readings	Unknown Operations	0	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Operations Counter	15	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Found Counter	135762	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Left Counter	135762	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Current Tap Position	2R	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Max Tap Position	12R	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Min Tap Position	8L	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Operations Since Last Insp	616	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Unknown Operations	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Switching Operations	4	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations This Read Vac	4	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AL	295	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AF	291	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Maintenance Operations	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations Ground	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations C Ø	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations B Ø	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations A Ø	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1283.04	kw
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	100.00	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7128	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Unknown Operations	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Switching Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Oil Temp Max	55	°C
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Oil Temp Present	40	°C
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations This Read Vac	2	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Switching Operations	2	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Unknown Operations	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BAT001514	Battery	663-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Found Counter	82800	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Left Counter	826800	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Current Tap Position	3R	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Max Tap Position	8R	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Operations Since Last Insp	933	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Operations Counter	95	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	General Comments		
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Found Counter	6562	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Left Counter	6562	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Current Tap Position	4R	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Max Tap Position	7R	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Min Tap Position	10L	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	14	°C
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Operations Since Last Insp	1065	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	All Connections OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Operation Checked?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Unknown Operations	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Switching Operations	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations This Read Vac	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AL	159	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AF	159	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Maintenance Operations	0	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Totalizer Meter Reading	.8862	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Winding Temp Max	60	°C
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	Winding Temp Present	40	°C
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	LTC Totalizer Reading	14280.00	kw
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Present	25	°C
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Reading	.5950	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Max	52	°C
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Present	27	°C
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Regulator As Left Counter	39386	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations B Ø	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations C Ø	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations Ground	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Grounds in Place?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Maintenance Operations	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AF	146	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AL	146	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations This Read Vac	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Switching Operations	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Num Operations Last 9 Months	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations Counter AF	183	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations Counter AL	163	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Operations This Read SF6	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Switching Operations	0	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Readings	Unknown Operations	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Unknown Operations	0	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	General Comments		
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations	0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps A Ø	440.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps B Ø	510.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps C Ø	450.0	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushing Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Vegetation	None	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	General Comments		
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	SF6 Pressure	67	psi
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Tank Paint Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Vegetation	None	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	General Comments		
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/25/2022 10:36	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Ambient Temperature	40	F
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	General Comments	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001506	BreakerSF6	663-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/25/2022 14:03	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	General Comments		
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Vegetation	None	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/25/2022 14:32	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Ambient Temp	40	F
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/25/2022 11:34	Distribution	Corporate Drive Quarterly Inspection	BK001505	BreakerSF6	663-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/25/2022 14:11	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	All Connections OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Operations Since Last Insp	931	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Max Tap Position	3R	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Current Tap Position	6L	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Left Counter	98971	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Found Counter	931	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Reading	1.1810	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	LTC Totalizer Reading	11337.60	kw
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Max	35	°C
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Present	30	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps A Ø	103.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps B Ø	97.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Amps C Ø	110.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Top Oil Temperature Max	120	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WithLTC Trn Dynamic Health	210.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Max	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Present	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Max	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Present	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Max	35	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Present	35	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps C Ø	221.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps B Ø	224.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps A Ø	220.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	30	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	25	°C
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Min Tap Position	16L	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Operations Since Last Insp	1067	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	9 Month Operations	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Follow-up Action Required?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	General Comments	Oil temp guage can not reset	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Max	120	°C
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations Counter AF	182	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations Counter AL	184	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Operations This Read Vac	2	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Switching Operations	2	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Unknown Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	General Comments	WOOD 4 PLANK FARM FENCE	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Unknown Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Switching Operations	1	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations This Read Vac	1	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AL	237	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AF	237	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Switching Operations	2	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations This Read Vac	2	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations Counter AL	169	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Readings	Operations Counter AF	167	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001774	BreakerVacuum	690-0854	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Maintenance Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	General Comments	BFTC	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Unknown Operations	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Switching Operations	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations This Read Vac	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AL	68	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AF	68	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Maintenance Operations	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty C Ph V	5.81	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty B Ph V	4.91	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Current Tap Position	7L	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Left Counter	13484	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty A Ph V	4.47	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Found Counter	13484	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Found Counter	22992	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Left Counter	22992	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Current Tap Position	9L	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Max Tap Position	5L	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Operations Since Last Insp	225	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	9 Month Operations	3	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps A Ø	6.0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps B Ø	5.0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Amps C Ø	5.0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BK001802	BreakerVacuum	885-0857	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps C Ø	110.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps B Ø	109.0	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AF	515	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AL	515	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations This Read Vac	0	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	All Connections OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps A Ø	112.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	487	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	487	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Unknown Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Unknown Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Switching Operations	2	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations This Read Vac	2	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AL	273	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AF	271	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Maintenance Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations Ground	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations C Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations B Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations A Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	LTC Totalizer Reading	15966.72	kw
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Max	60	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Present	30	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Found Counter	133928	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Left Counter	133939	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Current Tap Position	4R	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Max Tap Position	12R	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Min Tap Position	6L	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Operations Since Last Insp	1242	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	179	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Min Tap Position	13L	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Current Tap Position	10L	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Left Counter	189619	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Found Counter	189619	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Operations Since Last Insp	401	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Min Tap Position	9L	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Max Tap Position	2L	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Current Tap Position	6L	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Left Counter	203350	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Found Counter	203341	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Reading	1.6632	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Max	55	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Present	30	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	55	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	50	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	55	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	55	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Found Counter	6693	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Left Counter	6693	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Current Tap Position	1L	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Max Tap Position	2R	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Min Tap Position	6L	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Operations Since Last Insp	194	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations C Ø	2	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations B Ø	2	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations A Ø	2	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps C Phase V	11.99	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps B Phase V	11.99	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps A Phase V	11.99	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Switching Operations	2	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations This Read Vac	2	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations Counter AL	176	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Operations Counter AF	174	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Readings	Maintenance Operations	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001775	BreakerVacuum	690-0855	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps C Ø	25.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 1	LTC Control Insp	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps B Ø	23.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps A Ø	22.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations	7	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Unknown Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Switching Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations This Read Vac	6	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AL	428	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AF	428	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Maintenance Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps C Ø	98.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps B Ø	99.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps A Ø	102.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	9 Month Operations	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations	1	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty A Ph V	.43	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty B Ph V	.43	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty C Ph V	.43	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps A Ø	72.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps B Ø	89.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps C Ø	90.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AL	39	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AF	39	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Maintenance Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AF	186	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AL	186	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations This Read Vac	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Found Counter	307661	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Left Counter	307671	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Current Tap Position	6R	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Max Tap Position	11R	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Min Tap Position	6L	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Operations Since Last Insp	1230	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps A Ø	108.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	9 Month Operations	2	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	LTCC000939	LTCControl	766-2	LTC Control Insp	All Connections OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations	2	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty A Ph V	3.2	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty B Ph V	2.28	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps A Ø	74	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps B Ø	80	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps C Ø	65	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Unknown Operations	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AL	222	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AF	220	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Maintenance Operations	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps C Ø	155.0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps B Ø	155.0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps A Ø	145.0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations	5	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps A Ø	223.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps B Ø	180.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps C Ø	234.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps C Ø	20.0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps B Ø	20.0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps A Ø	20.0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations	6	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Unknown Operations	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Switching Operations	2	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations This Read Vac	2	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations A Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations B Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations C Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations Ground	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Maintenance Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AF	340	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AL	340	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations This Read Vac	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Switching Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	LTC Totalizer Reading	13230	kw
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Switching Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations This Read Vac	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AL	44	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AF	44	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000946	LTCControl	093-6	LTC Control Insp	All Connections OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	9 Month Operations	28	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps A Ø	324.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps B Ø	312.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Readings	Amps C Ø	298.0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Operations Since Last Insp	322	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Max Tap Position	3L	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Current Tap Position	8L	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Left Counter	1634	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Found Counter	1628	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001964	BreakerVacuum	FV-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Present	42	°C
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Max	50	°C
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Reading	.735	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps A Ø	110.0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps B Ø	80.0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps C Ø	100.0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Maintenance Operations	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AF	202	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AL	205	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations This Read Vac	3	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Switching Operations	3	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Found Counter	266358	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Left Counter	266358	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Vegetation	None	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations	7	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	367	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps C Ø	122.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps B Ø	145.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps A Ø	88.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	9 Month Operations	0	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Current Tap Position	3L	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Max Tap Position	1R	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Operations Since Last Insp	531	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Vegetation	None	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps A Ø	121.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	9 Month Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations This Read Vac	0	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Found Counter	37473	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Left Counter	37479	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCCControl	811-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCCControl	811-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCCControl	811-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCCControl	811-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCCControl	811-1	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCCControl	811-1	LTC Control Insp	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCCControl	811-1	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000926	LTCCControl	811-1	LTC Control Insp	All Connections OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations Counter AL	38	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations Counter AF	38	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations	1	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps A Ø	400.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps B Ø	392.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps C Ø	436.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations A Ø	0	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Operations Counter	830	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Vegetation	None	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Max	30	°C
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Reading	.6340	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Ambient Temp	45	°F
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Unknown Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Switching Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations This Read Vac	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AL	258	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AF	258	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations B Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations C Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations Ground	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Maintenance Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AF	154	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AL	154	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations This Read Vac	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Switching Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Unknown Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	LTC Totalizer Reading	6086.40	kw
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps B Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps A Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	9 Month Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations Counter AL	345	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations Counter AF	345	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Vegetation	None	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations Counter AL	325	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations Counter AF	325	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations B Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Max	55	°C
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Present	22	°C
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Reading	.3672	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps A Ø	20	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps B Ø	20	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps C Ø	20	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Operations Counter	1784	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps A Ø	18	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps B Ø	15	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps C Ø	15	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps B Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps A Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	9 Month Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	LTC Totalizer Reading	3525.12	kw
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1860.48	kw
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	187.50	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	180.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Max	50	*C
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Present	30	*C
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5814	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Maintenance Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AF	204	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AL	204	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations This Read Vac	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Switching Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Unknown Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Present	30	°C
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Max	60	°C
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Reading	1.2570	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	LTC Totalizer Reading	22626.00	kw
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Reading	.6714	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Max	25	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Present	20	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps A Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps B Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations Counter AF	333	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations Counter AL	333	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Unknown Operations	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Vegetation	None	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	9 Month Operations	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	LTC Totalizer Reading	9668.16	kw
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Max	66	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Present	31	°C
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	General Comments	WOOD FARM FENCE	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Maintenance Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations Ground	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations C Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations B Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations A Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps C Ø	452.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps B Ø	407.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps A Ø	443.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations	5	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	All Connections OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	45	°F
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Operations Since Last Insp	1017	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Min Tap Position	16L	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Max Tap Position	2L	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Current Tap Position	9L	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Left Counter	36340	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Found Counter	36340	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	9 Month Operations	2	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps A Ø	100.0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps B Ø	100.0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps C Ø	105.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations A Ø	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations B Ø	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations C Ø	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations Ground	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	All Connections OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Operations Since Last Insp	431	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Min Tap Position	13L	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Max Tap Position	4L	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Current Tap Position	8L	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Left Counter	16171	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Found Counter	76171	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	All Connections OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Evidence of Insects	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps B Ø	106.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps A Ø	159.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	9 Month Operations	2	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Low	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	General Comments	oil level is low	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations This Read Vac	2	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations Counter AL	171	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Operations Counter AF	169	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Maintenance Operations	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panels Dusted?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	70.0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	55.0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	3	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Amps C Ø	125.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	9 Month Operations	4	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps A Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps B Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AF	142	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AL	142	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations This Read Vac	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	LTC Totalizer Reading	4913.28	kw
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Max	60	°C
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Present	40	°C
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Reading	.5118	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps A Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps B Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AF	174	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AL	174	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Unknown Operations	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001773	BreakerVacuum	690-0853	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001768	BreakerVacuum	690-0852	VCB Readings	Switching Operations	2	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps C Ø	76.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps B Ø	57.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Amps A Ø	117.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BK001771	BreakerVacuum	690-0851	VCB Readings	9 Month Operations	2	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps A Ø	106.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps B Ø	93.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps C Ø	89.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AF	162	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AL	162	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	*F
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27	VDC
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps A Ø	46.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	9 Month Operations	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AF	300	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AL	300	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Regulator As Left Counter	16938	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	9 Month Operations	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps A Ø	312.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps B Ø	311.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps C Ø	306.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps C Ø	46.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Amps B Ø	45.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	50	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitrogen 6 Pack needs nitrogen	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12833	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AF	80	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AL	80	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations This Read Vac	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Switching Operations	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Unknown Operations	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Reading	.3140	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	9 Month Operations	2	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps A Ø	93.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps B Ø	80.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps C Ø	95.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Switching Operations	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	9 Month Operations	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps A Ø	111.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps B Ø	123.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps C Ø	109.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Grounds in Place?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	LTC Totalizer Reading	3014.40	kw
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AF	74	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AL	74	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations This Read Vac	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Switching Operations	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations Counter AL	351	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001524	BreakerVacuum	FV-14KV TR 1	VCB Readings	Operations Counter AF	351	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AF	164	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AL	164	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Unknown Operations	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	9 Month Operations	21	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps A Ø	105.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps B Ø	119.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps C Ø	104.0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	LTC Totalizer Reading	11145.60	kw
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Max	35	*C
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Present	35	*C
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Vegetation	None	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps A Ø	160	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps B Ø	184	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	9 Month Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps A Ø	116.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps B Ø	124.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps C Ø	114.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	All Connections OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	General Comments	2-4FT bulbs need changed to led	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panels Dusted?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AL	197	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations This Read Vac	1	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Switching Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	9 Month Operations	20	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations	2	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty A Ph V	7.77	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AF	85	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AL	85	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Maintenance Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AF	192	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AL	192	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Switching Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Unknown Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Unknown Operations	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Switching Operations	4	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations This Read Vac	4	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AL	274	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AF	270	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Maintenance Operations	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCCControl	690-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCCControl	690-2	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCCControl	690-2	LTC Control Insp	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCCControl	690-2	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCCControl	690-2	LTC Control Insp	All Connections OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	General Comments	IOC B Phase	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps C Ø	148	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCCControl	569-1	LTC Control Insp	All Connections OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Reading	1.1610	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Max	50	°C
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Present	35	°C
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Vegetation	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations This Read Vac	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations Counter AL	26	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Maintenance Operations	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AF	279	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AL	283	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations This Read Vac	4	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Switching Operations	4	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps C Ø	83	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps B Ø	94	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps A Ø	102	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps C Ø	384.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps B Ø	427.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps A Ø	406.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	9 Month Operations	1	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations A Ø	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations B Ø	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations C Ø	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations Ground	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations Ground	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations This Read Vac	1	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AL	424	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AF	424	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Maintenance Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	General Comments	BFTC	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations Ground	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations C Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations B Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations A Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Maintenance Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AF	197	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps C Ø	244.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps B Ø	206.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps A Ø	257.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty C Ph V	6.4	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty B Ph V	7.68	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty A Ph V	6.4	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations	5	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Evidence of Insects	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Follow-up Action Required?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Operations Counter AF	26	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Fault Operations C Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations	2	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty A Ph V	.85	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty B Ph V	1.28	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps A Ø	103.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps B Ø	98.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps C Ø	102.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps A Phase V	5.72	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations A Ø	1	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Unknown Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Switching Operations	1	
3/24/2022 11:39	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations B Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations C Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations	2	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Unknown Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations A Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations B Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations C Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations Ground	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Unknown Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Switching Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations This Read Vac	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Maintenance Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AF	195	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AL	99984	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AF	99984	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Maintenance Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations Ground	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations C Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations B Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations A Ø	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	LTCC00841	LTCControl	885-1	LTC Control Insp	All Connections OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps C Ø	325.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps B Ø	315.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps A Ø	315.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AL	149	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations This Read Vac	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Switching Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Unknown Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations	3	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty A Ph V	.99	%
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty C Ph V	.99	%
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps A Ø	19	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps B Ø	25	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps C Ø	25	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations A Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	9 Month Operations	22	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps A Ø	78.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps B Ø	69.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Amps C Ø	73.0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps C Ø	45	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps B Ø	45	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps A Ø	55	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty C Ph V	.33	%
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty B Ph V	.33	%
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty A Ph V	.66	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	70	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	70	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	70	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Nitrogen Bottle needs nitrogen	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps C Ø	0.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps B Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AF	186	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AL	186	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Unknown Operations	0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps A Ø	0.0	
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 11:39	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations	1	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Switching Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations This Read Vac	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AL	195	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	51	°F
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27	VDC
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps A Ø	77.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps B Ø	72.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Amps C Ø	66.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2	amps
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	126	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	126	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations	2	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Unknown Operations	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations B Ø	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations A Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Unknown Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	LTC Totalizer Reading	2522.88	kw
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps C Ø	200.0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps B Ø	120.0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps A Ø	60.0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations	8	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	480	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations A Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations B Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations C Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations Ground	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Unknown Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Maintenance Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AF	149	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Switching Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations This Read Vac	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AL	169	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AF	169	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Maintenance Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Reading	.3504	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations C Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations B Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations A Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	General Comments		
3/24/2022 14:48	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps A Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps B Ø	0.0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations C Ø	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Switching Operations	0	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Unknown Operations	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AL	242	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations This Read Vac	4	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Switching Operations	4	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps C Ø	160.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps B Ø	150.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Amps A Ø	150.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps C Ø	95.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps B Ø	106.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Amps A Ø	99.0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps B Ø	125.0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps A Ø	110.0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	9 Month Operations	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	9 Month Operations	4	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	9 Month Operations	20	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001956	BreakerVacuum	FV-1143	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations	4	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Switching Operations	2	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations This Read Vac	2	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations Counter AL	171	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Operations Counter AF	169	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps B Ø	180	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps A Ø	164	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations	2	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	9 Month Operations	20	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps A Ø	70.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps B Ø	68.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Amps C Ø	67.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps C Ø	145.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps B Ø	140.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Amps A Ø	140.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	9 Month Operations	4	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps A Ø	0.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps A Ø	46.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps B Ø	44.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps C Ø	46.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations This Read Vac	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations Counter AL	31	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Readings	Operations Counter AF	31	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001958	BreakerVacuum	FV-1145	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Maintenance Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AF	155	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	9 Month Operations	2	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AL	155	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AF	183	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AL	183	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations This Read Vac	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations Ground	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations C Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations B Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Operations A Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001569	BreakerVacuum	456-0607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps B Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Amps A Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Operations Since Last Insp	589	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Min Tap Position	14L	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Max Tap Position	2L	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Current Tap Position	5L	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Left Counter	61935	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Found Counter	61935	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	General Comments		
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001959	BreakerVacuum	FV-1146	VCB Readings	9 Month Operations	9	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations A Ø	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations B Ø	0	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps C Ø	180	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	General Comments		
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Unknown Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Switching Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations This Read Vac	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AL	192	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AF	192	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Maintenance Operations	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	General Comments		
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations Ground	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations C Ø	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations B Ø	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations A Ø	0	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:44	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps C Ø	80.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AF	185	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AL	185	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations This Read Vac	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Switching Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Unknown Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Switching Operations	2	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations This Read Vac	2	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations Counter AL	199	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Operations Counter AF	197	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Maintenance Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations Ground	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations C Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations B Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Operations A Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	1.6	AMPS
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
3/24/2022 14:19	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations C Ø	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations Ground	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Follow-up Action Required?	n	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	General Comments		
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001570	BreakerVacuum	456-0608	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Maintenance Operations	0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AF	238	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations	2	
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty A Ph V	.66	%
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty B Ph V	.33	%
3/24/2022 13:58	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty C Ph V	.33	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	9 Month Operations	4	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	3	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Present	18	°C
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Max	34	°C
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Reading	.7326	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Present	20	°C
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Max	36	°C
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	LTC Totalizer Reading	5274.72	kw
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Fault Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations A Ø	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Number of Ops last 9 Months	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AF	364	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AL	364	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations This Read Oil	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	3	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	78	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	78	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Bushing Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps C Ø	0.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps B Ø	0.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Amps A Ø	0.0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Vegetation	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	VRR Time Delay	30	Seconds
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AL	28	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AF	28	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations	6	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps A Ø	120.0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps B Ø	120.0	
3/24/2022 15:04	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps C Ø	120.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	LTC Operation Checked?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	General Comments		
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:08	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	General Comments		
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	Follow-up Action Required?	n	
3/24/2022 11:39	Distribution	London Quarterly Inspection	LTCC000777	LTCCControl	093-5	LTC Control Insp	All Connections OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001955	BreakerVacuum	FV-1142	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations Counter AF	28	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Maintenance Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Unknown Operations	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Switching Operations	2	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations This Read Vac	2	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations Counter AL	184	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Operations Counter AF	182	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Maintenance Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations Ground	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Follow-up Action Required?	n	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	General Comments		
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Maintenance Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Grounds in Place?	y	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	General Comments		
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Foundation Condition	Good	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Patrol Inspection	Follow-up Action Required?	n	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations Ground	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations C Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations B Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Operations A Ø	0	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AF	151	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AL	151	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/24/2022 10:05	Distribution	A O Smith Quarterly Inspection	BK001568	BreakerVacuum	456-0606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Unknown Operations	0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations This Read Vac	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Switching Operations	0	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Unknown Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps C Ø	0.0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps B Ø	0.0	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Regulator As Left Counter	22109	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/24/2022 14:58	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations Ground	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations C Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Foundation Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Tank Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	General Comments		
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Grounds in Place?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Switching Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Maintenance Operations	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations B Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations A Ø	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations This Read Vac	1	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AL	304	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Switching Operations	1	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/24/2022 14:58	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations This Read Vac	0	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AF	304	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/28/2022 8:35	Distribution	Fern Valley Quarterly Inspection	BK001957	BreakerVacuum	FV-1144	VCB Readings	Operations Counter AL	28	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Left Counter	3754	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.2743	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Current Tap Position	8L	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps C Ø	0.0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations Ground	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Follow-up Action Required?	n	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Found Counter	3744	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Maintenance Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AF	176	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AL	176	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations This Read Vac	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Switching Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Unknown Operations	0	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	General Comments		
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps A Ø	0.0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AL	120.2	VAC
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AF	120	VAC
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Output Voltage Level	120.2	VAC
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Operation Checked?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	General Comments		
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	All Connections OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	1316.64	kw
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	48	°C
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations This Read AM	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AL	311	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Operations Since Last Insp	633	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Min Tap Position	10L	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AF	311	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Found Counter	118230	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Left Counter	118230	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Max Tap Position	1L	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps C Ø	70	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps B Ø	75	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps A Ø	80	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	9 Months Operations	5	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty A Ph AM	1.23	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty B Ph AM	1.85	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty C Ph AM	3.09	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps A Ø	96.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps B Ø	121.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps C Ø	127.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Maintenance Operations	2	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AF	761	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AL	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations This Read AM	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Switching Operations	1	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Unknown Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations	2	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Present	35	°C
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Max	40	°C
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Max Tap Position	5R	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Min Tap Position	10L	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Operations Since Last Insp	541	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Winding Temp Present	0	°C
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Winding Temp Max	0	°C
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Reading	.0724	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Multiplier	4000	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Present	38	°C
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	LTC Totalizer Reading	289.6	kw
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	General Comments		
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	General Comments		
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations C Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations Ground	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Maintenance Operations	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AF	169	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AL	171	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations This Read Vac	2	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Switching Operations	2	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Unknown Operations	0	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	28390	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	28397	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	9L	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	649	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Reading	.5890	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	9 Month Operations	4	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps A Ø	30.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps B Ø	15.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps C Ø	20.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations A Ø	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations B Ø	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations C Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	LTC Totalizer Reading	8481.60	kw
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations A Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations B Ø	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Switching Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations	3	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps A Ø	238	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps B Ø	240	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps C Ø	240	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1219.20	kw
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Unknown Operations	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	All Connections OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	All Connections OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.44	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AL	123.9	VAC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	50	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	45	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1578	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1578	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	9 Months Operations	4	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty A Ph AM	8.49	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty B Ph AM	7.28	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty C Ph AM	6.07	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps A Ø	229.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps B Ø	191.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps C Ø	166.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations A Ø	1	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations B Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations Ground	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations C Ø	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations B Ø	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations A Ø	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps C Ø	112	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps B Ø	102	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps A Ø	100	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations	1	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AL	232	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations This Read Vac	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Switching Operations	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Unknown Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Unknown Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Switching Operations	2	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Unknown Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Switching Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations This Read Vac	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AL	175	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AF	175	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Maintenance Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.7	VDC
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	*F
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations This Read Vac	2	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AL	303	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AF	301	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Maintenance Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27	VDC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	9 Months Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	.56	%
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Vegetation	None	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations Ground	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations C Ø	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations B Ø	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations A Ø	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps C Ø	135.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps B Ø	100.0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps A Ø	95.0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations	18	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Found Counter	57075	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Left Counter	57079	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Current Tap Position	7L	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Max Tap Position	3L	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Min Tap Position	11L	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Operations Since Last Insp	743	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Unknown Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AL	903	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AF	903	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4402.56	kw
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27	VDC
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations Ground	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps B Ø	60.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps A Ø	40.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations	8	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Present	25	°C
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Max	30	°C
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Reading	.54	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Present	30	°C
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Max	35	°C
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	LTC Totalizer Reading	5184	kw
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	General Comments		
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Maintenance Operations	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AF	232	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps C Ø	54.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps B Ø	68.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps A Ø	49.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty C Ph AM	6.07	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty B Ph AM	13.35	%
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4586	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty A Ph AM	9.71	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Months Operations	2	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations	6	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps A Ø	245.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps B Ø	260.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps C Ø	225.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations A Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations B Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations C Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations Ground	0	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty B Ph AM	6.18	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps A Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps C Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations B Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AL	285	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AF	285	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Maintenance Operations	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations Ground	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations C Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations B Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations A Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps C Ø	245	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps B Ø	240	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps A Ø	255	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AF	635	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AL	635	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	83	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	83	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	5	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	5	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC As Found Counter	22560	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC As Left Counter	22570	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Current Tap Position	7L	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Max Tap Position	3L	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Min Tap Position	11L	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	2.43	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps A Ø	93.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps B Ø	94.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps C Ø	113.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations A Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Unknown Operations	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Switching Operations	1	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations This Read Vac	1	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	9 Months Operations	5	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty A Ph AM	3.09	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Switching Operations	3	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations This Read Vac	3	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AL	199	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AF	196	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Maintenance Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations Ground	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations C Ø	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations B Ø	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations A Ø	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations C Ø	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations A Ø	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps C Ø	1.0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps B Ø	10.0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps A Ø	7.0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	9 Month Operations	6	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps C Ø	56	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps B Ø	55	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps A Ø	60	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty C Ph V	.93	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Unknown Operations	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.66	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.66	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.66	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	8.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	8.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	8.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1483	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1483	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Operations Since Last Insp	683	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Unknown Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Switching Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations This Read Vac	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AL	181	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AF	181	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Maintenance Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations Ground	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Unknown Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AF	94	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AL	94	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations This Read Vac	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	9 Month Operations	1	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps A Ø	35.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps B Ø	38.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps C Ø	30.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AF	88	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AL	88	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations This Read Vac	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	9 Month Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty A Ph V	10.36	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty B Ph V	10.36	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty C Ph V	10.36	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps A Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps C Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations A Ø	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29753	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations B Ø	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Vegetation	None	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	9 Month Operations	3	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty B Ph V	9.57	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps A Ø	140.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps B Ø	163.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps C Ø	166.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	General Comments	x	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Found Counter	319100	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Left Counter	319108	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Current Tap Position	5L	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Max Tap Position	2R	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Min Tap Position	11L	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Operations Since Last Insp	493	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations A Ø	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AF	95	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AL	95	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations This Read Vac	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Switching Operations	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	9 Months Operations	7	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	4.85	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	12.13	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	5	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	5.78	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	5.78	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	5.78	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AF	13	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AL	13	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations This Read Vac	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty A Ph V	9.57	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty B Ph V	13.55	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps A Ø	111.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps B Ø	114.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps C Ø	116.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Vegetation	None	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27783	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations Ground	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations C Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations B Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations A Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Min Tap Position	2L	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Unknown Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Unknown Operations	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Switching Operations	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations This Read Vac	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AL	208	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AF	208	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Regulator As Left Counter	21973	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Leaks	None	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Maintenance Operations	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12467	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Maintenance Operations	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AF	282	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AL	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations This Read Vac	1	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Switching Operations	1	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Unknown Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	All Connections OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Operation Checked?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Leaks	None	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps C Ø	520	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps B Ø	520	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps A Ø	520	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty C Ph V	1.15	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty B Ph V	1.15	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty A Ph V	1.15	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations	0	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	General Comments		
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Regulator As Left Counter	19132	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Leaks	None	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations	3	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty A Ph V	3.08	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty B Ph V	2.06	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty C Ph V	1.03	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps A Ø	130	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps B Ø	145	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps C Ø	140	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Min Tap Position	10L	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Regulator As Left Counter	17644	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations A Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations B Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations C Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations C Ø	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations B Ø	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations A Ø	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps C Ø	41	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps B Ø	47	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps A Ø	40	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty C Ph V	3.78	%
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty B Ph V	3.4	%
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty A Ph V	3.78	%
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations	2	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	.95	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	.95	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	82.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	81.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1256	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1256	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations	4	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Unknown Operations	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Switching Operations	1	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations This Read Vac	1	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AL	217	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AF	216	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Maintenance Operations	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations Ground	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps C Ø	380	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps B Ø	380	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps A Ø	380	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations This Read Vac	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Switching Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AF	958	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AL	958	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Switching Operations	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Vegetation	None	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps A Ø	152	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps B Ø	148	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps C Ø	146	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.66	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.8	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Unknown Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Switching Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations This Read Vac	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AL	173	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AF	173	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Maintenance Operations	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	122	VAC
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations A Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations B Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations C Ø	0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations Ground	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations B Ø	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations C Ø	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations Ground	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Maintenance Operations	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AF	223	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AL	222	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations This Read Vac	1	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Switching Operations	1	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	9 Months Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty A Ph AM	1.23	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AF	746	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AL	746	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Unknown Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations This Read Vac	2	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AL	396	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations A Ø	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations B Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations C Ø	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AF	394	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Maintenance Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	General Comments		
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations Ground	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations	22	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps A Ø	0.0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps B Ø	0.0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps C Ø	0.0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Foundation Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations Ground	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations C Ø	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations B Ø	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations A Ø	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty B Ph AM	1.23	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps C Ø	325	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps B Ø	320	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps A Ø	330	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Unknown Operations	0	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 11:58	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Switching Operations	2	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps A Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps C Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps C Ø	40	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps B Ø	42	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps A Ø	44	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty C Ph V	6.42	%
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty B Ph V	7.93	%
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty A Ph V	3.4	%
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations	2	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	General Comments		
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Present	50	°C
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Max	50	°C
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Reading	.767	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Vegetation	None	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AF	123.9	VAC
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Operation Checked?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	General Comments		
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	All Connections OK?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	General Comments		
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations	5	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Vegetation	None	
3/23/2022 10:00	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Max	55	°C
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Present	60	°C
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Max	60	°C
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Reading	.591	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushing Condition	Good	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps C Ø	170.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps B Ø	200.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps A Ø	185.0	
3/23/2022 13:59	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/23/2022 7:38	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations A Ø	0	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	122	VAC
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	121.9	VAC
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/23/2022 15:07	Distribution	Elizabethtown 3 Quarterly Inspection	LTC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Max	42	°C
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	LTC Totalizer Reading	10638	kw
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	General Comments		
3/23/2022 11:47	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	LTC Totalizer Reading	13806	kw
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/23/2022 13:51	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	74.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	78.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	81.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.27	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	21.1	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	19.78	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps B Ø	60.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps A Ø	60.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	New Breaker	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AL	1421	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AF	1421	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Num Operations Last 9 Months	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Leaks	None	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Pressure OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Oil Level	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Fault Operations	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations This Read SF6	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AL	90	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AF	90	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Num Operations Last 9 Months	2	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AL	351	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AF	351	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Number of Ops last 9 Months	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Maintenance Operations	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Leaks	None	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Amps C Ø	60.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Fault Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Fault Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps C Ø	80.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps B Ø	80.0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2022-03-22 00:00:00.000000	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Fault Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps C Ø	350.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps B Ø	450.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps A Ø	350.0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations This Read Oil	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0	amps
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54	VDC
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BCH000522	Charger	796-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54	VDC
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps A Ø	80.0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Unknown Operations	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations This Read SF6	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CVVT Visible Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24782	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations	10	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps A Ø	20.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps B Ø	20.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps C Ø	20.0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Vegetation	None	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations This Read SF6	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AL	783	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AF	783	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Num Operations Last 9 Months	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Fault Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps C Ø	40.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps B Ø	40.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps A Ø	40.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Max Tap Position	9R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	9.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	10.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.32	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.32	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.32	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Max Tap Position	13R	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations This Read SF6	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AL	404	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AF	404	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Num Operations Last 9 Months	5	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Regulator As Left Counter	22885	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Regulator As Left Counter	20819	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Reading	.73	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2336	kw
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	72	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	72	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps B Ø	40.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps A Ø	60.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations	59	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	9 Month Operations	16	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Found Counter	235338	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Left Counter	235338	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations This Read SF6	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AL	687	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AF	687	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Num Operations Last 9 Months	3	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Fault Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps C Ø	90.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps B Ø	90.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps A Ø	90.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Max Tap Position	3R	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Min Tap Position	4L	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Operations Since Last Insp	118	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Readings	Operations This Read Vac	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001936	BreakerVacuum	SH-1458	VCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Operations This Read Vac	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	9 Month Operations	13	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations	10	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps A Ø	0.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps A Ø	75.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps B Ø	75.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps C Ø	75.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Fault Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Num Operations Last 9 Months	7	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AF	713	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AL	713	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations This Read SF6	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Readings	Operations This Read Vac	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001935	BreakerVacuum	SH-1457	VCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps C Ø	60.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	9 Month Operations	15	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Unknown Operations	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Switching Operations	5	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations This Read Vac	5	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AL	487	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AF	482	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Operation Checked?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	All Connections OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Readings	Operations This Read Vac	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001937	BreakerVacuum	SH-1459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Operations Since Last Insp	320	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Max Tap Position	4L	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps B Ø	0.0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps C Ø	0.0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Current Tap Position	7L	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations A Ø	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations B Ø	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations C Ø	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations Ground	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Left Counter	11127	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Found Counter	11127	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Switching Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations This Read Vac	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AL	309	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AF	309	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Maintenance Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations Ground	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations C Ø	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Vegetation	None	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.59	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	15.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	15.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	16.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Switching Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations This Read Vac	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	72	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	72	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Vegetation	None	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Unknown Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BCH001516	Charger	512-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001934	BreakerVacuum	SH-1456	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AL	296	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AF	296	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Maintenance Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	New Breaker	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	68	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	68	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations Ground	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations C Ø	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations B Ø	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations A Ø	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BAT001587	Battery	796-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	9 Month Operations	18	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	BK001933	BreakerVacuum	SH-GND TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	*C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Max	62	*C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	LTC Totalizer Reading	3922.56	kw
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations Ground	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations C Ø	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations B Ø	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Operations A Ø	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	All Connections OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Operation Checked?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Maintenance Operations	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Reading	.8172	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AF	488	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AL	492	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations This Read Vac	4	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Switching Operations	4	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Max	57	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Present	28	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	29	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	29	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	59	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	29	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	61	°C
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	83	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	220.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	220.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Max	35	°C
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Present	35	°C
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Found Counter	88244	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Left Counter	88244	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	68	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	68	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	New Breaker	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations	12	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps A Ø	110.0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps B Ø	110.0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps C Ø	110.0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations A Ø	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations B Ø	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations C Ø	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations Ground	0	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Follow-up Action Required?	n	
3/22/2022 12:56	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Unknown Operations	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	General Comments		
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	LTC Totalizer Reading	1719.36	kw
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	9 Month Operations	4	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty A Ph V	0	%
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty B Ph V	0	%
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Accumulated Fault Duty C Ph V	0	%
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps A Ø	260	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps B Ø	280	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Amps C Ø	260	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Bushing Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Present	34	°C
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	14.5	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	13.19	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	10.55	%
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	143.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	162.0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	166.0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Reading	.3582	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Found Counter	3860	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Foundation Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Left Counter	3860	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	10	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	General Comments		
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	102	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Grounds in Place?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Maintenance Operations	0	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations Counter AF	172	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	79	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	79	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	New Breaker	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations Counter AL	174	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Operations This Read Vac	2	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Readings	Switching Operations	2	
3/22/2022 15:21	Distribution	Falmouth Quarterly Inspection	BK001548	BreakerVacuum	796-0796	VCB Patrol Inspection	Tank Paint Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/22/2022 16:54	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/22/2022 12:17	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations This Read Vac	4	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Switching Operations	4	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Unknown Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AL	314	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AF	310	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Maintenance Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations	17	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps A Ø	35.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps B Ø	40.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps C Ø	40.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushing Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps A Phase V	6.98	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps B Phase V	6.98	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps C Phase V	6.98	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations A Ø	2	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations B Ø	2	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations C Ø	2	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations Ground	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Maintenance Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AF	196	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AL	200	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations This Read Vac	8	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Switching Operations	2	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Unknown Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations This Read Vac	3	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps A Ø	425.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps B Ø	405.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps C Ø	440.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushing Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations A Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations B Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations C Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations Ground	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations Ground	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations C Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations B Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations A Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushing Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps C Ø	525.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Operations Since Last Insp	1155	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations C Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations B Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations A Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	LTC Operation Checked?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTC0000347	LTCControl	539-2	LTC Control Insp	All Connections OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps B Ø	495.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps A Ø	530.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations A Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations B Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations C Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations Ground	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushing Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Maintenance Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AL	268	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AF	265	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	9 Month Operations	13	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps C Ø	90.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps B Ø	85.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps A Ø	90.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations	6	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps A Ø	14.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps B Ø	10.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps C Ø	10.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations	6	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	All Connections OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Operation Checked?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations	3	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushing Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Unknown Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Switching Operations	4	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations This Read Vac	4	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AL	178	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AF	174	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Maintenance Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations Ground	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Found Counter	201076	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Left Counter	201076	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Max Tap Position	15R	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Min Tap Position	14L	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Unknown Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Switching Operations	3	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations This Read Vac	3	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Operations Since Last Insp	2011	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Min Tap Position	12L	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Max Tap Position	7R	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Left Counter	74417	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Found Counter	74417	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Unknown Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AL	226	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AF	223	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Maintenance Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	LTC Totalizer Reading	12744.00	kw
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations Ground	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Vegetation	None	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Switching Operations	1	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations This Read Vac	1	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AL	214	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AF	213	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Maintenance Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Switching Operations	3	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Unknown Operations	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Max	50	°C
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Present	50	°C
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Reading	.7080	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Max	60	°C
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Present	50	°C
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	General Comments		
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	LTC Totalizer Reading	8000.64	kw
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations	7	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Reading	1.1112	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps A Ø	260.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps B Ø	245.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps C Ø	285.0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushing Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations A Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations B Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations C Ø	0	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 13:58	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations B Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AF	527	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AF	71	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AL	71	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AL	53	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Foundation Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushing Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	All Connections OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AF	97	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AL	97	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps C Ø	56.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps B Ø	59.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps A Ø	58.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Warning Signs OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AF	107	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations	6	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps B Ø	64.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps A Ø	37.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	2.6	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.6	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	560	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AL	107	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Left Counter	24505	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps A Ø	0.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Found Counter	24505	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Months Operations	1	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AF	53	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations A Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps C Ø	57.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Patrol Inspection	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushing Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	All Connections OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps B Ø	0.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	289.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	329.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	290.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps B Ø	81.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps A Ø	74.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	48	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AL	50	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AF	50	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	48	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Maintenance Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AL	211	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations This Read AM	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1411	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Left Counter	27714	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Found Counter	27714	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	37	°C
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	37	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	37	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	37	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	37	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	37	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Present	29	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Max	36	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AF	230	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AL	230	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	141	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	141	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Found Counter	25207	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Left Counter	25207	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Min Tap Position	Neutral	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	718	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Tank Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps C Ø	531.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps B Ø	529.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps A Ø	530.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations	1	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AL	101	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AF	101	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AL	149	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AF	149	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations	4	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps C Ø	81.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps B Ø	82.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps A Ø	81.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	18.07	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	26.5	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	66.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	84.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	65.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	155	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	155	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	One set of 4' lights is out.	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AL	107	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AF	107	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AL	104	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps C Ø	80.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps B Ø	80.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps A Ø	83.0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AF	104	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps A Ø	182.0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps B Ø	217.0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Amps C Ø	219.0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Bushing Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Unknown Operations	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	15.66	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	12.05	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	53.0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Foundation Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	9 Month Operations	3	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001781	BreakerVacuum	698-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	2.43	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AL	434	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	3.64	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Months Operations	1	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations This Read AM	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Switching Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	84.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	66.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	244	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Left Counter	78991	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Found Counter	78991	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	253	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	31	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps C Ø	51.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps B Ø	53.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps A Ø	53.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	5L	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Left Counter	61846	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Found Counter	61846	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	General Comments		LTC cabinet glass covering the drag hands is broken. Looks like a rock was thrown at it.
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AF	181	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AL	181	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	101	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AF	151	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AL	151	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Max Tap Position	4L	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Current Tap Position	7L	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Left Counter	257246	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Found Counter	257246	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Unknown Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty C Ph AM	1.21	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps A Ø	140.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps B Ø	170.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps C Ø	150.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations A Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations B Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations C Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Unknown Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Switching Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations This Read AM	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AL	2470	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AF	2470	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Maintenance Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations Ground	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Maintenance Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AF	434	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations Ground	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations C Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations B Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations A Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps C Ø	150.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps B Ø	150.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps A Ø	150.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps C Ø	0.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations C Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations Ground	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations	4	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty B Ph V	10.36	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps A Ø	101.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps B Ø	107.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps C Ø	97.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps A Ø	62.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps B Ø	61.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps C Ø	62.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AF	140	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AL	140	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TR nitro bottle empty	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AF	187	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AL	187	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AF	2043	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Maintenance Operations	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Grounds in Place?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Unknown Operations	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	*F
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.7	VDC
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Foundation Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations Ground	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations C Ø	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations B Ø	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations A Ø	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushing Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps C Ø	120.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps B Ø	120.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps A Ø	120.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations	5	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	116	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	116	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	135.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	144	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	144	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	DNO	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.4	psi
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Max	59	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Present	42	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	52	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	52	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	52	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AL	159	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AF	159	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	LTC Totalizer Reading	4860.00	kw
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	59	°F
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Vegetation	None	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AL	146	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Present	38	°C
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Max	38	°C
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Reading	.2700	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AF	146	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Found Counter	257662	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Left Counter	257662	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Current Tap Position	12L	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Max Tap Position	3L	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Min Tap Position	9L	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Operations Since Last Insp	505	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations Ground	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	General Comments	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AL	71	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AF	71	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps C Ø	0.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations This Read Vac	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AL	196	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AF	196	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Maintenance Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps C Ø	183.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps B Ø	194.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps A Ø	161.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations	2	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AF	122	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AL	122	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Unknown Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Unknown Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Switching Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AL	527	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations B Ø	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AF	170	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AL	170	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AF	178	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AL	178	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AL	172	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AF	172	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	124.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	91.0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AF	96	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AL	96	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Present	29	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Max	35	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AL	89	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AF	89	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	128.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	29	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	35	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	29	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	35	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	29	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	35	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Foundation Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Maintenance Operations	3	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AF	165	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AL	165	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations This Read Vac	6	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Switching Operations	3	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AF	61	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	53	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	53	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AL	61	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Vegetation	None	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Ambient Temp	59	*F
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	33	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	33	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	33	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	33	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	33	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	33	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AL	88	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Operations Counter AF	88	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Present	29	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Max	33	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AL	51	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AF	51	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	All Connections OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Operation Checked?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	LTCC000927	LTCControl	608-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps C Ø	109.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations Ground	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps B Ø	106.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps A Ø	105.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations	2	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AF	147	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AL	147	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Unknown Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations	5	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty B Ph V	.56	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps A Ø	20.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps B Ø	20.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps C Ø	20.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations A Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations B Ø	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations	5	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	LTC Totalizer Reading	2949.12	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Maintenance Operations	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps A Ø	215.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps B Ø	190.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps C Ø	220.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushing Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AF	186	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AL	186	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations This Read Vac	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Unknown Operations	0	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	General Comments		
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations A Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations B Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations C Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations Ground	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Maintenance Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AF	240	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AL	240	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations This Read AM	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Vegetation	None	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Left Counter	29821	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	3L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Max Tap Position	5L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Min Tap Position	1L	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	33	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	171	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations	2	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	General Comments		
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps A Ø	78.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps B Ø	78.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps B Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps C Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations A Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations B Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AF	51	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AL	51	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations This Read Vac	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AL	63	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AF	63	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Unknown Operations	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Maintenance Operations	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AF	241	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AL	241	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations This Read Vac	1	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Switching Operations	1	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Ambient Temp	70	*F
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/18/2022 15:00	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps A Ø	87.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Found Counter	29821	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Reading	.9216	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps A Ø	72.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps B Ø	72.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Max	38	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	General Comments		
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Maintenance Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AF	161	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AL	161	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1450	psi
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps C Ø	71.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps A Ø	121.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Maintenance Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AF	336	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AL	336	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	36	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	36	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Months Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations	3	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Unknown Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	36	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations C Ø	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations Ground	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	36	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	36	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	36	°C
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Switching Operations	0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations This Read Vac	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Switching Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations This Read Vac	0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps C Ø	0.0	
3/18/2022 12:12	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Present	0	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps B Ø	0.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps A Ø	0.0	
3/18/2022 15:17	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty B Ph AM	1.21	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty A Ph AM	1.21	%
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Maintenance Operations	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Reading	.9538	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Max	0	°C
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushing Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps C Ø	27.0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps B Ø	39.0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps A Ø	35.0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations	3	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Unknown Operations	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Tank Paint Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Switching Operations	1	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations This Read Vac	1	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AL	273	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	LTC Totalizer Reading	4578.24	kw
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Max	66	°C
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Present	38	°C
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AF	273	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations Ground	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations C Ø	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations B Ø	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations A Ø	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Max Tap Position	1R	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Left Counter	25740	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Found Counter	25740	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations	5	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps A Ø	92.0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps B Ø	85.0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps C Ø	95.0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushing Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Vegetation	None	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Present	0	°C
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Grounds in Place?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Foundation Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Operations Since Last Insp	761	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations A Ø	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations This Read Vac	2	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AL	283	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AF	283	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Operation Checked?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations C Ø	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations Ground	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Foundation Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Grounds in Place?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	All Connections OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Switching Operations	2	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Maintenance Operations	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Unknown Operations	0	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Tank Paint Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/17/2022 14:53	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Unknown Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Current Tap Position	2R	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Switching Operations	1	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations	4	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps C Ø	300.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps B Ø	325.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps A Ø	311.0	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AF	213	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AL	213	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations This Read Vac	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Switching Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Unknown Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Maintenance Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations A Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations B Ø	2	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations C Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations Ground	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Foundation Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Max Tap Position	7R	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	General Comments	26.7 is the float. .02 is the amps. needs to be added to inspection	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Months Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps A Ø	210.0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps B Ø	100.0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps C Ø	100.0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations A Ø	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations B Ø	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations C Ø	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations Ground	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Maintenance Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AF	474	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AL	474	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations This Read AM	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Switching Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Unknown Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps C Ø	100.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Maintenance Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations Ground	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AF	417	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AL	417	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations This Read AM	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Switching Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Unknown Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations C Ø	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations B Ø	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations A Ø	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations C Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations Ground	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps B Ø	100.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Maintenance Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps A Ø	150.0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Months Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/16/2022 15:04	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AF	272	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AL	273	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations This Read Vac	3	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	LTC Totalizer Reading	15681.60	kw
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations	4	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps A Ø	445.0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps B Ø	465.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps C Ø	454.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations A Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations B Ø	2	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.30	MegaVars
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.50	MegaVars
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.50	MegaWatts
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.30	MegaWatts
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Maintenance Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3490	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Max	25	°C
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Present	25	°C
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations Ground	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations C Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations B Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations A Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps C Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps B Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps A Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps B Ø	802.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps C Ø	783.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	49	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Max	60	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Present	60	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Max	35	°C
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	General Comments		
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Months Operations	2	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Unknown Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	290	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	263	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.0	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.0	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.0	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	120	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Found Counter	56687	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Left Counter	56692	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Max Tap Position	8R	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Operations Since Last Insp	1005	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	All Connections OK?	y	check oil cup
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	LTC Operation Checked?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000930	LTCControl	799-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	401.67	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	380.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Max	39	°C
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps C Ø	24.0	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	78	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	73	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	General Comments		
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	General Comments		
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Maintenance Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AF	254	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AL	255	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations This Read Vac	3	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Switching Operations	1	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations	2	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps A Ø	794.0	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Unknown Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Switching Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations This Read AM	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AL	422	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	General Comments		
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	22	°C
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	42	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations Ground	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations C Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations B Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations A Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	General Comments		
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Regulator As Left Counter	2401	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Leaks	None	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Operations Since Last Insp	2385	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	837.60	kw
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Reading	.8712	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Months Operations	2	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps A Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps B Ø	100.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps C Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations A Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations B Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations C Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations Ground	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Maintenance Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AF	551	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AL	551	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations This Read AM	1	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Switching Operations	1	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Unknown Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AF	422	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PF001343	PowerFuse	WE-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PF001343	PowerFuse	WE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PF001342	PowerFuse	WE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PF001342	PowerFuse	WE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PF001341	PowerFuse	VE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PF001341	PowerFuse	VE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Found Counter	131045	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Left Counter	131045	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.0	psi
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Max	60	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Present	55	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Current Tap Position	12L	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	General Comments		
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	General Comments		
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Max Tap Position	12R	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Min Tap Position	4R	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	55	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	120	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Left Counter	26756	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Found Counter	26756	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps A Ø	0.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps B Ø	0.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps C Ø	0.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Present	31	°C
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Max	37	°C
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations A Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations B Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations C Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations Ground	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps C Phase V	5.46	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations A Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations B Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations C Ø	1	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations Ground	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Maintenance Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.30	MegaVars
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.25	MegaVars
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.30	MegaWatts
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	1.50	MegaWatts
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AF	280	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AL	285	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations This Read Vac	6	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Switching Operations	5	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations	2	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	General Comments		
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Regulator As Left Counter	119118	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Leaks	None	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Current Tap Position	3R	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations A Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations B Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations C Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations Ground	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Maintenance Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AF	1006	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AL	1006	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations This Read AM	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Switching Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Unknown Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Maintenance Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Unknown Operations	0	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Present	35	°C
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Max	42	°C
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	160.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AF	271	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AL	272	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations This Read Vac	1	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Switching Operations	1	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Unknown Operations	0	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Maintenance Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AF	423	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AL	423	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations This Read AM	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Switching Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Unknown Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Operation Checked?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	All Connections OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations C Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations Ground	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	230.00	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Present	35	°C
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Max	35	°C
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	35	°C
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Present	30	°C
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Max	30	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations A Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps C Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps B Ø	100.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps A Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations	10	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps A Ø	420.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps B Ø	420.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps C Ø	420.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Vegetation	None	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Maintenance Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Ambient Temp	59	*F
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AF	99947	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AL	99947	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations This Read Vac	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Switching Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Vegetation	None	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Unknown Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Months Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps A Ø	25.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps B Ø	25.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps C Ø	25.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Unknown Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Switching Operations	0	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations This Read AM	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Present	50	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations	2	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps A Ø	17.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps B Ø	0.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps C Ø	0.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations Ground	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations A Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations B Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations C Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations Ground	0	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Vegetation	None	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	General Comments		
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/16/2022 5:08	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Found Counter	429297	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Left Counter	429297	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Reading	.8058	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Max	55	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Maintenance Operations	1	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AF	180	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AL	181	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps A Ø	200.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Unknown Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations	8	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Switching Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations This Read AM	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AL	612	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AF	612	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Maintenance Operations	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	General Comments		
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Vegetation	None	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations Ground	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations C Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations B Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations A Ø	0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	LTC Totalizer Reading	14504.40	kw
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps C Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps B Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps A Ø	50.0	
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/16/2022 15:04	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Months Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps B Ø	240.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps C Ø	240.0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushing Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations A Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations B Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations C Ø	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	General Comments		
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Maintenance Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Max Tap Position	5R	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Min Tap Position	6L	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Present	50	°C
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AF	99948	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AL	99952	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations This Read Vac	4	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Unknown Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Switching Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations This Read Vac	1	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Leaks	None	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Regulator As Left Counter	121763	
3/16/2022 11:13	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	84	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/16/2022 9:06	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Unknown Operations	0	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Switching Operations	4	
3/16/2022 15:22	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1509	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations A Ø	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations B Ø	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations C Ø	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations Ground	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps C Ø	60.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps B Ø	50.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps A Ø	100.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Operations Counter	890	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Reading	.5650	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Reading	.4992	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AL	254	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations This Read AM	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Switching Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AF	254	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Maintenance Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Unknown Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushing Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps A Ø	100.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps B Ø	120.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Months Operations	3	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps C Ø	100.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	9 Month Operations	3	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Maintenance Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AF	867	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AL	867	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations This Read AM	1	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Switching Operations	1	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps A Ø	95.0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps B Ø	104.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Months Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Amps C Ø	96.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Found Counter	2202	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Oil Level on LTC is high	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	LTC Totalizer Reading	3283.20	kw
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	General Comments		
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	General Comments		
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AL	295	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations This Read AM	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Switching Operations	0	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	All Connections OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	LTC Operation Checked?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	LTCC000929	LTCControl	556-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Months Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Unknown Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Reading	.3420	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Winding Temp Max	0	°C
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Winding Temp Present	0	°C
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AF	295	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Maintenance Operations	0	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	High	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Max	80	°C
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	General Comments		
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations Ground	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations C ∅	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	73	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations B Ø	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations A Ø	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps C Ø	50.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps B Ø	50.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Left Counter	2202	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps A Ø	50.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Found Counter	102025	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Left Counter	102025	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Current Tap Position	5L	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Max Tap Position	2L	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Min Tap Position	11L	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Operations Since Last Insp	603	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Unknown Operations	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Switching Operations	1	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	LTC Totalizer Reading	4792.32	kw
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations This Read Vac	1	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Present	25	°C
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AL	342	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Operations Counter AF	341	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Maintenance Operations	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Grounds in Place?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Foundation Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations Ground	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations C Ø	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations B Ø	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Readings	Fault Operations A Ø	0	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Found Counter	18202	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Left Counter	18202	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Max Tap Position	2R	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Min Tap Position	9L	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Operations Since Last Insp	751	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Operations Counter	1502	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Vegetation	None	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations Ground	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations C Ø	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations B Ø	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations A Ø	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushing Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Readings	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps C Ø	78.0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps B Ø	91.0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps A Ø	72.0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations	3	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LTO169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Unknown Operations	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Switching Operations	1	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations This Read Vac	1	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AL	386	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AF	385	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Maintenance Operations	0	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Grounds in Place?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Foundation Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	All Connections OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Operation Checked?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Vegetation	None	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Operations Counter	1432	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	General Comments	3 neighboring fences with neighborhood to the north	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Vegetation	None	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	General Comments		
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	General Comments		
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Vegetation	None	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	General Comments		
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	FE000885	Fence	597-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	All Connections OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	General Comments		
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Operation Checked?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PF001344	PowerFuse	SS-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PF001344	PowerFuse	SS-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	22	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Found Counter	90284	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Left Counter	90284	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	208	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	check oil cup
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 9:42	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	General Comments		
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Months Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps A Ø	0.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps B Ø	0.0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps C Ø	0.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Found Counter	220343	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Left Counter	220343	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations Ground	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Maintenance Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AF	325	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AL	325	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations This Read AM	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Switching Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Unknown Operations	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	0	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Operations Counter	1466	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/16/2022 5:29	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	1	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	583	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	583	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/15/2022 12:34	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	General Comments		
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	LTC Totalizer Reading	5424.00	kw
3/15/2022 11:56	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 7:52	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/15/2022 11:03	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	423848	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	98	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	423848	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	30	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps A Ø	12.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps B Ø	11.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Maintenance Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps C Ø	10.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	9 Months Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Operations Counter	21	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps A Ø	11	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps B Ø	10	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps C Ø	11	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Operations Counter	24	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps C Ø	48	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps B Ø	50	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps A Ø	51	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409607	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409607	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	9 Month Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	160.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	150.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	190.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushing Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps C Ø	98.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps B Ø	105.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps A Ø	104.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	9 Month Operations	2	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Unknown Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Switching Operations	0	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations This Read AM	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	312	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	312	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Present	25	°C
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Reading	.4338	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Max	30	°C
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Present	30	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations This Read Vac	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	LTC Totalizer Reading	7808.40	kw
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Max	35	°C
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Found Counter	225793	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Left Counter	225793	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AL	109	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AF	109	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Maintenance Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations Ground	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations C Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations B Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	88	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Unknown Operations	2	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Switching Operations	1	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations This Read Vac	3	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AL	190	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AF	189	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Maintenance Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Grounds in Place?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Foundation Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations Ground	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations C Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations B Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations A Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps C Phase V	2.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps C Ø	350.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps B Ø	375.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #*'s
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Negative DC Ground	66.3	VDC
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushing Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Left Counter	230528	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Found Counter	230528	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	9 Month Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps C Ø	214.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps B Ø	224.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps A Ø	211.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	161	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	161	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	9 Month Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PF001335	PowerFuse	SN-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Months Operations	1	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PF001335	PowerFuse	SN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PF001334	PowerFuse	SN-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PF001334	PowerFuse	SN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	Okay	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Unknown Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Switching Operations	1	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations This Read Vac	1	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AL	219	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AF	218	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Maintenance Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Grounds in Place?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Foundation Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.3	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations A Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps B Phase V	2.00	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps A Phase V	2.00	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushing Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps C Ø	116.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps B Ø	121.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps A Ø	108.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations B Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations C Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps A Ø	47.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps B Ø	47.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps C Ø	47.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations A Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations Ground	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	9 Month Operations	4	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PF001337	PowerFuse	SE-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PF001337	PowerFuse	SE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PF001336	PowerFuse	SE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PF001336	PowerFuse	SE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps A Ø	250.0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AF	99950	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AL	99950	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations This Read AM	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Maintenance Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AF	107	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AL	107	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations This Read Vac	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Switching Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Unknown Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Operations Since Last Insp	919	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Min Tap Position	12L	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Max Tap Position	2L	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Current Tap Position	8L	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Left Counter	130010	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Found Counter	130010	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations A Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations B Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations C Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations Ground	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Present	10	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Max	20	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Foundation Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps A Ø	29	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps B Ø	34	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps C Ø	30	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations Ground	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations C Ø	0	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations B Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations A Ø	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Operations Counter	21	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	468	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Operations Counter	51	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps C Ø	51.0	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps B Ø	51.0	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps A Ø	61.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Unknown Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Switching Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations This Read Vac	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AL	151	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AF	151	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Maintenance Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Grounds in Place?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Maintenance Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Num Operations Last 9 Months	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AF	95	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AL	95	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations This Read SF6	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Pressure	66	psi
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Switching Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Unknown Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Months Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps A Ø	195.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps B Ø	120.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps C Ø	190.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Ambient Temperature	43	°F
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Fault Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Foundation Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	General Comments	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Grounds in Place?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations This Read AM	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	345	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	345	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	220.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	180.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	160.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations Ground	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Maintenance Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AF	449	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AL	449	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations This Read AM	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Switching Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Unknown Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Winding Temp Present	30	°C
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Winding Temp Max	40	°C
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Totalizer Meter Reading	.297	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Oil Temp Max	38	°C
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	LTC Totalizer Reading	2138.4	kw
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Operations Since Last Insp	478	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Max Tap Position	3R	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Left Counter	28811	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Found Counter	28811	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.000	millivolts
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps A Ø	150.0	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps B Ø	110.0	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps C Ø	113.0	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Operations Counter	2043	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments	leaking around gauges	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	Need size info and qty
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	56	°F
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2023-06-23 00:00:00.000000	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	WithLTC	604-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	56	*F
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BAT001545	Battery	619-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations This Read AM	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	397	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	397	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	100.0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	100.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	General Comments	Two heavy concrete trench slabs broken 24" X 29.5" these may have been reported already.	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Found Counter	8069	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Left Counter	8069	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Current Tap Position	7L	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Max Tap Position	2L	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	24	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Operations Since Last Insp	505	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps A Ø	11	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps B Ø	10	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps C Ø	7	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Operations Counter	7	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Found Counter	321971	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Left Counter	321971	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	80	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	BCH001497	Charger	619-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 14:16	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	60.0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Months Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	General Comments	1 gate is blocked on rick house side by parking stops and is lined for parking spots in fron of it.	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Months Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps A Ø	100.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps B Ø	50.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps C Ø	75.0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations Ground	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Maintenance Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AF	432	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AL	432	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations This Read AM	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Switching Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Unknown Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	If no, which cells in comments
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations This Read AM	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	9 Months Operations	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AF	18563	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AL	18563	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations This Read AM	0	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.05	MegaVars
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.00	MegaWatts
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	1.00	MegaWatts
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	All Connections OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	LTC Operation Checked?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Tank Paint Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Grounds in Place?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Foundation Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushing Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	LTCC000808	LTCCControl	828-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Reading	.4610	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Max	38	°C
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Present	24	°C
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	1.50	MegaVars
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.05	MegaVars
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	.80	MegaWatts
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.30	MegaWatts
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Max	42	°C
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	38	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps A Ø	0.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps B Ø	0.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps C Ø	0.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations A Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations B Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations C Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations Ground	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Maintenance Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AF	170	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AL	170	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations This Read Vac	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Switching Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Unknown Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	32	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	38	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	32	°C
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	LTC Operation Checked?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	38	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	32	°C
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Operations Since Last Insp	230	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	All Connections OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	700	°F
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	All Connections OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	Okay	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	Okay	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Winding Temp Present	0	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCCM00035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	6	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	All Connections OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Operation Checked?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	LTCC000316	LTCControl	604-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Found Counter	26111	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Left Counter	26111	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Found Counter	7285	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Left Counter	7285	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	234	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations This Read Vac	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AL	290	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AF	290	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Maintenance Operations	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Grounds in Place?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Foundation Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations Ground	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations C Ø	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations B Ø	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations A Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Switching Operations	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Unknown Operations	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Maintenance Operations	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AF	19	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AL	19	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations This Read Vac	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Switching Operations	0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Unknown Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Nitrogen Bottle needs nitrogen	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Vegetation	None	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	30	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	One fan has been removed / missing from XFMR , new fan has not been installed. Fan Motor- Century / Magnetek, - 1/6 hp, 208-230 vac	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Max	37	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	General Comments		
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	All Connections OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Present	31	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	9 Month Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushing Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps C Ø	300.0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps B Ø	300.0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps A Ø	160.0	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	30	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	30	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	General Comments		
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations This Read AM	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AL	148	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AF	148	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	PF001265	PowerFuse	PL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	Okay	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	General Comments	OK	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	9 Month Operations	0	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	General Comments		
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/14/2022 14:23	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	General Comments		
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Present	38	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps A Ø	59.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps B Ø	59.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps C Ø	60.0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	60.0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	50.0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	60.0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	1	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Max	38	°C
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations Ground	0	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Min Tap Position	5L	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Parallel / Ind. Sw Position	parallelIND	Position
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Unknown Operations	0	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Switching Operations	0	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Max Tap Position	5R	
3/21/2022 7:48	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC Current Tap Position	1L	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC As Left Counter	11750	
3/14/2022 17:33	Distribution	New Haven Quarterly Inspection	C0412	LTCMechanism	604-1	LTC Counter Readings	LTC As Found Counter	11750	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations This Read AM	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	393	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	393	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 10:15	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Winding Temp Max	0	°C
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Reading	.5808	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	LTC Totalizer Reading	5575.68	kw
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 14:48	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 15:28	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 18:34	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 15:06	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	General Comments	.	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	9 Month Operations	6	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations A Ø	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations B Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Unknown Operations	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Switching Operations	2	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations This Read Vac	2	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps A Ø	35.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps B Ø	35.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Amps C Ø	50.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations Counter AL	198	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Operations Counter AF	196	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Unknown Operations	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Switching Operations	5	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations This Read Vac	5	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AL	183	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AF	178	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Maintenance Operations	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	General Comments		
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	General Comments		
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations Ground	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations C Ø	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	9 Month Operations	6	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Maintenance Operations	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps A Ø	40.0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	9 Month Operations	8	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps B Ø	40.0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps C Ø	40.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations Ground	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations C Ø	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations B Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Operations A Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001578	BreakerVacuum	686-0877	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations C Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations B Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations A Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps C Ø	50.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps B Ø	60.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Amps A Ø	40.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	9 Month Operations	6	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Regulator As Left Counter	51201	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Present	30	°C
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Max	35	°C
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Reading	1.0380	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Max	35	°C
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	LTC Totalizer Reading	4982.40	kw
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Vegetation	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Operations Since Last Insp	305	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Min Tap Position	6L	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Max Tap Position	2R	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Left Counter	14933	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Found Counter	14933	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6810	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Max	35	°C
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Present	30	°C
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	All Connections OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Operation Checked?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	LTC Output Voltage Level	125.0	VAC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Unknown Operations	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Switching Operations	2	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations This Read Vac	2	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations Counter AL	213	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Operations Counter AF	211	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Maintenance Operations	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BK001579	BreakerVacuum	686-0878	VCB Readings	Fault Operations Ground	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations A Ø	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations B Ø	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations C Ø	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations Ground	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Maintenance Operations	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AF	187	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AL	187	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations This Read Vac	2	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Switching Operations	2	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Unknown Operations	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Unknown Operations	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Switching Operations	2	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations This Read Vac	2	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AL	184	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AF	182	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Maintenance Operations	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	General Comments		
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations Ground	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations C Ø	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations B Ø	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations A Ø	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps C Ø	50.0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps B Ø	60.0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps A Ø	45.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Vegetation	None	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations	3	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps A Ø	14.0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps B Ø	12.0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps C Ø	13.0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Unknown Operations	0	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Regulator As Left Counter	181941	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Reading	1.2852	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Present	60	°C
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Max	35	°C
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	LTC Totalizer Reading	6168.96	kw
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations	5	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps A Ø	90.0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps B Ø	80.0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps C Ø	90.0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations A Ø	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations B Ø	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations C Ø	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations Ground	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Maintenance Operations	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AF	170	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AL	172	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations This Read Vac	2	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Switching Operations	2	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Unknown Operations	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps A Ø	70.0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps B Ø	50.0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps C Ø	50.0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Switching Operations	2	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations This Read Vac	2	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AL	229	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AF	227	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Maintenance Operations	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations Ground	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations C Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations B Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations A Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations A Ø	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations B Ø	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations C Ø	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations Ground	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Regulator As Left Counter	31985	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations	4	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33904	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Unknown Operations	3	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Switching Operations	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations This Read Vac	3	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations Counter AL	159	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Operations Counter AF	159	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37793	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Regulator As Left Counter	66657	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Min Tap Position	8L	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	General Comments		
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Regulator As Left Counter	168166	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Min Tap Position	4L	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	General Comments		
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1388	Regulator	212-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps A Ø	9.0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	General Comments		
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	9 Month Operations	26	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	General Comments		
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	*F
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Maintenance Operations	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	General Comments		
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations Ground	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations C Ø	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations B Ø	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Operations A Ø	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps C Phase V	3.00	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps B Phase V	3.00	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Fault Adjusted Amps A Phase V	3.00	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Vegetation	None	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	General Comments		
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps C Ø	14.0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001416	BreakerVacuum	212-0699	VCB Readings	Amps B Ø	18.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Max	40	°C
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	231.36	kw
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	General Comments		
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Regulator As Left Counter	70482	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	General Comments		
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Min Tap Position	5L	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Regulator As Left Counter	64527	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R1205	Regulator	212-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Reading	.2892	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Regulator As Left Counter	82698	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1179.36	kw
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Operations Since Last Insp	395	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Min Tap Position	15L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Max Tap Position	4L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Current Tap Position	9L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Left Counter	10933	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Found Counter	10933	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	General Comments	barrels deteriorated. metering conduit broken	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Regulator As Left Counter	115801	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9828	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Leaks	None	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Pressure OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps C Ø	60.0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps B Ø	80.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps A Ø	100.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations	5	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Fault Operations	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Heaters (All) Functioning?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Maintenance Operations	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Number of Ops last 9 Months	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AF	427	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AL	427	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations This Read Oil	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2022-03-11 00:00:00.000000	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Switching Operations	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Leaks	None	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Maintenance Operations	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AF	168	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AL	170	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations This Read Vac	2	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Switching Operations	2	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Unknown Operations	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2204	°C
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1952.64	kw
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	General Comments		
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	General Comments		
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Switching Operations	2	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Unknown Operations	0	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Regulator As Left Counter	65000	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	General Comments		
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Max Tap Position	5R	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Min Tap Position	6L	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Unknown Operations	0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations	3	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps A Ø	165.0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps B Ø	148.0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps C Ø	159.0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations A Ø	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations B Ø	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations C Ø	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations Ground	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Maintenance Operations	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AF	190	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AL	190	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations This Read Vac	2	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.8790	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Operation Checked?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations	14	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps A Ø	149.0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps B Ø	217.0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps C Ø	149.0	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps B Phase V	30.40	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps C Phase V	30.40	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations A Ø	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations B Ø	6	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations C Ø	6	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations Ground	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Found Counter	11118	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Left Counter	11125	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Current Tap Position	1L	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Max Tap Position	2R	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Operations Since Last Insp	265	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	1054.80	kw
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Vegetation	None	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	General Comments	driveway with large washouts from flooding	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3268.80	kw
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	General Comments	6 B&C 51 ops	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Maintenance Operations	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AF	198	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AL	197	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations This Read Vac	12	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Switching Operations	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Unknown Operations	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	All Connections OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	General Comments		
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	General Comments		
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	9 Month Operations	29	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps A Ø	0.0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps B Ø	2.0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Amps C Ø	18.0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations A Ø	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations B Ø	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations C Ø	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Fault Operations Ground	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	General Comments		
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	General Comments		
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Maintenance Operations	1	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations Counter AF	193	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations Counter AL	193	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Operations This Read Vac	1	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Switching Operations	0	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	BK001175	BreakerVacuum	212-0698	VCB Readings	Unknown Operations	0	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.7	VDC
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.7	VDC
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations	2	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	General Comments		
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	General Comments		
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Maintenance Operations	1	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AF	152	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AL	152	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations This Read Vac	1	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations Ground	0	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations C Ø	0	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Switching Operations	0	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations B Ø	0	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations A Ø	0	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Unknown Operations	0	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Vegetation	None	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps B Ø	150.0	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps A Ø	190.0	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations	5	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations A Ø	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations B Ø	1	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations C Ø	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations Ground	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Follow-up Action Required?	n	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	General Comments	1 BG op	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Maintenance Operations	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AF	198	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AL	198	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations This Read Vac	1	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Switching Operations	0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Unknown Operations	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	FE000879	Fence	686-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	49	°F
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	13.1	VDC
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	General Comments		
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Min Tap Position	6L	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Regulator As Left Counter	138231	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	12.9	VDC
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps A Ø	94.0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps B Ø	100.0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps C Ø	124.0	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 10:24	Distribution	Simmons Quarterly Inspection	R0994	Regulator	212-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 9:08	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps C Ø	150.0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations A Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations B Ø	0	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Vegetation	None	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations C Ø	0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations Ground	0	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Foundation Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Grounds in Place?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Maintenance Operations	0	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8472	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps B Ø	160.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps A Ø	170.0	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps C Ø	180.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Reading	.5214	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Max	45	°C
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	LTC Totalizer Reading	5005.44	kw
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	All Connections OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	Follow-up Action Required?	n	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	General Comments		
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Operation Checked?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushing Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/11/2022 12:49	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	General Comments		
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	General Comments		
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Regulator As Left Counter	93246	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	General Comments		
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AF	361	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AL	363	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations This Read Vac	2	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	General Comments	ok	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8133.12	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Switching Operations	2	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Unknown Operations	0	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Regulator As Left Counter	104330	
3/11/2022 11:36	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Max	30	°C
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/11/2022 10:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/11/2022 13:47	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
3/11/2022 13:46	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/11/2022 11:43	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations	4	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000249	Regulator	409-2218 C -Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000248	Regulator	409-2218 B -Line	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000247	Regulator	409-2218 A -Line	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0368	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Max	39	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps C Ø	100.0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps B Ø	100.0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps A Ø	100.0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations	3	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AF	216	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	162615	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AL	216	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations This Read Vac	1	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1244.16	kw
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations Ground	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Maintenance Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Maintenance Operations	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AF	205	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AL	205	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations This Read Vac	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Switching Operations	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Unknown Operations	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	General Comments	Brush growing into fence on back side. Needs trimmed back	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Switching Operations	1	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations B Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11169	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	General Comments		
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5137.92	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Found Counter	40161	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Left Counter	40161	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Current Tap Position	6L	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Max Tap Position	2L	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps B Ø	216.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps A Ø	216.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps C Ø	216.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11752	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCCControl	467-1	LTC Control Insp	All Connections OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCCControl	467-1	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCCControl	467-1	LTC Control Insp	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCCControl	467-1	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCCControl	467-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCCControl	467-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCCControl	467-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCCControl	467-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6218	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Min Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AL	386	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations This Read AM	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Switching Operations	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Switching Operations	2	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Unknown Operations	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations	2	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps A Ø	69.0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps B Ø	82.0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps C Ø	66.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations A Ø	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations B Ø	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Min Tap Position	11L	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Operations Since Last Insp	163	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Maintenance Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations	7	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations	8	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps A Ø	30.0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps B Ø	20.0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps C Ø	10.0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations A Ø	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations B Ø	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations C Ø	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations Ground	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Maintenance Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AF	53	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AL	55	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations This Read Vac	2	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AF	386	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Switching Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Maintenance Operations	2	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	General Comments	TC	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations	9	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps C Ø	34.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps B Ø	47.0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps A Ø	33.0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Max	55	°C
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	LTC Totalizer Reading	3867.84	kw
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Regulator As Left Counter	2199	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations	3	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	35	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	35	°C
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5352	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	2	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	237	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	237	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Unknown Operations	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Switching Operations	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations This Read Vac	2	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AL	204	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AF	204	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps A Ø	280.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps B Ø	240.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps C Ø	280.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Maintenance Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AF	266	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Unknown Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Switching Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations This Read Vac	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AL	408	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AF	408	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Maintenance Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AL	269	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations This Read Vac	3	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Switching Operations	3	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Unknown Operations	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations	6	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps A Ø	50.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps B Ø	35.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps C Ø	70.0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Reading	.8058	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	General Comments	Unknown/TC	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Maintenance Operations	1	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AF	192	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AL	192	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations This Read Vac	2	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Switching Operations	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Unknown Operations	1	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Unknown Operations	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Switching Operations	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations This Read Vac	2	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AL	200	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AF	200	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Maintenance Operations	2	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	General Comments	TC	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations C Ø	0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	2	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PF001331	PowerFuse	OR-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	General Comments	outside phase arcing horn broken off	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations Ground	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Maintenance Operations	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AF	471	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AL	471	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations This Read AM	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Present	35	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Switching Operations	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Unknown Operations	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	All Connections OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps C Ø	56.0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps B Ø	67.0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps A Ø	60.0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.8	VDC
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations	6	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations	32	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AL	206	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations This Read Vac	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Switching Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Unknown Operations	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations C Ø	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3513.60	kw
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations A Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps C Ø	179.0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps B Ø	176.0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps A Ø	172.0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations	7	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3660	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Operations Counter	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Maintenance Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AF	1006	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AL	1010	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations This Read Vac	4	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Switching Operations	4	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Unknown Operations	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations A Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Maintenance Operations	1	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	General Comments	3-6-22 AG/TC	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps C Ø	37.0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps B Ø	29.0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps A Ø	28.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Maintenance Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AF	206	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	36	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	21	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	36	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	36	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Unknown Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Leaks	None	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Switching Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2022-03-10 00:00:00.000000	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations This Read Oil	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AL	1091	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AF	1091	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Number of Ops last 9 Months	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Maintenance Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	16156	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Months Operations	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps B Ø	10.0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps A Ø	10.0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	General Comments	COUNTER SWITCH IN LTC CABINET NOT WORKING. STAYS ENERGIZED ALL THE TIME	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Found Counter	40593	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Left Counter	40493	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Max Tap Position	2L	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Min Tap Position	9L	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Operations Since Last Insp	95	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations C Ø	1	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations B Ø	1	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations A Ø	1	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps C Ø	80.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps B Ø	90.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps A Ø	80.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations	9	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps A Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps B Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps C Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations	8	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations	5	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Unknown Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps A Ø	20.0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Switching Operations	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations This Read Vac	2	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AL	220	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AF	220	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Unknown Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Switching Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations This Read Vac	3	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Unknown Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Switching Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations This Read Vac	9	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AL	161	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AL	620	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AF	620	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Maintenance Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	General Comments	a,b,c phase ioc	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AF	161	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Maintenance Operations	9	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCCControl	FM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCCControl	FM-TRANS 1	LTC Control Insp	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCCControl	FM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps A Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps B Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps C Ø	0.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Maintenance Operations	1	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AF	186	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AL	186	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations This Read Vac	1	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Switching Operations	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Unknown Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps B Ø	30.0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps C Ø	20.0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	*F
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Unknown Operations	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Switching Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations This Read Vac	1	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AL	208	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AF	208	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Maintenance Operations	1	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations A Ø	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations B Ø	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations C Ø	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations Ground	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps C Ø	21.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	*F
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps C Ø	7.0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps B Ø	0.0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps A Ø	0.0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations	4	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Max Tap Position	5R	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Min Tap Position	3L	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Unknown Operations	1	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Switching Operations	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations This Read Vac	2	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AL	152	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AF	152	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Maintenance Operations	1	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	General Comments	Unkown/TC	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps A Ø	560.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps B Ø	430.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps C Ø	450.0	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations	16	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps C Ø	15.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps A Ø	21.0	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Regulator As Left Counter	16993	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1593	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	LTC Totalizer Reading	7050.24	kw
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Max	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Present	30	°C
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Reading	.7344	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	General Comments		
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps A Ø	5.0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12387	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	98028	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations	3	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	lower drag hand will not reset	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Maintenance Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AF	169	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AL	169	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations This Read Vac	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Months Operations	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps A Ø	140.0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps B Ø	140.0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps C Ø	5.0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps B Ø	10.0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps C Ø	150.0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations Ground	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16L	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Left Counter	62100	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Found Counter	63199	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Regulator As Left Counter	36285	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps C Ø	100.0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations Ground	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Regulator As Left Counter	40020	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	General Comments	PT conduit broken at junctions.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Fault Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Pressure OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Leaks	None	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	All Connections OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Max	36	°C
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Operations Counter	25	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations A Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps C Ø	48.0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps B Ø	45.0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps A Ø	73.0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Unknown Operations	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Switching Operations	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations This Read Vac	1	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AL	276	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AF	276	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	All Identified and Legible?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35747	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Unknown Operations	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Maintenance Operations	1	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Switching Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations This Read AM	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AL	316	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AF	316	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Maintenance Operations	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Operating Linkage OK?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Live Parts Good Condition?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps C Ø	53.0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps A Phase V	16.19	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps B Phase V	16.19	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps C Phase V	16.19	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations A Ø	1	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations B Ø	1	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations C Ø	1	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Maintenance Operations	1	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AF	181	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AL	181	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations This Read Vac	4	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Switching Operations	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Unknown Operations	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps C Phase V	16.19	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Found Counter	693873	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2044.80	kw
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps C Ø	48.0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations	12	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps A Ø	33.0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps B Ø	35.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.40	MegaVars
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	.10	MegaVars
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	2.40	MegaWatts
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	40	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	40	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	40	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	General Comments	ok	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	LTC Totalizer Reading	4155.84	kw
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Reading	.5772	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations C Ø	1	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Maintenance Operations	3	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps C Ø	86.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps B Ø	64.0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Maintenance Operations	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AF	268	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AL	268	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps A Ø	88.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations	7	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Reading	.4344	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Unknown Operations	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Switching Operations	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations This Read Vac	2	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AL	204	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AF	204	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Maintenance Operations	1	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Operations Since Last Insp	222	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Min Tap Position	11L	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Max Tap Position	5L	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Current Tap Position	9L	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps B Ø	7.0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Left Counter	13227	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Found Counter	13220	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Operations Counter	36	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations This Read Vac	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Switching Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Unknown Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Found Counter	75259	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Left Counter	75259	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Current Tap Position	3L	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Min Tap Position	9L	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Operations Since Last Insp	194	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Operations Since Last Insp	309	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Max Tap Position	2R	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Left Counter	693882	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	General Comments	1-19-22AG/TC	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	General Comments	no spare fuses	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Present	16	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Max	31	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Reading	.1136	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Max	31	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations Ground	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations C Ø	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations B Ø	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations A Ø	1	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5331	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.4	VDC
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Regulator As Left Counter	4282	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	48	*F
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations A Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations B Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations C Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations Ground	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Maintenance Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AF	170	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AL	170	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations This Read Vac	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Switching Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Unknown Operations	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	9 Month Operations	10	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps C Ø	32.0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	49	°F
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	General Comments	METER WAS IN AN ERROR DUE TO LOW BATTERY	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations	7	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps A Ø	94.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps B Ø	61.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps C Ø	56.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps B Ø	23.0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps A Ø	19.0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations	6	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5778	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Maintenance Operations	3	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AF	245	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AL	245	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations This Read Vac	3	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Switching Operations	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Unknown Operations	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Switching Operations	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Unknown Operations	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations	5	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AF	249	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AL	249	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations This Read Vac	4	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	General Comments	bathroom needs to be fixed	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations A Ø	0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Maintenance Operations	1	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AF	181	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AL	181	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations This Read Vac	1	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Switching Operations	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Unknown Operations	0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Present	25	°C
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	LTC Totalizer Reading	3456.00	kw
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	General Comments		Nitro Press Gauge doesnt seem correct
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps A Ø	27.0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps B Ø	23.0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps C Ø	31.0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2773.44	kw
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Winding Temp Present	0	°C
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Reading	.3600	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations A Ø	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations	11	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps A Ø	110.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps B Ø	120.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps C Ø	85.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations A Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations C Ø	0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32250	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations A Ø	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Reading	.6808	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps C Ø	34.0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Unknown Operations	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Switching Operations	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations This Read Vac	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AL	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AF	320	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Maintenance Operations	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations Ground	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations C Ø	0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Operations Counter	102	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Maintenance Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AF	211	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AL	213	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations This Read Vac	2	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Switching Operations	2	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Unknown Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Unknown Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Switching Operations	4	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations This Read Vac	4	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AL	390	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AF	390	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Maintenance Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Present	40	°C
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Max	40	°C
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	LTC Totalizer Reading	6535.68	kw
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations	11	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations	21	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Min Tap Position	3R	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps A Ø	15.0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps B Ø	23.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations	10	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps A Ø	150.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps B Ø	150.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps C Ø	120.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations A Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations Ground	0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33831	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations A Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations B Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations C Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations Ground	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Maintenance Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AF	201	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AL	201	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations This Read Vac	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Switching Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Unknown Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps C Ø	73.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps B Ø	71.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps A Ø	82.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	General Comments	SPR system not in use	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	General Comments	Drag hands not operating	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Current Tap Position	3R	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Maintenance Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AF	203	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AL	205	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations This Read Vac	2	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Switching Operations	2	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Unknown Operations	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.6	VDC
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.6	VDC
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps C Ø	23.0	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:02	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations	8	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps A Ø	120.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps B Ø	100.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps C Ø	100.0	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	All Connections OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations	2	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps A Ø	120.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations A Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Maintenance Operations	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	357.60	kw
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	General Comments	Released vacuum to take DGA's	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations	13	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	65	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AL	1241.0	VAC
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	General Comments		
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	All Connections OK?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps A Ø	3.7	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps B Ø	.6	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations	13	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	7	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	71	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Operations Counter	99994	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps B Ø	125.0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps C Ø	210.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Unknown Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Switching Operations	1	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations This Read Vac	3	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AL	220	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AF	220	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Maintenance Operations	2	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AF	190	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AL	192	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations This Read Vac	4	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Switching Operations	4	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Unknown Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	General Comments		
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations	28	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps A Ø	77.0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps B Ø	82.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps C Ø	65.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps A Ø	38.0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps B Ø	53.0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps C Ø	44.0	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Maintenance Operations	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations Ground	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations C Ø	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations B Ø	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations A Ø	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations Ground	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations C Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations B Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations A Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps C Ø	75.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps B Ø	67.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps A Ø	53.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	General Comments	Released vacuum to take DGA's	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps C Ø	148.0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps B Ø	137.0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps A Ø	168.0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations C Ø	0	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations	17	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Unknown Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations This Read Vac	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AL	189	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AF	189	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Maintenance Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations B Ø	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Unknown Operations	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Switching Operations	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations This Read Vac	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AL	242	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AF	242	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps B Ø	33.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps C Ø	0.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps B Ø	0.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps A Ø	31.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations	0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4470	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	LTC Totalizer Reading	2085.12	kw
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps A Ø	0.0	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Max	35	°C
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Present	25	°C
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 10:29	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations A Ø	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Present	18	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Max	29	°C
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	General Comments	Released vacuum to take DGA's	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps C Ø	30.0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations Ground	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Left Counter	274988	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	General Comments	Needs bushing covers	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	General Comments	TC	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Maintenance Operations	3	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AF	248	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AL	248	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations This Read Vac	3	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Switching Operations	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	52	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Unknown Operations	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Reading	.6456	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Found Counter	274988	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations C Ø	0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps A Ø	130.0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations C Ø	0	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	9 Month Operations	0	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Found Counter	17584	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Left Counter	17595	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Current Tap Position	1L	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Max Tap Position	5R	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Min Tap Position	4L	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Operations Since Last Insp	380	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 9:51	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps A Ø	120.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps B Ø	130.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps C Ø	110.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations	1	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps A Ø	75.0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps B Ø	74.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	LTC Totalizer Reading	6197.76	kw
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps C Ø	140.0	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps B Ø	130.0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Found Counter	12120	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Left Counter	12127	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations Ground	0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Max Tap Position	2R	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-.5	psi
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Operations Since Last Insp	354	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Unknown Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Switching Operations	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations This Read Vac	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AL	44	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AF	44	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5886	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Maintenance Operations	0	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations Ground	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations C Ø	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations B Ø	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	General Comments		
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	761	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14L	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	All Connections OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	All Connections OK?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Regulator As Left Counter	13548	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Regulator As Left Counter	35101	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1412.64	kw
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations This Read Vac	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	4	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Unknown Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Switching Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations	19	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AL	190	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps A Ø	62.0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps B Ø	31.0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AF	190	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Maintenance Operations	0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps C Ø	42.0	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	General Comments		
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11886	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps C Ø	10.0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps B Ø	30.0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps A Ø	30.0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations	11	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Left Counter	121330	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Found Counter	121330	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.1	VDC
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.4	VDC
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	57	*F
3/10/2022 11:28	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	General Comments		
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Maintenance Operations	0	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AF	313	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 9:17	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 14:30	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AL	317	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Reading	.5808	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Unknown Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations Ground	0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Regulator As Left Counter	14616	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 13:43	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps C Ø	90.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps B Ø	100.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps A Ø	90.0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	General Comments	a,b,c, phase ioc	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Maintenance Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AF	36	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AL	36	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations This Read Vac	12	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations Ground	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations C Ø	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations B Ø	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations A Ø	0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 14:57	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Months Operations	0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Regulator As Left Counter	4425	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Switching Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	General Comments		
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Maintenance Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AF	203	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AL	203	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Switching Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/18/2022 8:24	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Found Counter	44806	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Left Counter	44816	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Current Tap Position	8L	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Max Tap Position	3L	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Operations Since Last Insp	278	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 11:04	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations	1	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps B Ø	33.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps A Ø	31.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps A Ø	70.0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps B Ø	84.0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps C Ø	109.0	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 14:22	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps C Ø	30.0	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	9 Month Operations	1	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps A Ø	350.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps B Ø	340.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps C Ø	360.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Maintenance Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Operations Counter	52	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	General Comments		
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/10/2022 12:59	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AF	69	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AL	69	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Switching Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Unknown Operations	0	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Unknown Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Switching Operations	2	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations This Read Vac	2	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations Counter AL	170	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Unknown Operations	0	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations Counter AF	168	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Maintenance Operations	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations B Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations C Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Switching Operations	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps C Phase V	44.72	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps C Ø	80.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps B Ø	80.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps A Ø	80.0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	9 Month Operations	25	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Present	45	°C
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	General Comments		
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps A Ø	27.6	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps B Ø	33.6	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	LTC Totalizer Reading	5575.68	kw
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations Ground	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AF	7	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AL	7	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations This Read Vac	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps C Ø	32.1	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	794	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Follow-up Action Required?	n	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Maintenance Operations	0	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations Ground	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:45	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps C Ø	75.0	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	General Comments		
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations C Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations B Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations A Ø	0	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	General Comments		
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations A Ø	4	
3/10/2022 7:30	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations B Ø	4	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations C Ø	4	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations A Ø	0	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 13:37	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 8:11	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/10/2022 9:46	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/10/2022 8:52	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	11461	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	11461	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	12	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	55	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Unknown Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Switching Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations This Read Vac	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations Ground	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AL	330	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AF	330	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Maintenance Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations Ground	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations C Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations B Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations A Ø	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AF	275	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AL	275	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Current Tap Position	5L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Min Tap Position	14L	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Operations Since Last Insp	298	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations	1	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Switching Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations This Read Vac	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations Counter AL	167	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Left Counter	8060	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Found Counter	8060	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps A Ø	5.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps B Ø	5.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Left Counter	65140	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Found Counter	65131	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps C Ø	5.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Switching Operations	2	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations This Read Vac	2	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Found Counter	12828	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Left Counter	12828	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps A Ø	219.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps B Ø	221.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps C Ø	210.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations A Ø	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations B Ø	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations Ground	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations C Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Current Tap Position	1L	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Max Tap Position	4R	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Min Tap Position	6L	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Operations Since Last Insp	360	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps A Ø	110.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations	5	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Found Counter	204685	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Left Counter	204695	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Current Tap Position	1L	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Max Tap Position	1R	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Min Tap Position	12L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Operations Since Last Insp	672	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations This Read AM	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Unknown Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps C Ø	100.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps B Ø	100.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PF001324	PowerFuse	LN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PF001323	PowerFuse	LN-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Unknown Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Switching Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations This Read Vac	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AL	6	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AF	6	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Maintenance Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Unknown Operations	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Switching Operations	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations This Read Vac	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations Counter AL	153	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Operations Counter AF	153	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Maintenance Operations	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Reading	.9960	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Present	35	°C
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Max	55	°C
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	LTC Totalizer Reading	7171.20	kw
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/9/2022 16:02	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Visible, and Proper?	y	
3/9/2022 16:02	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps C Ø	132.0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps B Ø	106.0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Amps A Ø	81.0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Readings	9 Month Operations	3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Unknown Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Switching Operations	5	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps C Ø	92.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps B Ø	85.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps A Ø	95.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	9 Month Operations	3	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001790	BreakerVacuum	361-0756	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	109	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	109	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	122	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	122	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	250.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	250.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	250.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Unknown Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	LTC Totalizer Reading	5623.20	kw
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Max	44	°C
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Present	35	°C
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Reading	.7810	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Switching Operations	2	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations This Read Vac	2	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Months Operations	13	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps A Ø	132.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps B Ø	131.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps C Ø	127.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations A Ø	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations B Ø	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AF	732	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AL	732	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations This Read AM	2	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AL	173	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AF	173	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Maintenance Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TRF POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	300.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	300.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	300.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	118	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	118	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Max	52	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Maintenance Operations	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations	1	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps A Ø	10.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps B Ø	10.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps C Ø	10.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps C Ø	0.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps B Ø	0.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps A Ø	0.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	144	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	144	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	General Comments		
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	FE000878	Fence	323-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Regulator As Left Counter	54762	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations	1	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps A Ø	144.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps B Ø	160.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps C Ø	132.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations A Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations B Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations C Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Operations Counter AF	167	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps C Ø	96.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps B Ø	102.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps A Ø	67.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	9 Month Operations	23	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Maintenance Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	121	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	121	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AF	324	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AL	324	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Switching Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2022-12-02 00:00:00.000000	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	9 Month Operations	1	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations	7	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps A Ø	40.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps B Ø	50.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps C Ø	70.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations This Read Vac	5	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AL	198	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AF	198	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Maintenance Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Regulator As Left Counter	53429	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	573	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	573	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Found Counter	80521	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Left Counter	80531	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Current Tap Position	7L	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Max Tap Position	3L	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Min Tap Position	14L	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Operations Since Last Insp	316	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	75.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AF	233	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AL	139	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AF	139	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Vegetation	None	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AL	233	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps A Ø	122.0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps B Ø	68.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Amps C Ø	98.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	low oil level	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	4	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AL	144	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AF	144	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Low	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	100.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	100.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	100.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	1	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps C Ø	270.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps B Ø	130.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps A Ø	218.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations	3	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations This Read AM	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	5	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	5	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B Ø	80.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C Ø	50.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Maintenance Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AF	185	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AL	185	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations This Read Vac	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Switching Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Unknown Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	502	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	502	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations This Read AM	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Switching Operations	1	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations This Read Vac	1	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AL	411	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AF	411	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations This Read Vac	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Switching Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	9 Month Operations	3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps A Ø	51.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps B Ø	46.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps C Ø	54.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations A Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations B Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations C Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations Ground	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A Ø	50.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Max Tap Position	1L	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	215	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	215	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Restroom Clean & OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps C Ø	80.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps B Ø	86.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps A Ø	93.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AL	476	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AF	476	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Found Counter	71819	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Left Counter	71819	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Time Delay	45	Seconds
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations	2	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.30	MegaWatts
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.10	MegaWatts
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps A Ø	333.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps B Ø	360.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps C Ø	425.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/9/2022 10:55	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersonstown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Maintenance Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Found Counter	76442	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Left Counter	76446	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Current Tap Position	2L	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Max Tap Position	3R	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Operations Since Last Insp	512	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	All Connections OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Time Delay	45	Seconds
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	All Connections OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	Needs Repair	note in comments if present
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.4	amps
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.9	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.9	VDC
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations	3	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps A Ø	127.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps B Ø	118.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps C Ø	148.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Found Counter	261733	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Left Counter	261733	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Unknown Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Switching Operations	2	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations This Read Vac	2	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AL	260	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AF	260	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Maintenance Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations C Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	76	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #'s
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AF	247	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AL	247	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Unknown Operations	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/9/2022 13:17	Distribution	Somers2 2 Quarterly Inspection	LTCC000701	LTCCControl	779-1	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Evidence of Insects	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Time Delay	45	Seconds
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments	neg ground	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations Counter AF	196	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Maintenance Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	99972	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps C Ø	134.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps B Ø	87.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	General Comments	ALL CELLS NEED WATER	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Unknown Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Switching Operations	2	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations This Read Vac	2	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations Counter AL	196	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	General Comments	cant read gauge	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Max Tap Position	3R	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Min Tap Position	9L	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations	7	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps A Ø	200.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps B Ø	190.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps C Ø	190.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps A Phase V	15.20	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps B Phase V	15.20	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps C Phase V	15.20	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Maintenance Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AF	232	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AL	234	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations This Read Vac	5	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Switching Operations	2	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Unknown Operations	3	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Operations Since Last Insp	709	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps A Ø	106.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	9 Month Operations	3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AL	436	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AF	436	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	99972	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps C Ø	58.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps B Ø	64.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps A Ø	62.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Months Operations	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Found Counter	19224	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Left Counter	19227	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Current Tap Position	2L	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	9 Month Operations	2	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps A Ø	49.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations	1	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps A Ø	190.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps B Ø	200.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps C Ø	110.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations A Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations B Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations C Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations Ground	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Maintenance Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AF	729	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AL	729	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations This Read Vac	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Switching Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	0	°C
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Left Counter	15343	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Found Counter	15343	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Unknown Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Switching Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations This Read Vac	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AL	179	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AF	179	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Maintenance Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations Ground	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations C Ø	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations B Ø	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations A Ø	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps C Ø	13.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps B Ø	13.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps A Ø	13.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y2 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y2 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y1 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	9 Month Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Maintenance Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AF	288	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AL	290	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	TV Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	TV Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations This Read Vac	7	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Switching Operations	2	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Totalizer Meter Multiplier	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Top Oil Temperature Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Top Oil Temperature Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Oil Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Oil Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LV Winding Temp Present	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LV Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	HV Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	HV Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H3 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H3 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H2 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H2 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H1 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	H1 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	0	°C
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations	9	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps B Ø	42.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps C Ø	26.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	326	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	326	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps A Ø	20.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps B Ø	25.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps C Ø	10.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps B Phase V	25.33	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations B Ø	5	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps C Ø	500.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps B Ø	500.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps A Ø	490.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	LTC Totalizer Reading	3421.44	kw
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Max	26	°C
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Present	26	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Reading	.3564	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Unknown Operations	3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations This Read AM	3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AL	451	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AF	451	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps C Phase AM	28.64	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	101	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	101	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations	5	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps A Ø	135.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Maintenance Operations	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AF	206	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AL	209	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations This Read Vac	3	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Switching Operations	3	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Unknown Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BCH001412	Charger	570-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps B Phase AM	28.64	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps A Phase AM	28.64	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps C Ø	134.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps B Ø	103.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps A Ø	161.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Months Operations	3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	2170	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	48	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Min Tap Position	14L	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Max Tap Position	9L	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Current Tap Position	10L	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Unknown Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Switching Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations This Read Vac	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AL	343	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AF	343	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Maintenance Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps B Ø	152.0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps C Ø	140.0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Maintenance Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AF	189	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AL	189	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Switching Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	1	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	door next to trans will not latch at bottom	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Max	67	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Oil Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Oil Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LV Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LV Winding Temp Max	0	°C
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Unknown Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Switching Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations This Read Vac	1	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AL	182	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AF	182	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Maintenance Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations C Ø	1	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps C Ø	110.0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps B Ø	131.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Maintenance Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	40	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	73	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	40	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	73	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	39	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	73	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Present	36	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	TV Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	TV Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Totalizer Meter Multiplier	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Top Oil Temperature Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Top Oil Temperature Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	146	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps C Ø	50.0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps B Ø	30.0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps A Ø	45.0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	9 Month Operations	4	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AF	349	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AL	349	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Unknown Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AF	756	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AL	756	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps A Ø	118.0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations	10	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Unknown Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Switching Operations	2	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations This Read Vac	2	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AL	236	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AF	234	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Maintenance Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations Ground	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations C Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations B Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations A Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	HV Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	HV Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H3 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H3 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H2 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H2 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H1 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	H1 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	146	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AF	163	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AL	163	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations This Read Vac	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Switching Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations	1	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps A Ø	80.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps B Ø	10.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps C Ø	40.0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	487	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	487	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations A Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations B Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations C Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations Ground	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 13:17	Distribution	Somers2 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations A Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations B Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations C Ø	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations Ground	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Maintenance Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	247.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	242.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	250.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	9	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000268	WithLTC	MG-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Vegetation	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y2 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y1 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X3 Winding Temp Present	0	°C
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50677	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X3 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X2 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X2 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X1 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	X1 Winding Temp Max	0	°C
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Switching Operations	1	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations This Read Vac	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	2	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	138.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	132.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	134.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AL	217	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AF	217	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps C Ø	90.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps B Ø	120.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps A Ø	90.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations	4	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps A Ø	.3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps B Ø	.3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps C Ø	4.2	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000267	WithLTC	MG-TRANS 7	LTC Transformer Readings	Y2 Winding Temp Present	0	°C
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations A Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations B Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations Ground	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AL	475	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AF	475	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Present	24	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Max	34	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Present	22	°C
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	General Comments		
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	General Comments		
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1609.92	kw
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Max	38	°C
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0062	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	LTC Totalizer Reading	1518.72	kw
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Present	25	°C
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Reading	.4746	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	9 Month Operations	4	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps A Ø	55.0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps B Ø	50.0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps C Ø	55.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AL	180	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations This Read Vac	3	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Switching Operations	3	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Present	21	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Max	30	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Present	22	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Max	32	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps C Ø	160.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps B Ø	140.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps A Ø	140.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AL	345	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AF	345	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Maintenance Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Max	34	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Maintenance Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AF	177	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Present	23	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Max	32	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Max	32	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations	4	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps A Ø	50.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps B Ø	45.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps C Ø	60.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Unknown Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps C Ø	67.0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps B Ø	70.0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps A Ø	43.0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations	2	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Switching Operations	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations This Read Vac	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AL	285	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AF	285	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Maintenance Operations	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	General Comments		
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations Ground	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations C Ø	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations B Ø	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations A Ø	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps C Ø	72.0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps B Ø	120.0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps A Ø	84.0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations	5	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7788	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	121.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	122.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	124.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	General Comments	Main tank is a little low	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	LTC Totalizer Reading	7527.60	kw
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Max	49	°C
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Present	44	°C
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Unknown Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	All Connections OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Reading	1.0455	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	General Comments	Some moisture in cabinet	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Maintenance Operations	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Moisture and Leak Free?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AF	482	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AL	482	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Switching Operations	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Unknown Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	1	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	80.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Unknown Operations	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Switching Operations	2	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations This Read Vac	2	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AL	275	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AF	273	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Maintenance Operations	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	100.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	100.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations	1	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	fence is rusty with wash out spots on creek side mentioned in previous inspection. some gaps in wire and multiple bends on posts.	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	186	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations	1	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps A Ø	215.0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps B Ø	283.0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps C Ø	219.0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AF	186	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AL	186	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps B Ø	90.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps A Ø	90.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations	4	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Unknown Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Switching Operations	2	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations This Read Vac	2	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AL	199	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AF	199	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	204	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	13	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Left Counter	7902	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	520	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	520	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations This Read AM	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations	8	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps A Ø	40.0	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps B Ø	50.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps C Ø	95.0	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps C Ø	70.0	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jefferson town Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Time Delay	45	Seconds
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps C Ø	117.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps B Ø	116.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps A Ø	76.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Maintenance Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AF	234	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AL	236	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations This Read Vac	2	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Switching Operations	2	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AF	371	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AL	371	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1878	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1878	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	All Connections OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Found Counter	23454	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Left Counter	23454	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AF	318	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AL	318	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	29	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	8	°C
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	General Comments	There needs to be a yard light installed.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Found Counter	11138	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Left Counter	11149	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Current Tap Position	1L	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Max Tap Position	1R	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Min Tap Position	9L	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Operations Since Last Insp	455	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Max	53	°C
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Present	35	°C
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Reading	.7040	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Max	36	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	36	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	36	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	36	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #'s
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.3	VDC
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.2	VDC
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AL	426	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AF	426	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps A Ø	0.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	LTC Totalizer Reading	5068.80	kw
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations B Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AF	359	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AL	359	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps A Ø	241.0	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	All Connections OK?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	LTC Operation Checked?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	VRR Base Voltage AF	125.4	VAC
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	VRR Base Voltage AL	125.4	VAC
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	LTCC000948	LTCControl	343-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	70.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Months Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps A Ø	39.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps B Ø	26.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps C Ø	35.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations	16	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Unknown Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	LTC Totalizer Reading	11145.60	kw
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Reading	1.1610	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps B Ø	38.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps A Ø	55.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations	2	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	1	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps C Ø	38.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations Ground	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AF	163	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AL	163	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	161	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	161	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	505	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	505	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Regulator As Left Counter	67433	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	General Comments		
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	472	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	472	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	50.0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations This Read AM	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	378	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	378	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	100.0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	80.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	100.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	1	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	40	*F
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Regulator As Left Counter	70193	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	General Comments		
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Switching Operations	2	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Unknown Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	General Comments		posts and rails getting rusty, cudzu and vegetation growing up fence in back corner of station
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Months Operations	1	LED lights?
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Unknown Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps A Ø	98.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps B Ø	131.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps C Ø	122.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Switching Operations	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AL	336	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AF	336	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Moisture and Leak Free?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Maintenance Operations	0	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	General Comments	Some moisture in cabinet	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations A Ø	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AF	276	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AL	276	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7476.48	kw
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BAT001546	Battery	773-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	BCH001475	Charger	773-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AF	242	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AL	242	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	685	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	685	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	9 Month Operations	4	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps A Ø	110.0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps B Ø	115.0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps C Ø	95.0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Months Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	247	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	247	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps A Ø	27.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps B Ø	43.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps C Ø	65.0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations A Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations B Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Maintenance Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AF	387	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AL	387	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations This Read Vac	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Switching Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	1.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	1.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps B Ø	234.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps C Ø	244.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps A Ø	12.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps B Ø	13.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps C Ø	12.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations A Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations A Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations B Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations C Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations Ground	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Current Tap Position	5L	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Max Tap Position	3R	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Min Tap Position	11L	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Operations Since Last Insp	836	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Maintenance Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AF	183	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AL	185	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations This Read Vac	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	43	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	43	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AF	246	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AL	246	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Switching Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Found Counter	20496	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Left Counter	20500	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	General Comments	Limbs growing over top of fence	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	LTC0000952	LTCControl	802-1	LTC Control Insp	All Connections OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	LTC0000952	LTCControl	802-1	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	LTC0000952	LTCControl	802-1	LTC Control Insp	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	LTC0000952	LTCControl	802-1	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	LTC0000952	LTCControl	802-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	LTC0000952	LTCControl	802-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	LTC0000952	LTCControl	802-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	LTC0000952	LTCControl	802-1	LTC Control Insp	VRR Time Delay	40	Seconds
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	General Comments	2 blown LA on A and B phase...one structure leg foundation is crumbling and another is starting to	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	General Comments		
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Switching Operations	2	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Unknown Operations	0	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	LTC Totalizer Reading	8899.20	kw
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Present	31	°C
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Reading	.9270	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Min Tap Position	16L	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Max Tap Position	16R	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC As Left Counter	898	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	LTC As Found Counter	898	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AF	408	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Current Tap Position	1L	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Left Counter	21693	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Found Counter	21690	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AL	410	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	117	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	117	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations This Read Vac	2	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Switching Operations	2	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
3/9/2022 12:27	Distribution	Somers1 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	All Connections OK?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	147	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	3	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	LTC Totalizer Reading	6577.92	kw
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Present	28	°C
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Operations Since Last Insp	718	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Min Tap Position	12L	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Max Tap Position	1R	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	5	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations	18	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations A Ø	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps A Ø	61.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps B Ø	68.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps C Ø	65.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps C Ø	116.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps B Ø	155.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps A Ø	138.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	9 Month Operations	1	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	150	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	150	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	1	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	41	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	41	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	34.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	32.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	34.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Unknown Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Switching Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations This Read Vac	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AL	200	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AF	200	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Maintenance Operations	0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	550.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	550.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	550.0	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	All Connections OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	General Comments		
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations	4	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps A Ø	40.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps B Ø	50.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps C Ø	70.0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	75.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations	4	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps A Ø	250.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps B Ø	280.0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps C Ø	280.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1432	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1432	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	168	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	168	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Regulator As Left Counter	68426	
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/9/2022 14:24	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Maintenance Operations	0	
3/10/2022 6:21	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Time Delay	0	Seconds
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	All Connections OK?	y	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 10:47	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AF	222	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AL	225	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations This Read Vac	2	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	147	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCC000897	LTCControl	MG-TRANS 6	LTC Control Insp	LTC Operation Checked?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 12:27	Distribution	Somers1 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	General Comments		
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 10:12	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	General Comments		
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/9/2022 11:43	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Maintenance Operations	0	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	238	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	238	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations C Ø	0	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Max	37	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Present	24	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	General Comments		
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations Ground	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Operations Since Last Insp	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Present	30	°C
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Max	40	°C
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Reading	.8208	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Present	30	°C
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Max	30	°C
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000116	LTCMechanism	MG-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	LTC Totalizer Reading	11819.52	kw
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations B Ø	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations C Ø	0	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	All Connections OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Time Delay	30	Seconds
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Reading	.4160	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	156	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	156	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	55.0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	55.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	55.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	General Comments		
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Grounds in Place?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Maintenance Operations	0	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	37	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	37	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	37	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Found Counter	7902	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	697	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	697	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/9/2022 12:53	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Reading	.6852	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Present	45	°C
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Max	57	°C
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	LTC Totalizer Reading	2496.00	kw
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Vegetation	None	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	General Comments		
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Operations Since Last Insp	802	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Min Tap Position	14L	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Max Tap Position	6R	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Current Tap Position	2L	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Left Counter	22485	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Found Counter	22485	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	General Comments		
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
3/9/2022 12:27	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	60.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/9/2022 11:57	Distribution	Hamblin Quarterly Inspection	BK001791	BreakerVacuum	361-0757	VCB Readings	Unknown Operations	0	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Reading	.9612	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	20	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Time Delay	30	Seconds
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 10:55	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Operation Checked?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	General Comments		
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	All Connections OK?	y	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 9:01	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Min Tap Position	16L	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	134	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	134	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/9/2022 11:27	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/9/2022 11:31	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.700	millivolts
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	All Connections OK?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	Follow-up Action Required?	n	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	LTC Operation Checked?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTC0000896	LTCControl	MG-TRANS 7	LTC Control Insp	VRR Time Delay	0	Seconds
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	Follow-up Action Required?	n	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/9/2022 13:17	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	General Comments		
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	General Comments		
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Present	45	°C
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Max	50	°C
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC As Found Counter	916	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC As Left Counter	916	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/9/2022 13:24	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	LTC Totalizer Reading	9227.52	kw
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/10/2022 9:28	Distribution	Magazine Quarterly Inspection	LTCM000115	LTCMechanism	MG-TRANS 7	LTC Counter Readings	LTC Max Tap Position	16R	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	SEVERAL CAPS ARE CRACKED NEEDS REPLACED	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations A Ø	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AL	230	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AF	230	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	General Comments	OK	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations	6	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	General Comments	no neighboring fence	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations B Ø	0	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Regulator As Left Counter	205849	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Maintenance Operations	1	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps A Ø	204.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps B Ø	208.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps C Ø	185.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AL	147	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AF	147	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps C Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps B Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps A Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations B Ø	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations C Ø	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations Ground	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Present	17	°C
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Max	17	°C
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	563.52	kw
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.4394	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AL	146	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AF	146	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3454.56	kw
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Maintenance Operations	1	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.0	VDC
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AL	174	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations This Read Vac	4	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.0	VDC
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Unknown Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Switching Operations	4	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations	3	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Unreadable	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps A Ø	70.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps B Ø	70.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps C Ø	70.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations B Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations Ground	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Unknown Operations	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations Ground	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Unknown Operations	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations C Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations B Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations A Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Maintenance Operations	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps C Ø	150.0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps B Ø	110.0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps A Ø	100.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AF	161	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AL	161	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Unknown Operations	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Switching Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations This Read Vac	1	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3522	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AF	170	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations	1	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Found Counter	82881	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Left Counter	82881	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Current Tap Position	9L	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Max Tap Position	7L	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Min Tap Position	13L	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Operations Since Last Insp	73	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Regulator As Left Counter	33856	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.2	volts
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Min Tap Position	10L	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps A Ø	5.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps B Ø	5.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps C Ø	40.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations	4	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Found Counter	41942	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Left Counter	41942	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	if no, which cells in comments
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	494	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Regulator As Left Counter	28505	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.3	volts
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Min Tap Position	10L	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Max Tap Position	1L	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	*F
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51376	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Current Tap Position	4L	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Maintenance Operations	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AF	222	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AL	222	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Switching Operations	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Unknown Operations	0	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations	1	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Unknown Operations	0	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Unknown Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Switching Operations	2	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations This Read Vac	2	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AL	568	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AF	556	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Maintenance Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations Ground	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations C Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations B Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations A Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps A Ø	21.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.6546	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	69.5	VDC
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	70.0	VDC
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Regulator As Left Counter	83692	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AF	144	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AL	144	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations This Read Vac	1	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Switching Operations	0	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps C Ø	153.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps B Ø	116.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps A Ø	117.0	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Regulator As Left Counter	88270	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps C Ø	133.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps B Ø	120.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps A Ø	122.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Unknown Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Switching Operations	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AL	220	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AF	220	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps C Ø	36.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps B Ø	36.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps A Ø	57.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps C Ø	60.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps B Ø	60.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps A Ø	60.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations	10	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Present	48	°C
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3971.04	kw
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Unknown Operations	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	General Comments	Oil level low	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AL	153	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AF	153	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Oil Level	Low	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Regulator As Left Counter	106468	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Regulator As Left Counter	300744	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Current Tap Position	12L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4737.60	kw
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Current Tap Position	8L	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Max Tap Position	5L	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Max	41	°C
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.9740	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Operations Since Last Insp	187	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps C Ø	171.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps B Ø	160.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps A Ø	187.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations	1	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Operations Counter	50	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	General Comments	Need to add counters for each phase now that new control has been installed.	50/49/52
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps C Ø	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps B Ø	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps A Ø	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty C Ph V	.41	%
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty B Ph V	.41	%
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty A Ph V	.41	%
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations	2	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Current Tap Position	5L	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Max Tap Position	10R	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Regulator As Left Counter	65491	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Unknown Operations	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Switching Operations	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AL	164	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AF	164	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Maintenance Operations	0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Present	41	°C
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Unknown Operations	1	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Switching Operations	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations This Read Vac	2	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AL	120	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AF	120	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	General Comments	Breaker is offline	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations B Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Regulator As Left Counter	125037	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	60	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	25	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	General Comments	Counter and position indicator do not work.	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79892	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Regulator As Left Counter	174171	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Found Counter	86438	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Left Counter	86438	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	General Comments	Skirt is broken on bottom insulator of C phase fuse holder.	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	30	°C
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps C Ø	23.0	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps A Ø	31.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps A Ø	54.0	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps B Ø	38.0	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps C Ø	67.0	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	LTC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AL	203	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations This Read Vac	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Switching Operations	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Unknown Operations	0	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations	5	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps A Ø	155.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps B Ø	200.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps C Ø	260.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Operations Counter	29	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations A Ø	0	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BCH001534	Charger	418-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations Ground	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Unknown Operations	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Switching Operations	3	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations This Read Vac	3	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AL	212	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AL	143	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AF	143	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Maintenance Operations	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AF	209	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Maintenance Operations	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Operations Counter	12	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations A Ø	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations B Ø	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations C Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BCH001537	Charger	797-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Unknown Operations	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Switching Operations	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations	9	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps A Ø	120.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps B Ø	100.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps C Ø	130.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Regulator As Left Counter	30178	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	BAT001609	Battery	797-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	BAT001606	Battery	418-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations	2	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps A Ø	70.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	121.9	volts
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Regulator As Left Counter	22595	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Maintenance Operations	1	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations Ground	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations C Ø	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations B Ø	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations A Ø	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps C Phase V	4.69	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Regulator As Left Counter	30272	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations B Ø	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations A Ø	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps C Ø	50.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps B Ø	55.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps A Ø	50.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations	7	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations A Ø	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations B Ø	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations C Ø	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations Ground	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Maintenance Operations	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AF	203	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	All Connections OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Operation Checked?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps C Ø	150.0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps B Ø	90.0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps A Ø	120.0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations	3	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps B Ø	60.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps C Ø	55.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Unknown Operations	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Switching Operations	3	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations This Read Vac	3	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AL	200	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AF	197	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Maintenance Operations	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	General Comments	50	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations Ground	0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations C Ø	0	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AF	185	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Maintenance Operations	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments	Breaker is out of service	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Operations Counter	62	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.9	VDC
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	13.9	VDC
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AF	413	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AF	160	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AL	160	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Unknown Operations	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations A Ø	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps C Ø	140.0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps B Ø	120.0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps A Ø	150.0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations	2	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Rust	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations This Read Vac	1	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AL	413	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Unknown Operations	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Switching Operations	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AL	185	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	General Comments	fance fabric and posts rusty	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps C Ø	0.0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps B Ø	0.0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps A Ø	0.0	
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:04	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Regulator As Left Counter	66474	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps B Ø	25.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	152	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	152	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Regulator As Left Counter	67229	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	2	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	2	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Unknown Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	4	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Unknown Operations	0	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Regulator As Left Counter	58868	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Operations Counter	455	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps C Ø	34.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71855	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Unknown Operations	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Switching Operations	1	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations	1	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps A Ø	499.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps B Ø	485.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps C Ø	494.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps C Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps B Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps A Ø	0.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Regulator As Left Counter	79012	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Unknown Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AL	372	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AF	372	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	General Comments	OK	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1800.00	kw
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations B Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7500	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Regulator As Left Counter	118486	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Regulator As Left Counter	67719	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2445.12	kw
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6792	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Regulator As Left Counter	209938	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	General Comments	wildlife prot needed	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations C Ø	0	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations A Ø	0	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Unknown Operations	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Switching Operations	4	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations This Read Vac	4	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AL	134	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AF	130	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Maintenance Operations	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations Ground	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations C Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations B Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations A Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps C Ø	110.0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps B Ø	120.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps A Ø	100.0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations	3	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations	1	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Foundation Condition	Cracked	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	All Connections OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Operation Checked?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Unknown Operations	0	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Switching Operations	0	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations This Read Vac	0	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AL	137	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AF	137	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Maintenance Operations	0	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	LTC Totalizer Reading	2473.92	kw
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps A Ø	278.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Unknown Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Switching Operations	2	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations This Read Vac	2	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AL	122	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AF	120	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Maintenance Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations	8	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps B Ø	277.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps C Ø	264.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations	0	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations Ground	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps A Ø	133.0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps B Ø	163.0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps C Ø	149.0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps C Ø	25.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps B Ø	25.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps A Ø	25.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations	13	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	All Connections OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations A Ø	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations B Ø	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations C Ø	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations Ground	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	General Comments	BFTC	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Maintenance Operations	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AF	187	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AL	187	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations This Read Vac	1	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Switching Operations	1	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Unknown Operations	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Operation Checked?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Reading	1.0308	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Present	39	°C
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Max	45	°C
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Maintenance Operations	1	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AF	9	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AL	10	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations This Read Vac	1	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Switching Operations	0	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Unknown Operations	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Unknown Operations	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Switching Operations	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AL	99958	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AF	99958	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Unknown Operations	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Switching Operations	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations This Read Vac	1	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Maintenance Operations	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AL	153	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AF	153	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Maintenance Operations	1	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations Ground	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations C Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations B Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations A Ø	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations Ground	0	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps C Ø	120.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps B Ø	120.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps A Ø	120.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations	14	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps A Ø	21.9	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps B Ø	25.2	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps C Ø	27.9	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3654	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations A Ø	0	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations B Ø	0	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations C Ø	0	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations Ground	0	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	General Comments	New Counter, LTC maint ops	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Max	33	°C
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1753.92	kw
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1860.48	kw
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Reading	.4700	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Present	45	*C
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Operation Checked?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Max	50	*C
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	All Connections OK?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	LTC Totalizer Reading	2820.00	kw
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps C Ø	50	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps B Ø	90	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps A Ø	90	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty C Ph V	2.06	%
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty B Ph V	2.06	%
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty A Ph V	2.06	%
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations	1	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Regulator As Left Counter	74637	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations This Read Vac	4	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	General Comments		
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	491.52	kw
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Unknown Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AL	350	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AF	350	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps C Ø	100.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps B Ø	116.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps A Ø	111.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	11L	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps A Ø	50.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps B Ø	50.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps C Ø	50.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations A Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations B Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations C Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations Ground	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Maintenance Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AF	424	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AL	428	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations B Ø	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations C Ø	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations Ground	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	General Comments	wash out in back by 303 switch	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	360408	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 11:37	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	LTC Totalizer Reading	2745.60	kw
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Max	45	°C
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Present	30	°C
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	265.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Unknown Operations	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Switching Operations	1	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations This Read Vac	1	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AL	209	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AF	209	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Maintenance Operations	0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	General Comments	BFTC	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Reading	.3432	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations	1	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps A Ø	155.0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps B Ø	139.0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps C Ø	148.0	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Max	38	°C
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Regulator As Left Counter	111448	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Unknown Operations	0	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Switching Operations	0	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations This Read Vac	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AL	213	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AF	212	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Maintenance Operations	1	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	General Comments	1 trip check	2 A & B phase to ground operations
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations Ground	2	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps C Phase V	9.88	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps B Phase V	9.88	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps A Phase V	9.88	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps C Ø	40.0	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps B Ø	30.0	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps A Ø	30.0	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations	10	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AF	370	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AL	370	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Unknown Operations	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Regulator As Left Counter	30499	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations	4	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	General Comments	Recloser is open along with line/buss disconnects	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Operations Counter	80	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations A Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations B Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations C Ø	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations Ground	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Maintenance Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AF	468	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AL	468	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations This Read Vac	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Switching Operations	0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Unknown Operations	0	
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 13:34	Distribution	Calvin Quarterly Inspection	RC000426	RecloserHydraulic	229-3426	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 13:35	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Unknown Operations	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Switching Operations	4	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations	6	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps A Ø	33.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps B Ø	62.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps C Ø	58.0	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations Ground	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations C Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations B Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations A Ø	0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps C Ø	142.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps B Ø	175.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps A Ø	100.0	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
3/8/2022 12:50	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations	12	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps A Ø	60.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps B Ø	60.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps C Ø	30.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	12	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9406.08	kw
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Operations Since Last Insp	169	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Max Tap Position	2L	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Current Tap Position	5L	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Left Counter	180825	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Found Counter	180825	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	56	°C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Maintenance Operations	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AF	169	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AL	173	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations This Read Vac	4	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Switching Operations	4	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Unknown Operations	0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Regulator As Left Counter	56956	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	RO912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	RO912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	RO999	Regulator	596-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/8/2022 13:59	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2288	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Unknown Operations	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Switching Operations	4	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations This Read Vac	4	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AL	128	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AF	124	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Maintenance Operations	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	RO912	Regulator	797-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations Ground	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations C Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations B Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations A Ø	0	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5814	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Regulator As Left Counter	313970	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 14:07	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations A Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations B Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations C Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations Ground	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Operations Since Last Insp	287	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Min Tap Position	5L	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Max Tap Position	2R	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Left Counter	1184	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Found Counter	1178	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	LTC Totalizer Reading	3593.60	kw
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Max	45	°C
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Regulator As Left Counter	69538	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BAT001557	Battery	692-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	BCH001489	Charger	692-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	General Comments		
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Reading	.4492	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Max	54	*C
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Present	23	*C
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	General Comments		
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Present	39	*C
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Max	48	*C
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9798	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 13:00	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	505	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Left Counter	98290	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Found Counter	98290	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
3/8/2022 12:53	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NITROGEN	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/8/2022 8:57	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	General Comments	Need to add counters for each phase now that new control has been installed. 73/63/63	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Operations Counter	73	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:35	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/8/2022 12:27	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations	1	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	General Comments		
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
3/8/2022 9:40	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	General Comments		
3/8/2022 13:42	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps C Ø	44.0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps B Ø	56.0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps A Ø	77.0	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Unknown Operations	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Tank Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Switching Operations	5	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/8/2022 13:53	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/8/2022 12:45	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations This Read Vac	5	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AL	45	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AF	40	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Maintenance Operations	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Grounds in Place?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	General Comments		
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Foundation Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations Ground	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations A Ø	0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations B Ø	0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Vegetation	None	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	General Comments		
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations C Ø	0	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushing Condition	Good	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps C Ø	40.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps B Ø	60.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps A Ø	120.0	
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/8/2022 10:43	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations	13	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/8/2022 11:25	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	187.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	202.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Readings	9 Months Operations	1	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0063	BreakerAirMagnetic	HI-1473	AMCB Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AF	450	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps C Ø	538.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps B Ø	546.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps A Ø	517.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Switching Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AL	450	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations This Read AM	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	9 Months Operations	1	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Maintenance Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0073	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	39	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	49	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	37	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	48	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	36	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	46	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	39	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	49	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations A Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps B Ø	60.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps A Ø	84.0	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	General Comments		
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	43.02	kw
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Max	25	°C
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Operations Since Last Insp	334	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Switching Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Left Counter	249012	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations	4	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Found Counter	48142	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Left Counter	48152	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Current Tap Position	7L	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Max Tap Position	1R	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Operations Since Last Insp	691	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps A Ø	19.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps B Ø	8.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps C Ø	13.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	74	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Vegetation	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations B Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	74	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations B Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushing Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	General Comments		
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1434	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Vegetation	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Charger Current	1.8	amps
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.3	VDC
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations C Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations A Ø	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.3	VDC
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Switching Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations This Read AM	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AL	584	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AF	584	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Maintenance Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps C Ø	9.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps B Ø	7.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps A Ø	10.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Months Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Vegetation	None	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Switching Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations A Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations B Ø	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations Ground	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps C Ø	63.0	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BCH001377	Charger	466-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Vegetation	None	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	9 Month Operations	1	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps A Ø	130.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps B Ø	98.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations This Read Vac	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps C Ø	100.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AL	190	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AF	190	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Maintenance Operations	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	General Comments		
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Maintenance Operations	26	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations Counter AF	196	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations Counter AL	196	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Operations This Read Vac	29	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Switching Operations	3	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Unknown Operations	0	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	General Comments	Indicator is not working	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	General Comments		
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AF	158	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AL	158	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations This Read Vac	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Max	101	°C
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	LTC Totalizer Reading	5860.80	kw
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Fault Operations Ground	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps C Ø	33.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations	1	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps B Ø	0.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps B Ø	0.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps A Ø	0.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	9 Month Operations	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	General Comments		
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Vegetation	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Switching Operations	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Unknown Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	9 Month Operations	25	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Amps C Ø	0.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Maintenance Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Operation Checked?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	All Connections OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Switching Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations This Read Vac	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations Counter AL	156	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Operations Counter AF	156	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Maintenance Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AF	219	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	General Comments	Tree branches growing over fence at back of station.	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Found Counter	249004	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations A Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations B Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations C Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations Ground	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations This Read AM	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AL	658	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AF	658	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Maintenance Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Unknown Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	LTC000171	LTCControl	466-9	LTC Control Insp	VRR Time Delay	30	Seconds
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations A Ø	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Amps C Ø	0.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Reading	.8140	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Months Operations	1	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps A Ø	31.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps B Ø	35.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations Ground	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations C Ø	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations B Ø	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Operations A Ø	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	ST000858	Structure	466-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	FE000883	Fence	466-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Present	42	°C
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AL	219	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Maintenance Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations Ground	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations This Read Vac	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Unknown Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Unknown Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Switching Operations	2	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations This Read Vac	24	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations Counter AL	166	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Operations Counter AF	166	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	Maintenance Operations	22	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Readings	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Vegetation	None	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	YD000968	Yard	466-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Switching Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Unknown Operations	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations C Ø	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001826	BreakerVacuum	466-9	VCB Readings	Fault Operations B Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001777	BreakerVacuum	466-4598	VCB Patrol Inspection	Foundation Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Winding Temp Max	31	°C
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Winding Temp Present	26	°C
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Nitrogen Bottle needs nitrogen	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Maintenance Operations	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AF	180	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AL	180	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations This Read Vac	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Switching Operations	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Unknown Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	General Comments	Meter wouldnt read ripple	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations	1	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	30	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Oil Temp Max	42	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Readings	Oil Temp Present	30	°C
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AF	191	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AL	191	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps A Ø	10.0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps B Ø	10.0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps C Ø	10.0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations This Read Vac	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Switching Operations	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations A Ø	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations B Ø	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations C Ø	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	LTC Totalizer Reading	3905.28	kw
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Max	44	°C
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Present	37	°C
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Reading	.4068	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	General Comments	Drain Pipe in Bathroom has water coming in from roof. Pic sent to Stinson	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	All Connections OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Operation Checked?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations	3	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps A Ø	19.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps B Ø	22.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps C Ø	20.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations A Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations B Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations C Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations Ground	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.400	millivolts
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.5	amps
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Maintenance Operations	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Maintenance Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Switching Operations	1	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Unknown Operations	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Operation Checked?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Unknown Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations B Ø	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations A Ø	0	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	General Comments		
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Max	30	°C
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps C Ø	67.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps B Ø	66.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps A Ø	64.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps C Ø	0.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Months Operations	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps B Ø	0.0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps A Ø	0.0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	9 Month Operations	1	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Switching Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Pressure	69	psi
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	SF6 Bushing Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations This Read SF6	7	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AL	1026	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Operations Counter AF	1026	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations C Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	99	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	10L	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Switching Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations This Read AM	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Reading	.0384	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Present	32	°C
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Max	42	°C
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	LTC Totalizer Reading	122.88	kw
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AL	973	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AF	973	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Left Counter	183092	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Found Counter	183092	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations Ground	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	General Comments	open	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Maintenance Operations	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AF	490	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AL	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations This Read Vac	1	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps C Ø	3.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps B Ø	2.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Amps A Ø	3.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Ambient Temperature	47	*F
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	379	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	*C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	34	*C
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	13L	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	7L	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	9L	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	234764	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	234764	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations A Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations B Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations C Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations Ground	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Roof is leaking and water coming in through vent fan and vent fan not working	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations	4	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps A Ø	19.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps B Ø	17.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps C Ø	26.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Num Operations Last 9 Months	14	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Unknown Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Switching Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations This Read Vac	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AL	227	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Maintenance Operations	7	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Heaters (All) Functioning?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AF	227	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Maintenance Operations	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Readings	Fault Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK000192	BreakerSF6	466-698	GCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	All Connections OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations Ground	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations C Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations B Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations A Ø	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushing Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps C Ø	111.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps B Ø	123.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps A Ø	125.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations	1	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AL	16	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations This Read AM	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Switching Operations	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Unknown Operations	0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations This Read Vac	1	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AL	76	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AF	76	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Maintenance Operations	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Present	26	°C
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	145.00	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	150.00	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	General Comments		
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	BI-Annunciator Panel Inspection	All Lights Functioning?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Maintenance Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	All Connections OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Operation Checked?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AF	368	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AL	368	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations This Read AM	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Switching Operations	0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.5	VDC
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	General Comments		
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC As Found Counter	1966	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC As Left Counter	1966	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Current Tap Position	4L	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Max Tap Position	1R	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Min Tap Position	5L	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	LTC Operations Since Last Insp	158	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations C Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations Ground	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Maintenance Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AF	16	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	General Comments		
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Unknown Operations	0	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Switching Operations	1	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/7/2022 10:36	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty C Ph AM	0.0	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps A Ø	61.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps B Ø	66.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps C Ø	59.0	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Operations Since Last Insp	749	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Min Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Max Tap Position	5R	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	General Comments		
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations B Ø	0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	General Comments		
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Left Counter	283430	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Found Counter	283425	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	General Comments		
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	9 Month Operations	33	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps A Ø	0.0	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	*F
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/7/2022 15:15	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/7/2022 12:06	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Months Operations	5	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps C Ø	171.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps B Ø	178.0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps A Ø	167.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Months Operations	0	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 12:32	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps C Ø	0.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BK001776	BreakerVacuum	466-4597	VCB Readings	Amps B Ø	0.0	
3/7/2022 13:48	Distribution	Glendale Temporary Construction Quarterly Inspection	BAT001622	Battery	466-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/14/2022 8:00	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations This Read Vac	2	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AL	242	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AF	242	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Maintenance Operations	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Oil Temp Max	15	°C
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5621.76	kw
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps B Ø	533.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Maintenance Operations	45	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps A Ø	512.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Unknown Operations	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations A Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Max	63	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Switching Operations	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations B Ø	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations C Ø	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations Ground	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	LTC Totalizer Reading	5270.40	kw
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Months Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	General Comments	ok	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7808	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2R	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations	5	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps A Ø	85.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps B Ø	65.0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps C Ø	75.0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Regulator As Left Counter	1439	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Vegetation	None	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	General Comments	gap under fence in right hand corner. some posts show rust	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Found Counter	28172	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Left Counter	28172	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2R	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	9 Month Operations	5	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	General Comments	ok	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Max	35	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Present	17	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	39	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	39	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	39	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	39	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	39	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	39	°C
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps C Ø	527.0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations B Ø	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations C Ø	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations Ground	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	General Comments	two large gaps in corner next to the scrap yard, brabed wire rusty and sagging, one bayonet broken, fence post very loose	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Operations Since Last Insp	1074	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Max Tap Position	4R	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Current Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Left Counter	132876	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Found Counter	132876	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Maintenance Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.500	millivolts
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations	45	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AF	215	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AL	215	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations This Read Vac	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Switching Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Unknown Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Switching Operations	2	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Found Counter	212314	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Left Counter	212314	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Current Tap Position	14L	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	372	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Min Tap Position	16L	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Max Tap Position	13L	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps B Ø	84.0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Reading	.5170	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Switching Operations	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations A Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations B Ø	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations C Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations Ground	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	LTC Totalizer Reading	3722.40	kw
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Unknown Operations	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Switching Operations	2	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations This Read Vac	2	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations Counter AL	170	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Operations Counter AF	170	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Maintenance Operations	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations Ground	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations C Ø	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations B Ø	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Operations A Ø	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations This Read Vac	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AL	72	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AF	72	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps C Ø	314.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps B Ø	302.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps A Ø	289.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps A Ø	99.0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations	47	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	General Comments	water below half in batteries	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Present	40	*C
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Max	45	*C
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	General Comments	top fence rails are rusty, fence fabric seperated from post on the left hand side of the station	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations A Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations B Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations C Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations Ground	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations B Ø	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations A Ø	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Paint Condition	Adequate	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps C Ø	166.0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps B Ø	201.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Present	26	°C
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Maintenance Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Switching Operations	2	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations This Read Vac	45	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AL	505	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Reading	.5280	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AF	505	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Maintenance Operations	43	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations	5	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Present	27	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps A Ø	104.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps B Ø	93.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps C Ø	81.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations Ground	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations C Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps C Ø	74.0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Max	37	°C
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	LTC Totalizer Reading	2534.40	kw
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1481	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000151	Regulator	798-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps A Ø	150.0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps B Ø	175.0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BK001567	BreakerVacuum	798-0610	VCB Readings	Amps C Ø	160.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Vegetation	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Vegetation	None	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations	3	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps A Ø	6.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps B Ø	7.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps C Ø	10.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AF	529	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AL	529	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations This Read Vac	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Switching Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Reading	.5490	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps A Ø	173.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AF	609	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	General Comments	ok	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Unknown Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	General Comments	one bulb blown in house	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Swept?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Evidence of Insects	None	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #'s
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Control House Lighting OK?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Broom on Site?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AL	609	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Operations Counter	335	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps C Ø	115.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps B Ø	115.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps A Ø	112.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	9 Month Operations	1	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps B Ø	28.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps A Ø	16.0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Unknown Operations	0	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BCH001478	Charger	536-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Found Counter	10251	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Left Counter	10259	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Current Tap Position	8L	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Min Tap Position	13L	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Operations Since Last Insp	859	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Present	40	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Max	55	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Maintenance Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations Ground	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations C Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations B Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations A Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Reading	.6468	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations Ground	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations C Ø	2	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations B Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations A Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps C Phase V	5.87	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Present	44	°C
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Max	64	°C
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	LTC Totalizer Reading	4656.96	kw
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Switching Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations This Read Vac	2	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	60	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	60	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	60	°C
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AL	193	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AF	193	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Maintenance Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations Ground	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Maintenance Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AF	297	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AL	297	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations This Read Vac	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Switching Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Unknown Operations	0	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Vegetation	None	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps A Ø	50.0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps B Ø	95.0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps C Ø	65.0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations A Ø	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations B Ø	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations C Ø	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations Ground	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Follow-up Action Required?	n	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations	2	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps A Ø	48.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps B Ø	21.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps C Ø	39.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Maintenance Operations	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AF	168	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AL	170	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations This Read Vac	2	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Switching Operations	2	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Unknown Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations A Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations B Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations C Ø	0	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	General Comments		
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Vegetation	None	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations A Ø	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations B Ø	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations C Ø	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations Ground	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Follow-up Action Required?	n	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Maintenance Operations	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AF	183	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AL	185	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations This Read Vac	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Switching Operations	0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Unknown Operations	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Vegetation	None	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Unknown Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Switching Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations This Read Vac	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AL	171	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AF	171	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	40	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	60	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	40	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	60	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	40	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	60	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	All Connections OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	General Comments	when operating LTC, raise relay is making a bad grinding noise.	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AF	124.1	VAC
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	9 Month Operations	3	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps A Ø	25.0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps B Ø	30.0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps C Ø	25.0	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Operations Counter	10	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	RC901734	RecloserElectronic	727-0612	Recloser Electronic Patrol Inspection	Amps A Ø	45.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	All Connections OK?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Found Counter	14346	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Left Counter	14352	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Max Tap Position	4R	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Operations Since Last Insp	499	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	General Comments	one insulator is broken	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/4/2022 10:40	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AL	325	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AF	325	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Time Delay	45	Seconds
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Bushing Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps C Ø	66.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps B Ø	96.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps A Ø	97.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	9 Month Operations	4	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps C Ø	339.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps B Ø	361.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps A Ø	373.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Months Operations	5	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Found Counter	200600	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Left Counter	200600	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	275	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Time Delay	45	Seconds
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AL	124.5	VAC
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AF	125.1	VAC
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	All Connections OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations Ground	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations C Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations B Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations A Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	All Connections OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Min Tap Position	6L	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Operations Since Last Insp	556	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Reading	.6324	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Present	40	°C
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Max	60	°C
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Found Counter	27779	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Left Counter	27779	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Current Tap Position	2L	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Operations Since Last Insp	915	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Min Tap Position	15L	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Max Tap Position	4L	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Current Tap Position	12L	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Left Counter	351705	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Found Counter	351695	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps C Ø	60.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps B Ø	58.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps A Ø	59.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	9 Month Operations	3	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	All Connections OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	LTC Totalizer Reading	4070.40	kw
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Max	25	°C
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Present	25	°C
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Reading	.4240	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Unknown Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Switching Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations This Read Vac	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AL	202	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AF	202	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Maintenance Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	General Comments		
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:23	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000951	LTCControl	478-1	LTC Control Insp	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	LTC Totalizer Reading	4553.28	kw
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Operations Since Last Insp	9478	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Max Tap Position	8R	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Current Tap Position	3L	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Left Counter	202003	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Found Counter	210944	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Operations Since Last Insp	1240	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Min Tap Position	9L	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Max Tap Position	4R	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Current Tap Position	6L	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Left Counter	39389	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Found Counter	39379	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Vegetation	None	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Found Counter	37790	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Left Counter	37790	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	5R	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	3R	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	17	°C
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	780	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations Ground	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Maintenance Operations	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AF	225	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AL	225	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations This Read Vac	1	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Switching Operations	1	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Unknown Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	heater not working	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	LTC Totalizer Reading	9336.96	kw
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations	4	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	General Comments		
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Swept?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps A Ø	55.0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps B Ø	58.0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps C Ø	40.0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations A Ø	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations B Ø	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations C Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	All Connections OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Time Delay	45	Seconds
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Regulator As Left Counter	1508	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps A Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps C Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Fault Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Maintenance Operations	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Low	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000150	Regulator	798-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AF	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AL	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations This Read Oil	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Switching Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Unknown Operations	0	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	RG000182	Regulator	798-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	General Comments		
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/4/2022 14:39	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations This Read Vac	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Switching Operations	1	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	General Comments		
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	General Comments	ok	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Maintenance Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AF	318	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps A Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Months Operations	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations This Read Vac	3	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AL	219	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AF	219	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Maintenance Operations	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	General Comments		
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations C Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations B Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations A Ø	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AL	318	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AF	466	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AL	466	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations This Read Vac	47	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Switching Operations	2	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations Ground	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations C Ø	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations B Ø	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations A Ø	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 10:24	Distribution	Williamsburg Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Unknown Operations	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations This Read AM	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	LTC000380	LTCControl	175-5	LTC Control Insp	All Connections OK?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	LTC000380	LTCControl	175-5	LTC Control Insp	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Maintenance Operations	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	General Comments		
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Follow-up Action Required?	n	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations Ground	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations C Ø	1	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps C Ø	69.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps B Ø	76.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Switching Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations B Ø	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations A Ø	1	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Unknown Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations This Read Vac	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AL	273	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps A Ø	68.0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AF	186	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations	1	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations Ground	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Unknown Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Unknown Operations	0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Switching Operations	3	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations B Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations A Ø	0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps C Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps B Ø	0.0	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AF	273	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Maintenance Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Grounds in Place?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Foundation Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations Ground	0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AL	186	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushing Condition	Good	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps C Ø	155.0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps B Ø	163.0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps A Ø	151.0	
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 11:12	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations	7	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	General Comments		
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps C Ø	98.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps B Ø	103.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps A Ø	93.0	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations	7	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Reading	.9726	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Present	31	°C
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Max	31	°C
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/4/2022 13:46	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Switching Operations	0	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	General Comments		
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Operation Checked?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/4/2022 12:15	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	9 Month Operations	5	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Time Delay	30	Seconds
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps A Phase V	3.95	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/4/2022 11:38	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps C Phase V	3.95	
3/4/2022 14:40	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps B Ø	71.0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps A Ø	57.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Maintenance Operations	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations	3	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations A Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations B Ø	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps C Ø	69.0	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	All Connections OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	LTC Operation Checked?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations	2	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C Ø	11.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B Ø	9.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A Ø	39.0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	LTCC000943	LTCControl	836-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations B Ø	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations C Ø	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations Ground	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	LTC Totalizer Reading	1458.00	kw
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations Ground	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Maintenance Operations	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AF	188	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AL	188	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations This Read Vac	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Switching Operations	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations C Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations B Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations A Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations A Ø	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps C Ø	160.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps B Ø	180.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps A Ø	185.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	9 Month Operations	4	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Unknown Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Switching Operations	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations This Read Vac	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations Counter AL	173	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Regulator As Left Counter	97017	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations Counter AF	171	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Maintenance Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Unknown Operations	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments	ok	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.8	millivolts
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations Counter AL	202	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Vegetation	None	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	208	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	208	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations Counter AF	200	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55	VDC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Operations This Read Vac	2	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Switching Operations	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	LTC Operation Checked?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000936	LTCControl	683-2	LTC Control Insp	All Connections OK?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Regulator As Left Counter	124771	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Leaks	None	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55	VDC
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations Counter AF	172	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Maintenance Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Vegetation	None	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations Ground	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations C Ø	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26	VDC
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26	VDC
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Reading	.8340	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Max	50	°C
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Present	40	°C
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations	4	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps A Ø	26.0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps B Ø	28.0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps C Ø	26.0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Unknown Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Switching Operations	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations This Read Vac	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations Counter AL	175	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	9 Month Operations	4	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps A Ø	120.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps B Ø	60.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps C Ø	70.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations A Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations B Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations C Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations Ground	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Maintenance Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AF	159	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AL	161	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Leaks	None	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Maintenance Operations	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AF	189	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AL	189	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations This Read Vac	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Maintenance Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AF	169	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AL	171	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations This Read Vac	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Switching Operations	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Unknown Operations	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Switching Operations	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	All Connections OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Unknown Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Current Tap Position	7L	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Left Counter	9571	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Found Counter	9571	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	9 Month Operations	5	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments	2 4ft bulbs need to change to LED, a GFCI plug by the north door of the control house doesn't work	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Vegetation	None	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	170	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	170	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Ambient Temp	69	*F
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	All Connections OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Operation Checked?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations This Read Vac	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Switching Operations	2	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Unknown Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	273.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	245.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	223.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps C Ø	65.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps B Ø	40.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps A Ø	40.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Operations Since Last Insp	602	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Min Tap Position	8L	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	705	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Operation Checked?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AF	124.7	VAC
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	9 Month Operations	4	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Reading	.2430	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations Ground	0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations C Ø	0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations B Ø	0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Operations A Ø	0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations A Ø	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations B Ø	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations C Ø	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations Ground	0	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Found Counter	10554	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Left Counter	10560	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	General Comments	Three hihg side insulators have large chips on the top skirts above transformer	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	44873	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	44873	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Operations Since Last Insp	327	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Vegetation	None	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	9 Month Operations	4	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Vegetation	None	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	LTC Totalizer Reading	8006.40	kw
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps A Ø	95.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps B Ø	70.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps C Ø	80.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations A Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations B Ø	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations C Ø	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Current Tap Position	3L	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps C Ø	85.0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps B Ø	65.0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK001566	BreakerVacuum	406-0617	VCB Readings	Amps A Ø	65.0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations Ground	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0.0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Found Counter	235984	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Left Counter	2351984	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	141	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	141	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Current Tap Position	6L	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Max Tap Position	1L	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Min Tap Position	7L	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Operations Since Last Insp	329	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Found Counter	412253	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Left Counter	412260	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Max Tap Position	9R	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Min Tap Position	5L	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Operations Since Last Insp	1031	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Found Counter	63092	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Left Counter	63092	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Max Tap Position	1R	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	193	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	193	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C Ø	141.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B Ø	153.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A Ø	154.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0.0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Reading	.4836	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Unknown Operations	0	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps A Ø	26.0	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps B Ø	3.0	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps C Ø	22.0	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Operations Since Last Insp	711	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Max Tap Position	6R	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Switching Operations	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations This Read Vac	1	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AL	204	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AF	204	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Maintenance Operations	1	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Operations Counter	103	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	65	psi
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations This Read SF6	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	58	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	58	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Operations Since Last Insp	320	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Unknown Operations	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations This Read Vac	1	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AL	326	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AF	326	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Maintenance Operations	1	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations Ground	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations C Ø	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations B Ø	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations A Ø	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps C Ø	100	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps B Ø	200	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps A Ø	50	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty C Ph V	12.43	%
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty B Ph V	21.21	%
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty A Ph V	23.4	%
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations	4	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	LTC Totalizer Reading	4642.56	kw
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Present	37	°C
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Found Counter	23701	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Follow-up Action Required?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Reading	1.2522	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	LTC Totalizer Reading	9015.84	kw
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	General Comments		8-8ft bulbs need changed to LED
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations	8	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps A Ø	480.0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps B Ø	480.0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps C Ø	480.0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Operation Checked?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C Ø	90.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	All Connections OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	222	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	222	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations This Read Vac	0	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.6	VDC
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.3	VDC
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Operations Since Last Insp	458	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Min Tap Position	8L	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Max Tap Position	4R	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Left Counter	23701	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	239	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	239	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations This Read Vac	1	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	1	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	LTC Totalizer Reading	4003.20	kw
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.5102	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Max	36	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Present	33	°C
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Reading	.4170	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	General Comments		
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
3/3/2022 11:34	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	All Connections OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	General Comments		
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Operation Checked?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AL	124.6	VAC
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A Ø	90.0	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	1	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	210.00	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2718.36	kw
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations A Ø	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations B Ø	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations C Ø	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations Ground	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AF	182	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AL	186	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B Ø	96.0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations This Read Vac	4	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	4	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Switching Operations	4	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Unknown Operations	0	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	0	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	0	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	0	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	General Comments		
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments		
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Present	32	°C
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Max	57	°C
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.400	millivolts
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	LTC Totalizer Reading	5227.20	kw
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Operations Counter	16	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps A Phase V	2.94	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations A Ø	1	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations B Ø	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations C Ø	0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations Ground	0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	General Comments		
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps B Ø	70.0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps C Ø	85.0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Regulator As Left Counter	101941	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations	6	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Reading	1.0890	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations	1	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	29	°C
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	39	°C
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	33	°C
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	50	°C
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	45	°C
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Switching Operations	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations This Read Vac	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AL	154	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AF	154	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Maintenance Operations	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	General Comments		
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations Ground	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	34	°C
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps A Ø	110.0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps B Ø	100.0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps C Ø	70.0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations B Ø	0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments		
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments		
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2250	psi
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:19	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	39	°C
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	33	°C
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Maintenance Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AF	243	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AL	245	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations This Read Vac	3	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Switching Operations	2	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Unknown Operations	0	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	28	°C
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	25	°C
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps B Ø	25	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps A Ø	50	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty C Ph V	7.31	%
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty B Ph V	6.58	%
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty A Ph V	5.85	%
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations	2	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Unknown Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	32	°C
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Unknown Operations	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Reading	.6846	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Switching Operations	2	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations This Read Vac	2	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AL	224	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AF	222	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Maintenance Operations	0	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Present	30	*C
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Max	60	*C
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations Ground	0	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations C Ø	0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	LTC Totalizer Reading	4107.60	kw
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AL	639	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AF	637	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Maintenance Operations	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Grounds in Place?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Unknown Operations	0	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Tank Paint Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations Ground	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations A Ø	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations This Read Vac	2	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	General Comments		
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Switching Operations	2	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	51	*F
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 11:11	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations	6	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Found Counter	102978	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Left Counter	102989	
3/3/2022 11:53	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps C Ø	25	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Foundation Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps C Ø	20.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps B Ø	22.0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations Ground	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations C Ø	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations A Ø	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps C Phase V	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps B Phase V	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps A Phase V	0	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	All Connections OK?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	Follow-up Action Required?	n	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	General Comments		
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations B Ø	0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	General Comments		
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps A Ø	65.0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps A Ø	0.0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/7/2022 8:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps B Ø	0.0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps C Ø	0.0	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushing Condition	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/3/2022 12:26	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Operation Checked?	y	
3/3/2022 14:05	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	General Comments		
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	9 Month Operations	4	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps A Ø	17.0	
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/3/2022 13:03	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Leaks	None	
3/3/2022 13:22	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AL	291	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations This Read Vac	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Present	50	°C
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	11	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.02	%
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.02	%
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	44.0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	44.0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	43.0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	9 Month Operations	5	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps A Ø	345.0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps B Ø	370.0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Amps C Ø	362.0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Maintenance Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AF	291	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	48	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	48	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps A Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps B Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps C Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations A Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations B Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations C Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations Counter AF	205	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations Counter AL	205	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Operations This Read Vac	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Switching Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Unknown Operations	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Unknown Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations A Ø	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations B Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Switching Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations This Read Vac	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AL	134	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AF	134	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations C Ø	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations Ground	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Maintenance Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Found Counter	15494	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Left Counter	15494	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Max Tap Position	7R	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Min Tap Position	10L	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Operations Since Last Insp	617	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps A Ø	0.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps B Ø	0.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps C Ø	0.0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations A Ø	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations B Ø	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations C Ø	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Fault Operations Ground	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	All Connections OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Present	30	°C
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Max	40	°C
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Reading	.7900	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Readings	Maintenance Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BK001334	BreakerVacuum	411-4619	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations	1	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps A Ø	0.0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps B Ø	0.0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps C Ø	0.0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Min Tap Position	12L	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Max Tap Position	2R	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Current Tap Position	3L	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Left Counter	34116	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Found Counter	34116	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	233	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Found Counter	118525	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Left Counter	118525	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Left Counter	103540	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Found Counter	103540	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	9 Month Operations	1	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps C Ø	45.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps B Ø	50.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps A Ø	55.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations	5	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	LTC Totalizer Reading	5136.00	kw
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Operations Since Last Insp	766	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AF	178	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AL	178	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations This Read Vac	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Switching Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Unknown Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Switching Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations This Read Vac	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AL	177	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AF	177	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Maintenance Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations Ground	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations C Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations B Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations A Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps C Ø	93.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps B Ø	82.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps A Ø	94.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps A Ø	145.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps B Ø	150.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps C Ø	143.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	92	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	267	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	267	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations A Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations B Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations C Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations Ground	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Maintenance Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps A Ø	119.0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps B Ø	200.0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps C Ø	220.0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps C Ø	115.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps B Ø	112.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps A Ø	160.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	All Connections OK?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Parallel / Ind. Sw Position	parallel	IND Position
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Time Delay	30	Seconds
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Switching Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations This Read Vac	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AL	234	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AF	234	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Maintenance Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations Ground	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations C Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations B Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations A Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AL	195	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AF	195	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps C Ø	66.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps B Ø	73.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps A Ø	70.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	9 Month Operations	2	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Maintenance Operations	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Switching Operations	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations	4	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Unknown Operations	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Unknown Operations	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Reading	.5350	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Present	40	°C
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Max	55	°C
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Maintenance Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations Ground	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	General Comments	TC	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Maintenance Operations	1	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AF	216	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations C Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations B Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations A Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AL	217	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations This Read Vac	1	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Switching Operations	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Unknown Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Unknown Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Oil Temp Max	40	°C
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Operations Since Last Insp	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Min Tap Position	5L	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations A Ø	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations B Ø	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations C Ø	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations Ground	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Switching Operations	3	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations This Read Vac	3	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AL	282	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AF	280	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Max Tap Position	5L	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Current Tap Position	3L	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Left Counter	767	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Found Counter	765	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	General Comments	left controller off	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Reading	1.0656	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps A Ø	282.0	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps B Ø	308.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Amps C Ø	298.0	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Maintenance Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AF	222	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AL	222	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations This Read Vac	6	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Switching Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Unknown Operations	0	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	All Connections OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations A Ø	0	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations B Ø	0	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations C Ø	0	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Fault Operations Ground	0	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Found Counter	205450	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Left Counter	205460	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9941.76	kw
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	9 Month Operations	43	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations Ground	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	General Comments	functional trip performed when work was being done by customer.	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Operations Since Last Insp	774	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Min Tap Position	12L	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Current Tap Position	5L	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Maintenance Operations	0	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations Counter AF	190	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations Counter AL	191	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Left Counter	134553	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Found Counter	134553	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BCH001473	Charger	611-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Operations This Read Vac	1	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Switching Operations	1	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BK001550	BreakerVacuum	840-2538	VCB Readings	Unknown Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Unknown Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Switching Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Current Tap Position	6L	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Max Tap Position	1R	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Min Tap Position	14L	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Operations Since Last Insp	898	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Present	40	°C
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Max	40	°C
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	LTC Totalizer Reading	10229.76	kw
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	General Comments	subs were paralleled together	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Operations Since Last Insp	660	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Min Tap Position	16L	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Max Tap Position	4L	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Current Tap Position	9L	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Left Counter	307009	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Found Counter	307009	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	5.58	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Base Voltage AL	120.5	VAC
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	VRR Base Voltage AF	120.5	VAC
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	LTC Output Voltage Level	120.4	VAC
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AL	189	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	All Connections OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	96.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	97.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	94.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	General Comments	cabinet heater not working properly, thermostat needs to be replaced.	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	9 Month Operations	1	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Maintenance Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AF	198	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	141	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	141	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Unknown Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Reading	1.1060	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000928	LTCControl	840-1	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	9 Month Operations	9	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Present	50	°C
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Max	62	°C
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0356	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps A Ø	33.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps B Ø	18.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps C Ø	24.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps B Phase V	35.15	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations A Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations B Ø	6	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	General Comments	OK	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Found Counter	100428	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Left Counter	100435	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Current Tap Position	5L	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Max Tap Position	5R	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Min Tap Position	11L	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Operations Since Last Insp	1024	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	All Connections OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Time Delay	60	Seconds
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	LTC Totalizer Reading	10617.60	kw
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Max	60	°C
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Present	35	°C
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	General Comments	OK	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	General Comments	ok	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Found Counter	2940	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Left Counter	2945	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Current Tap Position	3L	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Unknown Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Switching Operations	1	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations This Read Vac	1	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AL	164	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AF	164	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Maintenance Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations B Ø	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	3.61	%
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Broom on Site?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Unknown Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Switching Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AL	150	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AF	150	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Maintenance Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000520	ControlHouse	566-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations	6	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps A Ø	95.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps B Ø	97.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps C Ø	99.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps A Ø	60.0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps B Ø	30.0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps C Ø	60.0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Min Tap Position	7L	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Operations Since Last Insp	55	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	General Comments	VC is 222 not 227	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Maintenance Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AF	222	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AL	222	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Switching Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Unknown Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps C Ø	30.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps B Ø	35.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps A Ø	35.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	9 Month Operations	5	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	General Comments	ok	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	All Connections OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations	8	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations A Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations B Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations C Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Fault Operations Ground	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Present	55	°C
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Max	58	°C
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps C Ø	115.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps B Ø	100.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps A Ø	110.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations	5	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	9 Month Operations	35	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps A Ø	135.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps B Ø	138.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Amps C Ø	125.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations Ground	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations C Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations B Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations A Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Maintenance Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AF	200	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AL	200	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Switching Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps C Ø	259.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps B Ø	248.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps A Ø	254.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Unknown Operations	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Maintenance Operations	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations Counter AF	187	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations Counter AL	187	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Operations This Read Vac	3	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Switching Operations	3	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Unknown Operations	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	258.0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	244.0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	228.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	182	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	182	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001796	BreakerVacuum	611-2434	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7370	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Max	25	°C
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	All Connections OK?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Time Delay	30	Seconds
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	232	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	232	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A Ø	157.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B Ø	160.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C Ø	162.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations This Read Vac	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	208	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	208	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	General Comments	ok	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	197	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations	2	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	9.57	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	197	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	10.36	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	30.29	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A Ø	43.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B Ø	13.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C Ø	13.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations A Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations B Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Fault Operations Ground	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	General Comments	ok	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	237	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	237	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Maintenance Operations	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations Counter AF	172	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations Counter AL	172	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Operations This Read Vac	2	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Switching Operations	2	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Unknown Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BAT001558	Battery	680-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	LTC Totalizer Reading	1032.00	kw
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Maintenance Operations	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps C Ø	0.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps B Ø	0.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps A Ø	0.0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AF	337	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AL	341	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations This Read Vac	4	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Switching Operations	4	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Unknown Operations	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	9 Month Operations	34	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps A Ø	34.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps B Ø	30.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Readings	Amps C Ø	31.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK001797	BreakerVacuum	611-2436	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	29	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	28	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	39	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	28	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	33	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	39	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	950	psi
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7075.20	kw
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	130.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	130.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Reading	.1720	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	854.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	870.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	868.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BCH001495	Charger	840-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.4	VDC
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.3	VDC
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	BAT001560	Battery	840-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Oil Temp Max	50	°C
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Found Counter	173575	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Left Counter	173587	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Current Tap Position	6L	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Max Tap Position	4R	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Min Tap Position	10L	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Operations Since Last Insp	917	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Present	45	°C
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Max	50	°C
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	LTC Totalizer Reading	1770.24	kw
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Max	35	°C
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Present	30	°C
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Present	45	°C
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Max	45	°C
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations	1	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps A Ø	135.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps B Ø	150.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps C Ø	143.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Reading	.8940	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations A Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations B Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Operations Since Last Insp	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Min Tap Position	5	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Max Tap Position	6	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Current Tap Position	5	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	LTC Totalizer Reading	4913.28	kw
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.4	VDC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.5	VDC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Reading	.4100	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Present	20	°C
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Max	40	°C
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	LTC Totalizer Reading	11376.00	kw
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	LTC Totalizer Reading	3936.00	kw
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	33	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	48	°C
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Maintenance Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AF	149	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AL	149	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Switching Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Unknown Operations	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Reading	.5532	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations	1	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps A Ø	320.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps B Ø	320.0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps C Ø	320.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitro cyl at 0 psi alarm found isolated.	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	52	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	48	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	52	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	52	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	45	°C
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	40	°C
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	All Connections OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	9 Month Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps A Ø	250.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps B Ø	240.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps C Ø	260.0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushing Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Found Counter	227519	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Left Counter	227519	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Current Tap Position	4L	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Max Tap Position	16R	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Min Tap Position	11L	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Operations Since Last Insp	384	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps C Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps B Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps A Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations This Read Vac	3	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AL	316	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AF	314	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Maintenance Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations This Read Vac	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AL	107	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AF	107	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Maintenance Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	28	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	28	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations Ground	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations C Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations B Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations A Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Unknown Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Switching Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	FE000877	Fence	839-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Unknown Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Switching Operations	3	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Reading	.5118	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Maintenance Operations	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AF	255	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AL	255	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Switching Operations	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Unknown Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Left Counter	121473	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Found Counter	121473	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Present	60	°C
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Max	45	°C
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations C Ø	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations Ground	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Maintenance Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AF	163	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AL	163	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations This Read Vac	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Switching Operations	0	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Unknown Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	LTC Totalizer Reading	12873.60	kw
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Max	52	°C
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Present	43	°C
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	636	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Unknown Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Switching Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations This Read Vac	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AL	106	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AF	106	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Maintenance Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations Ground	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations C Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations B Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations A Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	44856	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	44856	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	688	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Operations Since Last Insp	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Current Tap Position	14	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Left Counter	77072	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Found Counter	77072	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments	ok	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	General Comments		operations counter rolled over
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Found Counter	103340	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Left Counter	3340	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps C Ø	141.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps C Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps B Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps A Ø	0.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps B Ø	145.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps A Ø	137.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations	2	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Unknown Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Switching Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AL	91	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AF	91	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Maintenance Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations Ground	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps C Ø	20.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps B Ø	10.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps C Ø	250.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps B Ø	268.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps A Ø	265.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps C Ø	131.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps B Ø	138.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps A Ø	154.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations	11	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Unknown Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Switching Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations This Read Vac	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AL	208	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AF	208	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Maintenance Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations Ground	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Unknown Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Switching Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AL	77	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AF	77	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Maintenance Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations	4	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Min Tap Position	12L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Regulator As Left Counter	46392	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Interrupters/Puffrs Visual OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps A Ø	39.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations	5	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Unknown Operations	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Switching Operations	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations This Read Vac	1	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AL	189	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AF	188	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations A Ø	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations B Ø	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations C Ø	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations Ground	0	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	General Comments		
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	General Comments	TC	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Maintenance Operations	1	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations	7	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps C Ø	322.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps B Ø	317.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations	4	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps A Ø	18.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps B Ø	21.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps C Ø	26.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations A Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations B Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations C Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations Ground	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Maintenance Operations	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AF	177	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AL	177	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations This Read Vac	2	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Switching Operations	2	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Unknown Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Unknown Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Switching Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AL	88	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AF	88	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Maintenance Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations	3	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Unknown Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Switching Operations	1	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations This Read Vac	1	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AL	91	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AF	91	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Maintenance Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations B Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Unknown Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Switching Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations This Read Vac	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AL	187	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AF	187	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Maintenance Operations	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Broom on Site?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	General Comments		
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps A Ø	377.0	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Basement Condition Acceptable	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/2/2022 18:58	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations	3	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps A Ø	24.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps B Ø	0.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps C Ø	0.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Maintenance Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AF	90	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AL	90	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Switching Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Unknown Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	General Comments	subs were paralleled together	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Maintenance Operations	4	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AF	176	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AL	176	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations This Read Vac	5	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Switching Operations	1	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Unknown Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Present	28	°C
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations	6	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps A Ø	276.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps B Ø	287.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps C Ø	272.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	36	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	29	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	36	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	29	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	36	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	29	°C
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	General Comments	barb wire rusty	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations A Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations B Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations C Ø	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations Ground	0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Maintenance Operations	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AF	205	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AL	207	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations A Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations B Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations C Ø	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Switching Operations	5	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations This Read Vac	5	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AL	322	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AF	320	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Maintenance Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Unknown Operations	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Switching Operations	2	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations This Read Vac	2	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	177	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	14	°C
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	27	°C
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Left Counter	14175	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Found Counter	14175	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 10:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps C Ø	80.0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps B Ø	95.0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps A Ø	75.0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations	4	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Unknown Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps C Ø	30.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps B Ø	25.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps A Ø	20.0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations This Read Vac	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	184	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	184	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Regulator As Left Counter	40566	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	67	psi
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations This Read SF6	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	58	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	58	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	35	*F
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	55.9	VDC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Left Float Voltage	55.9	VDC
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 11:23	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	General Comments		
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Grounds in Place?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Maintenance Operations	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AF	192	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AL	192	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations This Read Vac	2	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Switching Operations	2	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Unknown Operations	0	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 14:02	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/2/2022 14:02	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 14:02	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 14:02	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/2/2022 14:02	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
3/2/2022 14:02	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
3/2/2022 14:02	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
3/2/2022 14:02	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	545.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	548.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	536.0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Ambient Temp	63	*F
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations Ground	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations C Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations A Ø	0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps C Ø	72.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps B Ø	63.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps A Ø	74.0	
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 13:48	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations	4	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	*F
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	104	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	104	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations This Read Vac	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	193	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	193	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	24.71	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	0	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Unknown Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Switching Operations	0	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AL	60	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AF	60	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Maintenance Operations	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Grounds in Place?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	General Comments		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Foundation Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	5	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C Ø	145.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B Ø	155.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A Ø	160.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	19.13	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	27.9	%
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Regulator As Left Counter	104935	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Current Tap Position	3L		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushing Condition	Good		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Current Tap Position	8L		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments	fuses 10 and 12 replaced		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	y		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good		
3/2/2022 15:25	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C Ø	0		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations B Ø	0		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A Ø	0		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments	ok		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n		
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	All Identified and Legible?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Foundation Condition	Good		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	General Comments			
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Leaks	None		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good		
3/2/2022 13:49	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Structure Patrol Inspection	Whips Correctly Engaged?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Regulator As Left Counter	43060		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Oil Level	Good		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Min Tap Position	14L		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	General Comments		
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	General Comments		
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Operations Counter	38	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	307.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	284.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	245.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	222	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	222	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations This Read Vac	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	170	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	170	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations This Read Vac	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C Ø	92.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B Ø	118.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A Ø	103.0	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	19.93	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	33.48	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	22.32	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	1	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 10:53	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps A Ø	98.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps B Ø	83.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps C Ø	82.0	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Regulator As Left Counter	152342	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	General Comments		
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations	2	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	All Connections OK?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	All Connections OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps C Ø	23.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps B Ø	26.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps A Ø	31.0	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	All Connections OK?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Follow-up Action Required?	n	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Operation Checked?	y	
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations B Ø	0	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/2/2022 13:20	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	General Comments		
3/2/2022 13:14	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Time Delay	30	Seconds
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/7/2022 8:02	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Time Delay	30	Seconds
3/2/2022 14:31	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	General Comments		
3/2/2022 9:06	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Regulator As Left Counter	111310	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/2/2022 12:24	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	268	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	16.2	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.6	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.6	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	258	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	329	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000283	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps B Ø	31.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps A Ø	3.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Maintenance Operations	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps C Ø	2.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	General Comments	2-22 outage from Beechmont	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	9 Month Operations	7	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Unknown Operations	0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations A Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations B Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations C Ø	0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations Ground	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps B Ø	93.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps C Ø	94.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps B Ø	91.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps A Ø	137.0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4374.72	kw
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Present	43	°C
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations	2	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	155	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9114	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	9 Month Operations	8	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps A Ø	36.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps B Ø	14.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps C Ø	18.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps A Phase V	2.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations A Ø	2	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations B Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations C Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations Ground	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	General Comments	A-G 2-22/A-G 1-19	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Maintenance Operations	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AF	190	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AL	190	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations This Read Vac	2	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Switching Operations	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	9 Month Operations	3	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps A Ø	11.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps B Ø	14.0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps C Ø	12.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations A Ø	1	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations B Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations C Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations Ground	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	General Comments	2-22 outage AB/ 1 op switching	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Maintenance Operations	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AF	194	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AL	194	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations This Read Vac	2	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Switching Operations	1	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Unknown Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:01	Distribution	Bever Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 14:01	Distribution	Bever Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	34	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	31	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	34	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AF	221	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AL	221	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations This Read Vac	2	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Switching Operations	2	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	918.00	kw
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Unknown Operations	0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Max	38	°C
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Present	31	°C
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	155	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps A Ø	95.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	General Comments	Bkr. open	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	4	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AL	381	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AF	381	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Maintenance Operations	0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7650	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 14:01	Distribution	Bever Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:01	Distribution	Bever Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/1/2022 14:01	Distribution	Bever Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	General Comments	ok	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations Ground	0	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations C Ø	0	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations B Ø	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Y3 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Y3 Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Y2 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Y2 Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Y1 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Y1 Winding Temp Max	0	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Num Operations Last 9 Months	0	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	X3 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	X3 Winding Temp Max	0	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AF	378	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AL	378	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Regulator As Left Counter	38450	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AL	226	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AF	226	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations A Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations	2	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Oil Temp Max	36	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2639.52	kw
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps A Ø	604.0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	LV Winding Temp Present	0	°C
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	LV Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	HV Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	HV Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	H3 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	H3 Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	H2 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	H2 Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	H1 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	X2 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	X2 Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	X1 Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	X1 Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Winding Temp Present	24	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Winding Temp Max	34	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	TV Winding Temp Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	TV Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3666	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AF	375	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AL	375	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AF	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Top Oil Temperature Present	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Top Oil Temperature Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	General Comments	Fnctn TC	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Operations Counter	162	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	General Comments	prev counter must be from R663	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BCH001466	Charger	142-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Regulator As Left Counter	49564	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Regulator As Left Counter	374292	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps A Ø	0.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps B Ø	0.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps C Ø	0.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Fault Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	General Comments	ok	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Regulator As Left Counter	9998	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps A Ø	62.0	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps B Ø	81.0	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps C Ø	65.0	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10383	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	9 Month Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps A Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps C Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	General Comments	OPEN	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	General Comments	tower leg foundations crumbling, as well as transformer	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	General Comments	ok	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	General Comments	prev counter must be from R661	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Fault Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps C Ø	45.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps B Ø	42.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps A Ø	49.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AF	445	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AL	445	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Switching Operations	0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Regulator As Left Counter	1588	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations This Read SF6	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AL	275	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AF	275	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Num Operations Last 9 Months	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	9 Month Operations	4	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps A Ø	47.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps B Ø	44.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps C Ø	47.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Regulator As Left Counter	203319	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	9 Month Operations	2	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps A Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps C Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	540.72	kw
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	163	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	High	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Regulator As Left Counter	159565	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4506	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations	3	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps A Ø	17.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Found Counter	59857	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Left Counter	59857	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps B Ø	38.0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps C Ø	25.0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Reading	.9180	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Trn Dynamic Health	NonLTC Trn Dynamic Health	45.00	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	734.40	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	336	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Left Counter	132152	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Found Counter	132152	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	General Comments	Frctn TC	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Maintenance Operations	1	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Operations Counter	113	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AF	192	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AL	192	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations This Read Vac	1	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Switching Operations	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Unknown Operations	0	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	General Comments		
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Switching Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AL	105	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AF	105	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Found Counter	19632	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Left Counter	19632	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	1R	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AF	366	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AL	366	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations A Ø	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations B Ø	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations C Ø	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations Ground	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	9 Month Operations	1	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	General Comments	electric fence around 3ft on back side	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	General Comments		
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations	24	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps A Ø	170.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps B Ø	171.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps C Ø	179.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Max	25	°C
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2034.72	kw
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	9 Month Operations	4	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps A Ø	72.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps B Ø	66.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps C Ø	71.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	34	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	31	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	General Comments	fuse barrels very old High side fuse barrels have no fusing	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps A Ø	577.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps B Ø	572.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps C Ø	569.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AF	207	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Annunicator test switch in Cabinet is broken. Noted in previous insp.	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	0	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	0	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Max	33	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Present	29	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AL	207	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	General Comments		
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps C Ø	534.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps B Ø	551.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps A Ø	557.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations	2	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	9 Month Operations	1	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps A Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps C Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AF	509	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AL	509	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations This Read Vac	0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	General Comments		
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Oil Temp Present	15	°C
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AF	241	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AL	241	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Present	21	°C
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Max	31	°C
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8478	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AF	239	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AL	239	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	9 Month Operations	1	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps A Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps C Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations A Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Fault Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps C Ø	140.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps B Ø	126.0	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Ambient Temp	63	*F
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps A Ø	138.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50376	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	General Comments	entrance culverts are washed out narrowing entrance.Rt side culvert collapsed.	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps B Ø	48.0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps C Ø	47.0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Regulator As Left Counter	426763	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps B Ø	115.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps C Ø	106.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Neighboring Fence within 6'	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	General Comments	Fence ie only grounded in one spot on each side.	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	General Comments		
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	General Comments		
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Switching Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Switching Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations This Read SF6	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AL	720	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AF	720	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Num Operations Last 9 Months	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations This Read Vac	0	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps C Ø	86.0	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps B Ø	59.0	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps A Ø	61.0	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations	5	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps A Ø	430.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations B Ø	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	General Comments	Barbwire broke in one place and rusted	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations C Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps C Ø	376.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps B Ø	378.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations Ground	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AF	175	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AL	175	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	General Comments		
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	912	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Left Counter	175397	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Found Counter	175397	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	9 Month Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Switching Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations This Read Vac	2	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AL	177	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AF	177	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations A Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations B Ø	2	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations C Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations Ground	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	General Comments	B Phase IOC	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Maintenance Operations	0	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5645	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Operations Counter	212	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	General Comments	Fnctn TC	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps A Ø	116.0	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10785	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	General Comments	ok	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Winding Temp Present	65	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	47	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Wood Structures OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	9 Month Operations	4	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps A Ø	60.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps B Ø	76.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps C Ø	66.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations C Ø	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AL	381	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AF	381	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Max	40	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Present	37	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations Ground	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	General Comments	fence and barb wire rusty, gaps under fence more than 4 inches	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Leaks	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Operations Counter	367	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	General Comments	Frctn TC/1 C-G fault	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	45	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	57	°C
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Oil Temp Present	60	°C
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	37	°C
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	General Comments	Fiberglass on xfmr fuses and spare fuses is started to be exposed.	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	40	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	40	°C
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	General Comments	top 2 on Rt radiator not operational	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	General Comments		
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	General Comments	Some ruts and washout forming at the bottom of the hill as you turn up to sub.	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Current Tap Position	7L	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Min Tap Position	9L	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Regulator As Left Counter	210420	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Regulator As Left Counter	214228	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps C Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps A Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	9 Month Operations	4	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	General Comments		
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Operations Counter	111	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AL	365	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AF	365	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	General Comments	OPEN	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps C Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Amps A Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	9 Month Operations	0	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0998	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations Counter AL	402	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations Counter AF	402	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	General Comments	ok	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1319.76	kw
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Max	31	°C
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	9 Month Operations	3	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps A Ø	5.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps B Ø	6.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Amps C Ø	5.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps B Ø	598.0	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	148	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Max Tap Position	10	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Left Counter	80547	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Found Counter	80547	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Operations Counter	204	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	General Comments	1 trip check	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations Counter AF	331	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations Counter AL	331	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001391	BreakerVacuum	AL-GND TR 4	VCB Readings	Unknown Operations	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Floor Swept?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	CH000514	ControlHouse	142 Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AL	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations This Read SF6	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Switching Operations	0	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps B Ø	87.0	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps C Ø	64.0	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps C Ø	296.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Top Oil Temperature Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Top Oil Temperature Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.4568	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	TV Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	TV Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Max	32	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Present	24	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X1 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X1 Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X2 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X2 Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X3 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X3 Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y1 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y1 Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y2 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y2 Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y3 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y3 Winding Temp Present	0	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	H1 Winding Temp Max	0	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10276	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	TX000254	NonLTC	643-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	9 Month Operations	9	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps A Ø	37.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps B Ø	40.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Amps C Ø	40.0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations Counter AF	366	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations Counter AL	366	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations	1	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps B Ø	306.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps A Ø	308.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3496.32	kw
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	LV Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	LV Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	HV Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	HV Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H3 Winding Temp Present	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H3 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H2 Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H2 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H1 Winding Temp Present	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H1 Winding Temp Max	0	°C
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	General Comments	no nitrogen system on site	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	General Comments	outer door issues..	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51943	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	TRANK Paint Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	General Comments	ok	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1343.52	kw
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	187.50	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	180.00	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5598	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	9 Month Operations	1	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Trash Emptied?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps A Ø	184.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps B Ø	187.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps C Ø	194.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	General Comments	ok	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations	2	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	General Comments	Counter not working	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	General Comments		
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Regulator As Left Counter	72772	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AL	217	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations This Read Vac	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Switching Operations	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Unknown Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	55	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	55	°C
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Regulator As Left Counter	1461	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Switching Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AL	282	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AF	282	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1549	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000217	Regulator	643-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps C Ø	607.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations A Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations B Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations C Ø	1	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations Ground	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	General Comments	C Phase IOC	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AF	115	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AL	115	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000218	Regulator	643-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Regulator As Left Counter	96220	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	General Comments	ok	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps C Ø	82.0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps B Ø	38.0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps A Ø	58.0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AF	217	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Maintenance Operations	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations Ground	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations C Ø	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations B Ø	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations A Ø	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations This Read Vac	1	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Switching Operations	0	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Present	45	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2485.44	kw
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	General Comments		
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	General Comments		
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Unknown Operations	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Switching Operations	1	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	General Comments	SPR no longer on site	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Unknown Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations This Read Vac	0	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations Counter AL	306	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Operations Counter AF	306	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bever Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps A Ø	133.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps B Ø	131.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps C Ø	133.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Fault Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Num Operations Last 9 Months	1	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AF	938	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AL	938	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations This Read SF6	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Switching Operations	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0356	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations This Read Vac	2	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations Counter AL	195	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Operations Counter AF	195	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Maintenance Operations	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	General Comments	Bus Diff 2-22	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	General Comments	ok	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Regulator As Left Counter	93931	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Min Tap Position	9L	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Max Tap Position	1L	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AL	206	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AF	206	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps C Ø	38.0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps B Ø	38.0	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	General Comments		
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	General Comments		
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Amps A Ø	59.0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	9 Month Operations	2	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	General Comments		
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Maintenance Operations	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	General Comments	diff 2-22	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations Ground	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations C Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations B Ø	1	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Operations A Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps B Phase V	7.12	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5327	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	9 Month Operations	8	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps A Ø	169.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps B Ø	172.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps C Ø	173.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations A Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BCH001436	Charger	643-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AF	443	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AL	443	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations This Read Vac	2	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Switching Operations	2	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BAT001506	Battery	643-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations B Ø	1	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations A Ø	1	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps B Phase V	2.62	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps A Phase V	2.62	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps C Ø	66.0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps B Ø	113.0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps A Ø	124.0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations	4	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	General Comments		
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Max Tap Position	6R	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Min Tap Position	1R	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Regulator As Left Counter	312	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	General Comments	ok	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations Ground	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations C Ø	0	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	General Comments	Had to re-adjust found at 165V	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Current Tap Position	7L	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AL	537	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AF	537	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps C Ø	212.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps B Ø	210.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps A Ø	217.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations	1	
3/1/2022 14:01	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Regulator As Left Counter	42530	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Max	37	°C
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	159.17	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps C Ø	186.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps B Ø	187.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps A Ø	180.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations	1	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	General Comments		
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	General Comments		Entire station needs wildlife protection.
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps C Ø	0.0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Unknown Operations	0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.5	VDC
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	2.8	AMPS
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Trash?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	TX000284	GroundTransformer	AL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations B Ø	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	General Comments		
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	9 Month Operations	15	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	124	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	174	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps C Ø	35.1	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps B Ø	37.7	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps A Ø	31.9	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	158	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps C Ø	24.0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps B Ø	24.0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Amps A Ø	17.0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	9 Month Operations	3	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 12:03	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Switching Operations	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations This Read Vac	2	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AL	310	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AF	310	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Maintenance Operations	0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Ambient Temp	57	*F
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Amps A Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001478	BreakerVacuum	AL-GND TR 3	VCB Readings	9 Month Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Unknown Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations Counter AL	367	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Operations Counter AF	367	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations Ground	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations C Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations B Ø	1	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Operations A Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps B Phase V	7.12	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001631	BreakerVacuum	643-0695	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps C Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001477	BreakerVacuum	AL-GND TR 2	VCB Readings	Amps A Ø	0.0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	General Comments	2-22 T-Diff	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations Ground	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations C Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations B Ø	1	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Operations A Ø	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps C Ø	24.0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps B Ø	26.0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Amps A Ø	25.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations This Read SF6	0	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	General Comments	ok	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Max	67	°C
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Trash Emptied?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps A Ø	238.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps B Ø	242.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps C Ø	230.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AF	208	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Unknown Operations	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Switching Operations	1	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations This Read Vac	2	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations Counter AL	173	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Operations Counter AF	173	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps A Ø	32.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps B Ø	34.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps C Ø	22.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	General Comments		
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Regulator As Left Counter	51835	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46918	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001636	BreakerVacuum	643-308	VCB Readings	9 Month Operations	5	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AL	208	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations This Read Vac	0	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Regulator As Left Counter	57874	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps C Ø	358.0	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	General Comments		
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps B Ø	357.0	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	General Comments		
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	9 Month Operations	3	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps A Ø	339.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AL	342	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AF	342	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Regulator As Left Counter	49672	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	General Comments		
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
3/1/2022 10:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Maintenance Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AF	390	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AL	390	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations This Read Vac	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	General Comments		
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 10:54	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Regulator As Left Counter	1533	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Tank Leaks	None	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	RG000206	Regulator	643-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps A Ø	257.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps B Ø	264.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps C Ø	266.0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Fault Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations	3	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Num Operations Last 9 Months	2	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AF	620	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AL	620	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations	2	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps A Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps B Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps C Ø	0.0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushing Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations A Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations B Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations C Ø	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations Ground	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Foundation Condition	Good	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	General Comments		
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	General Comments	OPEN	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5558	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations Counter AL	187	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations Counter AF	187	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Maintenance Operations	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Num Operations Last 9 Months	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AF	1345	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AL	1345	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations This Read SF6	0	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Switching Operations	0	
3/1/2022 17:22	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Present	15	°C
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Max	15	°C
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	General Comments	ok	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	General Comments	H2 bushing has two skirts that are chipped.	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Vegetation	None	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	General Comments		
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
3/1/2022 9:53	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	General Comments	ok	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	General Comments	ok	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 13:29	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
3/1/2022 14:24	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Panels Dusted?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Broom on Site?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Floor Swept?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Switching Operations	1	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Evidence of Insects	None	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	General Comments		
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Follow-up Action Required?	n	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Follow-up Action Required?	n	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Operations This Read Vac	2	
3/1/2022 14:18	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Fault Operations	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	BK001632	BreakerVacuum	643-0696	VCB Readings	Unknown Operations	0	
3/1/2022 9:50	Distribution	Beechmont Quarterly Inspection	CH000499	ControlHouse	643-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
3/1/2022 8:51	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Regulator As Left Counter	48987	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushing Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps C Ø	210.0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps B Ø	220.0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps A Ø	195.0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps C Ø	80.0	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushing Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps B Ø	140.0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps C Ø	116.0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps B Ø	120.0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps A Ø	90.0	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	9 Month Operations	2	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	9 Month Operations	5	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Regulator As Left Counter	52040	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Vegetation	None	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Regulator As Left Counter	51892	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	*F
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations A Ø	0	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations B Ø	0	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations C Ø	0	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations Ground	0	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Foundation Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Grounds in Place?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations A Ø	0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations B Ø	0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations C Ø	0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations Ground	0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Foundation Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Grounds in Place?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Maintenance Operations	0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AF	308	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AL	308	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations This Read Vac	3	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Switching Operations	3	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Tank Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Unknown Operations	0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps A Ø	110.0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Maintenance Operations	0	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Present	20	°C
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Max	30	°C
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Reading	1.1040	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Tank Paint Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Unknown Operations	0	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Switching Operations	1	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations This Read Vac	1	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AL	295	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	LTC Operation Checked?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Vegetation	None	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCCControl	647-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	All Connections OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AF	294	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7833.60	kw
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8160	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Max	32	°C
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Operations Counter	21	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Max	30	°C
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	LTC Totalizer Reading	10598.40	kw
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	General Comments		
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/24/2022 16:10	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Follow-up Action Required?	n	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	General Comments		
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	General Comments		
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	General Comments		
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Found Counter	49788	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Left Counter	49788	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Min Tap Position	6L	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Operations Since Last Insp	259	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
2/24/2022 14:27	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/24/2022 16:10	Distribution	Taylorville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations Ground	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations C Ø	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations B Ø	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	General Comments		
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Follow-up Action Required?	n	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	LTCMechanism	020-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps A Ø	80.0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AF	99937	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Maintenance Operations	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AL	99938	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps B Ø	75.0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Follow-up Action Required?	n	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	9 Month Operations	57	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Foundation Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps C Ø	75.0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	General Comments		
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Unknown Operations	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushing Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations This Read Vac	2	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Switching Operations	2	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Tank Paint Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Grounds in Place?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations A Ø	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations This Read Vac	4	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AL	134	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AF	133	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Foundation Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Follow-up Action Required?	n	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCCControl	020-5	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	General Comments		
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Foundation Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	General Comments		
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Follow-up Action Required?	n	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	General Comments		
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Maintenance Operations	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCCControl	020-5	LTC Control Insp	Follow-up Action Required?	n	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCCControl	020-5	LTC Control Insp	VRR Time Delay	30	Seconds
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCCControl	020-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCCControl	020-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations Ground	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations C Ø	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations B Ø	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations A Ø	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCCControl	020-5	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCCControl	020-5	LTC Control Insp	LTC Operation Checked?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	LTCC000384	LTCCControl	020-5	LTC Control Insp	General Comments		
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Switching Operations	4	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Tank Paint Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Unknown Operations	0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushing Condition	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps C Ø	0.0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps B Ø	0.0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps A Ø	0.0	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Grounds in Place?	y	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	9 Month Operations	127	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	General Comments		
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/23/2022 15:27	Distribution	Finchville Quarterly Inspection	B0357	WithLTC	020-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCCControl	MC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCCControl	MC-Offline-Distribution	LTC Control Insp	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCCControl	MC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Vegetation	None	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations C Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations B Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations A Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations This Read Vac	7	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Switching Operations	1	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Unknown Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Maintenance Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Operations Counter AF	167	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Operations Counter AL	167	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations Ground	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	HVAC Filter Replaced?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations A Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations B Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTC000884	LTCControl	639-2	LTC Control Insp	All Connections OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTC000884	LTCControl	639-2	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTC000884	LTCControl	639-2	LTC Control Insp	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTC000884	LTCControl	639-2	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTC000884	LTCControl	639-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTC000884	LTCControl	639-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTC000884	LTCControl	639-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTC000884	LTCControl	639-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps C Ø	113.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps B Ø	144.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps A Ø	114.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations	10	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations Ground	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Amps C Ø	73.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Amps B Ø	78.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Amps A Ø	86.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	9 Month Operations	2	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Maintenance Operations	7	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AF	233	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AL	233	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations This Read Vac	8	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Switching Operations	1	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AL	203	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AF	203	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Maintenance Operations	6	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Operations A Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Operations B Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations C Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	9 Month Operations	11	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps A Ø	296.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps B Ø	290.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps C Ø	280.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Reading	.7470	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Max	75	°C
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Present	30	°C
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Unknown Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps C Ø	100.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps B Ø	102.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps A Ø	121.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	9 Month Operations	9	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Max	45	°C
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Reading	.9792	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	LTC Transformer Multiplier	15240	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Unknown Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	9 Month Operations	8	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps A Ø	186.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps B Ø	190.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps C Ø	191.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Switching Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Operations This Read Vac	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Present	30	°C
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Max	45	°C
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	LTC Totalizer Reading	14923.01	kw
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	All Connections OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AL	225	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AF	225	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Found Counter	135196	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Left Counter	135196	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Maintenance Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Current Tap Position	6L	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Max Tap Position	3L	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Min Tap Position	16L	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Operations Since Last Insp	2529	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations Ground	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations C Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations A Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations A Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations B Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations C Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations Ground	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Switching Operations	1	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Oil Temp Present	30	°C
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Oil Temp Max	55	°C
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	LTC Totalizer Reading	13446.00	kw
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations This Read Vac	1	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps B Ø	0.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps C Ø	0.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Switching Operations	1	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations This Read Vac	1	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AL	193	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AF	193	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Maintenance Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	9 Month Operations	9	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps A Ø	90.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps B Ø	112.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps C Ø	125.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	9 Month Operations	2	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps A Ø	450.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps B Ø	400.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations Ground	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations C Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations B Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations A Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Unknown Operations	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Unknown Operations	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Switching Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	9 Month Operations	4	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps A Ø	170.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps B Ø	209.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps C Ø	190.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations A Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations B Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations C Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations Ground	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Maintenance Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AF	155	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AL	155	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations This Read Vac	1	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Switching Operations	1	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Vegetation	None	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.7	amps
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	9 Month Operations	10	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Amps A Ø	0.0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations A Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations B Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations C Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations Ground	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Maintenance Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	9 Month Operations	10	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps A Ø	296.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps B Ø	290.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps C Ø	280.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations A Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations B Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations C Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations Ground	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Maintenance Operations	7	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AF	220	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AL	220	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations A Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations B Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations C Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Fault Operations Ground	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations This Read Vac	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations Counter AL	508	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Operations Counter AF	508	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Maintenance Operations	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations Ground	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations C Ø	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations B Ø	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Fault Operations A Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Maintenance Operations	5	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AF	180	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AL	180	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations This Read Vac	7	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Switching Operations	2	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Unknown Operations	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Regulator As Left Counter	41932	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Max Tap Position	5L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Current Tap Position	8L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	General Comments	ok	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	9 Month Operations	9	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps A Ø	84.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps B Ø	96.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps C Ø	94.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Vegetation	None	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Present	40	°C
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Max	40	°C
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	All Connections OK?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X1 Winding Temp Present	40	°C
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Max	40	°C
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Present	40	°C
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Max	35	°C
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Present	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	LTC Output Voltage Level	120.1	VAC
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	All Connections OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Leaks	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations Counter AF	211	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations Counter AL	211	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Operations This Read Vac	8	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Switching Operations	1	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Unknown Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	9 Month Operations	11	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps A Ø	194.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps B Ø	191.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Amps C Ø	196.0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Maintenance Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations Counter AF	156	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations Counter AL	156	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations This Read Vac	5	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Switching Operations	1	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Unknown Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations A Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations B Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations C Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Fault Operations Ground	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Ambient Temp	57	*F
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Maintenance Operations	9	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations Counter AF	189	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations Counter AL	189	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Operations This Read Vac	10	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000548	BreakerVacuum	724-2522	VCB Readings	Switching Operations	1	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Ambient Temp	59	*F
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations A Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations B Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations C Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Fault Operations Ground	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	9 Month Operations	11	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps A Ø	47.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps B Ø	55.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps C Ø	56.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps B Phase V	9.62	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps C Phase V	9.62	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations A Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations B Ø	2	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations C Ø	2	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations Ground	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Maintenance Operations	7	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Switching Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Unknown Operations	0	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Bushing Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Grounds in Place?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Switching Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations This Read Vac	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AL	58	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AF	58	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Maintenance Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Grounds in Place?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	General Comments	ok	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	General Comments	ok	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Bushing Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Grounds in Place?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations Ground	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations C Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations B Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations A Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations A Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations B Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations C Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations Ground	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.5	VDC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Positive DC Ground	30.0	VDC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000060	LTCMechanism	724-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	All Connections OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Operations Since Last Insp	367	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	23	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Min Tap Position	12L	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Max Tap Position	2L	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Current Tap Position	8L	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Left Counter	17401	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Found Counter	17401	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Maintenance Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AF	192	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AL	192	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations This Read Vac	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps C Ø	420.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps B Ø	420.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps A Ø	340.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	9 Month Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Bushing Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6138.72	kw
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Oil Temp Max	22	°C
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Oil Temp Present	18	°C
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Grounds in Place?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8526	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Present	25	°C
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Amps A Ø	36.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Amps B Ø	35.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Amps C Ø	35.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Operations A Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Operations B Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Operations C Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps C Ø	180.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps B Ø	120.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps A Ø	160.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Bushing Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Grounds in Place?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	9 Month Operations	5	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Unknown Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Switching Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations This Read Vac	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AL	99956	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AF	99956	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Maintenance Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations Ground	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations C Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations B Ø	0	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001818	BreakerVacuum	786-2539	VCB Readings	9 Month Operations	21	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Operations A Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps C Ø	170.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps B Ø	183.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps A Ø	189.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	9 Month Operations	18	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Operations Since Last Insp	754	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Min Tap Position	7L	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Max Tap Position	8R	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Current Tap Position	1R	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Left Counter	58001	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Found Counter	58001	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Operations Since Last Insp	340	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Max Tap Position	4L	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC Current Tap Position	9L	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC As Left Counter	83703	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	LTC As Found Counter	83703	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Maintenance Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AF	286	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AL	286	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations This Read Vac	1	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Switching Operations	1	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Unknown Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations Ground	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations C Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations B Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations A Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	All Connections OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations This Read Vac	8	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Switching Operations	1	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps C Ø	9.0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps B Ø	9.0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Amps A Ø	9.0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AF	187	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AL	187	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations This Read Vac	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Switching Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Unknown Operations	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Readings	9 Month Operations	5	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Unknown Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Vegetation	None	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	General Comments		
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	9 Month Operations	3	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps A Ø	100.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps B Ø	85.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps C Ø	66.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations A Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations B Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations C Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations Ground	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	All Connections OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Maintenance Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AF	73	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AL	73	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations This Read Vac	1	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Switching Operations	1	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps C Ø	160.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps B Ø	180.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps A Ø	180.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	9 Month Operations	11	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	9 Month Operations	4	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps C Ø	400.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	General Comments	ok	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	General Comments	ok	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Operations Since Last Insp	3	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Min Tap Position	11L	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Max Tap Position	10L	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Current Tap Position	11L	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Left Counter	239898	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Found Counter	239898	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps C Ø	178.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps B Ø	175.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps A Ø	218.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Switching Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations This Read Vac	1	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AL	489	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AF	489	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Maintenance Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations Ground	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations C Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations B Ø	1	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations A Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations Counter AL	185	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations Counter AF	185	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Maintenance Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Reading	.6920	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations Ground	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations C Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations B Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations A Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps C Ø	175.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations A Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations B Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations C Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations A Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations B Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	LTC Totalizer Reading	6643.20	kw
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Max	60	°C
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations C Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations Ground	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Maintenance Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AF	227	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AL	227	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations This Read Vac	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	9 Month Operations	3	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps A Ø	460.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Present	45	°C
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps B Ø	480.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps C Ø	485.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Switching Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Unknown Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Switching Operations	1	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations This Read Vac	1	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps C Ø	94.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps B Ø	85.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps A Ø	91.0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	9 Month Operations	8	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panels Dusted?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	General Comments		
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Evidence of Insects	None	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/28/2022 9:25	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Present	27	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Max	34	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Reading	.6410	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations Ground	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps B Ø	147.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps A Ø	151.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	9 Month Operations	2	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Maintenance Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AF	176	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AL	176	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations This Read Vac	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Switching Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Unknown Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Found Counter	77036	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Left Counter	77036	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Current Tap Position	1L	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Max Tap Position	7R	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Min Tap Position	7L	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Operations Since Last Insp	561	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations A Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Leaks	None	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Regulator As Left Counter	41239	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps C Ø	150.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations A Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations B Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations C Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations Ground	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations B Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	59	*F
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Reading	.8610	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Max	60	°C
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	LTC Totalizer Reading	8265.60	kw
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps C Ø	187.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps B Ø	192.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps A Ø	194.0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	9 Month Operations	10	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations Ground	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations C Ø	1	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations B Ø	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations A Ø	1	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps C Phase V	3.26	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps A Phase V	3.26	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	9 Month Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps A Ø	300.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps B Ø	160.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Amps C Ø	160.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Maintenance Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AF	203	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AL	203	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations This Read Vac	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Switching Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Unknown Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps B Ø	184.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps A Ø	145.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Max Tap Position	4L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	9 Month Operations	5	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps B Phase V	9.62	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	LTC Totalizer Reading	11538.00	kw
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Vegetation	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations A Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations B Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations C Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Fault Operations Ground	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Maintenance Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations Counter AF	178	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations Counter AL	178	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Operations This Read Vac	1	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Switching Operations	1	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Unknown Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #’s
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	9 Month Operations	6	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps A Ø	63.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps B Ø	66.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Amps C Ø	78.0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Found Counter	74262	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Left Counter	74262	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Current Tap Position	5L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Vegetation	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Min Tap Position	10L	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Operations Since Last Insp	264	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	General Comments	x	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	LTC Totalizer Reading	9216.00	kw
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Oil Temp Max	44	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Reading	.5120	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Max	30	°C
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Present	30	°C
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Present	24	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Max	36	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Operations Since Last Insp	225	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	General Comments	x	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Min Tap Position	11L	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Max Tap Position	2L	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Current Tap Position	5L	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Left Counter	92472	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Found Counter	92472	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Operations Since Last Insp	957	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Min Tap Position	13L	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Max Tap Position	1R	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Current Tap Position	2L	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Left Counter	66186	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Found Counter	66186	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Reading	.6294	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations This Read Vac	5	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AL	206	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations B Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	General Comments	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Present	40	°C
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Reading	.9414	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Operations Counter AF	159	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Operations Counter AL	159	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Operations This Read Vac	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Switching Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Unknown Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	9 Month Operations	3	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps A Ø	0.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps B Ø	0.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps C Ø	0.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations A Ø	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	LTC Totalizer Reading	11329.20	kw
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Max	55	°C
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Present	46	°C
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Maintenance Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Num Operations Last 9 Months	-1	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations Counter AF	60	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations Counter AL	60	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Maintenance Operations	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AF	206	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations This Read SF6	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations Ground	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations C Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Ambient Temperature	57	°F
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	LTC Totalizer Reading	6778.08	kw
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Found Counter	275667	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Left Counter	275667	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	LTC Totalizer Reading	12204.00	kw
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Oil Temp Max	42	°C
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Current Tap Position	7L	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Max Tap Position	5L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Current Tap Position	7L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Min Tap Position	9L	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Operations Since Last Insp	322	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Re-Paint	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Switching Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations This Read Vac	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AL	205	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AF	205	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Switching Operations	1	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Switching Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Max	49	°C
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Reading	.6780	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Maintenance Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Num Operations Last 9 Months	3	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AF	32	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps B Ø	475.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps A Ø	460.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations Ground	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	9 Month Operations	4	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Maintenance Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AF	207	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Unknown Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Fault Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	General Comments		
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Maintenance Operations	0	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations Counter AF	177	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations Counter AL	177	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations This Read Vac	2	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Switching Operations	2	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Unknown Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	General Comments		
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Switching Operations	1	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Reading	.1256	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Leaks	None	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Regulator As Left Counter	42366	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Maintenance Operations	7	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AF	225	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AL	225	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations This Read Vac	8	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations C Ø	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Unknown Operations	0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushing Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Ambient Temperature	58	*F
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Max	80	*C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Switching Operations	1	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Present	35	*C
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Fault Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps C Phase V	9.62	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations A Ø	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations B Ø	2	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations C Ø	2	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations Ground	0	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	All Connections OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	Follow-up Action Required?	n	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	LTC Operation Checked?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps C Ø	475.0	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	LTCC000908	LTCControl	609-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	General Comments	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Maintenance Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Operations Ground	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AF	44	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AL	44	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations This Read SF6	1	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Maintenance Operations	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AL	207	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations This Read Vac	2	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Switching Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Unknown Operations	0	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	LTC Totalizer Reading	753.60	kw
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 13:27	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/22/2022 14:52	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	General Comments		
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/22/2022 10:34	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Left Counter	9047	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Ambient Temperature	58	°F
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Fault Operations	0	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Operations Since Last Insp	424	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Tank Paint Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Switching Operations	1	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Foundation Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	General Comments		
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	General Comments	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Grounds in Place?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Maintenance Operations	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Num Operations Last 9 Months	2	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Found Counter	9047	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	General Comments		
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Follow-up Action Required?	n	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/22/2022 16:14	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/22/2022 14:18	Distribution	Simpsonville Quarterly Inspection	BK001820	BreakerVacuum	786-2528	VCB Readings	Fault Operations C Ø	0	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations This Read SF6	1	
2/22/2022 11:41	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AL	32	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	183	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Ambient Temp	50	F
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty B Ph V	80.51	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty A Ph V	98.85	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	9 Month Operations	15	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AL	656	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty C Ph V	78.12	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps A Ø	137.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AF	656	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations Ground	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations B Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations A Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps B Ø	129.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps C Ø	136.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps A Ø	25.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps B Ø	25.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps C Ø	25.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AF	315	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AL	315	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations This Read AM	1	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Unknown Operations	1	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	32.73	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	32.73	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	32.73	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	252	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps A Ø	180.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations This Read Vac	1	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Unknown Operations	1	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	9 Months Operations	6	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty A Ph AM	2.41	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty B Ph AM	8.43	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps A Ø	320.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	9 Month Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	9 Month Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	All Connections OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	LTC Operation Checked?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Maintenance Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Grounds in Place?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Foundation Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations C Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations Ground	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Grounds in Place?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Maintenance Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps A Ø	75.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps B Ø	55.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps C Ø	50.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations Counter AF	175	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations Counter AL	175	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations This Read Vac	1	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Switching Operations	1	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Unknown Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	110.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	100.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	100.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	1	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations A Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations B Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations C Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Months Operations	1	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps A Ø	100.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps B Ø	140.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps C Ø	120.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations A Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations B Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations C Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations Ground	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Foundation Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Bushing Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps C Ø	115.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps B Ø	110.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps A Ø	113.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	9 Month Operations	4	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Unknown Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Switching Operations	1	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations This Read Vac	1	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations Counter AL	170	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations This Read AM	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	393	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	393	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations A Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations B Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations Counter AF	169	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PF001335	PowerFuse	SN-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PF001335	PowerFuse	SN-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations C Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations B Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PF001334	PowerFuse	SN-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PF001334	PowerFuse	SN-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations A Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Bushing Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps C Ø	116.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps B Ø	96.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps A Ø	95.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushing Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps C Ø	185.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	9 Month Operations	2	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations Ground	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	131	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations C Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	423750	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	423750	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations Ground	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Maintenance Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AF	236	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AL	236	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations This Read AM	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations B Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations A Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations This Read AM	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	397	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	397	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AF	2063	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AL	2063	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations This Read AM	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Unknown Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	120.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	130.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	100.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations A Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations B Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations C Ø	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations Ground	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Foundation Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Operations Since Last Insp	128	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	22	°C
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Min Tap Position	11L	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Max Tap Position	6L	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Current Tap Position	9L	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Left Counter	16136	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Found Counter	16136	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps A Ø	2.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps B Ø	1.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps C Ø	2.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Present	24	°C
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Max	33	°C
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps A Ø	35.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	LTC Totalizer Reading	9115.20	kw
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps B Ø	27.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps C Ø	32.0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Bushing Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	9 Months Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps A Ø	0.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps B Ø	0.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps C Ø	0.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Foundation Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations Ground	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments	leaking around gauges	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	9 Month Operations	21	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Months Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AF	247	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AL	247	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Maintenance Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AF	572	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AL	572	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations This Read AM	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Switching Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Unknown Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Grounds in Place?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Maintenance Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations Counter AF	177	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations Counter AL	178	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations This Read Vac	1	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Switching Operations	1	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PNS1	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Unknown Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Switching Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations This Read Vac	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AL	43	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AF	43	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Maintenance Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Grounds in Place?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Unknown Operations	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	9 Month Operations	2	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Unknown Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps A Ø	230.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	3.61	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	3.61	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	9 Months Operations	2	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps A Ø	100.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty A Ph AM	1.2	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	9 Months Operations	4	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	9 Month Operations	2	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Present	18	°C
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Max	18	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations This Read Vac	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409607	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Reading	.5064	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Switching Operations	1	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations This Read Vac	1	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AL	711	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AF	711	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps C Ø	150.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps B Ø	125.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AF	478	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AL	478	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations This Read AM	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AF	366	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps C Ø	260.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps B Ø	230.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations This Read Vac	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AL	423	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AF	423	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps C Ø	136.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AL	366	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations This Read AM	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps B Ø	137.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps A Ø	108.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty C Ph V	35.87	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty B Ph V	50.22	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty A Ph V	43.84	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	General Comments		
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409607	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	252	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty A Ph V	70.95	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty B Ph V	70.15	%
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty C Ph V	48.63	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps A Ø	190.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps B Ø	209.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps C Ø	175.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 11:44	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/21/2022 16:50	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Operations Since Last Insp	500	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Max Tap Position	2R	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Current Tap Position	6L	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Left Counter	8062	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Found Counter	8062	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	General Comments	counter was not working so estimated number of ops for the quarter	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps B Ø	348.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps C Ø	386.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations A Ø	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations B Ø	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations C Ø	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations Ground	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Maintenance Operations	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AF	384	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AL	384	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations This Read Vac	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Switching Operations	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Unknown Operations	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps A Ø	395.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty A Ph V	.71	%
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	9 Month Operations	22	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Vegetation	None	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps B Ø	150.0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Unknown Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps C Ø	150.0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	KRC000415	RegulatorControl	542-1	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations C Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations Ground	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations This Read AM	1	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations A Ø	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations B Ø	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps C Ø	117.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps B Ø	119.0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	873	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	869	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Maintenance Operations	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AF	360	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AL	364	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps A Ø	21.0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	149	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations This Read Vac	4	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Switching Operations	4	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps A Ø	114.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	9 Months Operations	5	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	General Comments		
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Max Tap Position	5R	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Operations Since Last Insp	1068	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations Ground	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps A Ø	150.0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	9 Months Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations This Read AM	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AL	557	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AF	557	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps A Ø	120.0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	149	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps B Ø	140.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps C Ø	130.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Found Counter	230654	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Left Counter	230654	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations A Ø	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Operations B Ø	0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Current Tap Position	3L	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps C Ø	480.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps B Ø	480.0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps A Ø	480.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations A Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations B Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations C Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	9 Month Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Operations Ground	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	180.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Maintenance Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	199	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AL	888	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AF	888	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations	14	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps A Ø	60.0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps B Ø	60.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps C Ø	351.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps B Ø	331.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps A Ø	312.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	9 Months Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations Ground	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations C Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations B Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations A Ø	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Maintenance Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AF	4	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AL	8	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations This Read Vac	4	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Switching Operations	4	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Unknown Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps C Ø	120.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps B Ø	120.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps A Ø	60.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	9 Month Operations	12	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Maintenance Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations Counter AL	23	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AF	368	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AL	368	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations This Read AM	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Switching Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Switching Operations	1	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations This Read Vac	1	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AL	355	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AF	354	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations This Read Vac	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Btl needs nitrogen	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Unknown Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Maintenance Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Vegetation	None	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps C Ø	60.0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Operations Counter AF	23	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations A Ø	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations B Ø	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations C Ø	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations Ground	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	General Comments		
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	General Comments		
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations	14	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations Ground	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations Ground	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Unknown Operations	0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Max	40	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	psi
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Left Counter	80518	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Found Counter	80518	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTO220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	173	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps A Ø	21.0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	166	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	192	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	General Comments		
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	General Comments		
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallellND	Position
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Operations This Read Vac	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Operations Counter AL	36	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Operations Counter AF	36	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps C Ø	0.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps B Ø	0.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps A Ø	0.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	9 Months Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	9 Months Operations	3	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	95	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Min Tap Position	8L	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Amps C Ø	509.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Amps B Ø	490.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Amps A Ø	519.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	9 Month Operations	1	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7L	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BAT001578	Battery	473-Battery Bank	Battery Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations A Ø	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Operations Since Last Insp	115	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Min Tap Position	4L	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Maintenance Operations	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Max Tap Position	1L	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations Counter AF	50	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations Counter AL	50	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations This Read Vac	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Unknown Operations	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC As Left Counter	2208	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC As Found Counter	2323	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	LTC Operation Checked?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	All Connections OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.106	millivolts
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	9 Month Operations	1	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps A Ø	76.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps B Ø	80.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps C Ø	67.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	LTC Totalizer Reading	12279.60	kw
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Max	40	°C
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Present	40	°C
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Operations This Read Vac	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Reading	.6822	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Max	52	°C
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Present	45	°C
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	General Comments		
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Regulator As Left Counter	116622	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Amps A Ø	0.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	9 Month Operations	2	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Amps B Ø	0.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Amps C Ø	0.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Operations Counter AF	22	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001745	BreakerVacuum	WT-12KV BUS TIE SEC 4	VCB Readings	Operations Counter AL	22	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Regulator As Left Counter	62001	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations This Read AM	1	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AL	755	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AF	755	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations This Read AM	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AL	914	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AF	914	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	General Comments	B phase ioc	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations B Ø	1	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps C Ø	109.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps B Ø	90.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps A Ø	80.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001744	BreakerVacuum	WT-12KV TR 4	VCB Readings	Switching Operations	0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	General Comments		
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Current Tap Position	12L	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	°F
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Poor	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	40	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	45	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	40	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	40	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Present	40	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Max	40	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Regulator As Left Counter	114289	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Winding Temp Present	30	°C
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Winding Temp Max	40	°C
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Totalizer Meter Reading	.6270	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	572	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Min Tap Position	10L	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Max Tap Position	4L	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Current Tap Position	8L	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Left Counter	276659	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations Counter AF	61	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations Counter AL	61	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations This Read Vac	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Found Counter	276659	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty C Ph V	7.5	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty B Ph V	4.17	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty A Ph V	5.83	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	9 Month Operations	21	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Maintenance Operations	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Unknown Operations	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Switching Operations	8	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	9 Month Operations	5	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps A Ø	81.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps B Ø	84.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps C Ø	78.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations This Read Vac	8	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Switching Operations	1	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations This Read Vac	1	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AL	332	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AF	332	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps C Ø	133.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps B Ø	129.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps A Ø	129.0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AL	294	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AF	286	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Max Tap Position	16R	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations C Ø	0	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Operations Counter AF	86	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Operations Counter AL	86	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Operations This Read Vac	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	LTC Totalizer Reading	6019.20	kw
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	General Comments	Vent fan wouldn't run in bypass. I did check breaker.	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations Ground	0	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	9 Month Operations	2	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps A Ø	81.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps B Ø	76.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps C Ø	73.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Oil Temp Max	35	°C
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Operations Counter AF	13	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Operations Counter AL	13	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Operations This Read Vac	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	9 Month Operations	4	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Amps A Ø	134.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Amps B Ø	140.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Readings	Amps C Ø	130.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001655	BreakerVacuum	WT-1210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Vegetation	None	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	General Comments		
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Foundation Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations Ground	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations C Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations B Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations A Ø	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps C Ø	161.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps B Ø	155.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps A Ø	166.0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	9 Month Operations	4	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7728	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Ambient Temp	63	*F
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps C Ø	260.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps B Ø	290.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps A Ø	265.0	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	9 Month Operations	4	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Present	40	*C
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Max	40	*C
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1854.72	kw
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Unknown Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Switching Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations This Read Vac	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations Counter AL	36	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations Counter AF	36	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Maintenance Operations	0	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/17/2022 12:37	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	General Comments		
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/17/2022 7:33	Distribution	Metal And Thermit Quarterly Inspection	BCH001492	Charger	473-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/17/2022 10:41	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:34	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Max Tap Position	16R	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	28	°C
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Operations Since Last Insp	604	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations A Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Current Tap Position	5L	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Regulator As Left Counter	3919	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations Ground	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations A Ø	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Present	30	°C
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Max	45	°C
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC As Found Counter	23782	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Left Counter	23782	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Current Tap Position	7L	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	9 Month Operations	1	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty A Ph V	21.52	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty B Ph V	19.13	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty C Ph V	13.55	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps A Ø	350.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps B Ø	303.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps C Ø	290.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Months Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	9 Month Operations	1	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø	0.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps A Ø	901.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps B Ø	890.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps C Ø	905.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Unknown Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Switching Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AL	141	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AF	141	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Maintenance Operations	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	LTC Operation Checked?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	All Connections OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Vegetation	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Max	41	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Present	21	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	32	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	18	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	42	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	31	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	18	°C
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	9 Month Operations	5	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps A Ø	14.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps B Ø	14.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps C Ø	12.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps A Phase V	4.94	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Left Counter	45201	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Found Counter	45201	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Max	36	°C
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	LTC Totalizer Reading	4446.72	kw
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Reading	1.0704	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Max	50	°C
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Present	40	°C
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Operations Since Last Insp	638	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	All Connections OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	LTC Operation Checked?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	LTC Totalizer Reading	15413.76	kw
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Min Tap Position	15L	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Vegetation	None	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	421	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	31	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Reading	.4632	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6436	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AF	273	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AL	273	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Switching Operations	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations This Read Vac	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations Counter AL	204	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations Counter AF	203	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Maintenance Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø	29.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C Ø Max	29.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Switching Operations	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations This Read Vac	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AL	195	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AF	194	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Maintenance Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations Ground	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations C Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations B Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations A Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Switching Operations	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	9 Month Operations	2	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	9 Month Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps A Ø	0.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations This Read Vac	2	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AL	186	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AF	185	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Operations Counter	2004	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations Ground	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations C Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations B Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations A Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps C Ø	160.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps B Ø	180.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Amps A Ø	182.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	9 Month Operations	2	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Unknown Operations	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø Max	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø	.7	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations Counter AL	386	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations This Read SF6	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Switching Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø Max	.7	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø Max	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Maintenance Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Num Operations Last 9 Months	8	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Operations Counter AF	386	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Operations Since Last Insp	1131	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	60	°C
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	General Comments	Actual counter	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Fault Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Months Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Min Tap Position	10L	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Max Tap Position	6R	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Current Tap Position	1L	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Left Counter	62763	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps C Ø	169.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps B Ø	165.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Readings	Amps A Ø	170.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Found Counter	62763	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Switching Operations	0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Vegetation	None	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø Max	51.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø	51.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø Max	60.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø	60.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø Max	57.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø	57.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Months Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Months Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø	40.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A Ø Max	40.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø	27.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B Ø Max	27.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations A Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AF	2559	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AL	2559	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Unknown Operations	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AL	11589	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AF	11589	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations C Ø	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations This Read Vac	2	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AL	1132	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AF	1132	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø Max	60.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø	60.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø Max	40.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø	40.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø Max	60.0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Switching Operations	1	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Unknown Operations	1	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø	60.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Months Operations	1	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Unknown Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Switching Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AL	185	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AF	185	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Switching Operations	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps C Phase V	3.15	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations A Ø	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations B Ø	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations C Ø	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations Ground	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Maintenance Operations	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AF	215	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AL	216	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	General Comments		If no, which cells in comments
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	9 Months Operations	1	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Unknown Operations	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Found Counter	70233	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Left Counter	70233	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps C Ø	0.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps B Ø	0.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps A Ø	0.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	9 Month Operations	2	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	All Connections OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	LTC Operation Checked?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AL	1044	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AF	1044	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Switching Operations	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations This Read Vac	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AL	188	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AF	187	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Maintenance Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Maintenance Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations Counter AF	211	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations Counter AL	212	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Operations This Read Vac	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Switching Operations	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations Ground	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations C Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations B Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations A Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations Ground	0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps B Ø	155.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps C Ø	160.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	LTCMechanism	S-TRANS 1	LTC Counter Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps B Ø	170.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps A Ø	175.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	9 Month Operations	2	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Regulator As Left Counter	5913	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	*F
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations Ground	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps C Ø	175.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0110	RecloserElectronic	687-2312	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Maintenance Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations Counter AF	155	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations Counter AL	155	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Switching Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	116	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Left Counter	98694	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Found Counter	98694	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Amps A Ø	160.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations C Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Fault Operations Ground	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	9 Month Operations	2	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0053	BreakerVacuum	540-0334	VCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AL	747	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AF	747	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Months Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	72	°C
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations Ground	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations C Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations B Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations A Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø	66.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø Max	66.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø	54.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø Max	54.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations C Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations C Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps C Ø	108.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps B Ø	122.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps A Ø	100.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty C Ph V	17.54	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty B Ph V	32.68	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty A Ph V	30.29	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	9 Month Operations	3	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations A Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations B Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations C Ø	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations Ground	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Switching Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AL	254	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AF	254	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Maintenance Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	95	°C
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations Ground	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø	47.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø Max	47.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø	111.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø Max	111.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø	91.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø Max	91.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø Max	200.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø	200.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø Max	100.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø	100.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø Max	300.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø	300.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Months Operations	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps B Ø Max	0.0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF001281	PowerFuse	S-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF001282	PowerFuse	S-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps C Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AL	398	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AF	398	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AL	354	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AF	354	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations B Ø	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Maintenance Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Grounds in Place?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	9 Months Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø	72.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø Max	72.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	9 Month Operations	2	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AF	801	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Operations Counter AL	801	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps A Ø	170.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps B Ø	170.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps C Ø	170.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AF	4991	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AL	4991	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF001282	PowerFuse	S-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF001282	PowerFuse	S-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Vegetation	None	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Switching Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations This Read Vac	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AL	168	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AF	168	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps A Ø	78.0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps B Ø	35.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps A Ø	30.0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	9 Month Operations	3	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps A Ø	160.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty C Ph V	4.78	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AF	244	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AL	245	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	9 Month Operations	2	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations This Read Vac	2	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Switching Operations	1	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Unknown Operations	1	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO185	LTCMechanism	S-TRANS 2	LTC Counter Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Found Counter	12302	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Left Counter	12302	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LTO185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	9 Month Operations	15	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps A Ø	120.0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps B Ø	105.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Operations Counter	109	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps C Ø	165.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps B Ø	172.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	All Connections OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Months Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø	108.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø Max	108.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø	72.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø Max	72.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø	96.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø Max	96.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	LTC Operation Checked?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps C Ø	110.0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations A Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations B Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations C Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations Ground	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Maintenance Operations	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations Counter AF	256	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations Counter AL	258	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations This Read Vac	2	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Switching Operations	2	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	184	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	All Connections OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	LTC Operation Checked?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps C Ø	195.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps B Ø	205.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps A Ø	199.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty C Ph V	4.78	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty B Ph V	7.97	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	9 Month Operations	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Maintenance Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AF	211	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AL	212	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations This Read Vac	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Switching Operations	1	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Landscape Good Condition?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	General Comments	Yard light by TR1 is flashing and vegetation needs attention...Pic sent to Stinson	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Unknown Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Switching Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AL	168	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AF	168	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Maintenance Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Unknown Operations	0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps C Ø	490.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps B Ø	515.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Amps A Ø	490.0	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	9 Month Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Switching Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AL	190	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AF	190	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Maintenance Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations B Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Left Counter	159454	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Found Counter	159454	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps C Ø	40.0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Left Counter	303901	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Found Counter	303901	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps A Phase V	3.15	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps B Phase V	3.15	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps C Phase V	3.15	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations A Ø	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations B Ø	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations C Ø	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations Ground	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Follow-up Action Required?	n	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Maintenance Operations	0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations B Ø	0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Operations Counter	1797	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	LTC Totalizer Reading	3412.80	kw
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Max	32	°C
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps C Ø	3.0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps A Ø	19.0	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Tank Oil Level	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Reading	.4740	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Winding Temp Max	0	°C
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Winding Temp Present	0	°C
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Unknown Operations	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Operations Since Last Insp	329	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Max Tap Position	3R	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Operations Since Last Insp	806	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Min Tap Position	11L	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Max Tap Position	8R	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Current Tap Position	2L	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations C Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Vegetation	None	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AL	794	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AF	794	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Unknown Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Switching Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AL	156	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AF	312	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AL	312	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Max	30	°C
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations A Ø	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	666.00	kw
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1100	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AF	4513	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AL	4513	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations This Read AM	3	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AF	391	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AL	391	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø	10.0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Operations B Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	General Comments		
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Reading	.9130	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø Max	0.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø Max	0.0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	9 Months Operations	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AL	844	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AF	844	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps C Ø	73.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps B Ø	71.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps A Ø	75.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty A Ph V	3.19	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	9 Month Operations	1	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	LTC Totalizer Reading	4382.40	kw
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Months Operations	1	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	LTC Totalizer Reading	6307.20	kw
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø Max	107.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø	107.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø Max	96.0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	General Comments		
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Oil Temp Max	37	°C
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø	96.0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Oil Temp Present	26	°C
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø Max	110.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø	110.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Months Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Months Operations	0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Present	22	°C
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Max	33	°C
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	9 Months Operations	0	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Reading	.6570	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 12:57	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AF	156	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Maintenance Operations	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø Max	300.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø	300.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø Max	300.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AL	929	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AF	929	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø	300.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø Max	300.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps A Ø Max	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps B Ø Max	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø Max	10.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø	10.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø Max	10.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø	10.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø Max	10.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Months Operations	7	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø	102.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø Max	102.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø	103.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø Max	103.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø	70.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø Max	70.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps A Phase AM	19.09	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AF	418	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AL	418	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations This Read AM	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	9 Months Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Unknown Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations C Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations C Ø	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Vegetation	None	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AL	257	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AF	257	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Maintenance Operations	0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Switching Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	General Comments		
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/16/2022 15:47	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	General Comments		
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Months Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø	300.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Follow-up Action Required?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	General Comments		
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF001281	PowerFuse	S-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Months Operations	1	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Amps A Ø	0.0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	PF001281	PowerFuse	S-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø Max	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø Max	0.0	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations C Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations Ground	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	General Comments		
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Amps C Ø Max	.6	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations A Ø	2	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations B Ø	1	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Maintenance Operations	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AF	917	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AL	917	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/16/2022 11:31	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Months Operations	0	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/16/2022 7:13	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/17/2022 9:24	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 7:26	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	111	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations This Read Vac	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations Counter AL	100	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations Counter AF	100	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AF	369	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Regulator As Left Counter	37569	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AL	369	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations This Read AM	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Switching Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations This Read Vac	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AL	168	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AF	168	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Maintenance Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Operations Counter AL	115	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Unknown Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Switching Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	SF6 Pressure	86	psi
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Left Counter	10240	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Found Counter	10240	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AF	357	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AL	357	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Maintenance Operations	13	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Num Operations Last 9 Months	25	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Operations This Read SF6	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Unknown Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Switching Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	SF6 Pressure	62	psi
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations This Read AM	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Operations Counter AF	88	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Operations Counter AL	88	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Operations This Read SF6	13	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Min Tap Position	11L	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Ambient Temperature	49	°F
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Fault Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Fault Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	General Comments	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Maintenance Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001725	BreakerSF6	695-618	GCB Patrol Inspection	General Comments	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Unknown Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Num Operations Last 9 Months	17	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Operations Counter AF	115	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	TANK Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps A Ø	750.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	9 Months Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	33	*C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	50	*C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	12	*C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	57	*C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	12	*C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	57	*C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	12	*C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	57	*C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3123.20	kw
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AF	533	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AL	533	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Unknown Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	MD-TRANS 2	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	200	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Present	31	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Max	37	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	9 Months Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.6	psi
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps C Ø	750.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps B Ø	750.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps A Ø	100.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps B Ø	100.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps C Ø	110.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Left Counter	172303	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Found Counter	172303	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Regulator As Left Counter	37427	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	9 Months Operations	7	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations Ground	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	9 Month Operations	3	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps A Ø	0.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps B Ø	0.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps C Ø	59.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Present	23	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Max	48	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	12	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	57	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9760	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	9 Month Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps A Ø	206.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps B Ø	200.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps C Ø	205.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps A Ø	32.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps B Ø	24.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	TX000262	GroundTransformer	GL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	9 Month Operations	2	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	VRR Base Voltage AF	1245.0	VAC
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	LTCC000934	LTCControl	666-1	LTC Control Insp	All Connections OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AL	122	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AF	122	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Maintenance Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	General Comments	This is the correct VC	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AF	305	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Trash Emptied?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTC000803	LTCControl	795-1	LTC Control Insp	All Connections OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	LTC000934	LTCControl	666-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AF	125	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AL	125	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Unknown Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	9 Month Operations	2	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AL	571	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AF	571	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Unknown Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations This Read AM	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AL	256	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AF	256	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Maintenance Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps C Ø	150.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps B Ø	180.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps A Ø	200.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	9 Months Operations	2	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Maintenance Operations	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps C Ø	220.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps B Ø	220.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps A Ø	200.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	9 Month Operations	2	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Present	35	°C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Max	35	°C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Reading	.9468	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	LTC Totalizer Reading	11728.80	kw
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Reading	.7098	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps A Ø	90.0	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps B Ø	75.0	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps C Ø	105.0	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Follow-up Action Required?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	General Comments	HAS 3 COUNTERS PLEASE ADD PLACE TO RECORD EACH PHASE	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Operations Counter	282116	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	9 Month Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	LTC Totalizer Reading	6814.08	kw
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Max	67	°C
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Present	53	°C
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps A Ø	9.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps B Ø	9.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps C Ø	9.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Maintenance Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AF	217	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AL	217	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations This Read Vac	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Switching Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Unknown Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Max	45	°C
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCCControl	795-1	LTC Control Insp	VRR Time Delay	45	Seconds
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCCControl	795-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCCControl	795-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCCControl	795-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Reading	1.6290	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	9 Month Operations	1	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	40	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	25	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Max	25	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Switching Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations Ground	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations C Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations B Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations A Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	9 Month Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	9 Months Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	9 Month Operations	5	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	9 Month Operations	7	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations Counter AL	73	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations Counter AF	73	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	9 Month Operations	1	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps A Ø	0.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps B Ø	0.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps C Ø	0.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps C Ø	20.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps B Ø	75.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations Counter AL	493	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations Counter AF	493	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations Ground	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Current Tap Position	2L	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps A Ø	61.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AF	134	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AL	134	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps A Ø	0.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps B Ø	0.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps C Ø	0.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations B Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Negative DC Ground	18.4	VDC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Positive DC Ground	18.0	VDC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Maintenance Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AF	187	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments	2 8ft bulbs need changed to LED	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	9 Month Operations	2	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AF	223	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AL	223	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	9 Months Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AL	187	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations This Read Vac	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Switching Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	9 Month Operations	4	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations B Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Switching Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations This Read Vac	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AL	193	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AF	193	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Maintenance Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Max	45	°C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	LTC Totalizer Reading	17042.40	kw
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	General Comments	Job order created to replace guage max needle is missing	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Unknown Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations This Read AM	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AL	218	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AF	218	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Maintenance Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Max	35	°C
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	LTC Totalizer Reading	14078.88	kw
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	9 Month Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations	2	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AF	9	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AL	9	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations This Read AM	2	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Unknown Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Unknown Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Reading	1.9554	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps B Ø	100.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AF	184	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps A Ø	100.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AF	204	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AL	204	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Switching Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AL	168	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AF	168	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations This Read Vac	2	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Switching Operations	2	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Unknown Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Operations Since Last Insp	1297	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Min Tap Position	6L	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Max Tap Position	15R	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Current Tap Position	4R	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Left Counter	257639	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Found Counter	257630	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Maintenance Operations	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps C Ø	140.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AL	184	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	9 Month Operations	1	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AF	243	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AL	245	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AF	167	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AL	167	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	9 Months Operations	2	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps A Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations Ground	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	9 Month Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps A Ø	125.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps B Ø	123.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps C Ø	121.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	General Comments	Breaker out of service	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	37.04	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	37.04	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	37.04	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	165	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.5	psi
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC As Left Counter	11071	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AL	114	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AF	114	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC As Found Counter	11071	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Maintenance Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AF	747	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AL	747	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations This Read AM	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps C Ø	0.0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Time Delay	30	Seconds
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Base Voltage AL	123.6	VAC
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Base Voltage AF	123.6	VAC
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	All Connections OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations Counter AF	152	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations Counter AL	152	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations This Read Vac	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Unknown Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	6	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations A Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations Ground	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	9 Month Operations	29	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AF	126	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Reading	.6894	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AL	126	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Switching Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	9 Month Operations	1	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	LTC Totalizer Reading	4963.68	kw
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Max	67	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Present	32	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps C Ø	130.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps B Ø	141.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps A Ø	87.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps A Ø	60.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps B Ø	60.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps C Ø	60.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations A Ø	1	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations B Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations C Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Unknown Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Switching Operations	1	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations This Read Vac	2	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AL	331	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AF	331	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Maintenance Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AF	612	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AL	612	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Found Counter	36070	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Left Counter	36070	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Operations Since Last Insp	1362	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Min Tap Position	8L	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Max Tap Position	4R	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations This Read AM	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	LTC Totalizer Reading	10454.40	kw
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Max	80	°C
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Present	40	°C
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Reading	1.0890	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	9 Month Operations	20	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps A Ø	138.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps B Ø	165.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps C Ø	116.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	9 Months Operations	3	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps C Ø	425.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps B Ø	420.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps A Ø	425.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	9 Month Operations	1	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	General Comments	Breaker open	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	116	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Unknown Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Switching Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations This Read Vac	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AL	728	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AF	728	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Maintenance Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	116	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AL	139	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AF	139	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	9 Months Operations	6	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps A Ø	10.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps B Ø	10.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps C Ø	10.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	9 Month Operations	5	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	VRR Base Voltage AF	116.8	VAC
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	VRR Base Voltage AF	117.0	VAC
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Max Tap Position	10R	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Regulator As Left Counter	19412	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	9 Month Operations	3	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	9 Months Operations	2	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps A Ø	100.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps B Ø	100.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Current Tap Position	5L	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Max Tap Position	7R	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Regulator As Left Counter	16911	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	CH000504	ControlHouse	695-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	9 Month Operations	10	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AL	142	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Unknown Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Switching Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations This Read Vac	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AL	230	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AF	230	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Maintenance Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations Ground	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AF	142	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Maintenance Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AF	175	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AL	176	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations This Read Vac	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Switching Operations	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	9 Month Operations	3	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps A Ø	329.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps B Ø	367.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps C Ø	334.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps C Ø	100.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations A Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Maintenance Operations	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Unknown Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Switching Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations This Read Vac	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AL	830	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AF	830	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Maintenance Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations Ground	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations C Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations A Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Switching Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Amps B Ø	0.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Readings	Amps A Ø	0.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001724	BreakerSF6	695-728	GCB Patrol Inspection	Ambient Temperature	49	*F
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Unknown Operations	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Regulator As Left Counter	33770	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	*C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	*C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	35	*C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	*C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	*C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	*C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AF	114	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AL	114	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	*C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	*C
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Min Tap Position	13L	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Max Tap Position	5L	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Gaugel(s) Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Current Tap Position	5L	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AL	232	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AF	232	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Maintenance Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Max Tap Position	7R	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Regulator As Left Counter	18138	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations B Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps C Ø	78.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps B Ø	55.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps A Ø	64.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	9 Month Operations	10	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AF	40	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AL	42	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations This Read Vac	2	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Switching Operations	2	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	40	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	40	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	180	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Maintenance Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations Counter AF	136	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations Counter AL	136	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations This Read Vac	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	9 Month Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps A Ø	249.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps B Ø	238.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Time Delay	45	Seconds
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	All Connections OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps C Ø	240.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations Counter AF	106	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations Counter AL	106	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations This Read Vac	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps C Ø	80.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps B Ø	80.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps A Ø	90.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	9 Months Operations	9	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	88	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	31	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Left Counter	21339	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Found Counter	21339	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	9 Month Operations	4	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps A Ø	1.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps B Ø	1.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps C Ø	1.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	9 Month Operations	4	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Found Counter	256702	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	9 Months Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps A Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps B Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps C Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	9 Month Operations	2	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps A Ø	260.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps B Ø	290.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps C Ø	240.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Left Counter	256711	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Current Tap Position	6L	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Max Tap Position	4R	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Min Tap Position	11L	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Operations Since Last Insp	644	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps A Ø	178.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps B Ø	183.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps C Ø	282.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AF	29	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AL	29	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF001268	PowerFuse	GL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF001268	PowerFuse	GL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF001268	PowerFuse	GL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF001269	PowerFuse	GL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF001269	PowerFuse	GL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF001269	PowerFuse	GL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Unknown Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	9 Month Operations	3	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps A Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps B Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps C Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	General Comments	Breaker racked out	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Maintenance Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations Counter AF	103	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations Counter AL	103	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations This Read Vac	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Unknown Operations	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Operations Since Last Insp	549	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Max Tap Position	8R	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Left Counter	54687	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Found Counter	54687	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	9 Month Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Present	17	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Max	36	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Unknown Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Switching Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Operations This Read Vac	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Operations Counter AL	161	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Operations Counter AF	161	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Maintenance Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps B Ø	0.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Amps A Ø	78.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Amps B Ø	70.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001828	BreakerVacuum	695-1	VCB Readings	9 Month Operations	2	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	All Connections OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AL	652	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AF	652	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Time Delay	45	Seconds
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AF	631	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	9 Month Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AL	249	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AF	249	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Maintenance Operations	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Operations Since Last Insp	20	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	*C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	*C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Min Tap Position	7L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.1	psi
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Present	25	*C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Max	40	*C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	LTC Totalizer Reading	8359.20	kw
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	General Comments	ok	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AF	226	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AL	226	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Unknown Operations	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	9 Month Operations	4	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps A Ø	185.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps B Ø	200.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps C Ø	230.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Max	37	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Present	22	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps A Ø	234.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps B Ø	241.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps C Ø	293.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Switching Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Max Tap Position	2R	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Left Counter	43611	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Found Counter	43611	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	9 Month Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps A Ø	889.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps C Ø	256.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps B Ø	261.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps A Ø	266.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	9 Month Operations	4	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps B Ø	874.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps C Ø	873.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Oil Temp Present	15	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Oil Temp Max	20	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	LTC Totalizer Reading	13656.00	kw
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps C Ø	39.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps B Ø	36.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps A Ø	18.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Operations Since Last Insp	651	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Max Tap Position	9R	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Current Tap Position	1R	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AL	236	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Min Tap Position	10L	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Max Tap Position	4R	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Left Counter	107122	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Found Counter	107122	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Parallel / Ind. Sw Position	parallel	Position
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	All Connections OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Winding Temp Present	20	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Winding Temp Max	25	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Totalizer Meter Reading	.5690	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations Ground	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations C Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations B Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations A Ø	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	TX000282	WithLTC	695-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Ambient Temp	20	°F
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	9 Month Operations	3	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	9 Month Operations	4	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps A Ø	110.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps B Ø	150.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps C Ø	185.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps B Ø	245.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps A Ø	255.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	9 Month Operations	4	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	PF001333	PowerFuse	PV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	PF001333	PowerFuse	PV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations C Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Present	25	°C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Max	36	°C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Reading	.4644	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AF	236	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Maintenance Operations	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps C Ø	250.0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Left Counter	108493	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Found Counter	108493	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps C Ø	12.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AF	503	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Unknown Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Switching Operations	1	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Operations This Read Vac	1	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Operations Counter AL	94	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Operations Counter AF	94	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Maintenance Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Amps C Ø	40.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Amps B Ø	50.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Amps A Ø	55.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	9 Month Operations	13	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Unknown Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AL	12	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AF	12	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AL	503	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps C Ø	500.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps B Ø	600.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps A Ø	600.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	9 Month Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	9 Month Operations	1	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps A Ø	11.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps B Ø	13.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps A Ø	154.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps B Ø	150.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps C Ø	153.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Unknown Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AF	142	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AL	142	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Unknown Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Maintenance Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Unknown Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Switching Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Operations This Read Vac	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Operations Counter AL	122	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Operations Counter AF	122	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Maintenance Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AF	194	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Amps C Ø	0.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Amps B Ø	0.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Amps A Ø	0.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001539	BreakerVacuum	695-BT2-1	VCB Readings	9 Month Operations	12	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AF	170	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AL	170	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	9 Months Operations	3	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	25	°C
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Switching Operations	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	9 Month Operations	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Switching Operations	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	9 Month Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps A Ø	0.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	37	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	22	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	37	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	22	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	37	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	22	°C
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Maintenance Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AF	189	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AL	189	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations This Read Vac	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Switching Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Operations Counter AL	174	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Operations Counter AF	174	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Maintenance Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Amps C Ø	0.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Amps B Ø	0.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Amps A Ø	0.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001543	BreakerVacuum	695-0456	VCB Readings	9 Month Operations	12	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Maintenance Operations	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AF	290	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AL	292	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations This Read Vac	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Switching Operations	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AF	275	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AL	277	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations This Read Vac	2	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Amps C Ø	125.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Amps B Ø	100.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Amps A Ø	120.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001541	BreakerVacuum	695-0451	VCB Readings	9 Month Operations	10	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Unknown Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Switching Operations	1	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Operations This Read Vac	1	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Operations Counter AL	108	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Operations Counter AF	108	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Maintenance Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Operations Ground	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001540	BreakerVacuum	695-0450	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001271	PowerFuse	MD-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001271	PowerFuse	MD-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	9 Months Operations	7	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001272	PowerFuse	MD-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001272	PowerFuse	MD-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001272	PowerFuse	MD-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001273	PowerFuse	MD-1445 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001273	PowerFuse	MD-1445 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001273	PowerFuse	MD-1445 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Maintenance Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations Ground	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps C Ø	0.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps B Ø	0.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps A Ø	0.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	9 Month Operations	5	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	197	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	197	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AL	506	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AF	506	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001274	PowerFuse	MD-1446 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001274	PowerFuse	MD-1446 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001274	PowerFuse	MD-1446 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	246	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001275	PowerFuse	MD-1447 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001275	PowerFuse	MD-1447 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001275	PowerFuse	MD-1447 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001276	PowerFuse	MD-1448 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Switching Operations	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations This Read Vac	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AL	236	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AF	235	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Maintenance Operations	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	20	*F
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations Ground	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations C Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations B Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations A Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallellND	Position
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	All Connections OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Reading	2.3126	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Vegetation	None	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	LTC Totalizer Reading	4162.68	kw
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Max	25	°C
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Present	25	°C
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	General Comments	DNO on	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AF	180	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AL	180	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Unknown Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Maintenance Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	9 Months Operations	1	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps C Ø	180.0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Switching Operations	1	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations This Read Vac	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AL	194	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AF	193	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AF	128	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AL	128	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations This Read AM	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	SWG000226	Switchgear	695-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AL	558	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AF	558	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Maintenance Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	9 Month Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	229	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	229	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Trash Emptied?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Present	19	°C
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Max	51	°C
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Reading	.0180	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Present	21	°C
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Max	52	°C
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	172.80	kw
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1450	psi
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.2	psi
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	All Connections OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	LTC000158	LTCControl	833-2	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations This Read Vac	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Unknown Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Switching Operations	2	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations This Read Vac	2	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AL	254	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AF	254	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Maintenance Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AF	601	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AL	601	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Unknown Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Operations Since Last Insp	900	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC Operations Since Last Insp	499	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC Min Tap Position	12L	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC Max Tap Position	1L	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC Current Tap Position	6L	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC As Left Counter	3434	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	LTC As Found Counter	3434	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCM000120	LTCMechanism	695-2	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	2	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Regulator As Left Counter	23440	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000917	LTCControl	695-2	LTC Control Insp	All Connections OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Oil Temp Max	30	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	9 Month Operations	1	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps A Ø	60.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps B Ø	59.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps C Ø	62.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Insulators In Good Condition?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AF	221	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AL	491	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AF	491	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001276	PowerFuse	MD-1448 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001276	PowerFuse	MD-1448 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001277	PowerFuse	MD-1449 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001277	PowerFuse	MD-1449 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001277	PowerFuse	MD-1449 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	245	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps C Ø	150.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps B Ø	150.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps A Ø	150.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	9 Months Operations	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Winding Temp Max	30	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Found Counter	154448	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Left Counter	154448	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	336	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1311	BreakerVacuum	AS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps C Ø	110.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	VRR Base Voltage AF	117.3	VAC
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps B Ø	110.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps A Ø	120.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	9 Months Operations	1	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	9 Months Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AL	221	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	117.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	113.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	116.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001278	PowerFuse	MD-1450 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001278	PowerFuse	MD-1450 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001278	PowerFuse	MD-1450 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001279	PowerFuse	MD-1451 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001279	PowerFuse	MD-1451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001279	PowerFuse	MD-1451 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001280	PowerFuse	MD-1452 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001280	PowerFuse	MD-1452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF001280	PowerFuse	MD-1452 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps C Ø	141.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps B Ø	140.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps A Ø	162.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	9 Month Operations	3	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Maintenance Operations	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AF	191	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AL	193	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations This Read Vac	2	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Switching Operations	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Maintenance Operations	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AF	270	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AL	272	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations This Read Vac	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Switching Operations	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Unknown Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Unknown Operations	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps A Ø	243.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	9 Month Operations	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Present	22	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Max	24	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Reading	.5172	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Operational?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Condition	Leaks	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Present	24	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Max	80	°C
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	LTC Totalizer Reading	7447.68	kw
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	General Comments	Pump will not turn on.	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Present	10	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Max	15	°C
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Maintenance Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	LTC Totalizer Reading	306.00	kw
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23498	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Reading	.7380	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Present	25	°C
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	9 Month Operations	4	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Found Counter	24034	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Left Counter	24034	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	5L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	3L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	8L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	26	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	7	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	456	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps C Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps B Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	9 Month Operations	0	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	LTCC00682	LTCControl	422-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	LTCC00682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	LTCC00682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	LTCC00682	LTCControl	422-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Found Counter	33275	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	oil level low Pic sent to Stinson	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Maintenance Operations	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps C Ø	165.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps B Ø	130.0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps A Ø	160.0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	All Connections OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	9 Month Operations	10	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	LTCC000940	LTCControl	777-1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps A Ø	120.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps B Ø	160.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps C Ø	100.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Present	5	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Max	10	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Reading	.0170	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps C Ø	231.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps B Ø	236.0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	9 Month Operations	4	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7084.80	kw
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AL	307	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations This Read Vac	2	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Switching Operations	2	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Unknown Operations	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Oil Temp Max	20	°C
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps A Ø	215.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps B Ø	175.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps C Ø	220.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Oil Temp Present	15	°C
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AF	236	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AL	236	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Unknown Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Ambient Temperature	60	°F
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AL	440	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AF	440	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations C ∅	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations B ∅	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps A ∅	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps B ∅	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps C ∅	0.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	9 Month Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps A ∅	81.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps B ∅	77.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps C ∅	86.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations A ∅	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Regulator As Left Counter	24835	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations B ∅	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Maintenance Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Maintenance Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Num Operations Last 9 Months	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AF	78	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AL	78	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations This Read SF6	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 1	59	psi
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 2	59	psi
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 3	58	psi
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Switching Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	30	°C
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Vegetation	None	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps C Ø	315.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps B Ø	320.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps A Ø	316.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty C Ph V	31.78	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty B Ph V	36.08	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Accumulated Fault Duty A Ph V	37.79	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	9 Month Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Fault Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	General Comments	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations A Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations B Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations C Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations Ground	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Maintenance Operations	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AF	202	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AL	204	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations This Read Vac	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Switching Operations	2	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Unknown Operations	0	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Unknown Operations	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	9 Month Operations	4	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps A Ø	60.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps B Ø	65.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps C Ø	90.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	East side door handle is broken	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Min Tap Position	6L	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Max Tap Position	4R	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Current Tap Position	3L	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Left Counter	211131	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AL	317	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AF	317	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Found Counter	211131	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	9 Month Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	397.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	366.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	390.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Switching Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	347	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	346	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations This Read Vac	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	All Connections OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AL	209	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AF	209	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Operations Since Last Insp	446	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations This Read Vac	1	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations Ground	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Switching Operations	1	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps A Ø	0.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	9 Months Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AL	549	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AF	549	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AL	130	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AF	130	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Maintenance Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations Ground	0	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AF	245	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AL	245	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AF	942	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AL	942	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	9 Months Operations	3	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AF	213	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AL	213	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Operations Since Last Insp	1002	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1465	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps A Ø	130.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps B Ø	120.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps C Ø	120.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AL	368	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AF	368	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	9 Month Operations	3	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps A Ø	118.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps B Ø	122.0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps C Ø	130.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushing Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations A Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations B Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations C Ø	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations Ground	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Foundation Condition	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Grounds in Place?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Maintenance Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AF	236	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AL	237	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations This Read AM	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Switching Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Unknown Operations	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Amps B Ø	150.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Amps C Ø	170.0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Found Counter	50938	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Left Counter	50938	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Current Tap Position	4R	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Max Tap Position	4R	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Operations A Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Operations B Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Operations C Ø	0	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Fault Operations Ground	0	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Min Tap Position	8L	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Operations Since Last Insp	678	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/15/2022 14:56	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Unknown Operations	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Tank Paint Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Switching Operations	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations This Read Vac	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AL	194	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	General Comments		
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	General Comments		
2/16/2022 8:48	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
2/15/2022 7:10	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	20	°F
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/15/2022 15:22	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps A Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	9 Months Operations	8	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps A Ø	100.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps B Ø	80.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps C Ø	60.0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations Ground	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	9 Months Operations	0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Min Tap Position	9L	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Max Tap Position	4R	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Left Counter	229469	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	9 Month Operations	9	
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Found Counter	229461	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	General Comments		
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	General Comments		
2/15/2022 15:08	Distribution	Rogers Gap Quarterly Inspection	BK001538	BreakerVacuum	695-2	VCB Readings	Amps A Ø	180.0	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 12:15	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Follow-up Action Required?	n	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	General Comments		
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Maintenance Operations	0	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AF	41	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AL	41	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations B Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations A Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps C Ø	345.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps B Ø	345.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps A Ø	341.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	9 Month Operations	20	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps A Ø	100.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps B Ø	100.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps C Ø	100.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations A Ø	0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Found Counter	95738	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Left Counter	95738	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations C Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Maintenance Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AF	585	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AL	585	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations This Read AM	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/15/2022 18:43	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	9 Months Operations	13	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps A Ø	180.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	9 Months Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Operation Checked?	y	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	General Comments		
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Follow-up Action Required?	n	
2/15/2022 12:46	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	All Connections OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AF	287	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Switching Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations This Read Vac	0	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AL	289	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations This Read Vac	2	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Switching Operations	2	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Left Counter	33275	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4L	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	93	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Unknown Operations	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	9 Months Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations Ground	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Follow-up Action Required?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	General Comments		
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/15/2022 7:17	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Maintenance Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AF	187	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AL	187	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations This Read Vac	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	9 Months Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Unknown Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Switching Operations	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations This Read Vac	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AL	244	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps C Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps B Ø	0.0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps A Ø	0.0	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations B Ø	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations C Ø	0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations Ground	0	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Follow-up Action Required?	n	
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/15/2022 13:54	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	General Comments		
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	9 Month Operations	2	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	General Comments		
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/15/2022 7:00	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps A Ø	82.0	
2/21/2022 8:17	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps B Ø	78.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Time Delay	30	Seconds
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	LTC Operation Checked?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AL	250	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AF	250	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps C Ø	90.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	380.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	All Connections OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations B Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	LTC Operation Checked?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps C Ø	38.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	460.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps B Ø	40.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps A Ø	43.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty B Ph V	.6	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty A Ph V	.6	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	9 Month Operations	6	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	190.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	All Connections OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps C Ø	510.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps B Ø	540.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps A Ø	560.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AF	239	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AL	239	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps A Ø	122.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty C Ph V	35.08	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty B Ph V	33.48	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty A Ph V	45.44	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	9 Month Operations	3	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Current Tap Position	1R	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Max Tap Position	10R	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Min Tap Position	9L	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps B Ø	119.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps C Ø	109.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations B Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Operations Since Last Insp	1034	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations C Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	903	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	897	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps B Ø	86.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps A Ø	86.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	9 Month Operations	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations Ground	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations C Ø	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations B Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations A Ø	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Found Counter	62193	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations C Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Left Counter	62201	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	9 Month Operations	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps C Ø	120.0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps B Ø	120.0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps A Ø	120.0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	9 Month Operations	1	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty A Ph V	7.97	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty B Ph V	13.55	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps A Ø	136.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps B Ø	136.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps C Ø	154.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations C Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AF	148	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AF	240	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AL	240	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AL	148	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Switching Operations	0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Present	35	°C
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9180	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BCH001367	Charger	431-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	48	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	36	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	44	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Unknown Operations	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Switching Operations	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations This Read Vac	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AL	55	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Vegetation	None	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AF	55	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Maintenance Operations	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations Ground	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations C Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations B Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations A Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	LTC Totalizer Reading	3127.68	kw
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Present	50	°C
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	LTC Totalizer Reading	17802.00	kw
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Max	58	°C
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Present	30	°C
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Reading	.9890	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Max	50	°C
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Present	38	°C
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Present	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Max	65	°C
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	LTC Totalizer Reading	18910.80	kw
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Reading	.3258	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations This Read Vac	0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	9 Month Operations	4	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty A Ph V	3.19	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty B Ph V	3.99	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps A Ø	95.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps B Ø	116.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps C Ø	90.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AF	149	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AL	149	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Switching Operations	0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8812.80	kw
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Present	38	°C
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Max	50	°C
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Reading	1.0506	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AF	244	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AL	244	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Switching Operations	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Unknown Operations	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Switching Operations	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations This Read Vac	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AL	162	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AF	162	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Maintenance Operations	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations Ground	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations C Ø	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations B Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps A Ø	10.0	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0078	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations Counter AF	367	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations Counter AL	367	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Switching Operations	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Switching Operations	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Vegetation	None	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations This Read Vac	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AL	151	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AF	151	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations Ground	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations A Ø	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	9 Month Operations	1	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps A Ø	10.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps B Ø	10.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps C Ø	10.0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Vegetation	None	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps C Ø	350.0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps B Ø	350.0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps A Ø	350.0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	224	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	232	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Time Delay	30	Seconds
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Found Counter	4381	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Left Counter	4381	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Current Tap Position	3R	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Max Tap Position	4R	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Min Tap Position	1R	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Operations Since Last Insp	62	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Operation Checked?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	All Connections OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BCH001490	Charger	431-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations A Ø	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps B Ø	10.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps C Ø	10.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations A Ø	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	110.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	18.72	kw
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	9 Month Operations	25	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps B Ø	0.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps C Ø	0.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations A Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations B Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations C Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations Ground	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Maintenance Operations	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AF	562	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AL	562	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations This Read Vac	7	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Switching Operations	7	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Unknown Operations	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Operations Counter	57	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AF	217	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps C Ø	180.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps B Ø	185.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Amps A Ø	185.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty C Ph V	5.89	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty B Ph V	5.01	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Accumulated Fault Duty A Ph V	3.83	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Present	32	°C
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Max	42	°C
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Reading	.9570	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	9 Month Operations	8	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Present	32	°C
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Max	42	°C
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	LTC Totalizer Reading	17226.00	kw
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	LTC Totalizer Reading	16081.20	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Operation Checked?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	All Connections OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps C Ø	125.0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps B Ø	127.0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps A Ø	98.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Present	30	°C
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Max	55	°C
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Reading	.8934	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Present	40	°C
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Max	60	°C
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations B Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations C Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations Ground	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Maintenance Operations	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AF	280	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AL	282	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations This Read Vac	2	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Switching Operations	2	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Unknown Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps C Ø	70.0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps B Ø	65.0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Amps A Ø	70.0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps C Ø	90.0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps B Ø	90.0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Amps A Ø	90.0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	9 Month Operations	4	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Unknown Operations	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Switching Operations	2	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations This Read Vac	2	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations Counter AL	173	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Operations Counter AF	171	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Maintenance Operations	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations Ground	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations C Ø	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations B Ø	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Operations A Ø	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations A Ø	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Operations Since Last Insp	1000	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Max Tap Position	3R	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Current Tap Position	1R	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Left Counter	36897	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Found Counter	36897	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	27	°F
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	4	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AL	217	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps A Ø	0.0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001401	BreakerVacuum	818-0710	VCB Readings	9 Month Operations	7	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AF	195	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AL	195	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AF	171	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AL	171	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Switching Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Trash Emptied?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations C Ø	0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations Ground	0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Maintenance Operations	0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations Counter AF	154	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations Counter AL	155	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations This Read Vac	1	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Switching Operations	1	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Unknown Operations	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	26	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	26	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps C Ø	610.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps B Ø	520.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps A Ø	590.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Unknown Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Switching Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AL	151	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AF	151	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Maintenance Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations Ground	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations C Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations B Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations A Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24163	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Unknown Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Switching Operations	4	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations This Read Vac	4	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AL	99955	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AF	99951	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Regulator As Left Counter	368278	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Regulator As Left Counter	27155	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps C Ø	180.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps B Ø	180.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps A Ø	180.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	9 Month Operations	14	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Switching Operations	0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	9 Month Operations	14	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps A Ø	35.0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps B Ø	40.0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps C Ø	55.0	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Present	35	°C
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Max	45	°C
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Reading	.8540	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Multiplier	10160	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Max	35	°C
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Unknown Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Switching Operations	2	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations This Read Vac	2	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AL	324	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AF	322	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTC000656	LTCControl	534-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations A Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations B Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations C Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations Ground	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AF	206	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AL	208	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations This Read Vac	2	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Switching Operations	2	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Unknown Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	30.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AL	282	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AF	280	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Maintenance Operations	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations Ground	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations C Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations B Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations A Ø	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations Ground	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations C Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations B Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations A Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps C Ø	200.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps B Ø	195.0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?		If no, which cells in comments
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	LTC Operation Checked?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	All Connections OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	LTC Totalizer Reading	8676.64	kw
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	23	*F
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Vegetation	None	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	9 Month Operations	2	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps A Ø	25.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps B Ø	35.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps C Ø	35.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations A Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations B Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations C Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations Ground	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Regulator As Left Counter	198295	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Regulator As Left Counter	410719	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BAT001548	Battery	534-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	6	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Switching Operations	2	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations This Read Vac	2	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	9 Month Operations	3	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps A Ø	180.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps B Ø	120.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps C Ø	110.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AF	207	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AL	208	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations This Read Vac	1	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Switching Operations	1	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Unknown Operations	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BCH001477	Charger	534-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Unknown Operations	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BCH001480	Charger	704-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	BAT001549	Battery	704-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Present	10	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8345.40	kw
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	All Connections OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	9 Month Operations	1	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps A Ø	10.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps B Ø	10.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps C Ø	10.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations B Ø	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	9 Month Operations	7	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps A Ø	255.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps B Ø	200.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps C Ø	235.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Operations Since Last Insp	677	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Min Tap Position	15L	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Max Tap Position	4L	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Current Tap Position	7L	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Left Counter	17651	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Found Counter	17651	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Winding Temp Present	10	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1987	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	42000	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Switching Operations	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Unknown Operations	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Unknown Operations	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Switching Operations	2	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations This Read Vac	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations Counter AL	194	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Operations Counter AF	192	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Maintenance Operations	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations Ground	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations C Ø	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations B Ø	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Operations A Ø	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	BK001402	BreakerVacuum	818-0711	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Found Counter	31263	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Left Counter	31263	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Max Tap Position	2L	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Min Tap Position	12L	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Operations Since Last Insp	776	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	9 Month Operations	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps A Ø	0.0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps B Ø	0.0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps C Ø	18.0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations A Ø	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations B Ø	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations C Ø	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations Ground	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Maintenance Operations	0	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AF	171	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AL	171	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations This Read Vac	0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Max	30	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Present	25	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Reading	1.0260	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Max	30	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Present	25	°C
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps C Ø	300.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps B Ø	340.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps A Ø	320.0	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	LTC Totalizer Reading	4890.24	kw
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Max	60	°C
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Present	323	°C
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Reading	.6792	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps A Ø	215.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	9 Month Operations	22	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	General Comments		
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	LTC Totalizer Reading	18468.00	kw
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCControl	545-1	LTC Control Insp	LTC Operation Checked?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Operation Checked?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	All Connections OK?	y	
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 11:13	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	9 Month Operations	7	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/14/2022 9:35	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Current Tap Position	5L	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Max Tap Position	2L	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Min Tap Position	13L	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Operations Since Last Insp	600	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps C Phase V	6.27	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations A Ø	1	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations B Ø	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations C Ø	1	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations Ground	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Reading	.8964	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Present	39	°C
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Max	41	°C
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	LTC Totalizer Reading	4302.72	kw
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	General Comments		
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Maintenance Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AF	199	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AL	201	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations This Read Vac	3	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Switching Operations	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Pressure Indicator	good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations This Read SF6	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AL	15	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	General Comments	Barbwire rusty, large gap in back of lot and back right post washed out.	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Found Counter	101577	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Left Counter	101577	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Trash Emptied?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	9 Month Operations	4	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps A Ø	253.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps B Ø	275.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps C Ø	290.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps C Ø	31.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps B Ø	31.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Amps A Ø	30.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Unknown Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Switching Operations	4	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations This Read Vac	4	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AL	342	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AF	338	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Maintenance Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations Ground	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations C Ø	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations B Ø	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations A Ø	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps C Ø	10.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps B Ø	10.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps A Ø	10.0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	9 Month Operations	8	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	9 Month Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	°F
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AF	15	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Num Operations Last 9 Months	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Maintenance Operations	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Fault Operations	0	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Ambient Temperature	45	°F
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Switching Operations	1	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Unknown Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps A Ø	132.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps B Ø	142.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps C Ø	132.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Fault Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	General Comments	ok	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Maintenance Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Num Operations Last 9 Months	1	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AF	738	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Found Counter	118879	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Left Counter	118879	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Current Tap Position	4L	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Min Tap Position	12L	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Operations Since Last Insp	729	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Operations Since Last Insp	742	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AL	738	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations This Read SF6	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Switching Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Unknown Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Min Tap Position	16L	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Max Tap Position	1L	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Current Tap Position	7L	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Left Counter	22589	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Found Counter	22589	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	General Comments	reset manually	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations Counter AL	188	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Operations Counter AF	188	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	280.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	260.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	879	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	883	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations This Read Vac	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AL	48	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AF	48	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Maintenance Operations	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations Ground	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Vegetation	None	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps C Ø	0.0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps B Ø	0.0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps A Ø	0.0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	9 Month Operations	3	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	9 Month Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps A Ø	400.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps B Ø	320.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps C Ø	320.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	General Comments		
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations A Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations B Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations C Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AF	47	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AL	47	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations This Read Vac	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Switching Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Vegetation	None	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Unknown Operations	0	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/14/2022 13:00	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AL	246	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AF	246	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations C Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	795	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	799	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Vegetation	None	
2/14/2022 12:13	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	General Comments		
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations C Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations B Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations A Ø	0	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 13:52	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Fault Operations	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations Ground	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations C Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps C Ø	76.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps B Ø	76.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps A Ø	75.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty C Ph V	.29	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty B Ph V	.59	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty A Ph V	2.36	%
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Unknown Operations	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Leaks	None	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Switching Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps A Ø	215.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps B Ø	245.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps C Ø	300.0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	All Connections OK?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Follow-up Action Required?	n	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations A Ø	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Oil Level	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Operation Checked?	y	
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Parallel / Ind. Sw Position	parallellof	Position
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AF	127.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 7:11	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AL	127.0	VAC
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	9 Month Operations	15	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Switching Operations	1	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations This Read Vac	1	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AL	408	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AF	407	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Maintenance Operations	0	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Grounds in Place?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	General Comments		
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Leaks	None	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Pressure OK?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	General Comments		
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Foundation Condition	Good	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	9 Month Operations	19	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AL	340	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AF	340	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Unknown Operations	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Number of Ops last 9 Months	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations This Read Oil	0	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2022-02-11 00:00:00.000000	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 14:51	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Follow-up Action Required?	n	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 16:20	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/14/2022 7:24	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Maintenance Operations	0	
2/14/2022 10:56	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	9 Month Operations	2	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	143.52	kw
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTO164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Reading	.3864	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Maintenance Operations	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations Counter AF	215	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations Counter AL	215	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations This Read Vac	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Switching Operations	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Unknown Operations	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Reading	.2640	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Max	60	°C
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	LTC Totalizer Reading	1267.20	kw
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps A Ø	104.0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps B Ø	86.0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps C Ø	104.0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps A Phase V	6.09	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps B Phase V	6.09	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps C Phase V	6.09	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations A Ø	2	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations B Ø	2	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations C Ø	2	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations Ground	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Reading	.3906	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AF	165	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AL	165	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Switching Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	LTC Totalizer Reading	3749.76	kw
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Max	60	°C
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	9 Month Operations	12	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	9 Month Operations	4	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	9 Month Operations	16	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps A Ø	58.0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps B Ø	49.0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps C Ø	25.0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations A Ø	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations B Ø	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations C Ø	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations Ground	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations	7	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	177	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	177	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	46	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	23	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	49	°C
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Maintenance Operations	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCC000421	LTCControl	SM-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations Counter AF	214	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations Counter AL	214	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations This Read Vac	6	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Switching Operations	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	35	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	49	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	35	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	PT Free of Leaks?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PT002285	PT	SM-14KV BUS SEC 1 POT	PT Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	40	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	44	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	40	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	45	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	40	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	50	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	9 Months Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps A Ø	110.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AF	143	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AL	143	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Reading	.7884	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Amps C Ø	0.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	9 Month Operations	4	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Operations Counter	57	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	3	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Max Tap Position	6	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps C Ø	62.0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps B Ø	64.0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps A Ø	61.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Left Counter	9865	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Found Counter	9865	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps B Ø	150.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps C Ø	100.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations A Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations B Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations C Ø	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Operations Since Last Insp	898	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations Ground	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Maintenance Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AF	195	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AL	195	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations This Read AM	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Switching Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Min Tap Position	7L	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Max Tap Position	5R	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Current Tap Position	2L	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Left Counter	287426	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Found Counter	287419	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.5	VAC
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Max	40	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	General Comments	Counter was put in wrong on the last QTR. LTC has operated 558 times since last quarter. (JB fixed Nov quarterly counter reading)	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Found Counter	165294	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Left Counter	165294	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Current Tap Position	7L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Max Tap Position	2L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Min Tap Position	12L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Operations Since Last Insp	558	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations This Read Vac	2	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Switching Operations	2	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Found Counter	23714	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Left Counter	23714	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	16	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	General Comments	Trees hangin into substation on the right had side when looking at the station from the gate.	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Found Counter	85531	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Left Counter	85531	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Max	40	°C
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	LTC Totalizer Reading	3709.44	kw
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1196	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	C ∅ Operations Counter	103	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	B ∅ Operations Counter	591	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps C ∅	7.1	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps B ∅	7.9	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps A ∅	8.1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	142	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations Ground	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Maintenance Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AF	1588	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AL	1590	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Found Counter	41907	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Left Counter	41907	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Current Tap Position	7L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Max Tap Position	5L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Min Tap Position	9L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	43	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Operation Checked?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Switching Operations	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	LTC Totalizer Reading	7568.64	kw
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Max	52	°C
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Present	44	°C
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	All Connections OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Operations Counter AL	338	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Operations Counter AF	338	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001840	BreakerVacuum	SM-14KV TR 1	VCB Readings	General Comments	Can't read display for cirrent reading pic sent to stinson	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations C Ø	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1680	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1676	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	16	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	30.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AL	138	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AF	223	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Present	23	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Max	46	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1393	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AL	223	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Switching Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations C Ø	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Fault Operations Ground	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Operations Since Last Insp	360	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Max Tap Position	4L	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Current Tap Position	7L	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Left Counter	72855	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AF	226	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AL	226	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	HV Winding Temp Max	40	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	35	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	49	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	35	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	49	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	35	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	49	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Present	35	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Max	49	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AF	138	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	*F
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AF	170	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AL	170	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	9 Month Operations	9	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Operations Since Last Insp	116	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Max Tap Position	5R	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Found Counter	72855	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	General Comments	nitrogen bottle is empty	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Fault Operations B Ø	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	General Comments	all cells needed water	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #'s
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps A Ø	89.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps B Ø	76.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps C Ø	82.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AF	119	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AL	119	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AL	280	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AF	276	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Maintenance Operations	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Operations Since Last Insp	74	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Min Tap Position	6L	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Left Counter	479193	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Found Counter	479193	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Unknown Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Switching Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations Ground	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Found Counter	382412	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Left Counter	382412	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Operations Counter AF	347	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	General Comments	Cant read display for current reading pic sent to stinson	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Operations Counter AL	347	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Operations This Read Vac	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations This Read Vac	4	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Switching Operations	4	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps A Ø	156.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps B Ø	111.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps C Ø	147.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Found Counter	331923	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Left Counter	331923	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	80	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	9 Month Operations	2	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Max	70	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	HV Winding Temp Present	30	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	107	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations This Read Vac	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AL	68	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AF	68	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Maintenance Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations Ground	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations C Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations B Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps C Ø	200.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps B Ø	200.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Operations Counter AF	344	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps A Ø	200.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty C Ph V	4.64	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty B Ph V	4.64	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty A Ph V	4.64	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	9 Month Operations	1	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Present	25	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Operations Counter AF	345	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Operations Counter AL	345	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Operations This Read Vac	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations	3	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps A Ø	0.0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Operations Counter AF	346	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Operations Counter AL	346	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	9 Month Operations	31	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Amps A Ø	50.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Amps B Ø	50.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Readings	Amps C Ø	50.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001843	BreakerVacuum	SM-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	9 Month Operations	4	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Max	49	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PF001318	PowerFuse	LG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	General Comments	tower leg foundation crumbling	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations A Ø	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations B Ø	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations This Read Vac	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AL	160	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AF	160	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	General Comments	correct vc	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps C Ø	101.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps B Ø	100.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps A Ø	101.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	7.7	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	7.7	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	7.7	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps C Ø	0.0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Vegetation	None	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	General Comments	rusty barbed wire and fence posts	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Vegetation	None	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Vegetation	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Amps B Ø	48.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Amps A Ø	48.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	9 Month Operations	32	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	9 Month Operations	10	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Operations Counter AL	344	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Operations This Read Vac	2	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Switching Operations	2	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Unknown Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps C Ø	180.0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps B Ø	150.0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps A Ø	150.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AL	131	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AF	131	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Maintenance Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Current Tap Position	3R	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Left Counter	10726	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Found Counter	10726	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations B Ø	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations A Ø	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001839	BreakerVacuum	SM-1362	VCB Readings	Amps C Ø	52.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001841	BreakerVacuum	SM-14KV TR 2	VCB Readings	Amps B Ø	0.0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PF001317	PowerFuse	LG-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PF001317	PowerFuse	LG-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PF001317	PowerFuse	LG-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PF001318	PowerFuse	LG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	PF001318	PowerFuse	LG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK001842	BreakerVacuum	SM-14KV BUS TIE SEC 1-2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps B Ø	0.0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	238	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	243	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Vegetation	None	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Present	45	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Max	45	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Reading	.6444	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Present	30	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Max	45	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	LTC Totalizer Reading	9820.66	kw
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AF	272	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AL	272	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps A Ø	482.0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps B Ø	485.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps C Ø	481.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps A Ø	10.0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	9 Month Operations	8	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Unknown Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Switching Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations This Read AM	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AL	418	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	9 Month Operations	3	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Regulator As Left Counter	135544	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations B Ø	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations C Ø	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AF	149	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AL	149	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Regulator As Left Counter	127820	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	196	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	200	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Switching Operations	3	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations This Read Vac	3	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Operation Checked?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps C Ø	10.0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps B Ø	10.0	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps C Ø	570.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps B Ø	558.0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Vegetation	None	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps A Ø	599.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	All Connections OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AF	143	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AL	143	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	General Comments	ok	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AF	258	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AL	258	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Switching Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	60	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	56	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	1 int on nuetral	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	1	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AF	372	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AL	372	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Found Counter	19087	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Left Counter	19087	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Max Tap Position	5L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Min Tap Position	8L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	49	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps C Ø	89.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps B Ø	82.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps A Ø	90.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	9 Month Operations	2	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	General Comments	trans needs nitrogen	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps A Ø	96.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps B Ø	92.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps C Ø	95.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations A Ø	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Max Tap Position	4L	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Current Tap Position	9L	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Left Counter	241015	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Found Counter	241015	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	General Comments	reset drag hands manually	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Fault Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations A Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps C Ø	130.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps B Ø	150.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps A Ø	190.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Unknown Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Switching Operations	2	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations This Read Vac	2	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AL	239	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AF	237	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Maintenance Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AF	418	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Maintenance Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations Ground	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations C Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations This Read Oil	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AL	516	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AF	516	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Number of Ops last 9 Months	2	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	General Comments	nitrogen is 0. trans needs nitrogen	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Operations Since Last Insp	157	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps A Ø	0.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	9 Month Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps A Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps C Ø	0.0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	General Comments		
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations Ground	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations C Ø	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations B Ø	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations A Ø	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps C Ø	0.0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps A Ø	0.0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	9 Months Operations	0	
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 7:28	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations	3	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AL	298	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AF	298	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	LTC Totalizer Reading	9864.85	kw
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Vegetation	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Switching Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations This Read Vac	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AL	144	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AF	144	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Maintenance Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations Ground	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations B Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations A Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps C Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps B Ø	0.0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps A Ø	0.0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	9 Month Operations	4	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCCControl	415-1	LTC Control Insp	All Connections OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCCControl	415-1	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCCControl	415-1	LTC Control Insp	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCCControl	415-1	LTC Control Insp	LTC Operation Checked?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCCControl	415-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCCControl	415-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCCControl	415-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCCControl	415-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Vegetation	None	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	9 Month Operations	4	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps A Ø	0.0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps B Ø	0.0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps C Ø	0.0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations A Ø	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations B Ø	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations C Ø	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations Ground	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Maintenance Operations	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AF	217	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AL	219	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations This Read Vac	2	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Switching Operations	2	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Unknown Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Current Tap Position	13L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Max Tap Position	8L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Min Tap Position	9L	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	382	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AL	229	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations This Read Vac	2	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Switching Operations	2	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Unknown Operations	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs Nitrogen	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	General Comments	no heater	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	4	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	25.03	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	25.03	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	25.03	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	198	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	198	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	2	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	2	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations A Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations B Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations C Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations Ground	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Maintenance Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AF	413	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AL	413	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	59	*F
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Unknown Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Switching Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations This Read AM	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	9 Month Operations	4	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps A Ø	110.0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps B Ø	115.0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps C Ø	155.0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations A Ø	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations B Ø	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations C Ø	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations Ground	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Follow-up Action Required?	n	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	General Comments		
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Reading	.6288	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Maintenance Operations	0	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 7:39	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AF	227	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Found Counter	36535	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Follow-up Action Required?	n	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	General Comments		
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Maintenance Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.542	millivolts
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AF	305	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AL	309	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations This Read Vac	4	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Switching Operations	4	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	General Comments		
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Regulator As Left Counter	272822	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/11/2022 11:44	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 13:56	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Unknown Operations	0	
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/11/2022 9:45	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	General Comments		
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Max	40	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Present	35	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	9 Months Operations	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Ambient Temp	54	°F
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LTCM00030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Left Counter	36535	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Present	25	°C
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Max	60	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	9 Months Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps A Ø	100.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps B Ø	50.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps C Ø	75.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations A Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations B Ø	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations C Ø	0	
2/16/2022 8:13	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations Ground	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	General Comments		
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Max	40	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Reading	.6473	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps C Ø	120.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps B Ø	100.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps A Ø	100.0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Maintenance Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	LTC Totalizer Reading	6036.48	kw
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AF	365	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AL	365	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations This Read AM	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Switching Operations	0	
2/11/2022 17:56	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Unknown Operations	0	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/11/2022 11:45	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Unknown Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations This Read AM	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AL	66	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AF	66	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps C Ø	132.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps B Ø	139.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps A Ø	140.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	9 Months Operations	7	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Maintenance Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps C Ø	50.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps C Ø	115.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps B Ø	128.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Found Counter	60977	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps A Ø	97.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations Ground	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Maintenance Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AF	382	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations Ground	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps C Ø	50.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps B Ø	80.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps A Ø	50.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	9 Months Operations	3	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	9 Months Operations	2	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps A Ø	50.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps B Ø	30.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Left Counter	60977	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Found Counter	54453	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Left Counter	54453	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	9 Month Operations	7	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	29	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	17	°C
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps A Ø	44.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps B Ø	50.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps C Ø	47.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	General Comments		
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	471	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations A Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations B Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations C Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations Ground	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps C Ø	0.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps B Ø	0.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps A Ø	0.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	9 Month Operations	11	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AL	382	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations This Read AM	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Switching Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Unknown Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations A Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations B Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations C Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations Ground	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	PF000174	PowerFuse	IN-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	PF000174	PowerFuse	IN-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Maintenance Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AF	215	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AL	215	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations This Read Vac	2	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Switching Operations	2	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Unknown Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Maintenance Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AF	212	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AL	212	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations This Read Vac	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Switching Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Switching Operations	10	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations This Read Vac	10	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AL	99883	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AF	99883	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Maintenance Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations Ground	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations C Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations B Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations A Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AL	126	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AF	126	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Maintenance Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations Ground	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations C Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations B Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Operations A Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps C Ø	0.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps B Ø	0.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Amps A Ø	0.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	9 Month Operations	1	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	Regulator	Regulator	800-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	130	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Left Counter	327823	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Found Counter	327823	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Needs 2 screw on type desicant filters for the LTC.	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Left Counter	193247	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Found Counter	193247	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	351	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4L	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	1L	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Left Counter	31795	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Found Counter	31795	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2L	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Left Counter	408762	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Found Counter	408762	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	General Comments	No operations since last reading. Notified control to look into.	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	37	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Left Counter	450861	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Found Counter	450861	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Switching Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations This Read Vac	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	9 Months Operations	1	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.1	psi
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps A Ø	.3	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps B Ø	.4	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	General Comments		
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Operations Counter	143	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Regulator As Left Counter	39277	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Unknown Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations This Read AM	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AL	768	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AF	768	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps C Ø	8.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps B Ø	6.0	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps A Ø	5.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.0	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps A Ø	.6	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Unknown Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Switching Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations This Read AM	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AL	589	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AF	589	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Maintenance Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations Ground	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps C Ø	60.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps B Ø	100.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps A Ø	100.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	9 Months Operations	17	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10358	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	9 Month Operations	3	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BAT001593	Battery	HI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Reading	.8406	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AF	857	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AL	857	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations This Read AM	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Switching Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Unknown Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Present	16	°C
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Max	20	°C
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	LTC Totalizer Reading	8069.76	kw
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Operations Counter	147	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps A Ø	200.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps B Ø	200.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps C Ø	300.0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Regulator As Left Counter	189651	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations A Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations B Ø	0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Regulator As Left Counter	93154	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	30	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	9 Months Operations	8	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps A Ø	61.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps B Ø	59.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps C Ø	61.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AF	813	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AL	813	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations This Read AM	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Unknown Operations	0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Vegetation	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	9 Month Operations	1	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	General Comments		
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps A Ø	138.0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps B Ø	153.0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps C Ø	150.0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Operations Counter	8	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations This Read Vac	0	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	All Connections OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	General Comments		
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	LTC Operation Checked?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	LTCC000953	LTCControl	503-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AL	156	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AF	156	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps C Ø	100.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps B Ø	97.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps A Ø	99.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty A Ph V	3.19	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	9 Month Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Found Counter	36146	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	LTC Totalizer Reading	14919.96	kw
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Poor	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	General Comments	Standing water in drive.	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps A Ø	400.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps B Ø	400.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps C Ø	400.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations A Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations B Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations C Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations Ground	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.0	amps
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AF	275	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AL	275	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations This Read Vac	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Switching Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Present	25	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Max	42	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Reading	.9790	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Operations Since Last Insp	344	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Min Tap Position	12L	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Current Tap Position	7L	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Left Counter	36151	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Present	23	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Max	40	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Regulator As Left Counter	11310	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Operations Since Last Insp	897	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Min Tap Position	13L	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Current Tap Position	9L	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Left Counter	242062	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Found Counter	242049	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Unknown Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Switching Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations This Read Vac	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AL	162	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AF	162	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Maintenance Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations Ground	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations C ∅	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations B ∅	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations A ∅	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	9 Month Operations	9	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps A Ø	89.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps B Ø	88.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps C Ø	118.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PF001321	PowerFuse	HE-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PF001321	PowerFuse	HE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PF001321	PowerFuse	HE-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Reading	.9160	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Maintenance Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PF001320	PowerFuse	HE-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PF001320	PowerFuse	HE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PF001320	PowerFuse	HE-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AF	194	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AL	194	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations This Read Vac	1	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Unknown Operations	1	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Present	28	°C
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	LTC Totalizer Reading	6595.20	kw
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	General Comments	all fences around highland sub are closer than 6 feet	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	General Comments	Barb wire is rusty	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Fair	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps C Ø	65.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps B Ø	87.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps A Ø	47.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	9 Month Operations	8	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Unknown Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations This Read Vac	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AL	269	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AF	269	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	General Comments	Barb wire rusty	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps C Ø	527.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps B Ø	513.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps A Ø	499.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	9 Month Operations	0	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6426	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	771.12	kw
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Reading	.0940	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Present	29	°C
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Max	35	°C
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps A Ø	105.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps B Ø	115.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps C Ø	110.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AF	221	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AL	221	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations This Read Vac	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Switching Operations	0	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	LTC Totalizer Reading	451.20	kw
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	General Comments		
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Present	25	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Max	40	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Reading	.6610	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Present	30	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Max	45	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	LTC Totalizer Reading	10073.64	kw
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.5228	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	General Comments	Cap bank has been disconnected from the buss.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3654.72	kw
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	General Comments	added 1 psi	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	All Connections OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Operation Checked?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	All Connections OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Operation Checked?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	35	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	24	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	35	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	24	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	35	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Present	23	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Time Delay	30	Seconds
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Operation Checked?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	All Connections OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	195	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	9 Month Operations	8	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps A Ø	47.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps B Ø	54.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps C Ø	80.0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Unknown Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps C Phase V	13.68	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations A Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations B Ø	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations C Ø	3	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations Ground	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Maintenance Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AF	200	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AL	200	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations This Read Vac	3	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Switching Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCCControl	722-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCCControl	722-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCCControl	722-1	LTC Control Insp	LTC Operation Checked?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCCControl	722-1	LTC Control Insp	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCCControl	722-1	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCCControl	722-1	LTC Control Insp	All Connections OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	9 Month Operations	1	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps A Ø	200.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps B Ø	200.0	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps C Ø	200.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations A Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations B Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations C Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations Ground	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Switching Operations	3	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations This Read Vac	3	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AL	145	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AF	145	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Maintenance Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations Ground	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations C Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations B Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Operations A Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	20	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	10	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Max	20	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Present	10	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	General Comments	Yard light is not working, wired directly into staion supply.	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps C Ø	535.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps B Ø	510.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Amps A Ø	500.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	9 Month Operations	1	
2/11/2022 10:32	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/11/2022 10:32	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Switching Operations	2	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations This Read Vac	2	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AL	110	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AF	110	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Maintenance Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations Ground	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations B Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations A Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps C Ø	100.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps B Ø	100.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps A Ø	100.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	9 Month Operations	3	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LTCC00598	LTCControl	HI-TRANS 2	LTC Control Insp	General Comments	ok	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LTCC00598	LTCControl	HI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps C Ø	147.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps B Ø	140.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Amps A Ø	130.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	9 Month Operations	5	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	9 Month Operations	4	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Maintenance Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AF	59	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AL	59	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations This Read Vac	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Switching Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations This Read Vac	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations Counter AL	168	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Operations Counter AF	168	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Maintenance Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations Ground	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations C Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations B Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Operations A Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11216	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Unknown Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations This Read Vac	1	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AL	702	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AF	702	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	General Comments	B phase IOC	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations B Ø	1	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps A Ø	189.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	9 Month Operations	11	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps C Ø	129.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps B Ø	127.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps A Ø	124.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	9 Month Operations	13	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations Counter AF	93	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps C Ø	183.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps B Ø	191.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Maintenance Operations	6	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps C Ø	87.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps B Ø	99.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps A Ø	91.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty B Ph V	4.78	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty A Ph V	3.99	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	9 Month Operations	8	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	BCH001515	Charger	722-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.360	millivolts
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	General Comments	trash has been dumped in front of first gate	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Trash?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Regulator As Left Counter	291299	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PF001316	PowerFuse	HA-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PF001316	PowerFuse	HA-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PF001316	PowerFuse	HA-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	9 Month Operations	9	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AF	216	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AL	216	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations This Read Vac	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Unknown Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Vegetation	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Operation Checked?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Maintenance Operations	2	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations This Read Vac	1	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations Counter AL	58	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations Counter AF	58	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	All Connections OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	LTC Operation Checked?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations This Read Vac	3	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations Counter AL	35	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations Counter AF	35	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps C Ø	200.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps B Ø	200.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps A Ø	200.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	9 Month Operations	13	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Operations Counter	271	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	General Comments		
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	All Connections OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Operation Checked?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Time Delay	30	Seconds
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.2	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps B Ø	.5	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps A Ø	.3	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Switching Operations	1	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	All Connections OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	LTC Operation Checked?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps A Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps B Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps C Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations B Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Time Delay	30	Seconds
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Unknown Operations	0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Switching Operations	1	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations This Read Vac	7	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations Counter AL	93	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps C Ø	133.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps B Ø	133.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps A Ø	142.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Oil Temp Present	35	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Oil Temp Max	50	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	LTC Totalizer Reading	12975.34	kw
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty A Ph V	14.35	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	9 Month Operations	8	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	9 Month Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	All Connections OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	9 Month Operations	1	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty A Ph V	3.19	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Present	25	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Max	30	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Reading	.3580	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Oil Temp Present	20	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Oil Temp Max	30	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	LTC Totalizer Reading	5455.92	kw
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps A Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps B Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps C Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations C Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations Ground	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations Ground	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps C Ø	40.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps B Ø	50.0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Maintenance Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AF	99898	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AL	99898	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Switching Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Unknown Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps A Ø	130.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps B Ø	135.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps C Ø	123.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Operations Ground	0	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations Counter AF	875	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations C Ø	0	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Regulator As Left Counter	308061	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Operations A Ø	0	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Operations C Ø	0	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations C Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	9 Month Operations	4	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps A Ø	93.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps B Ø	88.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps C Ø	78.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AF	162	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AL	162	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations This Read Vac	1	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Switching Operations	1	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Unknown Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps A Ø	40.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	9 Months Operations	1	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	9 Month Operations	2	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty A Ph V	3.19	%
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Unknown Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Switching Operations	2	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Operations Since Last Insp	662	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Max Tap Position	5L	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1836.00	kw
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Max	100	°C
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Present	27	°C
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Current Tap Position	7L	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Left Counter	1531	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Found Counter	1523	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	General Comments		
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:01	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps A Ø	43.0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps B Ø	72.0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.7	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	General Comments	barbed wire on front half of station is rusty	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Reading	.9820	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Oil Temp Present	25	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Oil Temp Max	40	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	LTC Totalizer Reading	14965.68	kw
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	General Comments	two arresters missing above cir 302	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTC000228	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	LTC000228	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Operations Counter AF	47	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Operations Counter	493	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Operations Since Last Insp	385	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Unknown Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Switching Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations This Read AM	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Min Tap Position	12L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Max Tap Position	3L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Current Tap Position	6L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Left Counter	307425	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AL	362	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AF	362	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Found Counter	307425	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7650	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Maintenance Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Unknown Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations This Read Vac	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations Counter AL	875	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Operations This Read Vac	2	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Operations Counter AL	47	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	13386	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	13386	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Present	30	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Max	45	°C
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations This Read Vac	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AL	151	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AF	151	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Operations Since Last Insp	426	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations Ground	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Found Counter	220104	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Left Counter	220104	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Current Tap Position	6L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Max Tap Position	2L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Min Tap Position	15L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Operations Since Last Insp	119	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	9 Month Operations	1	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Max Tap Position	3L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Current Tap Position	6L	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Operations Counter	588	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps C Ø	37.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Left Counter	948812	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Found Counter	948812	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps B Ø	34.0	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps A Ø	39.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps A Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	9 Month Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0540	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	100	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5.40	kw
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	General Comments	TR needs nitro	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	General Comments	Gauges will not reset with my magnet on a stick.	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps A Ø	91.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	9 Months Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps A Ø	0.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps B Ø	0.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps C Ø	0.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AF	383	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations B Ø	1	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations Ground	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	General Comments	B phase IOC target in, no VC change.	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Maintenance Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AF	524	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AL	524	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations This Read AM	1	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Switching Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps C Ø	0.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps B Ø	0.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps C Ø	90.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps B Ø	130.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps A Ø	90.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	9 Months Operations	1	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Amps C Ø	1.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Amps B Ø	1.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Amps A Ø	1.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations A Ø	0	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	General Comments		
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Operations This Read Vac	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Operations Counter AL	48	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Operations Counter AF	48	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps B Ø	107.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps C Ø	109.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	General Comments		
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Operations B Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/10/2022 17:40	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Unknown Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Switching Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations This Read AM	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AL	398	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AF	398	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Maintenance Operations	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	General Comments		
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations Ground	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps C Ø	276.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AF	904	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AL	904	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations This Read Vac	1	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Maintenance Operations	0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	General Comments		
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Regulator As Left Counter	177241	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AF	432	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AL	432	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations This Read AM	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Unknown Operations	1	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	9 Months Operations	3	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps A Ø	74.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps B Ø	73.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps C Ø	72.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	9 Months Operations	10	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	8.54	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	11.74	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps A Ø	70.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps B Ø	100.0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps C Ø	100.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations A Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	9 Months Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps A Ø	284.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps B Ø	280.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations A Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations B Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	-60	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	-60	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	-60	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	-60	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	-60	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	-60	°C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations Ground	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Current Tap Position	7L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Max Tap Position	2L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Min Tap Position	15L	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps A Ø	18.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty B Ph V	12.75	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	9 Month Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Found Counter	98406	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Operations Since Last Insp	309	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Max Tap Position	4L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Current Tap Position	8L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Left Counter	133971	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Found Counter	133971	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PNS4	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PNS4	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PNS4	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PNS4	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	30	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	32	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	30	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	*C
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
2/10/2022 12:39	Distribution	Pineville Quarterly Inspection	CH000521	ControlHouse	722-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AF	308	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AL	308	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations This Read AM	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Unknown Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Maintenance Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AF	66	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations Counter AF	47	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations Counter AL	47	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations This Read Vac	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AL	66	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations This Read Vac	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Unknown Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Switching Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Present	40	*C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Max	45	*C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Reading	.8514	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Unknown Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Tank Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Switching Operations	1	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	37	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	25	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	*C
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	442	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	18	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.0	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps A Ø	19.0	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	398	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Switching Operations	12	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations This Read Vac	12	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AL	99932	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AF	99932	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Maintenance Operations	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Grounds in Place?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	33	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Operations Since Last Insp	539	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations Ground	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations C Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations B Ø	0	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations A Ø	0	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/10/2022 10:59	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	9 Month Operations	1	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AL	392	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AF	392	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Operations Since Last Insp	435	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Min Tap Position	13L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Max Tap Position	4L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Current Tap Position	9L	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Left Counter	98406	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AL	247	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AF	247	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Maintenance Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	General Comments		
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Follow-up Action Required?	n	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Unknown Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	9 Month Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	General Comments		
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	General Comments		
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Crumbling	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/10/2022 11:35	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	General Comments		
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Maintenance Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AF	802	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AL	802	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations This Read AM	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Switching Operations	0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Unknown Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Amps A Ø	542.0	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LTCC000432	LTCControl	HI-TRANS 1	LTC Control Insp	General Comments	ok	
2/10/2022 11:45	Distribution	Highland Quarterly Inspection	LTCC000432	LTCControl	HI-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 14:58	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Amps B Ø	539.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Amps C Ø	518.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	9 Months Operations	9	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps C Ø	17.0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps B Ø	18.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Found Counter	12407	
2/10/2022 14:38	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Left Counter	12407	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps C Ø	350.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps B Ø	350.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps A Ø	300.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	9 Month Operations	1	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps A Ø	0.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps B Ø	0.0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps C Ø	0.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushing Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/10/2022 13:39	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	General Comments	Switch handle ground missing	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations Ground	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations C Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations B Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AL	383	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations A Ø	0	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/11/2022 10:32	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Unknown Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Switching Operations	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations This Read AM	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AL	410	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AF	410	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Switching Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations This Read Vac	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AL	269	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AF	269	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Maintenance Operations	0	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Grounds in Place?	y	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	General Comments		
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Foundation Condition	Good	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Follow-up Action Required?	n	
2/11/2022 5:21	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps A Ø	150.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps B Ø	100.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps C Ø	100.0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations Ground	0	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	General Comments		
2/10/2022 17:03	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Operations A Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Maintenance Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Operations Counter AF	165	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Left Counter	15437	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Found Counter	15437	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Operations Counter AL	165	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Operations This Read Vac	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Switching Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Unknown Operations	0	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	General Comments		
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Current Tap Position	1R	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	414	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations A Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations B Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations C Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Maintenance Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AF	120	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AL	120	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations This Read Vac	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Switching Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Unknown Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Vegetation	None	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	9 Month Operations	1	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	FD-TRC Min Tap Position	11L	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	34	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTC000582	LTCControl	723-1	LTC Control Insp	LTC Operation Checked?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Amps A Ø	52.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Amps B Ø	32.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Readings	Amps C Ø	10.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001778	BreakerVacuum	072-4600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Unknown Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Switching Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations This Read Vac	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AL	265	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AF	265	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Maintenance Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations C Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations B Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations A Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps A Ø	60.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps B Ø	100.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Found Counter	256511	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps C Ø	80.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations Ground	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps C Ø	515.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps B Ø	510.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps A Ø	500.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	9 Month Operations	21	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations A Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations B Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations C Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations Ground	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Maintenance Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Operations Since Last Insp	1540	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Min Tap Position	12L	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Max Tap Position	4L	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Current Tap Position	8L	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Left Counter	256520	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	9 Month Operations	16	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps A Ø	8.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps B Ø	0.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps C Ø	8.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Maintenance Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AF	315	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AL	317	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Max Tap Position	4R	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Min Tap Position	2L	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	9 Months Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Regulator As Left Counter	12713	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Time Delay	60	Seconds
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	LTC Operation Checked?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	All Connections OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations This Read Vac	2	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Switching Operations	2	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Unknown Operations	0	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Vegetation	None	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Ambient Temp	57	*F
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	33	*C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps C Ø	350.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps B Ø	340.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps A Ø	335.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	9 Month Operations	4	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Max	35	*C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Present	26	*C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	22	*C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Vegetation	None	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	9 Month Operations	18	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps A Ø	0.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps B Ø	0.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Vegetation	None	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	General Comments		
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Max	33	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Present	16	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Max	33	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Present	22	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	33	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	22	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	33	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	22	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Unknown Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Switching Operations	2	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations This Read Vac	2	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AL	322	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AF	320	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Maintenance Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations C Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations B Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations A Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	15L	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	General Comments	the back right corner of fence is a foot off ground...left corner post of station is washing out	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Ambient Temp	28	*F
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	General Comments	Boom needs gravel on high side	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Vegetation	None	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	General Comments		
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	All Connections OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	General Comments		
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	16L	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	9 Month Operations	4	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps A Ø	150.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps B Ø	200.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps C Ø	160.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps C Ø	0.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations A Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations B Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations C Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations Ground	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps B Ø	8.0	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	General Comments	28.6/25.3	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Operations Counter	14	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	196	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	14	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	24	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	General Comments		
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Found Counter	18010	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Left Counter	18010	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	All Connections OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	LTC Operation Checked?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps C Ø	50.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps B Ø	50.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps A Ø	50.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	9 Months Operations	1	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Unknown Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Switching Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations This Read Vac	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AF	99955	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AL	99955	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations This Read AM	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Switching Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Unknown Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AL	239	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AF	239	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Maintenance Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations Ground	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations C Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations B Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations A Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps C Ø	2.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps B Ø	0.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps A Ø	0.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33970	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	335	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2L	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	Neutral	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Left Counter	501109	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Found Counter	501109	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	147	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Left Counter	39480	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Found Counter	39480	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Maintenance Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations Ground	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations C Ø	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations B Ø	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations A Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Max	25	*C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Present	10	*C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Ambient Temp	42	*F
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	9 Month Operations	17	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Unknown Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Switching Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations This Read Vac	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AL	301	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AF	301	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Maintenance Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations Ground	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations C Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations B Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations A Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps C Ø	6.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps B Ø	4.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps A Ø	4.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	9 Month Operations	15	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	352.80	kw
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Present	14	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	10500	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0336	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Regulator As Left Counter	53974	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Min Tap Position	2L	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Max Tap Position	6R	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Max Tap Position	6R	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Min Tap Position	1L	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Regulator As Left Counter	57279	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Current Tap Position	1R	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	9 Months Operations	6	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps A Ø	70.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps B Ø	90.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps C Ø	100.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations A Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations B Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations C Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations Ground	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Maintenance Operations	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	General Comments		
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps C Ø	12.0	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps B Ø	11.0	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Vegetation	None	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Regulator As Left Counter	256409	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Found Counter	417630	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Left Counter	417630	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5L	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	170	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	General Comments	ok	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Operations Counter	87	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	MX0465	RecloserHydraulic	575-0320	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps C Ø	20.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps B Ø	20.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps A Ø	20.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	9 Months Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Winding Temp Max	41	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	TV Winding Temp Present	22	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	TV Winding Temp Max	36	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Oil Temp Present	19	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Oil Temp Max	37	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	450	psi
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	LV Winding Temp Present	30	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	LV Winding Temp Max	41	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	HV Winding Temp Present	15	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	HV Winding Temp Max	30	°C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	General Comments		
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Max	23	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Present	26	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Operations B Ø	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Operations A Ø	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Adjusted Amps C Phase V	117.18	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	General Comments		
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	General Comments		
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	LTC Totalizer Reading	1171.20	kw
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Max	45	°C
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Present	10	°C
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Adjusted Amps B Phase V	117.18	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Adjusted Amps A Phase V	117.18	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Amps C Ø	47.0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Amps B Ø	57.0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Amps A Ø	55.0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	9 Month Operations	46	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Reading	.4880	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	145	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	27.0	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	212	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	196	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Unknown Operations	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Switching Operations	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations This Read AM	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AL	217	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AF	217	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Maintenance Operations	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations Ground	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations C Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations B Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations A Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Present	27	°C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	555.12	kw
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Operations Since Last Insp	10640	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Min Tap Position	16L	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Max Tap Position	6R	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Current Tap Position	1L	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Left Counter	804054	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Found Counter	804054	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Unknown Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Switching Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations This Read AM	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AL	622	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AF	622	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Maintenance Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Switching Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations This Read Vac	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AL	331	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AF	331	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AF	306	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AL	306	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Present	10	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Unknown Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	10	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Max	32	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Present	24	°C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.4626	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	32	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	24	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	32	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	32	°C
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Maintenance Operations	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AF	99937	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AL	99937	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations This Read AM	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Switching Operations	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Unknown Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	9 Month Operations	7	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps A Ø	500.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps B Ø	525.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps C Ø	515.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations A Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations B Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations C Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Operations Since Last Insp	1068	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Max Tap Position	2R	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Current Tap Position	2L	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Left Counter	68373	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Found Counter	68373	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	9 Month Operations	10	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps A Ø	300.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps B Ø	240.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps C Ø	280.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations A Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations B Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations C Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Maintenance Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AF	456	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AL	460	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations This Read Vac	4	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Switching Operations	4	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Unknown Operations	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	9 Months Operations	5	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps A Ø	40.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps B Ø	40.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps C Ø	50.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations A Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations B Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations C Ø	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	17150.40	kw
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.9528	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	60	°C
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	40	°C
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Unknown Operations	20	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Switching Operations	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Operations This Read Vac	21	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Operations Counter AL	171	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Operations Counter AF	170	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Maintenance Operations	1	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	General Comments	TC/ Install testing	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Operations Ground	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Readings	Fault Operations C Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Maintenance Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AF	255	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AL	255	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations This Read Vac	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Switching Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Unknown Operations	0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Operations Since Last Insp	610	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Min Tap Position	7L	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Max Tap Position	2R	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Current Tap Position	1L	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Left Counter	107734	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Found Counter	107726	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	General Comments		
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	178	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Left Counter	592189	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Found Counter	592189	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Operations Counter AF	167	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Maintenance Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Operations Ground	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Operations C Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Operations B Ø	1	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Operations A Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Adjusted Amps B Phase V	4.81	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	General Comments	some top rail and post showing signs of rust as well as fabric	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps A Ø	50.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps B Ø	80.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps C Ø	50.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations A Ø	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations B Ø	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations C Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty C Ph AM	1.07	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty B Ph AM	2.14	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty A Ph AM	2.14	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Amps C Ø	138.0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	47	°F
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations C Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations B Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations A Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Found Counter	2029	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	General Comments	SPR system has been removed	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations Ground	0	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Vegetation	None	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	9 Months Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Maintenance Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AF	176	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AL	176	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations This Read AM	9	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Switching Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Unknown Operations	0	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps C Ø	100.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps B Ø	60.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps A Ø	60.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PF001311	PowerFuse	GA-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	PF001311	PowerFuse	GA-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PF001310	PowerFuse	FO-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	PF001310	PowerFuse	FO-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Present	40	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Max	50	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Reading	1.5020	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Oil Temp Present	40	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	LTC Totalizer Reading	21628.80	kw
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Left Counter	2036	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Current Tap Position	6L	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Max Tap Position	3L	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Maintenance Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AF	361	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AL	365	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations This Read Vac	4	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Min Tap Position	11L	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Operations Since Last Insp	441	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Amps B Ø	216.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Amps A Ø	133.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	9 Month Operations	1	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Switching Operations	4	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Unknown Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	General Comments	Need Spare fuses	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Unknown Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AF	306	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AL	310	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations This Read Vac	4	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Switching Operations	4	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Unknown Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Reading	1.0900	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AF	142	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Maintenance Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Foundation Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AL	466	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations This Read AM	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Switching Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Unknown Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations This Read Vac	4	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Switching Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Unknown Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations Ground	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations C Ø	2	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations B Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations A Ø	2	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps C Phase V	15.70	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps A Phase V	15.70	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.200	millivolts
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	5	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	31.0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	22.0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	36.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps C Ø	50.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps B Ø	25.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps A Ø	50.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	9 Month Operations	8	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AL	142	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations Ground	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Maintenance Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AF	466	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps C Ø	170.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps B Ø	210.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps A Ø	160.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	LTC Totalizer Reading	7848.00	kw
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Max	47	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Present	37	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	9 Month Operations	15	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps B Ø	90.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps C Ø	110.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PF001314	PowerFuse	GD-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PF001314	PowerFuse	GD-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PF001314	PowerFuse	GD-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PF001313	PowerFuse	GD-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PF001313	PowerFuse	GD-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	PF001313	PowerFuse	GD-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps B Phase AM	85.91	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations B Ø	9	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations A Ø	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	275	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	278	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	3	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	2	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations B Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations C Ø	0	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	42	*F
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Maintenance Operations	0	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Regulator As Left Counter	299773	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Unknown Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Switching Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Operations This Read Vac	1	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001780	BreakerVacuum	072-4603	VCB Readings	Operations Counter AL	167	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	1	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 14:15	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	47107	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	47107	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	11L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps C Ø	4.0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	753	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	9 Months Operations	20	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty B Ph AM	3.2	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty C Ph AM	21.35	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps A Ø	120.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps B Ø	4.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps A Ø	4.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Operations Ground	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Operations C Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Operations B Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Operations A Ø	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations This Read Vac	1	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations Counter AL	200	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Operations Counter AF	199	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Maintenance Operations	1	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	General Comments	TC / SEL shows events with no counter ops..	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AL	486	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AF	486	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Maintenance Operations	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations Ground	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	9 Month Operations	6	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Bushing Condition	Good	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations C Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations B Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations A Ø	0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Amps C Ø	77.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Amps B Ø	68.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Amps A Ø	65.0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps C Ø	10.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps B Ø	10.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps A Ø	10.0	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	9 Months Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations Ground	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations C Ø	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations B Ø	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps A Phase V	33.68	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps B Phase V	4.81	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Adjusted Amps C Phase V	4.81	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations A Ø	7	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations B Ø	1	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations C Ø	1	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Fault Operations Ground	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	68.4	VDC
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	67.6	VDC
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	9 Months Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Unknown Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Switching Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	General Comments		
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Unknown Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Switching Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Operations This Read Vac	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Operations Counter AL	168	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Operations Counter AF	168	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	Maintenance Operations	0	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps B Ø	0.0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps A Ø	0.0	
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/9/2022 10:22	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps A Ø	53.0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps B Ø	42.0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps C Ø	70.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations Ground	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations B Ø	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations A Ø	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	General Comments	2-06 A-G/2-03 Ice storm ops/ TC 9 ops from storm 1 TC	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	500.0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	485.0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	450.0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	9 Months Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps A Ø	50.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps B Ø	75.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps C Ø	50.0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Unknown Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Switching Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations This Read Vac	10	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AL	209	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AF	208	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Maintenance Operations	1	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations A Ø	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BK001779	BreakerVacuum	072-4601	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	General Comments		
2/10/2022 10:38	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	LTC Totalizer Reading	5497.92	kw
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Max	32	°C
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Present	25	°C
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/9/2022 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	50	Seconds
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Unknown Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Switching Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations This Read AM	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AL	288	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AF	288	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Maintenance Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Reading	1.1454	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	9 Month Operations	2	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations Ground	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	General Comments		
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Maintenance Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AF	373	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	9 Month Operations	10	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AL	373	
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.5	VDC
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.5	VDC
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations This Read AM	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Switching Operations	0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Unknown Operations	0	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	General Comments		
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.8	VDC
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.6	VDC
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Oil Temp Present	30	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Oil Temp Max	50	°C
2/9/2022 15:22	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	9 Month Operations	13	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Control Readings	General Comments	ok	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 11:11	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Control Readings	Follow-up Action Required?	n	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	LTC Totalizer Reading	17136.00	kw
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	161	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	161	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
2/9/2022 9:40	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations B Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations A Ø	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Reading	1.1900	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Max	45	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Present	40	°C
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	General Comments		
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Maintenance Operations	0	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AF	302	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 9:32	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AL	304	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations This Read Vac	2	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps C Ø	0.0	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/9/2022 11:03	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Switching Operations	2	
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/9/2022 10:36	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	General Comments	6" future conduits do not have caps!! pose trip hazards.	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	318980	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Time Delay	60	Seconds
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	All Connections OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Regulator As Left Counter	146634	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.7	volts
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Switching Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations This Read Vac	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AL	206	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AF	206	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations C Ø	0	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	359402	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BCH000174	Charger	005-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations Ground	0	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	LTC000686	LTCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	LTC Totalizer Reading	2350.08	kw
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	9 Month Operations	2	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps A Ø	78.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps B Ø	63.0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Reading	.9792	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations A Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps C Ø	102.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	9 Month Operations	10	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Present	42	°C
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	509	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	509	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	299	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	212	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Regulator As Left Counter	64686	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	20	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	10	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	16.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	16.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	122.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	125.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Operations Counter	203	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	lights being changed out	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Regulator As Left Counter	57556	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps C Ø	150.0	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps B Ø	116.0	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	333	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	if no, which cells in comments
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	9	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	9	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1036	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1036	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A and B phase TOC	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	2	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	2	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	9 Month Operations	7	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps A Ø	49.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps B Ø	83.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps C Ø	74.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations A Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations B Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations C Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations Ground	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Maintenance Operations	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations Counter AF	179	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations Counter AL	180	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations This Read Vac	3	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Switching Operations	3	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	General Comments	OK	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Reading	.6120	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Present	30	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Max	0	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	LTC Totalizer Reading	5875.20	kw
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Operations Counter	205	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	404	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	27.4	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	24.8	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.1	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	770	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	411	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	LTC Totalizer Reading	5866.56	kw
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Max	55	°C
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Present	45	°C
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Reading	.8148	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.9128	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4590.72	kw
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps C Ø	22.0	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps B Ø	62.0	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	1400 on bottle	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Operations Counter	287	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps C Ø	62.0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps B Ø	64.0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps A Ø	78.0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Min Tap Position	16L	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	45	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Current Tap Position	10L	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	312	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	312	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	carded on 0120	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	9 Month Operations	3	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps A Ø	228.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps B Ø	257.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Amps C Ø	220.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations A Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations B Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations C Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations Ground	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Maintenance Operations	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations Counter AF	159	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations Counter AL	159	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations This Read Vac	1	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Switching Operations	1	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Unknown Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps C Ø	10.0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps B Ø	30.0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps A Ø	30.0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	9 Month Operations	9	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	General Comments	Did not see spare fuses	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	15	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	General Comments	Fence is only grounded on one spot on every side.	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Regulator As Left Counter	128198	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	9 Month Operations	3	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Current Tap Position	11L	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Max Tap Position	4L	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps A Ø	70.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps B Ø	60.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps C Ø	60.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations A Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations B Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations C Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations Ground	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps A Ø	36.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps B Ø	24.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps C Ø	34.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations A Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations B Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations C Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations Ground	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Maintenance Operations	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations Counter AF	170	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations Counter AL	170	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations This Read Vac	1	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Switching Operations	1	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Unknown Operations	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2022-08-16 00:00:00.000000	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	598	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	598	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CVVT Visible Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	General Comments		
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Maintenance Operations	0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AF	189	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AL	189	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations This Read Vac	0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Switching Operations	0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Unknown Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Leaks	None	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Pressure OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Fault Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Maintenance Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Number of Ops last 9 Months	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AF	56	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AL	56	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations This Read Oil	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2021-02-09 00:00:00.000000	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Switching Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Leaks	None	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Unknown Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	9 Month Operations	2	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations A Ø	0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations B Ø	0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations C Ø	0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations Ground	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	General Comments	empty nitro bottles	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.1	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Regulator As Left Counter	130633	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Unknown Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Switching Operations	4	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations This Read Vac	4	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AL	122	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AF	118	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Maintenance Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations Ground	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations C Ø	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations B Ø	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations A Ø	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	All Connections OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	340	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	193	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	340	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	11.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	282	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	108.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	81.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	117.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Regulator As Left Counter	54599	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Operations This Read Vac	4	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.3270	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Switching Operations	0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Present	15	°C
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	392.40	kw
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Unknown Operations	0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Operations Counter	80	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Amps A Ø	54.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	934	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	934	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	All Connections OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Reading	1.0998	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Present	28	°C
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Max	47	°C
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	General Comments	Breaker open	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments	Labeled :12 KV BUS TIE	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	125	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	125	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	LTC Totalizer Reading	1979.64	kw
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AF	204	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Maintenance Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations Ground	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations C Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations B Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations A Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Regulator As Left Counter	38338	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Present	17	°C
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Max	30	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Unknown Operations	0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Switching Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations This Read Vac	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AL	204	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps C ∅	22.0	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps B ∅	24.0	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps A ∅	15.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Switching Operations	1	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations This Read Vac	1	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AL	47	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AF	47	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Min Tap Position	16L	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Regulator As Left Counter	76079	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Current Tap Position	10L	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Min Tap Position	16L	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Operations Counter	60	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Regulator As Left Counter	112011	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	9 Month Operations	6	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps A Ø	46.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps B Ø	56.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps C Ø	44.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps A Phase V	8.87	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations A Ø	2	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations B Ø	1	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations C Ø	1	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Operations Ground	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Ambient Temp	28	*F
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	General Comments	ABC/511 Ops From Ice Storm	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Maintenance Operations	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Operations Counter AF	223	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Operations Counter AL	223	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Switching Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations This Read Vac	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AL	47	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AF	47	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps C Ø	895.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps B Ø	948.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps A Ø	1045.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	9 Month Operations	2	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99982	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99982	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	127.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	115.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	128.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps A Phase V	13.31	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations A Ø	3	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations B Ø	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations C Ø	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Fault Operations Ground	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Operations Since Last Insp	943	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Min Tap Position	10L	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Current Tap Position	8L	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Left Counter	47746	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Found Counter	47742	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	General Comments	Ice Storm AC/511 ops	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Maintenance Operations	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations Counter AF	230	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations Counter AL	230	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Operations This Read Vac	3	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Switching Operations	0	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Maintenance Operations	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations Ground	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations C Ø	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations B Ø	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations A Ø	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps C Ø	100.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps B Ø	100.0	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps A Ø	100.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	9 Month Operations	1	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	9 Month Operations	7	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps A Ø	25.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps B Ø	25.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps C Ø	25.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	oil low main tank	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations Counter AF	117	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations Counter AL	117	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Operations This Read Vac	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Switching Operations	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Unknown Operations	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Operations Since Last Insp	634	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Max Tap Position	14R	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Current Tap Position	3R	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Left Counter	47554	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Found Counter	47550	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Reading	.4716	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	9 Month Operations	1	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps A Ø	132.0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Present	32	°C
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	LTC Totalizer Reading	4527.36	kw
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps B Ø	105.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Amps C Ø	78.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Fault Operations C Ø	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	9 Month Operations	4	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3216	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Present	15	°C
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Max	31	°C
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	257.28	kw
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	General Comments		
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	9 Month Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps A Ø	70.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps B Ø	80.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps C Ø	115.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Regulator As Left Counter	572268	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Found Counter	379896	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Left Counter	379906	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Amps A Ø	22.0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Ambient Temperature	36	*F
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Current Tap Position	3L	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Unknown Operations	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Switching Operations	2	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations This Read Vac	2	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AL	343	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AF	341	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Maintenance Operations	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	62.50	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	General Comments		
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Regulator As Left Counter	82200	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps C Ø	190.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps B Ø	155.0	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps A Ø	180.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Left Counter	12674	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Max Tap Position	1R	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Min Tap Position	3L	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Operations Since Last Insp	344	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Reading	.9940	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Oil Temp Max	35	°C
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Unknown Operations	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2385.60	kw
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Unknown Operations	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Switching Operations	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations This Read Vac	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AL	191	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AF	191	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Unknown Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Switching Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations This Read Vac	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AL	122	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AF	122	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Current Tap Position	1R	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Max Tap Position	8R	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Min Tap Position	6L	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Operations Since Last Insp	1041	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations A Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations B Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations C Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AF	123	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AL	123	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	411	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	431	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	408	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations This Read Vac	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Switching Operations	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Found Counter	12664	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps C Ø	23.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps B Ø	27.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps A Ø	26.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	9 Month Operations	1	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	116	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.7	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps B Ø	8.3	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.5	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	139	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	112	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Unknown Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Switching Operations	4	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations This Read Vac	4	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AL	62	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AF	62	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Maintenance Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	All Connections OK?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Operation Checked?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Output Voltage Level	124.5	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Time Delay	30	Seconds
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps A Ø	101.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	General Comments	4 switching ops during tornado outage.	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps B Ø	103.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps C Ø	99.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Pumps Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Pumps Operational?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Maintenance Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations Ground	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	LTC Totalizer Reading	6134.40	kw
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Max	36	°C
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations C Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations B Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations A Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Reading	.4260	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Max	36	°C
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Present	20	°C
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps B Ø	83.0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps C Ø	86.0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	General Comments	This is the right VC. 120 was wrong.	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AF	119	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AL	119	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations This Read Vac	0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.1524	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Operations Counter	16	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Switching Operations	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.6	VDC
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations C Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations B Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations A Ø	0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	General Comments		
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	274.32	kw
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	51	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Found Counter	14770	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Left Counter	14774	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Current Tap Position	12L	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Max Tap Position	3L	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Min Tap Position	16L	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Operations Since Last Insp	3026	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps C Ø	27.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps B Ø	25.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps A Ø	25.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	9 Month Operations	5	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations Ground	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	General Comments		
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	9 Month Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	9 Month Operations	1	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps A Ø	160.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps B Ø	151.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Amps C Ø	166.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AF	90	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AL	90	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations This Read Vac	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps A Ø	98.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps B Ø	98.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps C Ø	85.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations A Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations B Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Found Counter	18879	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Left Counter	18879	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1003	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations Ground	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Maintenance Operations	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Pumps Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Pumps Operational?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	941	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	941	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	oil low main tank and tap changer	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Fans Operational?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	General Comments		
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Unknown Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Switching Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations This Read Vac	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AL	51	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AF	51	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Winding Temp Max	50	°C
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Readings	Winding Temp Present	25	°C
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Regulator As Left Counter	272748	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	78.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	74.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	86.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	General Comments	OK	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	9 Month Operations	1	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Fans Operational?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	462	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	462	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	General Comments		
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Found Counter	8900	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Left Counter	8910	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Current Tap Position	8L	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Max Tap Position	3L	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Min Tap Position	10L	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Operations Since Last Insp	412	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	3L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1196	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Regulator As Left Counter	358972	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Regulator As Left Counter	270625	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	49.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	48.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	42.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	148.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	193.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	150.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	General Comments	ok	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	General Comments		
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Max Tap Position	1R	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Regulator As Left Counter	161521	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	97	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	14L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	230793	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1196	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10968	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6642	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Max	53	°C
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	398.52	kw
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Current Tap Position	3L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	General Comments		
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.3	VDC
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.2	VDC
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps A Ø	114.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Max Tap Position	1L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Regulator As Left Counter	26456	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7382.88	kw
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0254	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Max Tap Position	1R	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Reading	1.0902	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	General Comments		
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Operations Counter	1039	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	General Comments		
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps C Ø	42.9	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps B Ø	35.1	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps A Ø	44.1	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	LTC Totalizer Reading	10465.92	kw
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Max	48	°C
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Present	40	°C
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	General Comments	ok	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	low oil (temp)	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	General Comments	ok	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	General Comments	ok	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Regulator As Left Counter	345514	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	19	*C
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	35	*C
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	General Comments	bushing 4th skirts broken	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	General Comments		
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Chipped	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0384	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	50	°C
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	30.72	kw
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	General Comments	oil level very low	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	General Comments		
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.7	amps
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCCControl	592-1	LTC Control Insp	All Connections OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCCControl	592-1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCCControl	592-1	LTC Control Insp	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCCControl	592-1	LTC Control Insp	LTC Operation Checked?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	General Comments		
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001677	BreakerVacuum	492-1742	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	General Comments		
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	All Connections OK?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Time Delay	30	Seconds
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Operations Counter AL	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1398.24	kw
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	General Comments	Needs new psi guage	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	General Comments		
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	184	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	14L	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Operations Counter AF	101	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Num Operations Last 9 Months	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Maintenance Operations	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	General Comments	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	General Comments	per SEL in House amp readings lw3	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Left Counter	14854	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Found Counter	14854	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Fault Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	54	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	16L	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Left Counter	14613	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Found Counter	14613	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	General Comments		
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Amps C Ø	36.0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Amps B Ø	17.0	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	19	°C
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	General Comments	very low oil level	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	General Comments		
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5826	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Present	29	°C
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Max	68	°C
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Unknown Operations	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Switching Operations	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	SF6 Pressure	64	psi
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001674	BreakerSF6	492-608	GCB Readings	Operations This Read SF6	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	General Comments	Some ruts in drive, no SPCC spill kit.	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Present	40	°C
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Max	58	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	97	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	46.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	51.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	52.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Unknown Operations	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Switching Operations	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Operations This Read Vac	1	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Operations Counter AL	177	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Operations Counter AF	176	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Maintenance Operations	1	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	General Comments	TC	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	General Comments		
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Foundation Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Present	50	°C
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Max	60	°C
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Reading	1.1300	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Vegetation	None	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Amps C Ø	32.0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Amps B Ø	22.0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Amps A Ø	29.0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	9 Month Operations	40	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Time Delay	30	Seconds
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	All Connections OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Percent Thermal Load X2 Max	110	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	123950	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	123950	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	8L	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	LTC Totalizer Reading	10848.00	kw
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Operations Ground	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Operations C Ø	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Operations B Ø	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Operations A Ø	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	BK001678	BreakerVacuum	492-1743	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	oil little low due to temp	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	540.00	kw
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	33	°C
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	22	°C
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.6750	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps B Ø	12.0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	25	°C
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps A Ø	7.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	15	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	15	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	15	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Present	40	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	80	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	80	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	70	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	70	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	75	°C
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Bad	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	General Comments	spare fuse barrels bad	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	General Comments	There is no max oil temp hand.	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1510	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1510	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Found Counter	17691	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	General Comments	TR is carded	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Present	15	°C
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	not here	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Maintenance Operations	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AF	404	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AL	406	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations This Read Vac	2	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Switching Operations	2	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Switching Operations	2	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations This Read Vac	2	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations Counter AL	191	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations Counter AF	189	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Maintenance Operations	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations C Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps C Ø	13.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps B Ø	0.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps A Ø	1.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps C Ø	150.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps B Ø	170.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps A Ø	145.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	9 Month Operations	4	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	General Comments	REMOVED ONE FAN FOR REPAIR	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	9 Month Operations	4	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Unknown Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Switching Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations This Read Vac	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AL	210	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AF	210	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Maintenance Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations Ground	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations C Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations B Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations A Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps C Ø	25.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps B Ø	27.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps A Ø	52.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	9 Month Operations	2	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Operations Counter	30	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	General Comments	27.4/25.1	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	533.52	kw
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Present	26	°C
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	900	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5928	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Unknown Operations	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Switching Operations	2	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations This Read Vac	2	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations Counter AL	185	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations Counter AF	183	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Maintenance Operations	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps C Ø	50.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps B Ø	50.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps A Ø	80.0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Regulator As Left Counter	77784	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	237.12	kw
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Present	21	°C
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2964	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Found Counter	31691	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Left Counter	31691	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Current Tap Position	11L	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Operations Since Last Insp	489	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations A Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations B Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations C Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Operations Ground	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	General Comments	4 Switching ops during tornado outage.	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Maintenance Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations Counter AF	196	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations Counter AL	196	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Operations This Read Vac	4	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Switching Operations	4	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Unknown Operations	0	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	All Connections OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3714	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Operations Since Last Insp	603	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Min Tap Position	15L	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Current Tap Position	10L	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Left Counter	86940	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Found Counter	86935	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments	not here	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 7:03	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	General Comments		
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Oil Temp Present	19	*C
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Oil Temp Max	32	*C
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2674.08	kw
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	General Comments		
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	General Comments	Fence fabric and railing are rusty.	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Found Counter	224937	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Left Counter	224937	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Current Tap Position	7L	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Max Tap Position	2L	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Min Tap Position	10L	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Operations Since Last Insp	278	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3528	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Present	19	°C
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	423.36	kw
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	75	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Left Counter	17713	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Current Tap Position	6L	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Max Tap Position	1R	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Min Tap Position	12L	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Operations Since Last Insp	799	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Structure Patrol Visible Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Wood Structures OK?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	72.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	67.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	78.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	672	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	672	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	295.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	307.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	3144.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	9 Month Operations	11	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps A Ø	0.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps B Ø	4.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Amps C Ø	3.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000009	BreakerVacuum	005-3409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	43	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	34	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	41	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	33	°C
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Operations Counter	9	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps A Ø	423.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps B Ø	466.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps C Ø	428.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AF	204	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AL	204	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations This Read Vac	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	42	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	34	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Max	41	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	42	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	34	°C
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Unknown Operations	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Operations Counter	227	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	General Comments	Frankfort Plant Board substation fence next to ours	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.2	VDC
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.2	VDC
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Operations Counter	104	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 12:10	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	p&c checking cooling, needs nitro	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps C Ø	60.0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps B Ø	70.0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps A Ø	52.0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	9 Month Operations	2	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	General Comments	ok	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	326804	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	General Comments		
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0070	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	313	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Min Tap Position	11L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Max Tap Position	4L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Current Tap Position	4L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Left Counter	18394	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Found Counter	18394	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	219	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Left Counter	216456	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Found Counter	216456	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Regulator As Left Counter	296901	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Regulator As Left Counter	63820	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	738.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	678.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	686.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1504.80	kw
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99791	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99791	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations Ground	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps C Ø	279.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps B Ø	253.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps A Ø	246.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	9 Month Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AF	55	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AL	55	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations This Read Vac	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Switching Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Unknown Operations	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Switching Operations	1	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations This Read Vac	1	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AL	400	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AF	399	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	General Comments		
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	243	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	251	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.8	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.4	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps A Ø	17.6	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	271	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Maintenance Operations	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations Counter AF	138	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations Counter AL	138	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations This Read Vac	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Switching Operations	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Unknown Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	All Connections OK?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	General Comments		
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Left Counter	4704	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Found Counter	4704	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Maintenance Operations	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations Ground	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations C Ø	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations B Ø	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations A Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	123.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	122.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 12:43	Distribution	Earlinton Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/8/2022 12:44	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6270	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	49	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	49	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Regulator As Left Counter	125411	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.6	volts
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Oil Level	Low	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	34	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	9 Month Operations	1	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps A Ø	326.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps B Ø	341.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps C Ø	307.0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations A Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations B Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations C Ø	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations Ground	0	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	General Comments		
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Regulator As Left Counter	498	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Regulator As Left Counter	58585	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	General Comments		
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Positive DC Ground	67.2	VDC
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Negative DC Ground	66.1	VDC
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	9 Month Operations	4	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps A Ø	0.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps B Ø	0.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	9 Month Operations	2	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps A Ø	18.0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps B Ø	11.0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps C Ø	18.0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations A Ø	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations B Ø	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations C Ø	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations Ground	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Maintenance Operations	0	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AF	322	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AL	323	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations This Read Vac	1	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Switching Operations	1	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Unknown Operations	0	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Regulator As Left Counter	64701	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Switching Operations	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Unknown Operations	0	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Regulator As Left Counter	517	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000221	Regulator	492-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23643	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	General Comments	trees hanging over	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Unknown Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Switching Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations This Read Vac	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AL	235	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AF	235	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Maintenance Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations Ground	0	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations C Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations B Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations A Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Unknown Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	KO148	BreakerVacuum	705-0726	VCB Readings	Amps C Ø	0.0	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000220	Regulator	492-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Switching Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations This Read Vac	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AL	225	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AF	225	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Maintenance Operations	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	General Comments	caution on	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations Ground	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations C Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations B Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations A Ø	0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps C Ø	7.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps B Ø	1.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps A Ø	10.0	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	9 Month Operations	3	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Regulator As Left Counter	114250	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Max Tap Position	4R	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	General Comments		
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Regulator As Left Counter	485	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	RG000222	Regulator	492-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Unknown Operations	0	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Regulator As Left Counter	131502	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Regulator As Left Counter	110640	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Regulator As Left Counter	128589	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 12:36	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Operations A Ø	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Operations B Ø	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	General Comments		
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	All Connections OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	245.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	240.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	225.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Fault Operations Ground	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99984	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99984	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Maintenance Operations	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Operations Counter AF	186	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Operations Counter AL	186	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Operations This Read Vac	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Switching Operations	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AL	195	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AF	195	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Maintenance Operations	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations Ground	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations C Ø	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations B Ø	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations A Ø	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps C Ø	48.0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps B Ø	57.0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps A Ø	30.0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	9 Month Operations	1	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:12	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	9 Month Operations	5	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Amps A Ø	130.0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Amps B Ø	145.0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Readings	Amps C Ø	146.0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001435	BreakerVacuum	338-4607	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Operations Counter AL	179	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Operations This Read Vac	2	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Switching Operations	2	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Unknown Operations	0	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps B Ø	85.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps C Ø	90.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations A Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Switching Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AL	130	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AF	130	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	9 Month Operations	1	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Out of service	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	General Comments	ok	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Regulator As Left Counter	62386	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Operations Counter AF	178	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Amps C Ø	23.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Amps B Ø	47.0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Amps A Ø	23.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	9 Months Operations	1	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AF	186	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AL	186	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations This Read Vac	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Switching Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Unknown Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Unknown Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Switching Operations	1	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations This Read Vac	1	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations Counter AL	191	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations Counter AF	190	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Maintenance Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	General Comments	Could use new spare fuse barrels because fiberglass is coming apart. Whole station needs wildlife protection and secondary cover for A	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations C Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations Ground	0	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Ambient Temp	38	F
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	General Comments	Bank opposite the gate needs attention. Animals can crawl under the fence and cause an outage	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps C Ø	500.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps B Ø	450.0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps A Ø	475.0	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Found Counter	46076	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Left Counter	46076	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	48	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	High	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 13:11	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations A Ø	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations B Ø	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations C Ø	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations Ground	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Operations Ground	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Operations C Ø	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Operations B Ø	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Operations A Ø	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	9 Month Operations	2	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps A Ø	72.0	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Regulator As Left Counter	62457	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Operations Counter AF	214	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Maintenance Operations	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	General Comments		
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Follow-up Action Required?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	9 Month Operations	3	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Amps A Ø	200.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Amps B Ø	194.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Amps C Ø	190.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Bushings Connection/Risers	Good	If no, which cells in comments
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Regulator As Left Counter	52321	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	General Comments		CONTROL WAS LEFT IN LOCAL CAALD JOE TO SEE IF IT WAS THERE FOR A REASON
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Found Counter	112132	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Left Counter	112132	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	773	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	SB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	SB0263	BreakerVacuum	600-0475	VCB Readings	Maintenance Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	SB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	SB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AF	120	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	15	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Basement Condition Acceptable	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	General Comments	ok	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Operations A Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Operations B Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Operations C Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Fault Operations Ground	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Readings	Maintenance Operations	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001576	BreakerVacuum	400-2506	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 14:04	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 6:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Unknown Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Switching Operations	1	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations This Read Vac	1	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations Counter AL	181	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Operations Counter AF	180	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Maintenance Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	General Comments		
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Unknown Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Switching Operations	4	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations This Read Vac	4	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AL	124	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments	27.9/25.3	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	9	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Left Counter	103132	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Found Counter	103132	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	General Comments		
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Reading	.5358	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Operations Since Last Insp	151	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Min Tap Position	7L	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	General Comments	neighboring substation fence is within 6', but has been cut free of our fence. multiple stolen grounds (repaired)	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Current Tap Position	5L	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	18.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	18.0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	21.0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations Ground	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations C Ø	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations B Ø	0	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	General Comments	SPR system has been removed	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	9 Month Operations	2	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps A Ø	0.0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps B Ø	0.0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Amps C Ø	0.0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:01	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Operations A Ø	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	LTC Totalizer Reading	2571.84	kw
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	General Comments		
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	General Comments	Max hand on liquid gauge is broken.	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 13:36	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 6:19	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Present	30	°C
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Max	80	°C
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Regulator As Left Counter	70377	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Present	0	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Max	10	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Max	44	°C
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Min Tap Position	7L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	LTC Totalizer Reading	12006.00	kw
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	General Comments		
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps C Ø	157.0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps B Ø	155.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	9 Month Operations	3	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps A Ø	110.0	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	BAT001592	Battery	ET-Battery Bank 48V	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 10:28	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations Ground	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations C Ø	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations B Ø	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations A Ø	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Winding Temp Present	30	°C
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Winding Temp Max	35	°C
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Totalizer Meter Reading	.6670	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Current Tap Position	4L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	General Comments		
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	69.17	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	9 Month Operations	3	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Operations A Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Operations B Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Operations C Ø	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Operations Ground	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Maintenance Operations	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Operations Counter AF	201	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Operations Counter AL	202	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Operations This Read Vac	2	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Switching Operations	2	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Unknown Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 14:54	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	99.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	95.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	94.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	LTC Totalizer Reading	9527.04	kw
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Max	20	°C
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Reading	.9924	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Max	30	°C
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Present	25	°C
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Amps A Ø	166.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Amps B Ø	165.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Amps C Ø	155.0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BK001577	BreakerVacuum	400-2507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Unknown Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Switching Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations This Read Vac	5	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AL	198	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AF	198	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	9 Month Operations	6	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Maintenance Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	General Comments		
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Maintenance Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations Ground	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations C Ø	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	General Comments	ok	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	General Comments	1 ABC T op, 2 CG ops	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations Ground	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations C Ø	3	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations B Ø	1	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations A Ø	1	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps C Phase V	16.37	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps B Phase V	5.46	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps A Phase V	5.46	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	All Connections OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	General Comments	neighbors fence is within inches of substation fence see pictures in comments on 1/4 inspection order	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations This Read Vac	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations Counter AL	157	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations Counter AF	157	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	13	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	13	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	0	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Current Tap Position	4L	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Left Counter	92852	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Found Counter	92852	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	General Comments	dead battery	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	165	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	165	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	32.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	32.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	31.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
2/8/2022 10:33	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments	not here	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps C Ø	48.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	83.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	91.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	94.0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations B Ø	0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations A Ø	0	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps C Ø	157.0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps B Ø	153.0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps A Ø	101.0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	9 Month Operations	1	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments	battery off, line side open and hc	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	2684	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 7:08	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 10:46	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	48	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	48	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Unknown Operations	0	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 11:47	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	General Comments	fence is not connected to our fence but within about a foot. see pictures in comments on 1/4 inspection order	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 10:09	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	848	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001293	PowerFuse	ET-1422 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001293	PowerFuse	ET-1422 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001293	PowerFuse	ET-1422 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	848	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	79.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	71.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	66.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001294	PowerFuse	ET-1423 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001294	PowerFuse	ET-1423 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001294	PowerFuse	ET-1423 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1055	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1055	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001295	PowerFuse	ET-1424 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001295	PowerFuse	ET-1424 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001295	PowerFuse	ET-1424 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	9 Month Operations	7	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps A Ø	32.0	
2/8/2022 12:43	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps B Ø	40.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	235.0	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001292	PowerFuse	ET-1421 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	General Comments		
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	203.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	196.0	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001292	PowerFuse	ET-1421 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/8/2022 9:48	Distribution	Ethel Quarterly Inspection	PF001292	PowerFuse	ET-1421 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Switching Operations	0	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Operations This Read Vac	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Operations Counter AL	214	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 6:44	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Switching Operations	0	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/8/2022 11:17	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 6:49	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Grounds in Place?	y	
2/8/2022 16:14	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	General Comments		
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Foundation Condition	Good	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 15:14	Distribution	Norton East Quarterly Inspection	BK001581	BreakerVacuum	338-4608	VCB Readings	Unknown Operations	0	
2/8/2022 13:43	Distribution	Florida Tile Quarterly Inspection	BCH001455	Charger	400-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 13:06	Distribution	Shadrack Quarterly Inspection	FE000874	Fence	600-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/9/2022 5:40	Distribution	Uniontown Quarterly Inspection	TX000274	NonLTC	492-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/8/2022 16:17	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 9:10	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.9	VDC
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.2	VDC
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.9	VDC
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Regulator As Left Counter	17978	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	General Comments		
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Current Tap Position	1L	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000095	Regulator	004-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	17068	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000093	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Switching Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Unknown Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Unknown Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Switching Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations This Read Vac	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AL	400	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Operations This Read Vac	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Operations Counter AL	133	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC Operations Since Last Insp	258	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC Min Tap Position	6L	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC Max Tap Position	5R	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	9 Month Operations	5	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Present	25	°C
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5870	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Maintenance Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AF	400	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	General Comments		
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	fence to the warter company within 6'	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Operations A Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Operations B Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Maintenance Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Operations Counter AF	133	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC Current Tap Position	1R	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC As Left Counter	2410	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	LTC As Found Counter	2410	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Max Tap Position	9R	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28079	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Amps A Ø	68.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Amps B Ø	54.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Amps C Ø	132.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Reading	.5328	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Max	40	°C
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Present	30	°C
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations A Ø	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations B Ø	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Unknown Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Switching Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Operations This Read Vac	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Operations Counter AL	182	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001529	BreakerVacuum	462-0298	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Unknown Operations	0	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations This Read SF6	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AL	376	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AF	376	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Num Operations Last 9 Months	3	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Maintenance Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Operations B Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Operations A Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Amps C Ø	0.0	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Amps B Ø	0.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Amps A Ø	0.0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	9 Month Operations	2	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	General Comments	FNTC- Counter did not move	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Maintenance Operations	1	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AF	160	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AL	160	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	337	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	9 Month Operations	2	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps A Ø	185.0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps B Ø	180.0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps C Ø	185.0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Unknown Operations	0	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Switching Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Left Counter	111963	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Found Counter	111963	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Operations Counter AF	182	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Maintenance Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Regulator As Left Counter	102736	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations This Read Vac	1	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Switching Operations	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps C Ø	320.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps B Ø	320.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps A Ø	320.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	9 Month Operations	2	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Vegetation	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps A Ø	0.0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps B Ø	0.0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps C Ø	0.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	LTC Totalizer Reading	7672.32	kw
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Max	40	°C
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1056.60	kw
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations Ground	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations C Ø	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations A Ø	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001530	BreakerVacuum	462-0299	VCB Readings	9 Month Operations	7	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Fault Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps C Ø	66.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps B Ø	48.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps A Ø	55.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG00088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	SWG00088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Operations Counter AF	90	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Operations Counter AL	90	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Operations This Read Vac	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Switching Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Unknown Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Operations Counter	85	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	30	°C
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps C Ø	44.0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps A Ø	44.0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Amps C Ø	167.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps A Ø	36.0	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	30	°C
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	15	°C
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	General Comments	27.2	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Operations Counter	12	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Operations A Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Operations B Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Maintenance Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations A Ø	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations B Ø	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations C Ø	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations Ground	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Regulator As Left Counter	300202	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	General Comments	one trip check	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Maintenance Operations	1	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AF	165	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AL	1	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations This Read Vac	1	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Switching Operations	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Regulator As Left Counter	69450	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	General Comments	ok	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Present	32	°C
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AF	146	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AL	147	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations This Read Vac	1	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Switching Operations	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Unknown Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Switching Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Operations This Read Vac	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Operations Counter AL	168	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Operations Counter AF	168	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5937	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	118.74	kw
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	General Comments		
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC As Found Counter	269888	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Maintenance Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	9 Month Operations	4	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps A Ø	200.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Operations B Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Operations A Ø	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps B Ø	180.0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps C Ø	150.0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCM000108	LTCMechanism	462-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Unknown Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	All Connections OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	LTC Operation Checked?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	9 Month Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Amps A Ø	273.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Amps B Ø	235.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Amps C Ø	285.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Operations A Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Operations B Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BCH001491	Charger	891-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Maintenance Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Operations Counter AF	128	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Operations Counter AL	128	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Operations This Read Vac	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Switching Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001525	BreakerVacuum	462-1	VCB Readings	Unknown Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	LTCC000869	LTCControl	462-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations A Ø	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations B Ø	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations C Ø	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Unknown Operations	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	General Comments	one trip check	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Maintenance Operations	1	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Unknown Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0698	BreakerSF6	OK-1271	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC As Left Counter	269888	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Current Tap Position	8L	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Max Tap Position	5L	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Operations Since Last Insp	246	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Current Tap Position	6R	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11623	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46548	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	9 Month Operations	9	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Amps A Ø	199.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001527	BreakerVacuum	462-0296	VCB Readings	Amps B Ø	173.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Amps C Ø	0.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Amps B Ø	0.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Amps A Ø	0.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001528	BreakerVacuum	462-0297	VCB Readings	9 Month Operations	9	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23982	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	9 Month Operations	4	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Amps A Ø	0.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Amps B Ø	0.0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0123	Regulator	891-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Amps C Ø	0.0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Regulator As Left Counter	172963	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Operations A Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Operations B Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Maintenance Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Operations Counter AF	63	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Operations Counter AL	63	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Operations This Read Vac	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	BK001526	BreakerVacuum	462-BT1-2	VCB Readings	Switching Operations	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Operations Counter AL	160	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Operations Counter AF	158	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Maintenance Operations	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Operations Ground	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Operations A Ø	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Amps A Ø	72.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Amps B Ø	84.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Amps C Ø	72.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Unknown Operations	0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Ambient Temp	28	*F
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Switching Operations	2	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Operations This Read Vac	2	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Negative DC Ground	-28.7	VDC
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	9 Month Operations	31	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH001483	Charger	670-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps A Ø	28.0	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	101	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2370.24	kw
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps A Ø	493.0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	116	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	121	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Operations Counter	82	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Switching Operations	0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Unknown Operations	0	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99995	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99995	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	General Comments	Whole station needs wildlife protection.	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	391.32	kw
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	207.50	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.6522	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps A Ø	9.0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps B Ø	7.0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps C Ø	7.0	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	ST000853	Structure	462-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Oil Temp Max	55	°C
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Regulator As Left Counter	906058	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Totalizer Meter Reading	1.0242	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Winding Temp Max	0	°C
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Winding Temp Present	0	°C
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Regulator As Left Counter	453649	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Readings	LTC Totalizer Reading	9832.32	kw
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	FE000871	Fence	462-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	9 Month Operations	34	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	9 Month Operations	27	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Amps A Ø	78.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Amps B Ø	98.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Amps C Ø	103.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Regulator As Left Counter	203688	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps C Ø	17.0	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps A Ø	17.0	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	General Comments		
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Current Tap Position	7R	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Max Tap Position	9R	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28079	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC Operations Since Last Insp	571	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC Min Tap Position	7L	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC Max Tap Position	11R	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC Current Tap Position	3R	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC As Left Counter	64581	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	LTC As Found Counter	64581	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Counter Readings	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Regulator As Left Counter	140998	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	VCB Readings	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Amps A Ø	377.0	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	General Comments	ok	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Operations Counter	178	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	General Comments	could not reset even with magnet	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	General Comments	left center fan not working	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1	psi
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3204.00	kw
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3350	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Operations A Ø	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Operations C Ø	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Fault Operations Ground	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	General Comments		
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Neighboring Fence within 6'	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	General Comments	fabric and fence very rsty multiple spots with 1in or greater gap	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	General Comments		
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Maintenance Operations	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Operations Counter AF	158	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Operations Counter AL	161	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Operations This Read Vac	3	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Readings	Switching Operations	3	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001788	BreakerVacuum	670-0406	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	General Comments	ok	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Maintenance Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Num Operations Last 9 Months	1	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AF	364	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AL	364	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations This Read SF6	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Switching Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Unknown Operations	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	General Comments		
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15526	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Operations A Ø	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Operations C Ø	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Fault Operations Ground	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9876	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Regulator As Left Counter	254411	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001552	Battery	670-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps B Ø	485.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps C Ø	516.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Fault Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Amps C Ø	89.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Amps B Ø	88.0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Amps A Ø	78.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Operations This Read Vac	3	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Switching Operations	3	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Unknown Operations	0	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Operations Counter	210	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	General Comments	ok	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	629.76	kw
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Max	55	°C
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7872	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Maintenance Operations	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Operations Counter AF	175	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001789	BreakerVacuum	670-0407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BK001787	BreakerVacuum	670-0405	VCB Readings	Operations Counter AL	178	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0122	Regulator	891-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Oil Temp Max	42	°C
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Regulator As Left Counter	157785	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	27.4	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	General Comments		
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Operations Counter	140	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Regulator As Left Counter	16493	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	1.1555	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	WB0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1434	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	WB0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	4200	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	9 Month Operations	1	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps A Ø	80.0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps B Ø	125.0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps C Ø	60.0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations A Ø	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Operations Since Last Insp	105	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Max Tap Position	4L	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Current Tap Position	6L	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC As Left Counter	998	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC As Found Counter	989	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	General Comments		
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Max	35	°C
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Present	19	°C
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1021	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1021	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	General Comments		
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	LTC Totalizer Reading	3477.60	kw
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Max	38	°C
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Present	22	°C
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Regulator As Left Counter	18033	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps A Ø	79.0	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps B Ø	73.0	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps C Ø	83.0	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	KR0100	Regulator	891-1 A	Regulator Patrol Inspection	Current Tap Position	7R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Operations Since Last Insp	170	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	General Comments	ok	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Left Counter	31199	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Found Counter	31199	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	9 Month Operations	1	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations A Ø	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Regulator As Left Counter	151025	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations A Ø	0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations C Ø	0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations Ground	0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	General Comments		
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	General Comments	1 - Sub Upgrade	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Maintenance Operations	1	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AF	181	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AL	181	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations This Read Vac	1	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	SWG000219	Switchgear	462-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Regulator As Left Counter	52930	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	126.0	volts
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	General Comments	ok	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps C Ø	102.0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps A Ø	127.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps B Ø	193.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps B Ø	108.0	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Oil Temp Max	42	°C
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps A Ø	105.0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps C Ø	190.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	9 Month Operations	3	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Present	36	°C
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Max	41	°C
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	602.28	kw
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	General Comments	ok	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2810.88	kw
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	General Comments		
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	General Comments	Distribution out of service at time of check	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations Ground	0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	General Comments		
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	General Comments	1- Sub Upgrade	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Maintenance Operations	1	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AF	126	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AL	126	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations This Read Vac	1	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Switching Operations	0	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Reading	.8784	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Present	42	°C
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Max	48	°C
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Unknown Operations	0	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	General Comments		
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Regulator As Left Counter	440537	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	31.3	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	General Comments		
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Operations Counter	489	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Unknown Operations	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Switching Operations	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations This Read Vac	1	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AL	207	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AF	206	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Maintenance Operations	1	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	General Comments	FNTC	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations Ground	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations C Ø	0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Max	45	°C
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:30	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Regulator As Left Counter	17663	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps C Ø	100.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps B Ø	130.0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps A Ø	90.0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	9 Month Operations	11	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Unknown Operations	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Switching Operations	2	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations This Read Vac	2	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AL	194	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AF	192	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Maintenance Operations	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations Ground	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations C Ø	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations B Ø	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations A Ø	0	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations Ground	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations B Ø	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations A Ø	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	28	*F
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps A Ø	84.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps B Ø	84.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Amps C Ø	88.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps A Ø	80.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps B Ø	91.0	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	General Comments	reset by hand	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Found Counter	12750	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Left Counter	12759	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Current Tap Position	6L	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Max Tap Position	1R	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Min Tap Position	14L	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Operations Since Last Insp	318	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	245.60	kw
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	141.00	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Reading	.3070	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	9 Month Operations	2	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps A Ø	52.0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps B Ø	80.0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps C Ø	52.0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps C Ø	10.0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps B Ø	35.0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps A Ø	40.0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	9 Month Operations	4	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 11:32	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Warning Signs OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps A Ø	7.0	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps B Ø	7.0	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps C Ø	8.0	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Operations Counter	9	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	General Comments	ok	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	General Comments	ok	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Unknown Operations	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Switching Operations	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations This Read Vac	1	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AL	141	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AF	140	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Maintenance Operations	1	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	General Comments	FNCTC	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations Ground	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations C Ø	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations B Ø	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations A Ø	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps C Ø	180.0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps B Ø	120.0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps A Ø	140.0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	9 Month Operations	2	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	LTC Totalizer Reading	13128.00	kw
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Oil Temp Max	25	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Unknown Operations	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Switching Operations	2	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations This Read Vac	2	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AL	205	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AF	203	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Maintenance Operations	0	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Totalizer Meter Reading	.5470	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Winding Temp Max	25	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Winding Temp Present	20	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X1 Winding Temp Max	25	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X2 Winding Temp Max	25	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X3 Winding Temp Max	25	°C
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	General Comments		
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 13:30	Distribution	Markland Dam Quarterly Inspection	YD0000375	Yard	489-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	TX000255	WithLTC	462-1	LTC Transformer Patrol Inspection	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCCControl	670-1	LTC Control Insp	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCCControl	670-1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCCControl	670-1	LTC Control Insp	All Connections OK?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	General Comments	wire and fabric rusty in places around fence	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	All Connections OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	LTC Operation Checked?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Evidence of Insects	None	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Follow-up Action Required?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	General Comments	missing both fire extinguishers	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panels Dusted?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	LTC Operation Checked?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	General Comments	ok	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Neighboring Fence within 6'	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	General Comments	Old sub from factory has fence connected to ours and 2 sides of site fence. Left side cut open	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.2	VDC
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.2	VDC
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	40	*F
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Landscape Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:21	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Fault Operations	2	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Follow-up Action Required?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	General Comments	IOC A and B Phase VD only counted one operation	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Maintenance Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Num Operations Last 9 Months	3	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations Counter AF	543	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations Counter AL	543	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Operations This Read SF6	2	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Switching Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Readings	Unknown Operations	0	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 10:28	Distribution	White Sulphur Quarterly Inspection	YD000951	Yard	462-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.000	millivolts
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Unknown Operations	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Switching Operations	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations This Read Vac	1	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AL	182	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AF	182	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Maintenance Operations	1	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	General Comments	Counter did not operate with FNTC	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations Ground	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations C Ø	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations B Ø	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations A Ø	0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps C Ø	180.0	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	All Connections OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	LTC Operation Checked?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations A Ø	0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations C Ø	0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations Ground	0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	General Comments	ok	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Maintenance Operations	1	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AF	141	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AL	141	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Switching Operations	0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Unknown Operations	0	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:03	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	639	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	639	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Amps C Ø	104.0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Fault Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps Ø	130.0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps A Ø	160.0	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	9 Month Operations	2	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	General Comments		
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Maintenance Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Num Operations Last 9 Months	5	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations Counter AF	655	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations Counter AL	655	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Operations This Read SF6	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Switching Operations	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Readings	Unknown Operations	0	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Ambient Temp	38	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	General Comments	ok	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Vegetation	Light	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	General Comments	FNTC- Counter did not move	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Maintenance Operations	1	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AF	129	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AL	129	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations This Read Vac	1	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Switching Operations	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	39	*F
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Unknown Operations	0	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 12:15	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations This Read Vac	2	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AL	183	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AF	181	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Maintenance Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	General Comments		
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4495.68	kw
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Max	29	°C
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BCH001536	Charger	458-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	General Comments	ok	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9366	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Winding Temp Max	26	°C
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Winding Temp Present	26	°C
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	General Comments		
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	General Comments	No spare fuse barrels	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 14:07	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/8/2022 7:21	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 13:36	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	General Comments		
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 11:18	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Unknown Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Switching Operations	2	
2/7/2022 13:32	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	General Comments	ok	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Max	47	°C
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	All Connections OK?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Present	33	°C
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations A Ø	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	LTC Operation Checked?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations C Ø	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	All Connections OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Unknown Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Switching Operations	2	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations This Read Vac	2	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AL	183	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AF	181	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Maintenance Operations	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	General Comments		
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	General Comments		
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	9 Month Operations	2	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps A Ø	200.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps B Ø	190.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps C Ø	190.0	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 12:54	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Operation Checked?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations A Ø	0	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations B Ø	0	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.3	VDC
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	General Comments	ok	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations C Ø	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 9:34	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Regulator As Left Counter	208456	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations Ground	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/8/2022 7:11	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations C Ø	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations B Ø	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations A Ø	0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps C Ø	0.0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps B Ø	0.0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps C Ø	0.0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps B Ø	0.0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps A Ø	0.0	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	9 Month Operations	5	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	9 Month Operations	5	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 9:34	Distribution	Webco 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 9:34	Distribution	Webco 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	General Comments		
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
2/7/2022 12:40	Distribution	Christian Quarterly Inspection	BAT001610	Battery	458-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Vegetation	None	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Follow-up Action Required?	n	
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 14:22	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 10:55	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations Ground	0	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 13:18	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	General Comments		
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/16/2022 7:59	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations Ground	0	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations C Ø	0	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AL	193	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations This Read Vac	0	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.2	VDC
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Switching Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Switching Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations This Read Vac	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.900	millivolts
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AL	340	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AF	340	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Maintenance Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Unknown Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Maintenance Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AF	193	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Vegetation	None	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Maintenance Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AF	165	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AL	165	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations This Read Vac	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Switching Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Unknown Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Ambient Temp	31	°F
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Vegetation	None	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	9 Month Operations	2	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps A Ø	60.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps B Ø	65.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps C Ø	103.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations A Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations B Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	LTC Operation Checked?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	LTCC000950	LTCControl	379-1	LTC Control Insp	All Connections OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Vegetation	None	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	General Comments		
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	General Comments		
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	General Comments	Brush growing over and through the fence	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations Counter AF	174	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	General Comments		
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Operations Counter	474	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations Ground	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations C Ø	1	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations B Ø	1	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	F
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.5	VDC
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	9 Month Operations	5	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps A Ø	128.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps B Ø	131.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps C Ø	135.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations C Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations A Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps C Ø	116.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps B Ø	116.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps A Ø	99.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	9 Month Operations	4	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations A Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations Ground	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations B Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations Ground	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations C Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations B Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations A Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps C Ø	166.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps B Ø	197.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps A Ø	182.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	9 Month Operations	2	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps A Ø	57.4	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.2	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.5	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Operations Counter	5	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	General Comments		
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Unknown Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Switching Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations This Read Vac	2	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations Counter AL	174	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Negative DC Ground	16.8	VDC
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Positive DC Ground	16.8	VDC
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations This Read Vac	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AL	125	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AF	125	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Maintenance Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations Ground	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations C Ø	0	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations B Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations A Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Maintenance Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AF	204	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AL	204	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations This Read Vac	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Switching Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Unknown Operations	0	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations A Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Unknown Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Switching Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations This Read Vac	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AL	198	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AF	198	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Maintenance Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations Ground	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations C Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations B Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	9 Month Operations	3	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps A Ø	106.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps B Ø	83.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps C Ø	154.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations A Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations B Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations C Ø	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations Ground	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	9 Month Operations	2	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Switching Operations	0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Present	25	*C
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Max	35	*C
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Reading	1.4580	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Present	30	*C
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Max	40	*C
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Present	28	*C
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Max	38	*C
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Reading	1.2018	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	LTC Totalizer Reading	13996.80	kw
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Present	25	°C
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Max	25	°C
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	LTC Totalizer Reading	11537.28	kw
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	General Comments		
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	LTC Totalizer Reading	1844.64	kw
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Max	45	°C
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Reading	.7686	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps C Ø	112.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps B Ø	128.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps A Ø	151.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps A Ø	400.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps B Ø	320.0	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps C Ø	450.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	9 Month Operations	2	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	LTC Operation Checked?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations Ground	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations C Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations B Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations A Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps C Ø	69.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps B Ø	70.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps A Ø	69.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	9 Month Operations	2	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Unknown Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Ambient Temp	31	*F
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	9 Month Operations	2	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps A Ø	409.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps B Ø	428.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Vegetation	None	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Unknown Operations	0	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Unknown Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Switching Operations	0	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	All Connections OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations This Read Vac	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations Counter AL	148	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations Counter AF	148	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Maintenance Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AL	178	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations This Read Vac	2	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Switching Operations	1	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Unknown Operations	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	LTCC000526	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	LTCC000526	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	LTCC000526	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	LTCC000526	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	LTCC000526	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	LTCC000526	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	LTCC000526	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Found Counter	123551	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Left Counter	123553	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Current Tap Position	3L	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Min Tap Position	10L	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Operations Since Last Insp	852	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	LTCC000526	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Grounds in Place?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	General Comments		
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 13:18	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	All Connections OK?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	General Comments		
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	LTC Operation Checked?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Min Tap Position	6L	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Current Tap Position	6L	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Left Counter	85419	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Found Counter	85419	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	General Comments	Counter switch is bad in LTC	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	General Comments		
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps C Ø	431.0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushing Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/4/2022 14:00	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations A Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations B Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations C Ø	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations Ground	0	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Foundation Condition	Good	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Operations Since Last Insp	751	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Min Tap Position	10L	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Current Tap Position	3L	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Left Counter	139285	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Found Counter	139283	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	General Comments		
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/4/2022 11:35	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Follow-up Action Required?	n	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AF	178	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	General Comments		
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Maintenance Operations	1	
2/4/2022 10:03	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	142	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	142	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	320.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	320.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	320.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BB0474	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Vegetation	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC As Found Counter	42377	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC As Left Counter	42377	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Current Tap Position	1R	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Max Tap Position	1R	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Min Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	LTC Operations Since Last Insp	62	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCM000113	LTCMechanism	067-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AF	273	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AL	276	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations This Read Vac	3	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AL	494	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AF	494	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Maintenance Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations Ground	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations C Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations B Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations A Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps A Ø	0.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Switching Operations	3	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Unknown Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Switching Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Reading	1.7250	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Max	50	°C
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Present	25	°C
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Maintenance Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations Counter AF	164	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations Counter AL	164	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	9 Month Operations	3	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps A Ø	13.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps B Ø	14.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps C Ø	14.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	40.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations Ground	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations C Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations B Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations A Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	60.0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCCControl	522-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCCControl	522-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCCControl	522-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCCControl	522-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	625	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations This Read Vac	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AL	173	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AF	173	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Maintenance Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations Ground	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations C Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations B Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps B Ø	0.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps C Ø	0.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Fault Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Switching Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations A Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps C Ø	93.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps B Ø	148.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps A Ø	74.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	9 Month Operations	4	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	9 Month Operations	5	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations This Read Vac	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AL	262	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AF	262	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Maintenance Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps B Ø	34.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps C Ø	32.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations B Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations C Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations Ground	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Maintenance Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations Counter AF	167	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations Counter AL	169	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations This Read Vac	2	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Switching Operations	2	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Unknown Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps A Ø	47.0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	133.0	VDC
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	9 Month Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Maintenance Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations C Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations B Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	All Connections OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Negative DC Ground	67.0	VDC
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.0	VDC
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	9 Month Operations	4	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Operations Since Last Insp	593	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Min Tap Position	15L	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Max Tap Position	3L	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Current Tap Position	8L	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Left Counter	42524	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Found Counter	42520	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps A Ø	52.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Present	30	°C
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Max	35	°C
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Present	35	°C
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Max	45	°C
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	9 Month Operations	4	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps A Ø	130.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps B Ø	90.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps C Ø	150.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	LTC Totalizer Reading	24840.00	kw
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	LTC Totalizer Reading	17616.96	kw
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Present	30	°C
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Max	40	°C
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Max	30	°C
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Reading	1.2234	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Max	32	°C
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Present	20	°C
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	General Comments	Chain length fence bent at back of lot. Pic sent to Stinson	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations Ground	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations C Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations B Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Maintenance Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations Counter AF	166	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations Counter AL	166	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Maintenance Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Number of Ops last 9 Months	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Unknown Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Switching Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations This Read Vac	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AL	261	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AF	524	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AL	524	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations This Read Oil	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Switching Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Leaks	None	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Oil Level	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Unknown Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AF	261	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Maintenance Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations Ground	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	All Connections OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Tank Oil Level	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	PT Free of Leaks?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	9 Month Operations	6	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps A Ø	215.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps B Ø	180.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps C Ø	170.0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations A Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Maintenance Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps C Ø	57.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps B Ø	53.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps A Ø	60.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	9 Month Operations	2	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Unknown Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Switching Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations This Read Vac	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AL	157	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AF	157	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Maintenance Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations Ground	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations C Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations B Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations A Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps C Ø	159.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps B Ø	179.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps A Ø	171.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	9 Month Operations	5	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	115056	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Switching Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Unknown Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Unknown Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Switching Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations This Read Vac	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AL	181	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AF	181	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Found Counter	55929	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	LTC Output Voltage Level	122.5	VAC
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Left Counter	55929	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	All Connections OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	141	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps A Ø	125.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps B Ø	130.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps C Ø	136.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations B Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Present	50	°C
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Max	65	°C
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	LTC Totalizer Reading	7881.60	kw
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Operations Since Last Insp	491	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	LTC000301	LTCControl	522-1	LTC Control Insp	All Connections OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Unknown Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Maintenance Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations Counter AF	163	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations Counter AL	163	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Switching Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	625	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps C Ø	86.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps B Ø	81.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps A Ø	90.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	9 Month Operations	21	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Reading	1.6420	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Amps A Ø	94.0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Amps B Ø	109.0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Amps C Ø	103.0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Found Counter	11721	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	General Comments	Need to replace descant filter.	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps C Ø	185.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps B Ø	210.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps A Ø	200.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	9 Month Operations	5	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Maintenance Operations	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Operations Counter AF	171	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Operations Counter AL	171	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Operations This Read Vac	1	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Switching Operations	1	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Max Tap Position	3R	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Current Tap Position	2L	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Left Counter	10389	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Found Counter	10389	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Found Counter	39302	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Left Counter	39302	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Max Tap Position	7R	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Min Tap Position	9L	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Operations Since Last Insp	643	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Vegetation	None	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	10.700	millivolts
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Operations Since Last Insp	1272	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Min Tap Position	12L	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Max Tap Position	1L	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Current Tap Position	8L	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Left Counter	11725	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	9 Month Operations	1	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK001785	BreakerVacuum	358-4720	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations A Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations B Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Operations Ground	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Maintenance Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations Counter AF	153	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations Counter AL	153	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Operations This Read Vac	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Switching Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Unknown Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Vegetation	None	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations This Read Vac	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Switching Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Unknown Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	9 Month Operations	6	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps A Ø	0.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps B Ø	0.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps C Ø	0.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations B Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Maintenance Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AF	261	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AL	261	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Switching Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Unknown Operations	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Reading	1.0500	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Winding Temp Max	60	°C
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Winding Temp Present	50	°C
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps A Ø	68.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps B Ø	73.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps C Ø	71.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.9530	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Maintenance Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AF	188	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AL	188	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Switching Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Unknown Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Vegetation	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	All Connections OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Unknown Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Switching Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Vegetation	None	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	3049.60	kw
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	45	°C
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	9 Month Operations	2	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps A Ø	12.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps B Ø	10.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Amps C Ø	13.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BCH001496	Charger	871-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	9 Month Operations	3	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	388	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	388	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations Ground	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations C Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations B Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	All Connections OK?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Time Delay	30	Seconds
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations A Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps C Ø	145.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps B Ø	135.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Reading	.8140	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	32000	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Oil Temp Present	40	°C
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Oil Temp Max	60	°C
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	26048.00	kw
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	34	°F
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Switching Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations This Read Vac	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AL	163	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AF	163	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Maintenance Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps A Ø	0.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps B Ø	0.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps C Ø	0.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	88-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	LTC Totalizer Reading	15120.00	kw
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Oil Temp Max	50	°C
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Oil Temp Present	45	°C
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations A Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations B Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations C Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations Ground	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Maintenance Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AF	314	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AL	314	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	General Comments	farm fence around most of the sub	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	9 Month Operations	4	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps A Ø	145.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps B Ø	145.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps C Ø	125.0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	180.0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	220.0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	200.0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps A Ø	132.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	9 Month Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	6	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	9 Month Operations	5	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations Counter AL	190	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations This Read Vac	2	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Switching Operations	2	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Unknown Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Reading	.5530	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Winding Temp Max	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Winding Temp Present	30	°C
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	General Comments	oil level is low pic sent to Stinson	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	69.17	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Max	35	°C
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load H2 Max	-60	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AL	185	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AF	185	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load X2 Max	-60	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Vegetation	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	9 Month Operations	3	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps A Ø	136.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps B Ø	145.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps C Ø	137.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations B Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations C Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations Ground	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Maintenance Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations Counter AF	188	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Evidence of Insects	None	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.4	amps
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	9 Month Operations	4	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps A Ø	119.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps B Ø	123.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps C Ø	137.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations B Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations C Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations Ground	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Maintenance Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations Counter AF	185	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations Counter AL	187	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Broom on Site?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations This Read Vac	2	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Switching Operations	2	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Unknown Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load Y2 Max	-60	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Maintenance Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations Ground	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations C Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations B Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Operations A Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Operations Since Last Insp	377	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Min Tap Position	7L	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Max Tap Position	2R	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Current Tap Position	2L	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Left Counter	54979	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Found Counter	54979	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	All Connections OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCControl	402-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps C Ø	58.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps B Ø	52.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Trash Emptied?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Swept?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations A Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations B Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations C Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	16448	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations This Read Vac	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	9 Month Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps A Ø	340.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps B Ø	365.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps C Ø	310.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations A Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations B Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations C Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations Ground	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Maintenance Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations Counter AF	154	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations Counter AL	154	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations This Read Vac	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Switching Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	8B-1103	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	8B-1103	VCB Readings	Switching Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	8B-1103	VCB Readings	Operations This Read Vac	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Oil Temp Max	35	°C
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	LTC Totalizer Reading	8104.32	kw
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Max	48	°C
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Present	48	°C
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Reading	.8442	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps A Ø	23.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	33	*F
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Maintenance Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations Counter AF	149	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations Counter AL	149	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Operations This Read Vac	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Switching Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001165	BreakerVacuum	838-0511	VCB Readings	Unknown Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BAT001561	Battery	871-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Operations Counter	67	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	General Comments	27.2/25	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	LTC Totalizer Reading	7963.20	kw
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps C Ø	110.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps B Ø	140.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps A Ø	155.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	9 Month Operations	7	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations This Read Vac	2	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AL	179	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AF	179	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Maintenance Operations	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Unknown Operations	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Switching Operations	1	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCControl	358-2	LTC Control Insp	All Connections OK?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Unknown Operations	0	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	9 Month Operations	10	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	General Comments	Need to add oil to LTC.	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Found Counter	12069	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps C Ø	143.0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps B Ø	152.0	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Amps A Ø	134.0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Left Counter	12073	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Current Tap Position	7L	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations A Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations B Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations C Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Fault Operations Ground	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	9 Month Operations	7	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	LTC Totalizer Reading	9360.00	kw
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations C Ø	1	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Regulator As Left Counter	29438	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps A Ø	262.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps B Ø	245.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Amps C Ø	235.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AF	309	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AL	312	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations This Read Vac	3	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Switching Operations	3	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Unknown Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	9 Month Operations	2	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Left Counter	99888	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Current Tap Position	2L	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	85947	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	General Comments	Needs gravel added to berm and below the fence.	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Min Tap Position	7L	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Operations Since Last Insp	69	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Found Counter	99888	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCControl00797	LTCControl	461-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations Ground	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations C Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations B Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations A Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps C Ø	335.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps B Ø	265.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Amps A Ø	345.0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations C Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations Ground	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Maintenance Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Left Counter	7782	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Min Tap Position	4L	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Current Tap Position	7L	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Max Tap Position	2L	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Min Tap Position	12L	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Operations Since Last Insp	403	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	9 Month Operations	3	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	LTCC000949	LTCCControl	358-2	LTC Control Insp	VRR Time Delay	60	Seconds
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps C Ø	750.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps B Ø	750.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps A Ø	700.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Regulator As Left Counter	647	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Vegetation	None	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	9 Month Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps C Ø	150.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps B Ø	125.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps A Ø	165.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Found Counter	7778	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Maintenance Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Operations This Read SF6	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Switching Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	SF6 Pressure	92	psi
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Switching Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Unknown Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 3	88	psi
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 2	88	psi
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 1	88	psi
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations This Read SF6	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AL	17	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AF	17	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Num Operations Last 9 Months	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Maintenance Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	General Comments	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Reading	.8652	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Maintenance Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations Counter AF	203	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations Counter AL	203	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Switching Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Maintenance Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Num Operations Last 9 Months	50	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Operations Counter AF	151	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Operations Counter AL	151	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Min Tap Position	3L	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Regulator As Left Counter	605	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AF	198	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Unknown Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Switching Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Maintenance Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AF	99748	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AL	99748	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations This Read Vac	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AL	198	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Operations Since Last Insp	1511	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	9 Month Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps A Ø	640.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps B Ø	430.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps C Ø	430.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Fault Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Ambient Temperature	34	*F
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Regulator As Left Counter	3416	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	General Comments		
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps B Ø	380.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps C Ø	390.0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Unknown Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Max	45	°C
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Switching Operations	0	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	9 Month Operations	4	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps A Ø	350.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Ambient Temperature	32	*F
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Unknown Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Amps A Ø	19.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Amps B Ø	19.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	9 Month Operations	4	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps A Ø	225.0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	General Comments		
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Totalizer Meter Reading	.6500	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Max	45	*C
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Present	40	*C
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Amps C Ø	19.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Fault Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps B Ø	195.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps C Ø	150.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Readings	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	General Comments	y	
2/3/2022 9:02	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK001743	BreakerSF6	KC-138KV TR 1	GCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	LTC Totalizer Reading	8305.92	kw
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations B Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations C Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Maintenance Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Max	35	°C
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Present	30	°C
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AF	421	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AL	421	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations This Read Vac	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Switching Operations	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	9 Month Operations	3	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations Ground	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations C Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations B Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations Ground	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations C Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations B Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations A Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps C Ø	340.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps B Ø	380.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps A Ø	400.0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	9 Month Operations	2	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	LTC Totalizer Reading	5624.64	kw
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Maintenance Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AF	194	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations Counter AL	194	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Operations This Read Vac	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Maintenance Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Switching Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Unknown Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps C Ø	19.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Unknown Operations	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	*C
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	*C
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Switching Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations Counter AL	176	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations Counter AF	176	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Maintenance Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	General Comments		
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations Ground	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations C Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations B Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations A Ø	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations A Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations Ground	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations C Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations B Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations A Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps A Ø	25.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps B Ø	21.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps C Ø	271.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps B Ø	270.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps A Ø	273.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	9 Month Operations	2	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations C Ø	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps C Ø	455.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps B Ø	474.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps A Ø	392.0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Maintenance Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AF	290	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AL	290	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Switching Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Unknown Operations	0	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	General Comments		
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Min Tap Position	2L	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps B Ø	13.0	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Amps A Ø	21.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps C Ø	44.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps B Ø	44.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps A Ø	44.0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	9 Month Operations	14	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations A Ø	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Regulator As Left Counter	754	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Unknown Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations B Ø	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Maintenance Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	General Comments		
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Operations Counter	57	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Reading	.7812	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	General Comments		
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	9 Month Operations	1	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations Counter AF	183	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Maintenance Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Switching Operations	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations This Read Vac	0	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AL	3241	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AF	3241	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Present	35	°C
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	General Comments		
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Unknown Operations	0	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 14:03	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Switching Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations This Read Vac	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations Counter AL	183	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations B Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations C Ø	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations Ground	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	General Comments	27.2/25	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0168	RecloserElectronic	027-0310	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Unknown Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Switching Operations	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations This Read Vac	0	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AL	252	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Regulator As Left Counter	27094	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Leaks	None	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AF	252	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Present	19	°C
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Max	25	°C
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Reading	.5262	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Max	30	°C
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2525.76	kw
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Operations Since Last Insp	338	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Min Tap Position	13L	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Current Tap Position	1L	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Left Counter	85663	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Reading	.6900	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Max	35	°C
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Present	27	°C
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AF	186	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AL	186	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Switching Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Unknown Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Switching Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations This Read Vac	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AL	190	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AF	190	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Unknown Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Maintenance Operations	0	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	All Connections OK?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	General Comments		
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	All Connections OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps C Ø	581.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps B Ø	563.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps A Ø	576.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Unknown Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	9 Month Operations	1	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Switching Operations	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations This Read Vac	0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations Counter AL	172	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations Counter AF	172	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Maintenance Operations	0	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	General Comments		
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	General Comments		
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Found Counter	85660	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations Ground	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations C Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations B Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations A Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 13:10	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps C Ø	285.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps B Ø	195.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps A Ø	275.0	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	General Comments		
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Follow-up Action Required?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	LTC Totalizer Reading	1656.00	kw
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	9 Month Operations	6	
2/3/2022 15:52	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Negative DC Ground	24.0	VDC
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations B Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 9:43	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Unknown Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Switching Operations	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations This Read Vac	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AL	179	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AF	179	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Maintenance Operations	0	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps C Ø	394.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps B Ø	400.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps A Ø	388.0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 9:21	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	General Comments		
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Vegetation	None	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	9 Month Operations	1	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 9:47	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 10:53	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Maintenance Operations	0	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Max	35	°C
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Present	28	°C
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 15:42	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations Ground	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations C Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations B Ø	0	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations A Ø	0	
2/7/2022 7:56	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/7/2022 8:04	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 16:00	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	176	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	26.0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	27.0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000900	LTCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000900	LTCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000900	LTCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000900	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000900	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000900	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000900	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000900	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations A Ø	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Switching Operations	3	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations This Read Vac	3	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AL	137	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations C Ø	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	279	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps B Ø	55.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps C Ø	55.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	9 Month Operations	10	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps A Ø	40.0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Found Counter	92852	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Left Counter	92852	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Current Tap Position	4L	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallellND	Position
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	9 Month Operations	2	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Unknown Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps A Ø	164.0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps B Ø	156.0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps C Ø	134.0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001837	BreakerVacuum	C-GND TR 3	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Maintenance Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AF	222	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AL	222	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations This Read Vac	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Switching Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Unknown Operations	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Unknown Operations	0	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Ambient Temp	40	*F
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF001325	PowerFuse	LS-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Maintenance Operations	3	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AF	152	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AL	152	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations This Read Vac	4	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Switching Operations	1	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Unknown Operations	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AF	137	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2L	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	133	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps C Ø	119.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps B Ø	60.0	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Time Delay	30	Seconds
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Counter AL	141638	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Counter AF	141634	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Bandwidth AL	0.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Min Tap Position	10L	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Max Tap Position	2L	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations Ground	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps A Ø	100.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Switching Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations This Read Vac	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AL	109	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Operations Counter AF	109	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Maintenance Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LTO105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LTO105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LTO105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LTO105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LTO105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Found Counter	11400	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LTO105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Left Counter	11400	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LTC000020	LTCControl	LY-TRANS 2	LTC Control Insp	General Comments	OK	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LTC000020	LTCControl	LY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	9 Month Operations	29	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Switching Operations	1	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Unknown Operations	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Maintenance Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AF	192	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AL	192	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.1	VDC
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.2	VDC
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations This Read Vac	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Switching Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Current Tap Position	7L	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	All Connections OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Maintenance Operations	5	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AF	130	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AL	130	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations This Read Vac	6	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations A Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations B Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations C Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations Ground	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Operations Counter AF	189	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Operations Counter AL	189	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Operations This Read Vac	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Switching Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	3	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Max Tap Position	4R	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Operations Since Last Insp	547	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	182.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Amps B Ø	160.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Amps C Ø	166.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Found Counter	23788	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Left Counter	23796	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	3	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	160	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	160	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Current Tap Position	2L	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Operations B Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Operations C Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Fault Operations Ground	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Maintenance Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Unknown Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Switching Operations	0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations This Read Vac	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AL	657	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AF	657	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Maintenance Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	General Comments	OK	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	14	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	9 Month Operations	1	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps A Ø	183.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps B Ø	177.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps C Ø	157.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Trash Emptied?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps C Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps B Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps A Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	9 Month Operations	8	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF001325	PowerFuse	LS-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF001325	PowerFuse	LS-12KV TR 5 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47602	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Broom on Site?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Evidence of Insects	None	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	25	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Swept?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	69.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	71.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	690	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	690	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	73.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	9 Month Operations	10	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	177.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	9 Month Operations	32	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	BK001415	BreakerVacuum	197-2500	VCB Readings	Amps A Ø	157.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	179.0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001838	BreakerVacuum	C-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Regulator As Left Counter	54411	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	FE000870	Fence	450-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Maintenance Operations	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations Counter AF	197	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations Counter AL	197	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations This Read Vac	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Switching Operations	0	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Switching Operations	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Operations This Read Vac	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Operations Counter AL	170	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Operations Counter AF	170	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Maintenance Operations	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	9 Month Operations	3	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps A Ø	89.0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps B Ø	72.0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps C Ø	87.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Maintenance Operations	3	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	391	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	391	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations A Ø	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations B Ø	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations C Ø	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations Ground	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	All Connections OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	LTC Operation Checked?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations A Ø	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations B Ø	0	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Oil Temp Present	8	°C
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Oil Temp Max	47	°C
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations C Ø	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations Ground	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Unknown Operations	0	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps C Ø	24.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps B Ø	20.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps A Ø	27.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	9 Month Operations	9	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	9 Month Operations	1	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	9 Month Operations	3	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps A Ø	110.0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps B Ø	95.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps A Ø	126.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps B Ø	125.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps C Ø	90.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps C Ø	108.0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations A Ø	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.7	amps
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations B Ø	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps C Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps B Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps A Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	9 Month Operations	9	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps A Ø	160.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps B Ø	137.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Amps C Ø	190.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Oil Temp Max	47	°C
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Oil Temp Present	8	°C
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Basement Condition Acceptable	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	All Connections OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Switching Operations	1	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Vegetation	None	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Switching Operations	1	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Unknown Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations This Read Vac	4	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Switching Operations	11	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AL	149	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AF	149	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Maintenance Operations	2	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AF	144	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AL	144	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations This Read Vac	3	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Reading	1.0602	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Present	30	°C
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Max	35	°C
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	LTC Totalizer Reading	10177.92	kw
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	764	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AF	285	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AL	285	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Operations B Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	764	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2500	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	581.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	577.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	584.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	25	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Present	34	°C
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Max	55	°C
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	All Connections OK?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Time Delay	30	Seconds
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Regulator As Left Counter	43971	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Min Tap Position	13L	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Operations Since Last Insp	295	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps C Ø	0.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps B Ø	0.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps A Ø	0.0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations This Read Vac	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Switching Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps B Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps A Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	9 Month Operations	6	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Max	59	°C
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6000.00	kw
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations C Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations B Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations A Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Amps C Ø	97.0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Amps B Ø	118.0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Amps A Ø	143.0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001817	BreakerVacuum	350-0777	VCB Readings	9 Month Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	LTC Totalizer Reading	6201.60	kw
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Time Delay	30	Seconds
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Switching Operations	1	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations This Read Vac	6	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AL	139	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charged Patrol Insp	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AF	139	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Maintenance Operations	5	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Operations Since Last Insp	140	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Min Tap Position	Neutral	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Max Tap Position	8L	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Current Tap Position	4L	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Left Counter	86714	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Found Counter	86710	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Readings	Operations This Read Vac	11	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Readings	Operations Counter AL	1228	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Readings	Operations Counter AF	1228	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Readings	Maintenance Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Operations Since Last Insp	324	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Min Tap Position	4L	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0063	BreakerVacuum	197-BTS-6	VCB Readings	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Max Tap Position	13L	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Current Tap Position	8L	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Left Counter	191225	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Found Counter	191220	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Reading	1.2920	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Maintenance Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Found Counter	39620	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Left Counter	39630	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps C Ø	0.0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	ST000852	Structure	450-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Current Tap Position	6L	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF001270	PowerFuse	LS-STA SER NO 5	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF001270	PowerFuse	LS-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF001270	PowerFuse	LS-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	OK	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	9 Month Operations	23	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Accumulated Fault Duty A Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Accumulated Fault Duty B Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Accumulated Fault Duty C Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Amps A Ø	11	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Amps B Ø	33	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Amps C Ø	31	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Operations A Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Operations B Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Operations C Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Fault Operations Ground	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Maintenance Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Operations Counter AF	103	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Operations Counter AL	105	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Operations This Read Vac	2	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Switching Operations	2	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001387	BreakerVacuum	450-0519	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AL	176	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations This Read Vac	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Switching Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Unknown Operations	0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	General Comments		
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Vegetation	None	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Vegetation	None	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Unknown Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Switching Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations This Read Vac	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AL	288	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AF	288	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Maintenance Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps C Ø	2.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps B Ø	2.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps A Ø	3.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	9 Month Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Instal/Remove?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	SWG000217	Switchgear	450-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Unknown Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations Ground	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations C Ø	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations B Ø	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations A Ø	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps C Ø	30.0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps B Ø	68.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Found Counter	427361	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Left Counter	427361	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps A Ø	48.0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	9 Month Operations	23	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2289	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Unknown Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Switching Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations This Read Vac	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AL	155	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AF	155	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Operations A Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Operations B Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Operations C Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Fault Operations Ground	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	General Comments	counter is not working	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Maintenance Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Operations Counter AF	57	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Operations Counter AL	59	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Operations This Read Vac	2	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Switching Operations	2	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Unknown Operations	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Switching Operations	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Operations This Read Vac	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Operations Counter AL	210	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Operations Counter AF	210	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Amps C Ø	100.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Amps B Ø	117.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Amps A Ø	155.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Accumulated Fault Duty C Ph V	.64	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Accumulated Fault Duty B Ph V	.64	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Accumulated Fault Duty A Ph V	1.28	%
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	9 Month Operations	3	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	9 Month Operations	4	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Accumulated Fault Duty A Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Accumulated Fault Duty B Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Accumulated Fault Duty C Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Amps A Ø	105	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Amps B Ø	103	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Readings	Amps C Ø	94	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001385	BreakerVacuum	450-0517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Operations A Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Operations B Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Operations C Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001386	BreakerVacuum	450-0518	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations B Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations C Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations Ground	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Max	40	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Present	35	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Max	30	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Present	25	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Max	36	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Present	30	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	100	psi
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Max	40	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Present	30	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Maintenance Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AF	189	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AL	189	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	9 Month Operations	1	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps A Ø	115.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps B Ø	100.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps C Ø	109.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	9 Months Operations	7	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations A Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Winding Temp Max	50	°C
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Winding Temp Present	25	°C
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	All Connections OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCC000802	LTCControl	450-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	182.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	177.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	183.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC As Found Counter	4419	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC As Left Counter	4419	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Max	30	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Present	20	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Max	30	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Present	25	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	LTC Totalizer Reading	8949.6	kw
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations This Read Vac	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Switching Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Unknown Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Oil Temp Present	25	°C
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	Totalizer Meter Reading	.3729	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCCControl	602-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCCControl	602-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCCControl	602-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCCControl	602-1	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCCControl	602-1	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCCControl	602-1	LTC Control Insp	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCCControl	602-1	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCCControl	602-1	LTC Control Insp	All Connections OK?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	50	°C
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Reading	.9726	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Present	45	°C
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	9 Months Operations	1	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Switching Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations This Read AM	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AL	57	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AF	57	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	General Comments	OK	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Operations Since Last Insp	5	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Min Tap Position	8L	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Max Tap Position	2R	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Current Tap Position	4L	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Left Counter	10777	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Found Counter	10777	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	General Comments	broken counter	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps C Ø	390.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps B Ø	400.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps A Ø	390.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Reading	.5646	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Present	45	°C
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Max	53	°C
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	LTC Totalizer Reading	2710.08	kw
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps A Ø	160.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps B Ø	190.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps C Ø	170.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations Ground	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	General Comments	OK	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Maintenance Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AF	57	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AL	57	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations This Read AM	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Switching Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Unknown Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	LTC Totalizer Reading	9336.96	kw
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	TX000221	WithLTC	450-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Accumulated Fault Duty C Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Amps A Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Amps B Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Amps C Ø	0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Maintenance Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AF	171	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AL	171	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations This Read Vac	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Operations A Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Operations B Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Operations C Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Fault Operations Ground	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	General Comments	breaker has been damaged during comm.	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Maintenance Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Operations Counter AF	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Operations Counter AL	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Operations This Read Vac	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Switching Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Unknown Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	VRR Time Delay	30	Seconds
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000899	LTCControl	124-6	LTC Control Insp	All Connections OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	9 Month Operations	7	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	General Comments		
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Found Counter	3310	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Left Counter	3314	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Current Tap Position	3L	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Max Tap Position	6L	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	9 Month Operations	33	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Accumulated Fault Duty A Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Accumulated Fault Duty B Ph V	0	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Operations B Ø	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Operations A Ø	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Adjusted Amps B Phase V	4.69	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Adjusted Amps A Phase V	4.69	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Amps C Ø	232.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Amps B Ø	257.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Amps A Ø	249.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	9 Month Operations	6	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	LTC Totalizer Reading	9525.60	kw
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	General Comments		
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Ambient Temp	40	*F
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Comments		
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	9 Month Operations	21	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Amps A Ø	250	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Amps B Ø	225	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Amps C Ø	250	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Spring Compression Ind.	springdischarged	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Switching Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Operations Since Last Insp	263	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001515	BreakerVacuum	450-BT1-2 FUT	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X3 Winding Temp Present	22	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X3 Winding Temp Max	22	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X2 Winding Temp Present	22	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X2 Winding Temp Max	22	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X1 Winding Temp Present	22	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	X1 Winding Temp Max	22	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Totalizer Meter Reading	.5292	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Oil Temp Present	22	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Oil Temp Max	22	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Switching Operations	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Operations This Read Vac	3	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Operations Counter AL	188	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Operations Counter AF	188	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Readings	Fault Operations Ground	0	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC As Found Counter	4382	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC As Found Counter	5046	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC As Left Counter	5056	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC Max Tap Position	6R	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC Min Tap Position	7L	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	12	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	12	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	LTC Operations Since Last Insp	736	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000119	LTCMechanism	124-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	9 Month Operations	37	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Accumulated Fault Duty A Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Accumulated Fault Duty B Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Accumulated Fault Duty C Ph V	0	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Amps A Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Amps B Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Amps C Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC Min Tap Position	7L	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC Max Tap Position	8R	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC Current Tap Position	2R	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC As Left Counter	4394	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	LTC Operations Since Last Insp	733	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	LTCM000118	LTCMechanism	124-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Maintenance Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AF	169	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AL	169	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations This Read Vac	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Switching Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Unknown Operations	0	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps A Ø	200.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	9 Month Operations	4	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps A Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps B Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Vegetation	None	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	YD000929	Yard	450-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Operations A Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Operations B Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Operations C Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Fault Operations Ground	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps C Ø	257.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps B Ø	200.0	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Maintenance Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Operations Counter AF	145	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Operations Counter AL	147	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Operations This Read Vac	2	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Switching Operations	2	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001514	BreakerVacuum	450-0520	VCB Readings	Unknown Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	36.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	23.0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	9 Month Operations	5	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps A Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps B Ø	0.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Vegetation	None	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	18.0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Amps C Ø	0.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps B Ø	387.0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps B Ø	383.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps A Ø	380.0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	9 Month Operations	8	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	2	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Switching Operations	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Operations This Read Vac	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Operations Counter AL	173	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Operations Counter AF	173	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Maintenance Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AF	147	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AL	147	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations This Read Vac	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Switching Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Unknown Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Unknown Operations	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Switching Operations	1	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Vegetation	None	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations This Read Vac	5	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Unknown Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Switching Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations This Read Vac	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AL	207	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AF	207	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Maintenance Operations	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	General Comments		
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	All Connections OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations Ground	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations C Ø	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations B Ø	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations A Ø	0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Operations A Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Operations B Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Operations C Ø	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Fault Operations Ground	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Follow-up Action Required?	n	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	All Connections OK?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	General Comments		
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Maintenance Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Operations Counter AF	141	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Operations Counter AL	141	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Operations This Read Vac	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Switching Operations	0	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	BK001516	BreakerVacuum	450-1	VCB Readings	Unknown Operations	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps A Ø	17.0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	9 Month Operations	4	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCCControl	197-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCCControl	197-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCCControl	197-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCCControl	197-5	LTC Control Insp	VRR Time Delay	30	Seconds
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	tree at corner has branches grown over fence	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000273	WithLTC	124-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AL	153	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AF	153	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Maintenance Operations	4	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Winding Temp Present	30	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Winding Temp Max	30	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Totalizer Meter Reading	.9190	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Oil Temp Present	28	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	Oil Temp Max	28	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	LTC Totalizer Reading	16542.00	kw
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps C Ø	13.0	
2/2/2022 15:13	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps B Ø	23.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	TX000272	WithLTC	124-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	LTC Totalizer Reading	176294400.00	kw
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	9 Months Operations	8	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Max	50	°C
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Present	20	°C
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Reading	18364.0000	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Pumps Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Pumps Operational?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	740	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	300	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	300	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Tank Paint Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Grounds in Place?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Foundation Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LTCC000532	LTCControl	C-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushing Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	582	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	582	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	673	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	All Connections OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	673	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	LTC Operation Checked?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Found Counter	42537	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Trash Emptied?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	X3 Winding Temp Present	50	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	X3 Winding Temp Max	58	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	X2 Winding Temp Present	55	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	X2 Winding Temp Max	62	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	X1 Winding Temp Present	50	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	X1 Winding Temp Max	60	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	38	°C
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps C Ø	52.0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps A Ø	65.0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Fans Operational?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	General Comments		
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Operations Counter	496	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Unknown Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Switching Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations This Read AM	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AL	665	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AF	665	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Maintenance Operations	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	General Comments	OK	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations Ground	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Pumps Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Pumps Operational?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Found Counter	24526	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Left Counter	24530	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	General Comments	empty nitro bottles	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Current Tap Position	3L	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Max Tap Position	4R	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Min Tap Position	7L	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Operations Since Last Insp	779	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000286	GroundTransformer	C-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Fans Condition	Good	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps C Ø	100.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps B Ø	250.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps A Ø	100.0	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	TX000287	GroundTransformer	C-GND TR 4	Ground Transformer Patrol Inspection	Fans Operational?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/2/2022 9:50	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	124.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	117.0	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Reading	.6768	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Vegetation	None	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	22.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	25.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	21.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Max	50	°C
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Present	22	°C
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF000201	PowerFuse	LS-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF000201	PowerFuse	LS-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	PF000201	PowerFuse	LS-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	6L	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	LTC Totalizer Reading	4492.80	kw
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	General Comments		
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Vegetation	None	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	126.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	2R	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Amps C Ø	74.0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Amps B Ø	44.0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Amps A Ø	48.0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	9 Month Operations	0	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Present	20	°C
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Operations C Ø	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Operations Ground	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	122	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Min Tap Position	7L	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Reading	.3120	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	740	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Winding Temp Max	50	°C
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Winding Temp Present	18	°C
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC Current Tap Position	5L	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	360	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Switching Operations	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Unknown Operations	0	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	General Comments		
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	LTC Totalizer Reading	6497.28	kw
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC Min Tap Position	10L	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/2/2022 14:56	Distribution	Paynes Mill Quarterly Inspection	LTCM000091	LTCMechanism	450-1	LTC Counter Readings	LTC Operations Since Last Insp	310	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 14:21	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	General Comments		
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Maintenance Operations	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Operations Counter AF	159	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Operations Counter AL	159	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	CO475	WithLTC	197-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	CO475	WithLTC	197-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Operations This Read Vac	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Max Tap Position	8L	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Current Tap Position	1L	
2/2/2022 12:34	Distribution	Eminence Quarterly Inspection	CO475	WithLTC	197-5	LTC Transformer Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	General Comments		
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Left Counter	82404	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Found Counter	82404	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	General Comments		
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Left Counter	42537	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
2/2/2022 11:31	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/2/2022 11:50	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	General Comments		
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/2/2022 13:04	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/3/2022 5:18	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/2/2022 18:45	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Operations B Ø	0	
2/2/2022 11:24	Distribution	Rose Hill Quarterly Inspection	BK001816	BreakerVacuum	350-0776	VCB Readings	Fault Operations A Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	All Connections OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Unknown Operations	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Max	45	*C
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	113	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	113	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations C Ø	1	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Follow-up Action Required?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	General Comments	IOC C phase and VD counter didn't change	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Maintenance Operations	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AF	1024	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AL	1024	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations This Read AM	1	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Switching Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Unknown Operations	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Regulator As Left Counter	39262	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	General Comments	some corrosion on terminals	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	9 Month Operations	1	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps C Ø	900.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps A Ø	900.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps B Ø	900.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Maintenance Operations	1	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AL	433	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AF	433	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AF	192	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AL	193	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations This Read Vac	1	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Switching Operations	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Unknown Operations	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	Y0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations B Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Maintenance Operations	0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	General Comments	Farm fence attached to station fence	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps C Ø	107	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps B Ø	116	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps A Ø	104	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty C Ph V	1.17	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty B Ph V	1.17	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty A Ph V	1.52	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	9 Month Operations	2	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps B Ø	185.0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps C Ø	163.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AF	302	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AL	302	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps A Ø	311.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps B Ø	317.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps C Ø	314.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Unknown Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Switching Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AL	228	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AF	228	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	General Comments		
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AL	774	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AF	774	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Maintenance Operations	0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Follow-up Action Required?	n	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Regulator As Left Counter	98467	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations C Ø	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Regulator As Left Counter	86628	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Switching Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Unknown Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	9 Month Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps C Ø	78.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps B Ø	92.0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	9 Months Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps A Ø	91.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps A Ø	255.0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps B Ø	264.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps C Ø	252.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Unknown Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Switching Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations This Read AM	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps C Ø	685.0	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps B Ø	708.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps A Ø	795.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps C Ø	106.0	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps B Ø	87.0	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps A Ø	117.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	9 Month Operations	0	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Regulator As Left Counter	97557	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations A Ø	0	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Operations Counter	0	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	General Comments		
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AL	177	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AF	177	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.0482	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC As Left Counter	65837	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC As Found Counter	65834	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2515.68	kw
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	35.28	kw
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	General Comments		
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	General Comments		
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	9 Month Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 12:18	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0588	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Operations Since Last Insp	246	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Min Tap Position	14L	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Max	35	°C
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Max Tap Position	4L	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Current Tap Position	8L	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps A Ø	60	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps B Ø	60	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps C Ø	105	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	9 Month Operations	2	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Present	18	°C
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Max	22	°C
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3774	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	21000	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps B Ø	61	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps A Ø	100	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps C Ø	200.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps B Ø	200.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps A Ø	200.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	9 Month Operations	5	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty B Ph V	.96	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Max Tap Position	3R	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Current Tap Position	4L	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Left Counter	45121	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Found Counter	45111	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	9 Month Operations	2	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty A Ph V	1.43	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Regulator As Left Counter	64766	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.4	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps B Ø	3.1	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.7	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Max	35	°C
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Reading	.5892	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	General Comments	1 operation	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Operations Counter	303	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Maintenance Operations	1	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Operations Since Last Insp	373	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Min Tap Position	11L	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Max Tap Position	3L	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Current Tap Position	8L	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Max	24	°C
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7925.40	kw
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Left Counter	18028	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Found Counter	18023	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	General Comments	unable to reset lower arm	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Regulator As Left Counter	86949	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Present	25	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	9 Months Operations	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Maintenance Operations	1	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AF	171	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AL	172	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations This Read Vac	1	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Switching Operations	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Unknown Operations	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Regulator As Left Counter	106685	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Unknown Operations	0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Switching Operations	4	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations This Read Vac	4	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AL	370	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AF	366	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Maintenance Operations	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations C Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations B Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Regulator As Left Counter	202751	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps C Ø	92.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps B Ø	103.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps A Ø	134.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations A Ø	0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AF	650	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AL	650	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushing Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Switching Operations	0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps C Ø	75.0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps B Ø	85.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Operations Since Last Insp	654	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Min Tap Position	11L	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps A Ø	90.0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	9 Month Operations	8	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Unknown Operations	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps C Ø	98	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Regulator As Left Counter	136255	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Amps A Ø	174.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	9 Month Operations	5	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.8	volts
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Regulator As Left Counter	258902	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AL	40	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AF	40	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations C Ø	0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations B Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps C Ø	27.0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Maintenance Operations	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations Counter AF	210	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps B Ø	57.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps A Ø	74.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	9 Month Operations	11	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations B Ø	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations C Ø	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations Ground	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AF	182	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AL	183	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations This Read Vac	1	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Switching Operations	0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Unknown Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Switching Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Unknown Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations This Read Vac	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AL	204	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AF	204	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Maintenance Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations Ground	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations C Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations B Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations A Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Present	25	°C
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Max	30	°C
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	LTC Totalizer Reading	8484.48	kw
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Regulator As Left Counter	134290	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Regulator As Left Counter	3520	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	9 Months Operations	1	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps A Ø	48.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps B Ø	57.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps C Ø	49.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Regulator As Left Counter	86673	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations Counter AL	210	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations This Read Vac	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Switching Operations	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Unknown Operations	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	9 Month Operations	8	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	9 Month Operations	1	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps A Ø	25.0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps B Ø	30.0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps C Ø	33.0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	4	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Regulator As Left Counter	84130	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.152	millivolts
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Switching Operations	4	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations This Read Vac	4	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AL	99797	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AF	99797	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps C Ø	103.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps B Ø	66.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps A Ø	70.0	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Regulator As Left Counter	89287	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Condition	Mountings	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Operational?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	General Comments	fans need to be replaced	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	LTC Totalizer Reading	4098.24	kw
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Max	46	°C
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Present	46	°C
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Reading	.8538	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	655	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	655	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	1	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	1	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Unknown Operations	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4260	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Present	45	°C
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	3067.20	kw
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Regulator As Left Counter	87295	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Fault Operations A Ø	0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Regulator As Left Counter	78495	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	General Comments	ok	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps C Ø	106.0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps B Ø	100.0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Amps A Ø	106.0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.3	VDC
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Regulator As Left Counter	129447	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.6	VDC
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.6	VDC
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BCH001525	Charger	613-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Min Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Max Tap Position	8R	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Current Tap Position	2R	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations Counter AF	445	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Maintenance Operations	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	General Comments		
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations Ground	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Operations A Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Current Tap Position	1R	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	General Comments	ok	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	*F
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BAT001596	Battery	613-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3832.80	kw
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.5970	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	9 Months Operations	2	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps A Ø	424.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps B Ø	406.0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps C Ø	384.0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	9 Month Operations	2	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AF	99967	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AL	99967	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Switching Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Unknown Operations	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	41	°F
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Time Delay	30	Seconds
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	All Connections OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Regulator As Left Counter	6789	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Unknown Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Switching Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AL	84	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	9 Month Operations	17	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Amps A Ø	62.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Amps B Ø	60.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Amps C Ø	64.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	All Connections OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	General Comments		
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	General Comments		
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Operations B Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Operations C Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Fault Operations Ground	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations This Read Vac	4	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AL	358	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AF	354	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Maintenance Operations	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Unknown Operations	0	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Regulator As Left Counter	71467	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Switching Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AL	256	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AF	256	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Maintenance Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	30	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Regulator As Left Counter	170705	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	General Comments		
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Min Tap Position	4L	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Regulator As Left Counter	77637	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Switching Operations	1	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations This Read Vac	1	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Operations Counter AL	445	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps C Ø	150.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps B Ø	180.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps A Ø	120.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	General Comments	New breaker, now in service.	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Maintenance Operations	16	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Operations Counter AF	144	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Operations Counter AL	161	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Operations This Read Vac	17	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Switching Operations	1	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Unknown Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Regulator As Left Counter	74576	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Min Tap Position	5L	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Max Tap Position	7R	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	9 Month Operations	8	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps C Ø	1015.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps B Ø	966.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps A Ø	1020.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	9 Month Operations	5	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps A Ø	180.0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps B Ø	165.0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps C Ø	160.0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	9 Month Operations	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations A Ø	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations Ground	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Maintenance Operations	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AF	142	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AL	142	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations This Read Vac	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Switching Operations	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	25	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	30	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	9 Month Operations	2	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Readings	Unknown Operations	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000004	BreakerVacuum	182-3402	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Maintenance Operations	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AF	437	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AL	441	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations This Read Vac	4	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Switching Operations	4	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Unknown Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	40	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.8	VDC
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.8	VDC
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	*F
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Maintenance Operations	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AF	173	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AL	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations This Read Vac	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Switching Operations	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Unknown Operations	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations A Ø	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations B Ø	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations C Ø	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations Ground	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Regulator As Left Counter	46626	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Operations Since Last Insp	40	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Min Tap Position	3L	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Max Tap Position	1R	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Current Tap Position	1L	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Left Counter	259964	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Found Counter	259964	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AL	206	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AF	206	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Maintenance Operations	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	9 Month Operations	12	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Maintenance Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations Counter AF	78	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations Counter AL	78	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations This Read Vac	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps A Ø	190.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps B Ø	185.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps C Ø	182.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Switching Operations	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Unknown Operations	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BCH001529	Charger	502-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AF	12	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AL	12	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Switching Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Unknown Operations	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps C Ø	76.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps B Ø	76.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps A Ø	85.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	9 Month Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	9 Month Operations	1	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps A Ø	25.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps B Ø	35.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps C Ø	40.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Reading	.5330	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Present	25	°C
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Max	25	°C
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	LTC Totalizer Reading	5116.80	kw
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations A Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations C Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Maintenance Operations	16	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Operations Counter AF	104	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Operations Counter AL	121	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Operations This Read Vac	17	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Switching Operations	1	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Regulator As Left Counter	83551	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Regulator As Left Counter	95756	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	BCH001533	Charger	510-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Unknown Operations	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Gauges(s) Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AF	84	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Maintenance Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	General Comments	needs counter	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps C Ø	90.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps B Ø	100.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps A Ø	80.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Regulator As Left Counter	88747	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	9 Month Operations	1	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	9 Month Operations	9	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps A Ø	60.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps B Ø	60.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps C Ø	60.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Operations A Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Operations B Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Operations C Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Fault Operations Ground	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Readings	General Comments		New breaker, now in service.
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001814	BreakerVacuum	780-0361	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Min Tap Position	9L	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Operations Since Last Insp	352	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1321	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations A Ø	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	9 Month Operations	4	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps A Ø	120.0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps B Ø	120.0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps C Ø	120.0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	BAT001600	Battery	502-Battery Bank	Battery Patrol Inspection	General Comments	ok	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Unknown Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Switching Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AL	285	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AF	285	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Maintenance Operations	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	9 Month Operations	18	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps A Ø	72.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps B Ø	82.0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps C Ø	101.0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Max Tap Position	6R	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Current Tap Position	2R	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1321	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Follow-up Action Required?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Found Counter	11852	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Left Counter	11852	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Current Tap Position	3L	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Max Tap Position	2R	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34041	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	345	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	345	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	61	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	61	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Regulator As Left Counter	1629	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps A Ø	250.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	9 Month Operations	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Switching Operations	0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	40	Seconds
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Unknown Operations	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	135.0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps A Ø	69.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	9 Month Operations	1	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Unknown Operations	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Switching Operations	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Operations Counter AL	180	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	201	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	201	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	1	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Operations Counter AF	180	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Maintenance Operations	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	9 Month Operations	44	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Amps A Ø	105.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Amps B Ø	73.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Amps C Ø	73.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	300.0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	300.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	300.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps C Ø	81.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps B Ø	99.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Regulator As Left Counter	4652	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps C Ø	120.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps B Ø	120.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps A Ø	120.0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	9 Month Operations	8	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Regulator As Left Counter	165273	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Max Tap Position	15R	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Regulator As Left Counter	373650	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.700	millivolts
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Unknown Operations	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Switching Operations	4	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.00	millivolts
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations This Read Vac	4	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AL	117	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AF	113	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Maintenance Operations	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps C Ø	1031.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps B Ø	978.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps A Ø	955.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	9 Month Operations	1	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AL	662	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AF	662	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	9 Month Operations	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps A Ø	18.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps B Ø	13.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps C Ø	12.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	General Comments	Fnctn TC	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Maintenance Operations	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AF	233	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AL	234	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations This Read Vac	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32176	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps C Ø	250.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps B Ø	250.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	715	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	715	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Regulator As Left Counter	122306	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Unknown Operations	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Switching Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations This Read Vac	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AL	200	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AF	199	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Maintenance Operations	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	General Comments	Fnctn TC	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Min Tap Position	5L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.9	volts
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Regulator As Left Counter	51992	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Unknown Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Switching Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AL	188	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AF	188	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	LTC Totalizer Reading	1948.80	kw
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Regulator As Left Counter	37738	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Max	30	°C
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Reading	.2030	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Min Tap Position	5L	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Max Tap Position	6R	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Reading	.6330	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:53	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	9 Month Operations	3	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Present	23	°C
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Max	27	°C
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	30.0	psi
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	LTC Totalizer Reading	2278.80	kw
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	General Comments		
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations Ground	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations C Ø	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations B Ø	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations A Ø	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps C Ø	20.0	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	BCH001352	Charger	780-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps B Ø	10.0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps A Ø	30.0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Current Tap Position	2R	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	General Comments		
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Max Tap Position	6R	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Min Tap Position	4L	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Regulator As Left Counter	3528	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations Ground	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations C Ø	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations B Ø	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations A Ø	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps C Ø	35.0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps B Ø	50.0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps A Ø	90.0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	9 Month Operations	1	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	General Comments	ok	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	9 Month Operations	17	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Unknown Operations	0	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Amps A Ø	63.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Amps B Ø	105.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Readings	Amps C Ø	23.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001813	BreakerVacuum	780-0356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Switching Operations	4	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Found Counter	211731	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Left Counter	211771	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Current Tap Position	4R	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Max Tap Position	12R	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Operations Since Last Insp	565	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Unknown Operations	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Switching Operations	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations This Read Vac	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AL	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AF	39	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Maintenance Operations	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2022-02-19 00:00:00.000000	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	General Comments	ok	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	59	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	59	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	General Comments	ok	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Amps B Ø	91.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Amps C Ø	70.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	General Comments	ok	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Unknown Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Operations A Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Operations B Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Operations C Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Fault Operations Ground	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Maintenance Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Operations Counter AF	225	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Operations Counter AL	225	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Operations This Read Vac	1	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Switching Operations	1	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001810	BreakerVacuum	780-0350	VCB Readings	Unknown Operations	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	General Comments	ok	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Amps C Ø	32.0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Amps B Ø	42.0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Amps A Ø	29.0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	BK001143	BreakerVacuum	613-1443	VCB Readings	9 Month Operations	4	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	9 Month Operations	34	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Amps A Ø	63.0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	All Connections OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCControl	649-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations A Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	9 Month Operations	2	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps A Ø	340.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps B Ø	340.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps C Ø	340.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Maintenance Operations	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AF	52	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AL	52	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Unknown Operations	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps C Ø	0.0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Amps A Ø	0.0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Unknown Operations	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Switching Operations	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations This Read Vac	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AL	1553	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AF	1553	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Maintenance Operations	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Operations A Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Operations B Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Operations C Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Fault Operations Ground	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Switching Operations	1	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations This Read Vac	1	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AL	252	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AF	252	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Maintenance Operations	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations Ground	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	General Comments	Missing a warning sign on the North side of fence.	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Maintenance Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Operations Counter AF	162	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Operations Counter AL	162	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Operations This Read Vac	3	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Switching Operations	3	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001811	BreakerVacuum	780-0351	VCB Readings	Unknown Operations	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	9 Month Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Max Tap Position	6R	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Regulator As Left Counter	77675	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Operations Since Last Insp	286	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.0	VDC
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.0	VDC
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Min Tap Position	13L	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Bushing Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.5	VDC
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.3	VDC
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Maintenance Operations	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations Counter AF	236	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations Counter AL	236	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations This Read Vac	1	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Switching Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Unknown Operations	0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps C Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps B Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps A Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BAT001547	Battery	780-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Amps C Ø	128.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Amps B Ø	142.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Amps A Ø	125.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	9 Month Operations	1	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	9 Month Operations	13	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BCH001488	Charger	029-Battery Charger 1	Battery Charger Patrol Insp	Ground Lights	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4512	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps A Ø	56.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps B Ø	49.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps C Ø	36.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	General Comments	oil level past LO	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations This Read Vac	1	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AL	802	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AF	802	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	General Comments	C Phase IOC	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations C Ø	1	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps C Ø	250.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps B Ø	250.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps A Ø	250.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	9 Month Operations	1	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations C Ø	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations B Ø	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations A Ø	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps C Ø	60.0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps B Ø	54.0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps A Ø	54.0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BAT001556	Battery	029-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Switching Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Unknown Operations	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	9 Month Operations	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	General Comments	Charger at 55, must be temp probe	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Regulator As Left Counter	41484	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	9 Month Operations	1	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps A Ø	105.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.1	VDC
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.1	VDC
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps B Ø	115.0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps C Ø	107.0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations A Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations Ground	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Maintenance Operations	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AF	180	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AL	180	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	339	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps C Ø	0.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps B Ø	0.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps A Ø	0.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations This Read Vac	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Switching Operations	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Unknown Operations	0	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	406	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.0	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.0	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.0	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	434	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27	VDC
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.3	VDC
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.0	VDC
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	9 Month Operations	3	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps A Ø	242.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps B Ø	225.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps C Ø	260.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations B Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Maintenance Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AF	593	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AL	593	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations This Read Vac	0	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AL	670	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AF	670	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Maintenance Operations	0	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	9 Month Operations	35	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps A Ø	97.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps B Ø	116.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps C Ø	110.0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations A Ø	1	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations B Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations C Ø	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations Ground	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations This Read Vac	1	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Switching Operations	1	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Unknown Operations	0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8394	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Max	34	°C
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	671.52	kw
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	General Comments	ok	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	General Comments		
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AF	181	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Maintenance Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps A Ø	0.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps C Ø	0.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps C Ø	356.0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps B Ø	363.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps A Ø	360.0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	9 Month Operations	1	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.600	millivolts
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.6764	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Present	25	*C
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Max	55	*C
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2682.24	kw
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Switching Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AL	181	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.9	VDC
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	9 Month Operations	1	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	9 Month Operations	2	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps A Ø	106.0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps B Ø	147.0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps C Ø	109.0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	General Comments	OK	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations A Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Present	40	°C
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Max	50	°C
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	LTC Totalizer Reading	3161.60	kw
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps A Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps B Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps C Ø	0.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations C Ø	0	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AF	131	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AL	131	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Unknown Operations	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	9 Month Operations	3	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Current Tap Position	6L	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Left Counter	6177	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Found Counter	6168	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Readings	General Comments	temp gauge not working. oil below "Lo" indicator	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Max	0	°C
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations A Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations B Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations C Ø	1	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	9 Month Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Follow-up Action Required?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Present	18	°C
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1082.88	kw
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	General Comments	line arrester on Aph needs changed its blown almost into	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Maintenance Operations	0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Reading	.9880	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Regulator As Left Counter	20604	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Steps are eroding on north side of swgr	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.9	VDC
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	General Comments	ok	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	9 Month Operations	2	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps A Ø	107.0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps B Ø	124.0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps C Ø	123.0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	PF001289	PowerFuse	BY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	PF001289	PowerFuse	BY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9126	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	365.04	kw
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	General Comments	ok	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	General Comments	Needs wildlife protection on secondary side.	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AF	686	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AL	686	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Regulator As Left Counter	115426	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Present	0	°C
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Max	0	°C
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Reading	.9960	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Max	35	°C
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	LTC Totalizer Reading	9561.60	kw
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	General Comments	small leak under ltc mech. cabinet	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	30	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	15	°C
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Operations Since Last Insp	1907	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Min Tap Position	11L	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Current Tap Position	6L	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Left Counter	159429	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps A Ø	116.0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps B Ø	114.0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps C Ø	102.0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	General Comments	Batt failed t5wice on ck	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Operations Counter	74	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Unknown Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:01	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 13:01	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 13:01	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	30	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	20	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps C Ø	237.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps B Ø	269.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps A Ø	227.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	9 Month Operations	1	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Grounds in Place?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	716.64	kw
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7320	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Operations Since Last Insp	909	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Min Tap Position	10L	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Max Tap Position	5R	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Present	22	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	40078	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Found Counter	43633	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Left Counter	43633	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	13	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	312	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Maintenance Operations	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	General Comments	Fncn TC	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations B Ø	0	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/2/2022 9:55	Distribution	Middleboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	9 Month Operations	1	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps A Ø	103.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps B Ø	120.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps C Ø	125.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1756.80	kw
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	General Comments	ok	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AF	152	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AL	153	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations This Read Vac	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Switching Operations	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Regulator As Left Counter	106669	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Current Tap Position	2L	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Left Counter	17926	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Found Counter	17916	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001629	BreakerVacuum	124-0367	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps A Ø	88.3	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	9 Month Operations	11	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps A Ø	117.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps B Ø	99.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps C Ø	132.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations A Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations B Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations C Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations Ground	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	General Comments	A&C ph line arresters are black on top with weather caps blown off and have had lightning strike	they are not blown apart
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Maintenance Operations	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations Counter AF	159	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations Counter AL	159	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55	VDC
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55	VDC
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Amps C Ø	89.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Amps B Ø	92.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Amps A Ø	92.0	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5972	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	W00126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Unknown Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	9 Month Operations	1	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Operations Counter	124	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps C Ø	88.6	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps B Ø	89.2	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps A Ø	111.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps B Ø	111.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps C Ø	131.0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AF	187	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Maintenance Operations	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	General Comments	ok	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	General Comments	OK	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	185	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Found Counter	138182	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Left Counter	138182	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations A Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations B Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations C Ø	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations Ground	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Maintenance Operations	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations Counter AF	197	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations Counter AL	197	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1R	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Switching Operations	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Unknown Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Neighboring Fence within 6'	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	General Comments	gate needs attention	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Switching Operations	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Operations This Read Vac	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Operations Counter AL	186	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Operations Counter AF	186	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001627	BreakerVacuum	124-0365	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AL	149	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AF	149	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Maintenance Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations A Ø	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Unknown Operations	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	All Connections OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	LTC Output Voltage Level	121.5	VAC
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AF	121.5	VAC
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AL	121.5	VAC
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Time Delay	60	Seconds
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Switching Operations	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations This Read Vac	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AL	187	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	9 Month Operations	6	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps B Ø	58.5	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps A Ø	59.0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations A Ø	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations Ground	0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Operations Counter	315	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	General Comments		
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Recloser Heaters Functioning?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps C Ø	99.0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps B Ø	125.0	
2/1/2022 9:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps A Ø	106.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000404	LTCControl	BY-TRANS 1	LTC Control Insp	General Comments	ok	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000404	LTCControl	BY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Found Counter	113577	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Left Counter	113577	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Found Counter	159425	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	General Comments		
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Operations Counter	243	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	General Comments	3 operations	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Regulator As Left Counter	17577	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	General Comments	Mice have eaten on the prints	House needs new set of prints
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps C Ø	63.4	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations This Read Vac	1	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Switching Operations	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Operations B Ø	0	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Present	0	°C
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Max	0	°C
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Reading	.8394	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.1478	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Operations Counter	106	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5509.44	kw
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Present	30	°C
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Max	40	°C
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	LTC Totalizer Reading	3021.84	kw
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	4803.84	kw
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Max	70	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	282	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.0008	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps A Ø	69.0	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 13:01	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Switching Operations	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Operations This Read Vac	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Operations Counter AL	184	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Operations Counter AF	184	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps C Ø	59.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001628	BreakerVacuum	124-0366	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Maintenance Operations	1	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Unknown Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Switching Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations This Read Vac	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AF	157	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AL	158	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	5	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	5	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	5	°C
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	9 Month Operations	4	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	9 Month Operations	4	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps A Ø	282.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps B Ø	226.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps C Ø	255.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Amps A Ø	0.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Amps B Ø	0.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Amps C Ø	0.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Operations Counter AF	167	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Regulator As Left Counter	29641	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:47	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Regulator As Left Counter	19523	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Present	5	°C
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Ambient Temperature	50	°F
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Fault Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	General Comments	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Num Operations Last 9 Months	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Operations Counter AF	105	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Operations Counter AL	105	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Operations This Read SF6	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	SF6 Pressure Pole 1	68	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	SF6 Pressure Pole 2	69	psi
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	SF6 Pressure Pole 3	68	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001749	BreakerSF6	124-658	GCB Readings	Unknown Operations	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Unknown Operations	0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	9 Month Operations	4	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Amps A Ø	68.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Amps B Ø	40.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Amps C Ø	60.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Switching Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Switching Operations	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Operations This Read Vac	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Operations Counter AL	208	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Operations Counter AF	208	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations B Ø	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Operations Counter AL	167	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Operations This Read Vac	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Switching Operations	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001622	BreakerVacuum	124-BT5-6	VCB Readings	Unknown Operations	0	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps A Ø	47.0	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps B Ø	71.0	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Amps C Ø	93.0	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	General Comments	B PHASE IOC	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AF	99777	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AL	99777	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations This Read Vac	1	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Switching Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Unknown Operations	0	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Operations Counter	254	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	X0059	RecloserHydraulic	321-4734	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	General Comments	Need to bring spare S&C fuses.	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	All Connections OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	General Comments		
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	LTC Output Voltage Level	130.9	VAC
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Time Delay	30	Seconds
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Reading	.1980	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Present	40	°C
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Max	60	°C
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	LTC Totalizer Reading	1584.00	kw
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	9 Month Operations	2	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps A Ø	144.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps B Ø	153.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps C Ø	143.0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	General Comments	ok	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Found Counter	194381	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Left Counter	194381	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	283	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Oil filter motor is not working	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Found Counter	217681	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Left Counter	217681	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1126	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	General Comments	SPR disabled	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations A Ø	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Present	50	°C
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Max	50	°C
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	General Comments		
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	General Comments	12-20 AG op/ Fcnct TC	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Maintenance Operations	1	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AF	199	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AL	200	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations This Read Vac	2	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Switching Operations	0	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:51	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	LTC Totalizer Reading	10780.80	kw
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Operations Counter AF	160	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Operations Counter AL	160	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Operations This Read Vac	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Switching Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Broom on Site?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Unknown Operations	0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	395	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	395	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BCH001313	Charger	747-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Swept?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Operations Counter	26	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	9 Month Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Unknown Operations	0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	1	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2849.28	kw
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Amps C Ø	38.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps C Ø	4.0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps B Ø	8.0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps A Ø	4.0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	9 Month Operations	1	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Amps A Ø	68.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001624	BreakerVacuum	124-0372	VCB Readings	Amps B Ø	38.0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Found Counter	60644	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Left Counter	60644	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7R	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	610	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Leaks	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Operations Counter	1458	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8904	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Ambient Temperature	50	*F
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Fault Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Gauge(s) Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	General Comments	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Heaters (All) Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Num Operations Last 9 Months	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Operations Counter AF	149	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Operations Counter AL	149	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Operations This Read SF6	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	SF6 Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	SF6 Pressure Pole 1	67	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	SF6 Pressure Pole 2	67	psi
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Switching Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	General Comments	ok	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	SF6 Pressure Pole 3	67	psi
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Switching Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001750	BreakerSF6	124-668	GCB Readings	Unknown Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AL	436	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	All Connections OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	LTC Operation Checked?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	General Comments		
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	44.40	kw
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
2/14/2022 12:21	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0370	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AF	436	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Maintenance Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations C Ø	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.4	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.4	VDC
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.600	millivolts
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations B Ø	0	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps C Ø	203.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps B Ø	206.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps A Ø	207.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Maintenance Operations	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps C Ø	152.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps B Ø	131.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps A Ø	154.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	9 Month Operations	2	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	52	°C
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	72	°C
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Operations Counter AF	198	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Operations Counter AL	198	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Operations This Read Vac	1	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001623	BreakerVacuum	124-0370	VCB Readings	Switching Operations	1	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations This Read Vac	0	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AL	153	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AF	153	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Maintenance Operations	0	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations Counter AL	301	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Operations Counter AF	301	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	General Comments		
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	General Comments	ok	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Trash Emptied?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Operations Counter	60	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	General Comments		
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps A Ø	55.0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Regulator As Left Counter	151818	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Min Tap Position	2L	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Max Tap Position	4R	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	General Comments		
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Panels Dusted?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Current Tap Position	2R	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Operations Counter	31	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	General Comments		
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	C ∅ Operations Counter	0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	B ∅ Operations Counter	0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps C ∅	0.0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps B ∅	0.0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps A ∅	0.0	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	A ∅ Operations Counter	0	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	*F
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.7	VDC
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.6	VDC
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BAT001595	Battery	787-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations Ground	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations C ∅	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations B ∅	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations A ∅	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps C ∅	307.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps B ∅	328.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps A ∅	338.0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	9 Month Operations	0	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations A ∅	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations B ∅	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations C ∅	0	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations Ground	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	General Comments		
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middleboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/2/2022 9:55	Distribution	Middleboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middleboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middleboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	General Comments		
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	250	psi
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Max	62	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Floor Swept?	n	
2/1/2022 15:28	Distribution	Middleboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8556	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Operations Since Last Insp	614	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Min Tap Position	10L	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Max Tap Position	1R	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Current Tap Position	4L	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Present	43	°C
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Vegetation	None	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 9:56	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AF	560	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AL	560	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations This Read Vac	1	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Switching Operations	0	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 13:05	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Unknown Operations	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	General Comments	ok	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	9 Month Operations	4	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps A Ø	0.0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps B Ø	0.0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps C Ø	0.0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Broom on Site?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 8:15	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 12:48	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Reading	1.1230	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001626	BreakerVacuum	124-0364	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2053.44	kw
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.5	VDC
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.5	VDC
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	BCH001524	Charger	787-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations C Ø	0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations Ground	0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Maintenance Operations	0	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AF	211	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AL	213	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations This Read Vac	2	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Switching Operations	2	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 14:12	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	General Comments	ok	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21540	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Leaks	None	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Unknown Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Switching Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations This Read Vac	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AL	260	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AF	260	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Maintenance Operations	0	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	General Comments		
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCC00285	LTCControl	FH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCC00285	LTCControl	FH-TRANS 1	LTC Control Insp	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	LTCC00285	LTCControl	FH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/1/2022 13:11	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:53	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
2/7/2022 8:01	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
2/1/2022 11:42	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Unknown Operations	0	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	General Comments	OK	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Vegetation	None	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushing Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	9 Month Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Amps A Ø	520.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Amps B Ø	517.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Readings	Amps C Ø	489.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001621	BreakerVacuum	124-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps C Ø	170.0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps B Ø	145.0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps A Ø	90.0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	9 Month Operations	3	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	General Comments	no spares	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	General Comments	OK	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
2/1/2022 11:37	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Unknown Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Switching Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations This Read Vac	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AL	269	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AF	269	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Maintenance Operations	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	General Comments		
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations Ground	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations C Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations B Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations A Ø	0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps C Ø	140.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps B Ø	124.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps A Ø	204.0	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	9 Month Operations	0	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Evidence of Insects	None	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
2/1/2022 15:28	Distribution	Middlesboro 2 Quarterly Inspection	CH000522	ControlHouse	780-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Unknown Operations	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Switching Operations	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations This Read Vac	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AL	130	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AF	130	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Maintenance Operations	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Grounds in Place?	y	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	General Comments	ok	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Foundation Condition	Good	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations Ground	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations C Ø	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations B Ø	0	
2/1/2022 9:02	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations A Ø	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Maintenance Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AF	72	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AL	72	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations This Read Vac	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Switching Operations	0	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Amps A Ø	247.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Amps B Ø	172.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Amps C Ø	169.0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Operations A Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Operations B Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Operations C Ø	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Fault Operations Ground	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 10:31	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Unknown Operations	0	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LTO294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	31	°C
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Follow-up Action Required?	n	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	General Comments		
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Maintenance Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Operations Counter AF	160	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Operations Counter AL	160	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Operations This Read Vac	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Switching Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.0	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.2	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps C Ø	.3	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
2/1/2022 11:39	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Equipment Properly Labeled?	y	Need size info and qty

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
2/1/2022 10:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
2/1/2022 9:18	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Trash?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	69	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001625	BreakerVacuum	124-0371	VCB Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Left Counter	41685	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Found Counter	41674	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	General Comments		
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 12:42	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Follow-up Action Required?	n	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Heaters (All) Functioning?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Maintenance Operations	1	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Moisture and Leak Free?	y	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AF	167	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AL	168	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations This Read Vac	1	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Switching Operations	0	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Tank Paint Condition	Good	
2/1/2022 9:50	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Unknown Operations	0	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	9 Month Operations	0	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/2/2022 9:55	Distribution	Middlesboro 1 Quarterly Inspection	BK001620	BreakerVacuum	124-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	31	°C
2/1/2022 12:13	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
2/1/2022 11:23	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	General Comments		
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Current Tap Position	4R	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
2/1/2022 13:46	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
2/1/2022 13:51	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Operations Ground	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Operations C Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Amps B Ø	280.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Amps C Ø	258.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	LTC Totalizer Reading	7020.00	kw
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Operations C Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Unknown Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Operations B Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Operations A Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Operations Since Last Insp	393	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Min Tap Position	16L	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Max Tap Position	9L	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Current Tap Position	9L	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Max	45	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Left Counter	155704	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Reading	.3900	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Winding Temp Max	62	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Winding Temp Present	39	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Amps C Ø	99.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Amps B Ø	93.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Amps A Ø	84.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Operations This Read Vac	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Operations Counter AL	165	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Operations Counter AF	165	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Maintenance Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	General Comments		
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001587	BreakerVacuum	451-2117	VCB Readings	Fault Operations Ground	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Max Tap Position	4L	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Min Tap Position	16L	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Operations Since Last Insp	560	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Unknown Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Switching Operations	1	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Operations This Read Vac	1	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Operations Counter AL	171	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Operations Counter AF	171	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Maintenance Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	General Comments		
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	340.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Ambient Temp	16	*F
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0335	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	General Comments		
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Found Counter	18440	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Left Counter	18443	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Current Tap Position	10L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Switching Operations	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations This Read Vac	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AL	330	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AF	330	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Maintenance Operations	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations Ground	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations C Ø	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations B Ø	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations A Ø	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps C Ø	42.0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps B Ø	41.0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps A Ø	43.0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	923.04	kw
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Amps C Ø	6.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Amps B Ø	7.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Amps A Ø	5.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	9 Month Operations	29	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Readings	Unknown Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001588	BreakerVacuum	451-2118	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Operations Ground	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Operations C Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Operations B Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Operations A Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001589	BreakerVacuum	451-2119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.5384	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Unknown Operations	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Oil Temp Max	20	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	All Connections OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Operation Checked?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Present	20	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Max	60	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	LTC Totalizer Reading	10465.20	kw
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Regulator As Left Counter	68927	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Switching Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations This Read Vac	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AL	248	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AF	248	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Maintenance Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations Ground	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations C Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations B Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations A Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Found Counter	155700	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	All Connections OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Oil Temp Present	16	°C
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps C Ø	277.0	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2806.56	kw
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	15	°C
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	General Comments		
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	10	°F
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps C Ø	0.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps B Ø	0.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps A Ø	0.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	9 Month Operations	31	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Vegetation	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	LTCC000935	LTCControl	677-2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Winding Temp Present	25	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Winding Temp Max	47	°C
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Reading	.5814	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Unknown Operations	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Regulator As Left Counter	70517	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Switching Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations This Read Vac	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AL	212	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AF	212	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Maintenance Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations Ground	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations C Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations B Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations A Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BAT001542	Battery	451-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Regulator As Left Counter	69433	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Vegetation	None	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	General Comments		
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Max Tap Position	15R	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	General Comments		
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Regulator As Left Counter	76116	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Regulator As Left Counter	16692	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	General Comments		
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Ambient Temp	7	*F
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Max Tap Position	11L	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	9 Month Operations	14	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Vegetation	None	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	9 Month Operations	6	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps A Ø	89.0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Vegetation	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps B Ø	88.0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps C Ø	80.0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations Ground	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations C Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations B Ø	0	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations A Ø	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Maintenance Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AF	413	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AL	413	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Max Tap Position	14R	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations This Read Vac	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Regulator As Left Counter	21334	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Switching Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Unknown Operations	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Operations Counter	345	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Operations Since Last Insp	250	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Min Tap Position	9L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Max Tap Position	2R	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Current Tap Position	4L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Left Counter	37093	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Found Counter	37090	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Follow-up Action Required?	n	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Maintenance Operations	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AF	338	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AL	338	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations This Read Vac	0	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Switching Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps B Ø	247.0	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations A Ø	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations B Ø	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations C Ø	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations Ground	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Operations Counter	74	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Unknown Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Switching Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Ambient Temp	16	*F
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations This Read Vac	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AL	341	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AF	341	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Maintenance Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Regulator As Left Counter	20925	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Oil Temp Present	35	°C
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Oil Temp Max	35	°C
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	LTC Totalizer Reading	11139.84	kw
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Max Tap Position	12R	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	General Comments		
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps C Ø	39.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps B Ø	36.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps A Ø	21.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	9 Month Operations	26	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Reading	1.1604	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	LTC Operation Checked?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCControl	451-2	LTC Control Insp	All Connections OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Unknown Operations	0	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Ambient Temp	13	*F
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Switching Operations	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Operations This Read Vac	0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Unknown Operations	0	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	General Comments		
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5360	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Present	32	*C
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps A Ø	97.0	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Max	50	*C
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	130.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	857.60	kw
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps B Ø	54.0	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps C Ø	49.0	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	General Comments		
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/29/2022 12:17	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Operations Ground	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Operations C Ø	0	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Operations B Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Operations A Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Amps C Ø	0.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Amps B Ø	0.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Amps A Ø	0.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	9 Month Operations	10	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/29/2022 11:05	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Operations Counter AL	152	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Operations Counter AF	152	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Maintenance Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Grounds in Place?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	General Comments		
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Foundation Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Follow-up Action Required?	n	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/29/2022 13:13	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Operations Ground	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Operations C Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Operations B Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Operations A Ø	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/29/2022 7:33	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000064	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Patrol Inspection	Bushing Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Amps C Ø	356.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Amps B Ø	370.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Amps A Ø	367.0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001591	BreakerVacuum	451-1	VCB Readings	9 Month Operations	15	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Unknown Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Switching Operations	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Operations This Read Vac	0	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Operations Counter AL	165	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Operations Counter AF	165	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/29/2022 9:54	Distribution	Danville Industrial Quarterly Inspection	BK001590	BreakerVacuum	451-BT2-1	VCB Readings	Maintenance Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1134.72	kw
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	50	°C
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.3546	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	6000	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7270	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Present	22	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Max	48	°C
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations A Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Vegetation	None	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps C Ø	180.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps B Ø	175.0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps A Ø	180.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty C Ph V	3.02	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty B Ph V	5.03	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations B Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations C Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations Ground	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Regulator As Left Counter	40117	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	All Connections OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Switching Operations	8	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	LTC Totalizer Reading	14169.6	kw
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations This Read Vac	8	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AL	137	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AF	137	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Maintenance Operations	0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	LTC Operation Checked?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	LTC Output Voltage Level	121.1	VAC
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCCControl	746-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Oil Temp Max	53	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations Ground	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Oil Temp Present	29	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.1	amps
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X3 Winding Temp Present	31	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps A Ø	214.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	9 Month Operations	9	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Switching Operations	6	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations This Read Vac	6	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AL	179	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AF	179	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Maintenance Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations Ground	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations C Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations B Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations A Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #-'s
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps C Ø	140.0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty A Ph V	7.04	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	9 Month Operations	38	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7957	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations B Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations A Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Vegetation	None	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Unknown Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Switching Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations This Read Vac	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AL	429	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AF	429	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Maintenance Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps C Ø	147.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps B Ø	209.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Totalizer Meter Reading	.5904	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X1 Winding Temp Present	32	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X2 Winding Temp Present	32	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTC000867	LTCControl	899-2	LTC Control Insp	All Connections OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X3 Winding Temp Present	42	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X3 Winding Temp Max	66	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X2 Winding Temp Present	42	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X2 Winding Temp Max	64	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Operations Since Last Insp	268	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	22	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Num Operations Last 9 Months	6	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Operations Counter AF	108	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Operations Counter AL	108	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Operations This Read SF6	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	49	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Min Tap Position	10L	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	SF6 Pressure	62	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Max Tap Position	1L	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Current Tap Position	2L	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC As Left Counter	4069	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC As Found Counter	4069	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Switching Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Unknown Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X1 Winding Temp Present	44	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X1 Winding Temp Max	64	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Totalizer Meter Reading	.963	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Ambient Temperature	25	*F
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Fault Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Ambient Temperature	24	*F
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	General Comments	sf6 pressure 92/93/92 need 3 blocks for pressure entry. breaker is in service	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	General Comments	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001511	BreakerSF6	516-628	GCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	LTC Operation Checked?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCControl	899-2	LTC Control Insp	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Oil Temp Present	38	*C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Oil Temp Max	61	*C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	LTC Totalizer Reading	23112	kw
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Ambient Temperature	24	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	LTC Operation Checked?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	All Connections OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	General Comments	90/90/91 psi need 3 entry blocks for sf6 pressure	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure	92	psi
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 1	92	psi
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 2	93	psi
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	SF6 Pressure Pole 3	92	psi
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 3	91	psi
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 2	90	psi
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure Pole 1	90	psi
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Pressure	90	psi
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	General Comments	draghands wont reset	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Found Counter	332128	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Left Counter	332132	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Max Tap Position	9L	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Min Tap Position	16R	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Operations Since Last Insp	552	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Operations Since Last Insp	324	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	54	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	29	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Min Tap Position	3L	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Max Tap Position	2L	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Current Tap Position	11L	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC As Left Counter	3279	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC As Found Counter	3279	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Ambient Temperature	25	*F
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Fault Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	General Comments	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8023	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	9 Month Operations	8	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	4362.00	kw
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps B Ø	207.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps A Ø	200.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	SF6 Pressure	60	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Switching Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Vegetation	None	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	LTCC000137	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	STO00548	Structure	582-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	STO00548	Structure	582-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Maintenance Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Num Operations Last 9 Months	5	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Operations Counter AF	179	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Operations Counter AL	179	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Readings	Operations This Read SF6	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001509	BreakerSF6	516-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Operations C Ø	0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Fault Operations Ground	0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Maintenance Operations	0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Operations Counter AF	187	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Operations Counter AL	187	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Unknown Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Switching Operations	1	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Operations This Read Vac	7	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Operations Counter AL	123	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Operations Counter AF	123	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Maintenance Operations	6	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Amps C Ø	135.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Amps B Ø	175.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Amps A Ø	135.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001553	BreakerVacuum	516-0054	VCB Readings	9 Month Operations	11	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001770	BreakerVacuum	746-0172	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	All Connections OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	LTC Operation Checked?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCC000880	LTCControl	516-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Output Voltage Level	121.2	VAC
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Operation Checked?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	All Connections OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC As Found Counter	3491	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC As Left Counter	3491	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC Max Tap Position	1L	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	4	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	LTC Operations Since Last Insp	297	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000110	LTCMechanism	516-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations Counter AL	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations Counter AF	0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Leaks	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Unknown Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Switching Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Operations Counter AL	193	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Operations Counter AF	193	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Maintenance Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Amps C Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Amps B Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Amps A Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001557	BreakerVacuum	516-BT2-1	VCB Readings	9 Month Operations	42	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC As Found Counter	3523	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC As Left Counter	3523	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC Current Tap Position	1L	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC Min Tap Position	9L	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	7	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	LTC Operations Since Last Insp	322	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	LTCM000111	LTCMechanism	516-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001556	BreakerVacuum	516-2	VCB Readings	9 Month Operations	38	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001736	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	9 Month Operations	36	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations Ground	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations C Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations B Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations A Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Amps C Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Amps B Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Amps A Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	9 Month Operations	18	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Unknown Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Switching Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Operations Counter AL	226	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Operations Counter AF	226	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Maintenance Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Amps C Ø	300.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Amps B Ø	335.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Amps A Ø	305.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001546	BreakerVacuum	516-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Current Tap Position	7L	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Min Tap Position	10L	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps C Ø	0.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps B Ø	0.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps A Ø	0.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	9 Month Operations	11	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Output Voltage Level	120.7	volts
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Regulator As Left Counter	19296	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Vegetation	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	NLTC Bushing Dyanmic Health	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	NonLTC Trn Dynamic Health	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Oil Temp Max	45	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Oil Temp Present	25	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations Counter AL	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Operations Counter AF	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001735	BreakerVacuum	516-Offline Distribution	VCB Readings	9 Month Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Unknown Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Switching Operations	1	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Operations This Read Vac	1	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	ST000381	Structure	899-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0507	NonLTC	746-3 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations C Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations B Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations A Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps C Ø	473.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps B Ø	460.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Amps A Ø	318.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	9 Month Operations	8	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Unknown Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Switching Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Operations Counter AL	207	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Operations Counter AF	207	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	Maintenance Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001547	BreakerVacuum	516-BT1-2	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Operations Counter AL	121	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Operations Counter AF	121	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Maintenance Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Amps C Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Amps B Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Amps A Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001549	BreakerVacuum	516-0028	VCB Readings	9 Month Operations	1	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Switching Operations	10	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations This Read Vac	10	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AL	197	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AF	197	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Maintenance Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Switching Operations	6	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations This Read Vac	6	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AL	173	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AF	173	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Fault Operations Ground	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	13645.44	kw
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Fault Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Ambient Temperature	30	°F
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Operations Ground	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations This Read SF6	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AL	183	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AF	83	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Num Operations Last 9 Months	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Maintenance Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Maintenance Operations	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Operations Counter AF	171	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Operations Counter AL	172	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Operations This Read Vac	1	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Switching Operations	1	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Unknown Operations	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.4214	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Unknown Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Switching Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations This Read Vac	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AL	113	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Operations Counter AF	113	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Maintenance Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations Ground	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations C Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations B Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Operations A Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps C Ø	360.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps B Ø	360.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps A Ø	325.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	9 Month Operations	0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	9 Month Operations	1	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	LTC Totalizer Reading	4020.48	kw
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Max	25	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000223	Switchgear	516-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Present	16	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	SWG000222	Switchgear	516-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Reading	.2792	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Max	30	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Present	17	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations Ground	2	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations C Ø	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Maintenance Operations	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations B Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations A Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps C Phase V	12.54	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps B Phase V	12.54	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps A Phase V	12.54	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps C Ø	10.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps B Ø	20.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps A Ø	10.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty C Ph V	6.03	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty B Ph V	18.1	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty A Ph V	8.04	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	9 Month Operations	6	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations Counter AF	172	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations Counter AL	172	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations This Read Vac	1	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Switching Operations	1	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Unknown Operations	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Unknown Operations	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Switching Operations	1	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps C Ø	453.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps B Ø	462.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps A Ø	308.0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Pressure	68	psi
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	9 Month Operations	8	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	FE000875	Fence	899-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Operations A Ø	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Operations B Ø	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Fault Operations C Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Fault Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Maintenance Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Amps B Ø	170.0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations Ground	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Readings	Amps C Ø	112.0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations C Ø	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations B Ø	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations A Ø	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps C Ø	147.0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps B Ø	155.0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps A Ø	108.0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	9 Month Operations	2	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Switching Operations	8	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations This Read Vac	8	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AL	124	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AF	124	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Maintenance Operations	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BK001573	BreakerVacuum	580-2106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Unknown Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Switching Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Operations Counter AL	28	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Operations Counter AF	28	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Reading	.1275	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Maintenance Operations	0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	LTC Totalizer Reading	9362.40	kw
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Oil Temp Max	42	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Oil Temp Present	15	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Totalizer Meter Reading	.3901	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Winding Temp Max	42	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	Winding Temp Present	16	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X1 Winding Temp Max	42	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X1 Winding Temp Present	16	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X2 Winding Temp Max	42	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X2 Winding Temp Present	16	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X3 Winding Temp Max	42	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	X3 Winding Temp Present	16	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BCH001470	Charger	746-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	*F
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BAT001541	Battery	746-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	LTC Totalizer Reading	765.00	kw
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Current Tap Position	3L	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Max Tap Position	3L	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Min Tap Position	3L	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Output Voltage Level	121.2	volts
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Regulator As Left Counter	81266	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	9 Month Operations	26	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Amps A Ø	0.0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Amps B Ø	0.0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	BK001769	BreakerVacuum	746-0171	VCB Readings	Amps C Ø	0.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	LTC Totalizer Reading	7070.40	kw
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Oil Temp Max	45	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Oil Temp Present	22	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Totalizer Meter Reading	.2946	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Winding Temp Max	45	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	Winding Temp Present	25	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X3 Winding Temp Max	45	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000264	WithLTC	516-2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Amps C Ø	35.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Amps B Ø	35.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Amps A Ø	30.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001558	BreakerVacuum	516-0113	VCB Readings	9 Month Operations	27	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Present	32	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Max	32	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Amps C Ø	20.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Amps B Ø	20.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Amps A Ø	18.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001562	BreakerVacuum	516-1102	VCB Readings	9 Month Operations	26	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Unknown Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Switching Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Operations Counter AL	102	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Operations Counter AF	102	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Maintenance Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps A Ø	360.0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps B Ø	240.0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Amps C Ø	260.0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001559	BreakerVacuum	516-0131	VCB Readings	9 Month Operations	36	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	TX000263	WithLTC	516-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Amps C Ø	50.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Amps B Ø	50.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Amps A Ø	50.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001561	BreakerVacuum	516-1102	VCB Readings	9 Month Operations	27	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Unknown Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Switching Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Operations Counter AL	94	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Operations Counter AF	94	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Maintenance Operations	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Amps C Ø	100.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Amps B Ø	100.0	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	BK001560	BreakerVacuum	516-1101	VCB Readings	Amps A Ø	100.0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations Counter AF	103	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations Counter AL	103	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	67.0	VDC
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	66.0	VDC
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	If no, which cells in comments
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Left Counter	23291	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Found Counter	23288	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	PF001322	PowerFuse	746-1F	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	PF001322	PowerFuse	746-1F	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps C Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Unknown Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Switching Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations This Read Vac	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AL	324	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AF	324	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Maintenance Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations Ground	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations C Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations B Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations A Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Unknown Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Switching Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Operations Counter AL	142	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Operations Counter AF	142	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Operations Counter AL	105	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Unknown Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Operations Since Last Insp	485	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Min Tap Position	14L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Max Tap Position	3L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Current Tap Position	9L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Left Counter	93905	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Found Counter	93900	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations Counter AF	114	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations Counter AL	114	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Unknown Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	9 Month Operations	3	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Maintenance Operations	0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Foundation Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	General Comments		
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps C Ø	60.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps B Ø	60.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps C Ø	160.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps B Ø	120.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps A Ø	160.0	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Max Tap Position	1R	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Min Tap Position	1R	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Regulator As Left Counter	51247	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	9 Month Operations	11	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Amps A Ø	60.0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty B Ph V	1.01	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Present	32	°C
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Max	42	°C
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Reading	.4920	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	9 Month Operations	9	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Present	25	°C
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Max	40	°C
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	LTC Totalizer Reading	8856.00	kw
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Maintenance Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Present	24	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	9 Month Operations	4	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps A Ø	170	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps B Ø	155	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps C Ø	180	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50405	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Amps A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Amps B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Amps C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Operations Counter AF	105	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Operations Counter AL	105	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	9 Month Operations	3	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	9 Month Operations	4	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps A Ø	270	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps B Ø	185	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps C Ø	200	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations Counter AF	98	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations Counter AL	98	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Max	35	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Reading	.4919	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Present	17	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Max	30	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	LTC Totalizer Reading	7083.36	kw
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	General Comments		
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Found Counter	24014	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Left Counter	24018	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Current Tap Position	7L	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Min Tap Position	12L	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	17	°C
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	22	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Operations Since Last Insp	680	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AF	353	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Maintenance Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	9 Month Operations	3	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	9 Month Operations	4	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps A Ø	370	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps B Ø	320	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps C Ø	320	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Current Tap Position	3L	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations B Ø	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Max Tap Position	5R	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Min Tap Position	8L	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	21	°C
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	21	°C
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations Counter AF	121	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations Counter AL	121	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Unknown Operations	0	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Operations Since Last Insp	755	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 8:55	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Unknown Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Switching Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations This Read Vac	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AL	353	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps A Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations Counter AF	134	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations Counter AL	134	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Unknown Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Ambient Temp	20	*F
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Leaks	None	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 10:00	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations Ground	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations C Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations B Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations A Ø	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	General Comments		
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Vegetation	None	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Vegetation	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	9 Month Operations	4	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/28/2022 7:36	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations B Ø	0	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	9 Month Operations	3	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations Counter AF	107	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations Counter AL	107	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	General Comments		
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Unknown Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	General Comments		
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Current Tap Position	10L	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	9 Month Operations	4	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations Counter AF	95	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations Counter AL	95	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Unknown Operations	0	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/28/2022 16:58	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9378	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	9 Month Operations	4	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps A Ø	460	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps B Ø	385	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps C Ø	340	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/28/2022 11:38	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations A Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations B Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations C Ø	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Switching Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps C Ø	800	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps B Ø	840	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps A Ø	970	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Unknown Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps A Ø	970	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations Ground	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Follow-up Action Required?	n	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	General Comments		
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations This Read Vac	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps C Ø	150	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps B Ø	100	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps A Ø	140	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Maintenance Operations	0	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations Counter AF	111	
1/28/2022 7:22	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations Counter AL	111	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations C Ø	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty A Ph V	4.28	%
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty B Ph V	3.8	%
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty C Ph V	3.33	%
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps A Ø	60.0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps B Ø	120.0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps C Ø	40.0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations A Ø	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty A Ph V	6.18	%
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	9 Month Operations	5	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	9 Month Operations	6	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty C Ph V	.48	%
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty B Ph V	1.9	%
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps A Ø	60.0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations A Ø	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Unknown Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations B Ø	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Switching Operations	1	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations This Read Vac	1	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AL	10	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AF	10	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps C Ø	40.0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	General Comments	reopened inspection so counter could recalculate. Corrected previous quarterly inspection counter reading	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Found Counter	204340	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Left Counter	204345	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Current Tap Position	10L	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Max Tap Position	3L	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Min Tap Position	15L	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Unknown Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Switching Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations This Read Vac	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AL	328	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps B Ø	120.0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AF	328	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Maintenance Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Maintenance Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations Ground	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations Ground	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations C Ø	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations B Ø	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Operations Since Last Insp	423	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Operation Checked?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	All Connections OK?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps C Ø	97.0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps B Ø	149.0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Present	25	°C
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Max	60	°C
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	LTC Totalizer Reading	5984.64	kw
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	9 Month Operations	4	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	LTC Operation Checked?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCC000815	LTCControl	509-1	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps A Ø	0.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps B Ø	0.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Regulator As Left Counter	30017	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps C Ø	0.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Reading	.6234	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps A Ø	127.0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Maintenance Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AF	291	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AL	291	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	9 Month Operations	6	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations Ground	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations C Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations This Read Vac	2	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Switching Operations	2	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Unknown Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations B Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations A Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations Ground	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations C Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations B Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Reading	.5970	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Max	60	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Present	20	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps C Ø	169.0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps B Ø	136.0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps A Ø	156.0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations	17	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Unknown Operations	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Switching Operations	2	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	LTC Operation Checked?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	All Connections OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps A Ø	160.0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps B Ø	120.0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps C Ø	180.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations B Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations C Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations Ground	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Present	20	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	LTC Totalizer Reading	14328.00	kw
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Unknown Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Switching Operations	2	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations This Read Vac	2	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AL	281	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Maintenance Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AF	87	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AL	87	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations This Read Vac	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Switching Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Unknown Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	9 Month Operations	5	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AF	281	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Maintenance Operations	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations This Read Vac	2	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AL	186	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AF	185	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Maintenance Operations	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations Ground	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations B Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Vegetation	None	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Regulator As Left Counter	86521	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	LTC Totalizer Reading	10627.20	kw
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Oil Temp Max	60	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Oil Temp Present	20	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Totalizer Meter Reading	.4428	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Winding Temp Max	55	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Winding Temp Present	20	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Found Counter	9939	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Left Counter	9939	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Current Tap Position	4L	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Max Tap Position	2L	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Min Tap Position	11L	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Operations Since Last Insp	409	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Switching Operations	4	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	9 Month Operations	2	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps A Ø	110.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps B Ø	125.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps C Ø	125.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations A Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations B Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations C Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Operations Ground	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps A Ø	237.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps B Ø	255.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps C Ø	243.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations A Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations B Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations C Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Unknown Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	9 Month Operations	14	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps A Ø	50.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Amps B Ø	75.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AF	201	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations Counter AL	201	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Operations This Read Vac	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Switching Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Unknown Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations Ground	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Regulator As Left Counter	80632	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations This Read Vac	4	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AL	233	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Ambient Temp	24	°F
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Vegetation	None	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps C Ø	10.0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps B Ø	10.0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps A Ø	10.0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	9 Month Operations	8	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Present	22	°C
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6942	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations B Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations C Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations Ground	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6664.32	kw
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Maintenance Operations	8	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AF	212	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations Counter AL	212	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Operations This Read Vac	8	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Switching Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Unknown Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	9 Month Operations	10	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps A Ø	120.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps B Ø	120.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Amps C Ø	125.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations A Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations B Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations C Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Fault Operations Ground	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000957	BreakerVacuum	509-0108	VCB Readings	Maintenance Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Maintenance Operations	6	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AF	165	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AL	165	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations This Read Vac	6	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Switching Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Unknown Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	9 Month Operations	7	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AL	197	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations This Read Vac	10	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Switching Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Unknown Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	9 Month Operations	8	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps A Ø	620.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps B Ø	575.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Amps C Ø	595.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations A Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations B Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations C Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Fault Operations Ground	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Maintenance Operations	7	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AF	162	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations Counter AL	162	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Operations This Read Vac	7	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Readings	Switching Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000966	BreakerVacuum	509-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Unknown Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Switching Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations B Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations C Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations Ground	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Maintenance Operations	7	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AF	200	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations Counter AL	200	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Operations This Read Vac	7	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Switching Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Unknown Operations	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations Ground	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations C Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations B Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps C Ø	180.0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps B Ø	200.0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps A Ø	180.0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	9 Month Operations	8	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps A Ø	0.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps B Ø	0.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Amps C Ø	0.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	Fault Operations A Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations This Read Vac	7	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Switching Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Unknown Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Oil Temp Max	70	°C
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Oil Temp Present	23	°C
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8250	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Ambient Temperature	13	°F
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Fault Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	General Comments	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Maintenance Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Num Operations Last 9 Months	2	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations Counter AF	81	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations Counter AL	81	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations This Read SF6	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 1	60	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 2	60	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 3	60	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Switching Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Unknown Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Ambient Temperature	13	*F
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	9 Month Operations	9	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7920.00	kw
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps A Ø	155.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps B Ø	140.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Amps C Ø	150.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations A Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations B Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations C Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Fault Operations Ground	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Maintenance Operations	7	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AF	196	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AL	196	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Maintenance Operations	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AF	745	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AL	749	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations This Read Vac	4	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Switching Operations	4	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Unknown Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Unknown Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Unknown Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	9 Month Operations	11	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps A Ø	210.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps B Ø	165.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps C Ø	196.0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations A Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations B Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations C Ø	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations Ground	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Maintenance Operations	10	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Operations Counter AF	197	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Fault Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	General Comments	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Maintenance Operations	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Num Operations Last 9 Months	2	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations Counter AF	123	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations Counter AL	123	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations This Read SF6	0	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 1	58	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 2	58	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 3	58	psi
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Switching Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Maintenance Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AF	265	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AL	265	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations This Read Vac	2	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Switching Operations	2	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations B Ø	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations C Ø	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations Ground	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Switching Operations	1	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Max Tap Position	4R	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Min Tap Position	16L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CO450	WithLTC	204-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CO450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Unknown Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Switching Operations	3	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations This Read Vac	3	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AL	252	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AF	252	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Maintenance Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations Ground	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations C Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Regulator As Left Counter	18302	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Leaks	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CO450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CO450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CO450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Maintenance Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AF	240	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AL	240	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations This Read Vac	1	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.0	VDC
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Negative DC Ground	67.0	VDC
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CO450	LTCMechanism	204-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	CO450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Operations Since Last Insp	692	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Max	100	°C
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps C Ø	252.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps B Ø	208.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps A Ø	206.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	9 Month Operations	7	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Present	23	°C
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Reading	.8770	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Max Tap Position	5L	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Unknown Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations B Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LTC Totalizer Reading	8419.20	kw
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Vegetation	None	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	*F
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	All Connections OK?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Area Ambient Temp	25	*F
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Overall Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Switching Operations	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Eyewash Solution	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Switching Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Pressure	90	psi
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations This Read SF6	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations Counter AL	68	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations Counter AF	68	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Num Operations Last 9 Months	1	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Maintenance Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	General Comments	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Fault Operations	0	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Ambient Temperature	24	*F
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations Ground	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations C Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations B Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations A Ø	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps C Ø	69.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps B Ø	70.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps A Ø	69.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	9 Month Operations	3	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Fault Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	General Comments	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Maintenance Operations	0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Num Operations Last 9 Months	2	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AF	70	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AL	70	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations This Read SF6	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations B Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations C Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Fault Operations Ground	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Min Tap Position	5R	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Max Tap Position	16L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	General Comments		
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Found Counter	188975	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Left Counter	188975	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Maintenance Operations	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations Counter AF	173	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations Counter AL	173	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Operations This Read Vac	1	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Switching Operations	1	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Current Tap Position	7L	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Unknown Operations	0	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Min Tap Position	11L	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Operations Since Last Insp	292	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Leaks	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Regulator As Left Counter	19559	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Max Tap Position	6R	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Min Tap Position	16L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	9 Month Operations	33	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps A Ø	69.0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps B Ø	62.0	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Regulator As Left Counter	20349	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Leaks	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Readings	Amps C Ø	59.0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001804	BreakerVacuum	788-2217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	CO455	LTCMechanism	788-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	CO455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	CO455	LTCMechanism	788-2	LTC Counter Readings	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations Ground	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations C Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations B Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Operations A Ø	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	YD000444	Yard	788-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Ambient Temperature	24	*F
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	All Connections OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Operation Checked?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps C Ø	41.0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps B Ø	68.0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Amps A Ø	65.0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	9 Month Operations	29	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Vegetation	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Reading	.9906	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Present	27	°C
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	LTC Totalizer Reading	9509.76	kw
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Current Tap Position	11L	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Unknown Operations	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Left Counter	29064	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Switching Operations	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Operations This Read Vac	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Operations Counter AL	172	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Operations Counter AF	172	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Readings	Maintenance Operations	0	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	BK001803	BreakerVacuum	788-2215	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Found Counter	29060	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Max Tap Position	6L	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Min Tap Position	16L	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Operations Since Last Insp	655	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Current Tap Position	6L	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Left Counter	210661	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Found Counter	210661	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.7	amps
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Operations Since Last Insp	1434	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/26/2022 15:43	Distribution	Danville North Quarterly Inspection	BCH001472	Charger	204-Battery Charger Dist	Battery Charger Patrol Insp	General Comments		
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.1	amps
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	General Comments		
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 11:18	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Follow-up Action Required?	n	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	CH000414	ControlHouse	427-Control House	Control House Patrol Inspection	General Comments		
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/26/2022 15:13	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	General Comments		
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Found Counter	13436	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Left Counter	13430	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Current Tap Position	7L	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Max Tap Position	4R	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/26/2022 18:08	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/26/2022 15:25	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	152	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	152	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	UG Pothead Condition Good?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	151743	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	151743	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	11L	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	455	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	LTC Operation Checked?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Min Tap Position	9L	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Current Tap Position	2L	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	All Connections OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Left Counter	101434	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Found Counter	101434	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Operations Since Last Insp	431	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AL	381	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AF	381	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Switching Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Unknown Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.5	amps
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Found Counter	82735	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Left Counter	82739	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Max Tap Position	4R	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Min Tap Position	9L	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Operations Since Last Insp	349	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Unknown Operations	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Unknown Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Switching Operations	1	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations This Read Vac	1	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations Counter AL	152	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations Counter AF	152	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Maintenance Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Operations Counter	11	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps C Ø	316.0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps B Ø	312.0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps A Ø	320.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	9 Month Operations	23	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps A Ø	0.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps B Ø	0.0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	9 Month Operations	1	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Found Counter	41015	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Left Counter	41015	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Current Tap Position	6L	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Max Tap Position	4L	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Min Tap Position	12L	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Operations Since Last Insp	357	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps C Ø	0.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Maintenance Operations	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AF	303	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AL	303	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations This Read Vac	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Switching Operations	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Unknown Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Unknown Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations This Read Vac	8	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AL	214	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AF	214	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Maintenance Operations	8	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Reading	1.4980	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	9 Month Operations	6	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	LTC Totalizer Reading	7190.40	kw
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Present	40	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Max	40	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Reading	.8860	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Present	40	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Max	45	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	LTC Totalizer Reading	12758.40	kw
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Unknown Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps A Ø	680	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps B Ø	690	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps C Ø	550	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps C Ø	200	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps B Ø	255	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps A Ø	235	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty C Ph V	7.72	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty B Ph V	8.58	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty A Ph V	7.72	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	9 Month Operations	12	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Maintenance Operations	11	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AF	208	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AL	208	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations This Read Vac	11	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Unknown Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	9 Month Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	9 Month Operations	12	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Amps A Ø	450.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Amps B Ø	513.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Amps C Ø	374.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Maintenance Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AF	120	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AL	120	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations This Read Vac	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Switching Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps A Ø	124.0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	9 Month Operations	1	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Maintenance Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushing Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Unknown Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Switching Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AL	275	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AF	275	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Maintenance Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations Ground	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations C Ø	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations B Ø	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations A Ø	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps C Ø	87.0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Amps B Ø	179.0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Vegetation	None	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	LTC000553	LTCControl	884-1	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Vegetation	None	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	All Connections OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps C Ø	145.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps B Ø	205.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps A Ø	168.0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Operations Since Last Insp	427	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	33	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	19	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Min Tap Position	7L	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Max Tap Position	4R	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Current Tap Position	2R	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Left Counter	28593	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Found Counter	28593	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BCH001471	Charger	550-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Operation Checked?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Unknown Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Regulator As Left Counter	132820	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	9 Month Operations	12	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty A Ph V	9.43	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty B Ph V	12.87	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Accumulated Fault Duty C Ph V	9.43	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Amps C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Reading	1.2630	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Max	37	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Maintenance Operations	7	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AF	226	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AL	226	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations This Read Vac	7	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Unknown Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Max	34	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Reading	7.6241	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Top Oil Temperature Present	16	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Top Oil Temperature Max	33	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Vegetation	None	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1086	Regulator	550-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Maintenance Operations	6	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AF	197	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AL	197	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations This Read Vac	6	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Maintenance Operations	10	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Operation Checked?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	All Connections OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Fault Operations Ground	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	LTC Totalizer Reading	7578.00	kw
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	LTC Totalizer Reading	7624.1	kw
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Unknown Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations This Read Vac	11	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AL	248	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AF	248	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Maintenance Operations	11	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Maintenance Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Operations Counter AF	220	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Operations Counter AL	223	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Operations This Read Vac	3	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Switching Operations	3	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Unknown Operations	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	9 Month Operations	10	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Amps A Ø	181.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Amps B Ø	164.0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	9 Month Operations	8	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Reading	1.6416	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Present	48	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations A Ø	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Max	65	°C
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	LTC Totalizer Reading	3939.84	kw
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	9 Month Operations	10	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Amps A Ø	77.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Amps B Ø	130.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Amps C Ø	77.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Present	20	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Max	35	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	LTC Totalizer Reading	13060.80	kw
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations Counter AL	200	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations This Read Vac	3	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Switching Operations	3	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Unknown Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X2 Winding Temp Present	17	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X2 Winding Temp Max	34	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X1 Winding Temp Present	17	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X1 Winding Temp Max	34	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Present	17	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	9 Month Operations	9	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Amps C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Amps C Ø	192.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Operation Checked?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	All Connections OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps C Ø	75	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps B Ø	65	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps A Ø	85	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty A Ph V	2.57	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	9 Month Operations	15	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Maintenance Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations Counter AF	197	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X3 Winding Temp Present	17	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X3 Winding Temp Max	34	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Present	35	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Max	45	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Reading	.9070	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0072	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Maintenance Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations Counter AF	178	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations Counter AL	180	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations This Read Vac	2	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Switching Operations	2	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Unknown Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushing Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	9 Month Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Maintenance Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AF	82	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AL	82	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations This Read Vac	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Unknown Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Foundation Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Grounds in Place?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps A Ø	0.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps B Ø	0.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps C Ø	0.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5.76	kw
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	107.50	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Maintenance Operations	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Operations Counter AF	173	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Operations Counter AL	173	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Operations This Read Vac	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Switching Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	All Connections OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Time Delay	30	Seconds
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	LTC Operation Checked?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	All Connections OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Grounds in Place?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations Counter AF	235	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations Counter AL	235	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Operations This Read Vac	10	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Unknown Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Switching Operations	2	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations This Read Vac	2	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AL	99831	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AF	99829	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0045	BreakerVacuum	428-0593	VCB Readings	Unknown Operations	0	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	LTC Operation Checked?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCControl	587-1	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	9 Month Operations	3	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	9 Month Operations	33	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Amps A Ø	1.0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Amps B Ø	1.0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Amps C Ø	2.0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Operations A Ø	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Operations B Ø	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Operations C Ø	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	BK001786	BreakerVacuum	550-0165	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps A Ø	362.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps B Ø	416.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps C Ø	394.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations This Read Vac	9	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AL	264	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AF	264	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Maintenance Operations	9	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps C Ø	270	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps B Ø	355	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps A Ø	350	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty C Ph V	6	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty B Ph V	12.87	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty A Ph V	12.01	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	9 Month Operations	13	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	9 Month Operations	9	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps A Ø	352.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps B Ø	420.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps C Ø	407.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Vegetation	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Found Counter	9702	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Left Counter	9702	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Current Tap Position	3L	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Min Tap Position	8L	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	12	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	31	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Operations Since Last Insp	307	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	9 Month Operations	8	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps A Ø	345	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps B Ø	420	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps C Ø	325	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Unknown Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Regulator As Left Counter	71775	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1117	Regulator	550-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000726	LTCControl	428-2	LTC Control Insp	All Connections OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000726	LTCControl	428-2	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000726	LTCControl	428-2	LTC Control Insp	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000726	LTCControl	428-2	LTC Control Insp	LTC Operation Checked?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	9 Month Operations	7	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000726	LTCControl	428-2	LTC Control Insp	LTC Output Voltage Level	125	VAC
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000726	LTCControl	428-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AF	125	VAC
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AL	125	VAC
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Maintenance Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations Counter AF	158	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations Counter AL	160	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations This Read Vac	2	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Switching Operations	2	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Unknown Operations	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Maintenance Operations	6	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AF	218	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AL	218	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations This Read Vac	6	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Unknown Operations	0	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Structure Patrol Inspection	PT/CT/CVVT Properly Grounded?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Maintenance Operations	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations Counter AF	180	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations Counter AL	180	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations This Read Vac	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Switching Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Operations Since Last Insp	331	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Min Tap Position	9L	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Max Tap Position	1L	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	9 Month Operations	10	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Left Counter	6973	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Vegetation	None	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Found Counter	105966	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Left Counter	105971	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Max Tap Position	4R	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Found Counter	6973	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Unknown Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations A Ø	1	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps A Phase V	6.55	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	9 Month Operations	23	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	9 Month Operations	23	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Maintenance Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AF	357	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AL	357	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations This Read Vac	2	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Switching Operations	2	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations B Ø	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty C Ph V	1	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty B Ph V	1.67	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty A Ph V	3.34	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Unknown Operations	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations Ground	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTC000299	LTCControl	428-1	LTC Control Insp	All Connections OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps A Ø	2.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	9 Month Operations	21	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Operations Counter AF	177	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Maintenance Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Kwh Reading	0	KwH
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	LTC Totalizer Reading	6443.8	kw
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	MegaVar Demand Meter Max	1.29	MegaVars
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps C Ø	2.0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps B Ø	2.0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Operations Since Last Insp	636	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Maintenance Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AF	76	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AL	78	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Unknown Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Switching Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Operations This Read Vac	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Operations Counter AL	177	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations This Read Vac	3	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Switching Operations	2	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Unknown Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC00665	LTCControl	662-1	LTC Control Insp	All Connections OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC00665	LTCControl	662-1	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Unknown Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Switching Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps B Ø	298.0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations This Read Vac	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AL	257	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AF	257	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Maintenance Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	chg 1st quarter
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	LTC Totalizer Reading	2788.80	kw
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	General Comments		
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AL	158	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Regulator As Left Counter	465943	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	General Comments	6	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps C Ø	228.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Ambient Temp	34	F
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AF	158	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Maintenance Operations	22	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps C Ø	145	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps B Ø	165	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps A Ø	185	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCCControl	428-1	LTC Control Insp	LTC Output Voltage Level	125	VAC
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCCControl	428-1	LTC Control Insp	LTC Operation Checked?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCCControl	428-1	LTC Control Insp	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Interrupts/Puffs Visual OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCCControl	428-1	LTC Control Insp	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps A Ø	305.0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations Ground	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations B Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	9 Month Operations	1	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps A Ø	144.0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps B Ø	135.0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps C Ø	114.0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Vegetation	None	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	9 Month Operations	2	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	9 Month Operations	1	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps A Ø	268.0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps B Ø	239.0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps C Ø	227.0	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Present	40	°C
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Vegetation	None	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps C Ø	160	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps B Ø	255	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps A Ø	170	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty C Ph V	.67	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty B Ph V	.67	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty A Ph V	.67	%
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	9 Month Operations	9	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Unknown Operations	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushing Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Switching Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations This Read Vac	22	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Follow-up Action Required?	n	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Foundation Condition	Good	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	General Comments		
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Grounds in Place?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/27/2022 5:47	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Reading	.5810	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	R1121	Regulator	550-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Switching Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Unknown Operations	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations A Ø	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations B Ø	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Operations Ground	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations This Read Vac	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AL	223	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AF	223	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Operations B Ø	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Operations A Ø	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Maintenance Operations	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	General Comments		
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps C Ø	12.0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps B Ø	62.0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps A Ø	26.0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations Ground	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Reading	.6850	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations C Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations B Ø	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations Ground	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Foundation Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Grounds in Place?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Maintenance Operations	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations Counter AF	156	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations A Ø	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations Counter AL	156	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations This Read Vac	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTC000665	LTCControl	662-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Switching Operations	0	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Unknown Operations	0	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/25/2022 14:37	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Present	27	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Max	37	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Present	27	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Max	40	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Present	27	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Oil Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	General Comments		
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Operation Checked?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Top Oil Temperature Max	37	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Top Oil Temperature Present	25	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Reading	6.4438	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Winding Temp Max	40	°C
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Winding Temp Present	27	°C
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100	
1/25/2022 7:27	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Max	39	°C
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	General Comments		
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	General Comments		
1/25/2022 13:38	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	LTC Totalizer Reading	6576.00	kw
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/25/2022 7:02	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/25/2022 13:59	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/25/2022 14:49	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Max	60	°C
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Maintenance Operations	12	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AF	465	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AL	465	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps A Ø	215.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations This Read Vac	13	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps B Ø	225.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	9 Month Operations	11	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations This Read Vac	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AL	218	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps C Ø	205.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations C Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AF	218	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Maintenance Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	LTC Totalizer Reading	3248.64	kw
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Max	35	°C
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations C Ø	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Amps A Ø	166.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Amps B Ø	156.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations C Ø	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Amps C Ø	194.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations A Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Switching Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Operations This Read Vac	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Operations Counter AL	177	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Operations Counter AF	177	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Maintenance Operations	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Unknown Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Operations Ground	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Operations C Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Reading	.3384	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Unknown Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Switching Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations This Read Vac	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AL	41	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AF	41	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Maintenance Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations C Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Maintenance Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AF	221	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AL	223	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations This Read Vac	2	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Switching Operations	2	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	All Connections OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations Ground	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Maintenance Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	9 Month Operations	1	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Switching Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Unknown Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Unknown Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Operations Counter AL	158	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Operations Counter AF	156	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Maintenance Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	All Connections OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Max Tap Position	10R	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Operations Since Last Insp	766	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Found Counter	146238	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Left Counter	146242	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Current Tap Position	5L	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Min Tap Position	12L	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Operations Since Last Insp	506	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps B Ø	25.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps C Ø	25.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps C Ø	120.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps B Ø	100.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps A Ø	100.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Switching Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AL	468	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AF	468	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Maintenance Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Switching Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations This Read Vac	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AL	176	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AF	176	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Found Counter	111636	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Left Counter	111636	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Unknown Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Switching Operations	2	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Operations This Read Vac	3	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Operations Since Last Insp	351	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Min Tap Position	9L	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Max Tap Position	2R	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Left Counter	105880	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Found Counter	105876	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Amps C Ø	64.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Amps B Ø	123.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Amps A Ø	125.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	9 Month Operations	25	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps A Ø	0.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Unknown Operations	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Switching Operations	2	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations This Read Vac	2	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations Counter AL	156	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations Counter AF	156	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Maintenance Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations C Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps B Ø	0.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps C Ø	0.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations C Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations B Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations A Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	9 Month Operations	5	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Maintenance Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations This Read Vac	8	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AL	259	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Switching Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AL	181	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AF	181	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Maintenance Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AF	259	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	9 Month Operations	11	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Maintenance Operations	7	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Operations C Ø	1	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Operations B Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Operations A Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Adjusted Amps C Phase V	.72	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001595	BreakerVacuum	710-0043	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Left Counter	594915	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Current Tap Position	11L	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Max Tap Position	7L	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Min Tap Position	16L	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Operations Since Last Insp	344	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	LTC Totalizer Reading	1562.88	kw
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Found Counter	33341	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Left Counter	33345	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Current Tap Position	4L	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Max Tap Position	10L	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Operations Since Last Insp	142	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	9 Month Operations	16	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK001611	BreakerVacuum	834-2114	VCB Readings	Unknown Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AF	352	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AL	352	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations This Read Vac	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Switching Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Unknown Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	9 Month Operations	16	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Unknown Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Unknown Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Switching Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations This Read Vac	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AL	159	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AF	159	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Maintenance Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations This Read Vac	10	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AL	90498	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AF	90498	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Maintenance Operations	9	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps C Ø	255.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps B Ø	255.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps A Ø	200.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Reading	.4884	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	General Comments	vented	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Found Counter	594915	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Reading	.1806	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Max	38	°C
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	All Connections OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000662	LTCControl	549-3	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Unknown Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Operations Since Last Insp	405	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Min Tap Position	11L	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Max Tap Position	1L	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Current Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Left Counter	23865	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Found Counter	23865	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations This Read Vac	7	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations Ground	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations C Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	sprayed corrosion	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Amps B Ø	120.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Amps C Ø	150.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	LTC Totalizer Reading	6595.20	kw
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1050	psi
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Max	40	°C
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Present	20	°C
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Maintenance Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Operations Counter AF	147	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Operations Counter AL	147	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	LTC Totalizer Reading	17936.64	kw
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Reading	.6900	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Present	10	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.4	amps
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps C Ø	0.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps B Ø	0.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps A Ø	0.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	9 Month Operations	6	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps A Ø	5.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	9 Month Operations	5	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	9 Month Operations	15	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	9 Month Operations	7	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Amps A Ø	125.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	General Comments	SPR RELAY BEEN REMOVED	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Volt Adjusted Amps C Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations A Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations B Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Reading	.9522	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Found Counter	71458	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Left Counter	71461	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Current Tap Position	6L	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Max Tap Position	1L	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Operations Since Last Insp	426	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	9 Month Operations	5	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps A Ø	10.0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps B Ø	10.0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps C Ø	10.0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Reading	.4580	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Max	40	°C
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Present	20	°C
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Switching Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001610	BreakerVacuum	863-0112	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Reading	.9090	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Present	25	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Max	55	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	LTC Totalizer Reading	13089.60	kw
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Maintenance Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AF	254	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AL	256	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations This Read Vac	2	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Switching Operations	2	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Unknown Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps A Ø	25.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	9 Month Operations	4	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	3312.00	kw
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Oil Temp Max	25	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Maintenance Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AF	45	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AL	45	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations This Read Vac	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Switching Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Unknown Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	9 Month Operations	4	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty A Ph V	.46	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps A Ø	5.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps B Ø	5.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps C Ø	5.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	9 Month Operations	8	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps A Ø	470.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps B Ø	475.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps C Ø	490.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AF	165	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Maintenance Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations Ground	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations C Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations B Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations A Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps C Ø	5.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps B Ø	5.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps C Ø	215.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps B Ø	240.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Amps A Ø	205.0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Present	35	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Max	55	°C
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations C Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations B Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations A Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Present	40	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Max	60	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Reading	1.2456	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Present	25	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Max	50	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	LTC Totalizer Reading	5155.20	kw
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Unknown Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Unknown Operations	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Oil Temp Max	25	°C
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Reading	.5370	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Switching Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations This Read Vac	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AL	165	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Unknown Operations	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	9 Month Operations	7	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps A Ø	120.0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps B Ø	120.0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps C Ø	130.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	9 Month Operations	15	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps A Ø	250.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps B Ø	250.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps C Ø	250.0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps B Phase V	4.81	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations B Ø	1	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	All Connections OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	LTC Totalizer Reading	16459.20	kw
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Max	80	°C
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps C Ø	160.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps A Ø	10.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps B Ø	10.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps C Ø	10.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations A Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations A Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations C Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations Ground	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Maintenance Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AF	2138	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AL	2138	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations This Read Vac	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Switching Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	9 Month Operations	5	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps A Ø	0.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps B Ø	0.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps C Ø	0.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Grounds in Place?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	LTC Totalizer Reading	3250.80	kw
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Max	40	°C
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Present	35	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Reading	1.1430	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Max	80	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Present	35	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Maintenance Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AF	397	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AL	397	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations This Read Vac	2	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Unknown Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Maintenance Operations	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AF	142	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AL	142	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Switching Operations	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Unknown Operations	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations C Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Present	40	*C
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Max	52	*C
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Maintenance Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AF	167	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AL	167	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations This Read Vac	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Switching Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Unknown Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	LTC Totalizer Reading	17139.60	kw
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B80460	BreakerVacuum	549-0150	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	9 Month Operations	13	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps A Ø	160.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps B Ø	125.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps C Ø	155.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	9 Month Operations	6	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps C Ø	395.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps B Ø	385.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps A Ø	360.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	9 Month Operations	5	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps A Ø	160.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps B Ø	160.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations This Read Vac	5	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AL	164	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	9 Month Operations	14	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps A Ø	0.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps B Ø	0.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps C Ø	0.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9770	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AF	164	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Maintenance Operations	4	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps B Ø	250.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps A Ø	250.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Switching Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations This Read Vac	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AL	260	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Operations Counter AF	260	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations This Read Vac	6	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AL	204	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AF	204	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Maintenance Operations	5	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Max	65	*C
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AF	251	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AL	251	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations This Read Vac	1	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Switching Operations	0	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Unknown Operations	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	9 Month Operations	18	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Unknown Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Switching Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations This Read Vac	2	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AL	214	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AF	214	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Maintenance Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	General Comments	time	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations Ground	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations C Ø	2	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations A Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps C Phase V	12.26	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps C Ø	200.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7541	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps B Ø	0.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps A Ø	0.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps C Ø	380.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps B Ø	450.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps A Ø	410.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	9 Month Operations	6	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	9 Month Operations	6	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Maintenance Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Current Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Switching Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AL	179	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AF	179	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Maintenance Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Maintenance Operations	8	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AF	237	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations Counter AL	237	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Operations This Read Vac	9	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	General Comments	time	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Maintenance Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Amps C Ø	95.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Amps B Ø	115.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Amps A Ø	90.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations C Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Maintenance Operations	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations Counter AF	186	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations Counter AL	186	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations This Read Vac	2	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Switching Operations	2	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Unknown Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	9 Month Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AL	240	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Switching Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Switching Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Operations Counter AL	200	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Operations Counter AF	200	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Maintenance Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Switching Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps A Ø	225.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	500.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	500.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	500.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	9 Month Operations	9	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	3	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	3	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Present	35	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001607	BreakerVacuum	863-0062	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Present	40	°C
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Max	65	°C
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Reading	.7804	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps C Ø	180.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps B Ø	230.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	9 Month Operations	6	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps A Ø	75.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps B Ø	50.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps C Ø	70.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps A Phase V	16.96	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps C Phase V	16.96	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations A Ø	1	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations C Ø	1	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AF	234	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AL	234	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations This Read Vac	2	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Max	40	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Present	20	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Amps A Ø	275.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Amps B Ø	279.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Amps C Ø	310.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps C Ø	0.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps B Ø	0.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps A Ø	0.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	9 Month Operations	5	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	9 Month Operations	11	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Min Tap Position	16L	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	9 Month Operations	3	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Current Tap Position	10L	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps A Ø	100.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps B Ø	100.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps C Ø	100.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Operations Counter AF	175	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Operations Counter AL	177	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Operations This Read Vac	2	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Switching Operations	2	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Unknown Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Found Counter	39815	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Left Counter	39815	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Current Tap Position	1L	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Max Tap Position	2R	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Max	30	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Present	20	°C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Min Tap Position	8L	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Operations Since Last Insp	748	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Found Counter	21628	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Left Counter	21628	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Current Tap Position	4L	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Min Tap Position	9L	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Operations Since Last Insp	444	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Switching Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AL	415	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AF	415	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Maintenance Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	9 Month Operations	5	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Present	20	°C
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Operations A Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Operations B Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Operations C Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BK001422	BreakerVacuum	710-0124	VCB Readings	Maintenance Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Ambient Temp	31	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AF	397	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AL	397	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations This Read Vac	3	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	9 Month Operations	7	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations Ground	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations C Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations A Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4886.40	kw
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Max	20	°C
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5090	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Max	20	°C
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Present	45	°C
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	LTC Totalizer Reading	11237.76	kw
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	General Comments	needs counter	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps C Ø	120.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps B Ø	120.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps A Ø	115.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations This Read Vac	11	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AL	285	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AF	285	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Maintenance Operations	10	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Leaks	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Regulator As Left Counter	30152	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Regulator As Left Counter	9325	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	29	*F
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Amps A Ø	415.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Switching Operations	2	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations This Read Vac	2	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations Counter AL	200	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations Counter AF	200	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Maintenance Operations	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Maintenance Operations	2	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations Ground	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations C Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations B Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations A Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps C Ø	98.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps B Ø	57.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps A Ø	54.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.1	amps
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Switching Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Operations This Read Vac	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Operations Counter AL	143	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Operations Counter AF	143	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Maintenance Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Current Tap Position	11L	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Operations Ground	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Amps C Ø	445.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	Amps B Ø	440.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps B Ø	40.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Max Tap Position	1R	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Current Tap Position	4L	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Left Counter	850	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Found Counter	850	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Left Counter	63194	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Found Counter	63194	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	9 Month Operations	1	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps A Ø	82.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps B Ø	87.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Amps C Ø	70.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Unknown Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Switching Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations This Read Vac	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AL	44	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AF	44	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Maintenance Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	9 Month Operations	1	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCCControl	710-3	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCCControl	710-3	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations Ground	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations C Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations B Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations A Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCCControl	710-3	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations A Ø	0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Overall Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK001812	BreakerVacuum	863-2	VCB Readings	9 Month Operations	1	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps A Ø	24.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps C Ø	17.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps B Ø	20.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps A Ø	17.0	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	9 Month Operations	4	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Operations Since Last Insp	541	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Min Tap Position	10L	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Current Tap Position	1L	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Operations Since Last Insp	20	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	9 Month Operations	10	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps C Ø	305.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps B Ø	260.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps A Ø	285.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	9 Month Operations	5	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations A Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations C Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Fault Operations Ground	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Maintenance Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	General Comments		
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Leaks	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Regulator As Left Counter	33293	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Min Tap Position	16L	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps C Ø	25.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps B Ø	41.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps A Ø	21.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	9 Month Operations	8	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps C Ø	0.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps B Ø	0.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps A Ø	0.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations A Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	9 Month Operations	1	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps A Ø	81.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps B Ø	116.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Amps C Ø	122.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/24/2022 14:53	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Maintenance Operations	7	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AF	257	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AL	257	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations This Read Vac	8	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps C Ø	45.0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	*F
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	All Connections OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BCH001482	Charger	863-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Min Tap Position	16L	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Max Tap Position	1L	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations C Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations B Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations A Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps C Ø	5.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps B Ø	5.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps A Ø	5.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	9 Month Operations	4	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	All Connections OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	BAT001551	Battery	863-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AF	175	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations Counter AL	175	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Leaks	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Regulator As Left Counter	25339	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Operations This Read Vac	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Switching Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000531	BreakerVacuum	834-2111	VCB Readings	Unknown Operations	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Max Tap Position	8L	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Current Tap Position	5L	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Left Counter	147591	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Found Counter	147591	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	General Comments		
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AL	259	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AF	259	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Maintenance Operations	6	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	9 Month Operations	10	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Follow-up Action Required?	n	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps A Ø	150.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps B Ø	200.0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps C Ø	200.0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations C Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations B Ø	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations A Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations B Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations C Ø	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations Ground	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Maintenance Operations	3	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AF	400	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AL	400	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations This Read Vac	4	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Switching Operations	1	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Unknown Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Unknown Operations	0	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Unknown Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Switching Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations This Read Vac	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AL	187	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AF	187	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Maintenance Operations	0	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	General Comments		
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations B Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations C Ø	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Operations Since Last Insp	599	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	LTC Totalizer Reading	4233.00	kw
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Oil Temp Max	45	*C
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/24/2022 9:50	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Oil Temp Present	25	*C
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Min Tap Position	10L	
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	33	*F
1/24/2022 13:10	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AF	240	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	9 Month Operations	4	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Maintenance Operations	0	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Reading	.7055	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	General Comments		
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
1/24/2022 14:39	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps C Ø	50.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps B Ø	50.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps A Ø	50.0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty B Ph V	1.1	%
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty A Ph V	1.1	%
1/24/2022 12:54	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations B Ø	0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations A Ø	0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps C Ø	21.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps B Ø	35.0	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCCControl	710-3	LTC Control Insp	All Connections OK?	y	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCCControl	710-3	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCCControl	710-3	LTC Control Insp	General Comments		
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps A Ø	43.0	
1/24/2022 11:39	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCCControl	710-3	LTC Control Insp	LTC Operation Checked?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	9 Month Operations	3	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 11:11	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations C Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps A Ø	97.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	9 Month Operations	36	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Left Counter	18383	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Maintenance Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AF	197	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AL	197	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AF	359	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	289	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AL	271	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8R	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps B Ø	160.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps C Ø	161.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AF	178	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AF	185	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	28	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	54	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Max	52	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Present	27	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	52	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	28	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty C Ph V	47.94	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations Ground	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations Counter AF	194	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations Counter AL	194	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Operations This Read SF6	4	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Switching Operations	4	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AL	185	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AF	271	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	39	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty B Ph V	55.32	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty A Ph V	59	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	27	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	9 Month Operations	36	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AL	178	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	54	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	17	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps B Ø	105.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Amps C Ø	104.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Fault Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Maintenance Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001697	BreakerSF6	CF-138KV TR 2	GCB Readings	Num Operations Last 9 Months	18	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	9 Month Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty A Ph V	15.98	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty B Ph V	13.52	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty C Ph V	11.06	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps A Ø	90.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps B Ø	78.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps C Ø	75.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations B Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps C Ø	109.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps B Ø	106.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps A Ø	100.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	9 Month Operations	39	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty A Ph V	38.11	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty B Ph V	38.72	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty C Ph V	36.26	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps A Ø	172.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations Ground	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	LTC Operation Checked?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty A Ph V	7.99	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps C Ø	120.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	552	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	552	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AL	359	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Unknown Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Switching Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations This Read SF6	64	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations Counter AL	121	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Operations Counter AF	121	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Num Operations Last 9 Months	64	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Maintenance Operations	64	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	General Comments	equip position name is 138KV TR1	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Follow-up Action Required?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Fault Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	VRR Time Delay	0	Seconds
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AF	395	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AL	395	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	9 Month Operations	6	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps C Ø	101.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps B Ø	103.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	BK001696	BreakerSF6	CF-138KV TR 1	GCB Readings	Amps A Ø	94.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations Ground	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	.85	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty B Ph V	8.6	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty C Ph V	7.99	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps A Ø	123.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps B Ø	120.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty A Ph V	38.72	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps C Ø	120.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Found Counter	18383	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty B Ph V	38.72	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	.85	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty C Ph V	35.65	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000898	LTCControl	CF-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	9 Month Operations	32	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty A Ph V	20.28	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty B Ph V	18.44	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty C Ph V	15.37	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps A Ø	21.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps A Ø	81.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	.85	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps B Ø	18.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps C Ø	72.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps B Ø	70.0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.5	VDC
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations This Read AM	6	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AL	375	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Switching Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AF	396	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AF	375	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Unknown Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Maintenance Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AL	396	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	9 Month Operations	7	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	28	*F
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps B Ø	500.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Operation Checked?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps A Ø	400.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	11.96	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	31.89	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	21.26	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	9 Months Operations	13	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations A Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Operations Since Last Insp	1160	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Min Tap Position	14L	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Max Tap Position	4L	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Current Tap Position	7L	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps A Ø	63.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps C Ø	68.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Left Counter	67987	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Found Counter	67984	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations Ground	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations C Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps B Ø	73.0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations Ground	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations C Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations B Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations A Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps C Ø	84.0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps B Ø	87.0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps A Ø	110.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps C Ø	300.0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps B Ø	280.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Switching Operations	6	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Unknown Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	9 Month Operations	31	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations This Read Vac	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Unknown Operations	0	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AL	294	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AF	294	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Vegetation	None	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Maintenance Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Maintenance Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	LTC000205	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Current Tap Position	4R	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations B Ø	0	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations A Ø	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Max Tap Position	16R	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Min Tap Position	8R	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Operations Since Last Insp	220	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps C Ø	220.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:39	Distribution	Campbellville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations C Ø	0	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations A Ø	0	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps C Ø	20.0	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps B Ø	20.0	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps A Ø	20.0	
1/20/2022 14:39	Distribution	Campbellville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations B Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations C Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations Ground	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Maintenance Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AF	99976	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AL	99976	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	LTC Totalizer Reading	2862.00	kw
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Max	35	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Present	10	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	General Comments		
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	General Comments		
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Found Counter	76475	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Left Counter	76482	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Reading	.1590	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Max	30	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Present	15	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AF	349	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Maintenance Operations	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	9 Month Operations	4	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	VCB Readings	Fault Operations A Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations B Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations C Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations This Read AM	2	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Switching Operations	2	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Unknown Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Unknown Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Switching Operations	3	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations This Read AM	3	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AL	99994	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AF	99994	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Maintenance Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations Ground	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Operation Checked?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	All Connections OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations This Read Vac	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations A Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AL	349	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps A Ø	220.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps B Ø	200.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps C Ø	160.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	All Connections OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	9 Months Operations	15	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF001326	PowerFuse	CF-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	need entry forms for Section 2 switchgear and breakers 12 KV bus tie sec 2, CF-1210, CF-1209, CF-1208, CF-1207, CF-1206, 12KV TR2,	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations This Read Vac	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AL	123	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AF	123	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Unknown Operations	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Reading	.9984	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Switching Operations	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Max	30	°C
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Switching Operations	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Vegetation	None	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps C Ø	400.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	9 Month Operations	1	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps A Ø	260.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	9 Months Operations	5	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	34.55	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	15.95	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	18.6	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps A Ø	21.0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	3.99	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	33.22	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps A Ø	240.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps B Ø	200.0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Vegetation	None	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Maintenance Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AF	271	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AL	271	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations This Read AM	5	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Switching Operations	5	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Unknown Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Time Delay	30	Seconds
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	LTC Totalizer Reading	2396.16	kw
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations A Ø	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations C Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	General Comments		
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps B Ø	40.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps C Ø	38.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Battery Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations Ground	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations C Ø	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Unknown Operations	0	
1/20/2022 13:47	Distribution	Battery Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Maintenance Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Switching Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations This Read Vac	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AL	99936	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AF	99936	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Maintenance Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Ambient Temp	20	*F
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	9 Months Operations	7	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	9.3	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	6.64	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	19.93	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations A Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations B Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations C Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations Ground	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Switching Operations	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations This Read Vac	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations A Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AL	219	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Operations Counter AF	219	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Maintenance Operations	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Regulator As Left Counter	103989	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations Ground	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations C Ø	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations B Ø	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Operations A Ø	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps C Ø	1000.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps B Ø	1000.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps A Ø	800.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps C Ø	27.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps B Ø	26.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps A Ø	53.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Unknown Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Switching Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps C Ø	299.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps B Ø	322.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps A Ø	381.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Present	0	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	9 Month Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	0	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	9 Month Operations	1	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	0	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AL	275	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AF	275	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Maintenance Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	TV Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	TV Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Oil Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Oil Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	HV Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	HV Winding Temp Max	0	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations C Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Switching Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations This Read Vac	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H1 Winding Temp Present	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	H1 Winding Temp Max	0	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	General Comments	Station inspection readings on cascade form don't match up to readings on transformer. Top Oil 16 C, WHS phase 1 16 C, WHS phase 2 1	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	TX000271	WithLTC	CF-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Unknown Operations	0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	9 Month Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Switching Operations	8	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations This Read AM	8	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AL	94	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AF	94	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Maintenance Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations C Ø	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations Ground	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations This Read Vac	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AL	336	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AF	336	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Maintenance Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations Ground	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations C Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations Ground	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations C Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations B Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations A Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushing Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations B Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations A Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps C Ø	100.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps B Ø	100.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps A Ø	70.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps A Ø	160.0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	38.54	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps B Ø	160.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps C Ø	160.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	*F
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	34.55	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	35.88	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	*C
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	9 Months Operations	3	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AL	53	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Operations Counter AF	53	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations A Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps C Ø	0.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps B Ø	0.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps A Ø	0.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Operations Since Last Insp	914	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Min Tap Position	11L	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Current Tap Position	4L	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Left Counter	42378	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Found Counter	42374	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	9 Month Operations	1	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	LTC Totalizer Reading	6343.20	kw
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Unknown Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Max	35	°C
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps C Ø	55.0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps B Ø	60.0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps A Ø	69.0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	9 Month Operations	1	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps A Ø	290.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Maintenance Operations	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations Counter AF	159	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps B Ø	280.0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps C Ø	290.0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations Counter AL	159	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Operations This Read Vac	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Switching Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Operations Since Last Insp	1227	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Min Tap Position	11L	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Unknown Operations	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC As Left Counter	2530	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC As Found Counter	2530	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Max Tap Position	1R	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Left Counter	82205	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	General Comments		
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	General Comments		Temp gauge cover needs replacing-hard to see through
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Found Counter	82201	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	LTC Totalizer Reading	2146.88	kw
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Max	20	°C
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Present	7	°C
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps A Ø	54.0	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations A Ø	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	9 Month Operations	2	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	72	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps A Ø	143.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps B Ø	118.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps C Ø	127.0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6R	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LTCM000117	LTCMechanism	CF-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations A Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations C Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BCH001153	Charger	472-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Unknown Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Switching Operations	0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	9 Month Operations	1	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Switching Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations This Read Vac	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations A Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations C Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AL	219	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AF	219	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations This Read Vac	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Unknown Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Unknown Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Switching Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations This Read Vac	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations Counter AL	179	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations Counter AF	179	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Maintenance Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Maintenance Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations C Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations A Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Maintenance Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations Counter AF	164	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations Counter AL	164	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations This Read Vac	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Switching Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Unknown Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations C Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations B Ø	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Maintenance Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	General Comments		
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Reading	.6709	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4905.60	kw
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Time Delay	30	Seconds
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Operations Counter	119	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Unknown Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps C Ø	132.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps B Ø	137.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps A Ø	98.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AF	99785	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Switching Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Unknown Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AL	99785	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations This Read AM	3	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Switching Operations	3	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Unknown Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5110	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	All Connections OK?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	Follow-up Action Required?	n	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	General Comments		
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Operation Checked?	y	
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Output Voltage Level	115.1	VAC
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AF	115.0	VAC
1/20/2022 13:47	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AL	115.0	VAC
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	9 Month Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations Ground	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations C Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	262	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Left Counter	25601	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Found Counter	25601	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Regulator As Left Counter	126191	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Positive DC Ground	7.9	VDC
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Negative DC Ground	7.9	VDC
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	9 Month Operations	6	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps C Ø	26.0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps B Ø	37.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Unknown Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Switching Operations	1	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Amps A Ø	4.0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	9 Month Operations	10	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations This Read Vac	1	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations Counter AL	159	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations Counter AF	159	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Maintenance Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTC000592	LTCControl	472-1	LTC Control Insp	All Connections OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations C Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations B Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Operations A Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps C Ø	77.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps B Ø	99.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps A Ø	116.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Operations Since Last Insp	244	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Min Tap Position	7L	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Max Tap Position	10R	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Current Tap Position	2L	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Left Counter	122481	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Reading	.4230	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Max	40	*C
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Found Counter	122473	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	General Comments		
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Present	30	*C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	20	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Maintenance Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Operations A Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Vegetation	None	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	LTC Totalizer Reading	7614.00	kw
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Max	45	*C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Present	20	*C
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations A Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations B Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations C Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations Ground	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Maintenance Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AF	176	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations Counter AL	176	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations This Read Vac	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Max	42	°C
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Present	35	°C
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	9 Month Operations	2	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps C Ø	79.0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps B Ø	67.0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps A Ø	104.0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	9 Month Operations	23	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps A Ø	98.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps B Ø	100.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps C Ø	95.0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations A Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Operations This Read Vac	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Switching Operations	0	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Operation Checked?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	General Comments		
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	Follow-up Action Required?	n	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	9 Month Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	General Comments	Both transfer switches on top bus needs wildlife protection disks	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Reading	.3524	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps A Ø	1165.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps B Ø	168.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps C Ø	174.0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	9 Months Operations	8	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/20/2022 12:03	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Regulator As Left Counter	109524	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	General Comments		
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Maintenance Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations Counter AF	370	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations Counter AL	370	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Operations This Read Vac	6	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations Counter AL	167	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations Counter AF	167	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Switching Operations	6	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	General Comments		
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Maintenance Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations Ground	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations C Ø	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations B Ø	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Unknown Operations	0	
1/20/2022 14:39	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Tank Paint Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	General Comments	X1 Winding temp gage glass needs replaced 6"	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Unknown Operations	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Adequate	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Unknown Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Switching Operations	0	
1/20/2022 13:39	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations This Read Vac	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations A Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations B Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations C Ø	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Fault Operations Ground	0	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Readings	Follow-up Action Required?	n	
1/20/2022 10:23	Distribution	Greensburg Quarterly Inspection	K0100	BreakerVacuum	783-2214	VCB Patrol Inspection	Foundation Condition	Good	
1/28/2022 13:24	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Switching Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations This Read AM	1	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AL	212	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AF	212	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AF	265	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Found Counter	68082	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Left Counter	68082	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Unknown Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Switching Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations This Read Vac	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AL	396	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AF	396	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Amps C Ø	169.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Amps B Ø	133.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Amps A Ø	163.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	9 Month Operations	2	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	9 Month Operations	9	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Operations Since Last Insp	225	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Maintenance Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Maintenance Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AF	677	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AL	679	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Switching Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations This Read AM	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AL	59	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AF	59	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AL	811	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AF	809	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Grounds in Place?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	9 Month Operations	25	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps A Ø	226.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps B Ø	243.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps C Ø	276.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	295.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	296.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	313.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AL	267	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Operations Counter AL	172	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Operations Counter AF	170	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps C Ø	231.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps B Ø	221.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps A Ø	210.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001805	BreakerVacuum	463-0056	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	402	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	402	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Regulator As Left Counter	99614	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Switching Operations	2	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Unknown Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AL	247	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AF	245	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Maintenance Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps C Ø	60.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps B Ø	44.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Regulator As Left Counter	88007	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AL	648	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AF	646	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Maintenance Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps C Ø	158.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps B Ø	166.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps A Ø	156.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	9 Month Operations	34	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps C Ø	79.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps B Ø	92.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps A Ø	88.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	9 Month Operations	24	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	165	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	163	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	General Comments	water company has fence near the sub fence	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps C Ø	83.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Maintenance Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AF	277	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AL	279	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Unknown Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations Ground	0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Structure Patrol Oil Level OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	9 Months Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Vegetation	None	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	9 Month Operations	30	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps A Ø	85.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps B Ø	91.0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations B Ø	0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations C Ø	0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations Ground	0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	General Comments		Tornado Switching and ops
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Maintenance Operations	0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AF	248	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AL	248	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations This Read Vac	4	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF001291	PowerFuse	AS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Operations Counter	1428	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AF	123	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AL	123	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations This Read AM	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Switching Operations	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	General Comments		
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	9 Month Operations	5	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps A Ø	51.0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps B Ø	62.0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Amps C Ø	54.0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps A Phase V	4.43	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps B Phase V	4.43	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps C Phase V	4.43	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Broom on Site?	y	If Bkr is Closed
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Maintenance Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AF	504	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AL	506	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations This Read Vac	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Switching Operations	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Unknown Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	9 Month Operations	4	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps A Ø	117.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps B Ø	103.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps C Ø	79.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	9 Month Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations A Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations B Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations C Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Vegetation	None	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AL	158	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations This Read Vac	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Switching Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Left Counter	16357	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	20	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	25	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	18	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	101	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps A Ø	470	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps B Ø	449	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps C Ø	429	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	9 Months Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps A Ø	472.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps B Ø	528.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps C Ø	462.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations A Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AF	158	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations C Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations Ground	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Operations Since Last Insp	325	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Current Tap Position	4L	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Left Counter	73550	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Found Counter	73550	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Maintenance Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Amps C Ø	776.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Amps B Ø	718.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Amps A Ø	727.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	9 Month Operations	6	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AF	523	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Maintenance Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Unknown Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Switching Operations	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations This Read Vac	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AL	525	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	98	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	98	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Switching Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Operations This Read Vac	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Operations Counter AL	161	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BK001342	BreakerVacuum	463-2	VCB Readings	Operations Counter AF	161	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations Ground	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations C Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations B Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations A Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps C Ø	110.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps B Ø	74.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps A Ø	93.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	9 Month Operations	4	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	9 Month Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps A Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps B Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Found Counter	16357	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps C Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCCControl	AS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCCControl	AS-TRANS 4	LTC Control Insp	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCCControl	AS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations This Read Vac	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations Counter AL	333	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Operations Counter AF	333	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps C Ø	375.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps B Ø	350.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Amps A Ø	350.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	9 Month Operations	1	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Operations Counter	1866	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	500.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	600.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	500.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	LTC Totalizer Reading	20256.00	kw
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Unknown Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Switching Operations	9	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations This Read Vac	9	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations Counter AL	362	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations Counter AF	362	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CVVT Visible Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps C Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps B Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps A Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	9 Month Operations	10	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CVVT Properly Grounded?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Readings	Switching Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001522	BreakerVacuum	AS-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	General Comments	nitrogen bottle needs refilled	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Max	40	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load X2 Max	60	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load Y2 Max	60	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Vegetation	None	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Present	30	°C
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Max	40	°C
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	General Comments	Display on meter not working	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Follow-up Action Required?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	388	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	388	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Present	40	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	7	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	7	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Max	45	°C
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Reading	.9790	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	9 Months Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty B Ph AM	5.32	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps A Ø	238	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps B Ø	217	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps C Ø	224	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Present	40	°C
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Max	45	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	LTC Totalizer Reading	23496.00	kw
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	LTC Operation Checked?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	All Connections OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AF	367	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AL	367	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations This Read AM	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Switching Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty B Ph V	9.43	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Operation Checked?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	9 Month Operations	27	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps A Ø	104.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps B Ø	117.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Amps C Ø	127.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	LTC Operation Checked?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	All Connections OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps A Ø	184.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps B Ø	178.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps C Ø	181.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations B Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations C Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Fault Operations Ground	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Reading	.6890	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Present	42	°C
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	LTC Totalizer Reading	6614.40	kw
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations A Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	All Connections OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Switching Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps A Ø	55.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps B Ø	53.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps C Ø	50.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps C Ø	98	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps B Ø	120	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps A Ø	117	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	1.33	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	1.33	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	9 Months Operations	1	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	9 Month Operations	4	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Present	40	°C
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Max	60	°C
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Reading	.8400	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations This Read Vac	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AF	641	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AL	641	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations This Read Vac	2	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Switching Operations	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AL	253	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AF	253	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AF	189	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AL	189	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps C Ø	133	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps B Ø	188	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations This Read AM	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps A Ø	155	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty C Ph V	7.95	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AF	255	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AL	255	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations This Read Vac	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Switching Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	245	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	245	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Switching Operations	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Vegetation	None	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6980	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Amps C Ø	36.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Present	60	°C
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	CX0120	RecloserElectronic	826-2227	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	837.60	kw
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Maintenance Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Present	45	°C
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty A Ph V	13.85	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	9 Month Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations B Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Maintenance Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AF	351	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations Counter AL	353	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Operations This Read Vac	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Switching Operations	2	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Unknown Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AF	600	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AL	602	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations This Read Vac	2	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	9 Month Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps A Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps B Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps C Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Switching Operations	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps C Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps B Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Amps A Ø	0.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	9 Month Operations	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	9 Month Operations	4	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps A Ø	160.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps B Ø	221.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps C Ø	155.0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations A Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations B Ø	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations Ground	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Maintenance Operations	0	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AF	508	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AL	510	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations This Read Vac	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Switching Operations	2	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Unknown Operations	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations Ground	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations C Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations B Ø	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Unknown Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AL	72	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations This Read Vac	4	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Switching Operations	4	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Operations Counter	211	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	General Comments		
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	General Comments		
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Unknown Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Switching Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations This Read Vac	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations Counter AL	339	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Operations Counter AF	339	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001518	BreakerVacuum	AS-1419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations A Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps A Ø	120	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	9 Months Operations	1	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	9 Month Operations	13	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2300	psi
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps C Ø	240.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps B Ø	240.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Amps A Ø	210.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	40	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Max	55	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Present	35	°C
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	9 Month Operations	5	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	General Comments		
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Max	55	°C
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Present	50	°C
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Operations Since Last Insp	696	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Min Tap Position	13L	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Found Counter	20283	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Left Counter	20285	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Current Tap Position	6L	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Max Tap Position	1R	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Switching Operations	2	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps C Ø	172.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps B Ø	174.0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps A Ø	145.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations This Read Vac	2	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations Counter AL	346	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Operations Counter AF	346	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	60	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	40	°C
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations B Ø	1	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Present	35	°C
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001517	BreakerVacuum	AS-1416	VCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps C Ø	103	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps B Ø	117	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Found Counter	76373	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	General Comments		
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Found Counter	59284	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Left Counter	59284	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	6	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	141	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Switching Operations	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Unknown Operations	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	251.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	262.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	8	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Regulator As Left Counter	88007	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	9 Month Operations	23	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	9 Month Operations	5	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps A Ø	73.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps B Ø	74.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps C Ø	76.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations A Ø	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations B Ø	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations C Ø	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations Ground	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Follow-up Action Required?	n	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Foundation Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	252.0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Operations Since Last Insp	357	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Min Tap Position	9L	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	B0400	LTCMechanism	463-2	LTC Counter Readings	LTC As Left Counter	76373	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Maintenance Operations	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AF	304	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AL	304	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations This Read Vac	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Present	47	°C
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Max	65	°C
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	LTC Totalizer Reading	7507.20	kw
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations B Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations C Ø	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations Ground	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Follow-up Action Required?	n	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	General Comments		
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Maintenance Operations	0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	All Connections OK?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	Follow-up Action Required?	n	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AF	72	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	7	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps B Ø	20.0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	206	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	General Comments		
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	General Comments		
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	LTC Operation Checked?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	General Comments		
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/19/2022 10:32	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	General Comments		
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	149	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/19/2022 9:13	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations A Ø	0	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Reading	1.5640	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushing Condition	Good	
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 11:54	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
1/20/2022 11:07	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	9 Month Operations	4	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps C Ø	5.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps B Ø	5.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps A Ø	5.0	
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 8:07	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations Counter AL	194	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps A Ø	0.0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps B Ø	0.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps C Ø	0.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations C Ø	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations Ground	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Vegetation	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations This Read Vac	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Switching Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Unknown Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Maintenance Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations Counter AF	194	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Switching Operations	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps C Ø	63.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps B Ø	65.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps A Ø	64.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	9 Month Operations	2	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AL	1167	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AF	1167	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Unknown Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Switching Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations This Read AM	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AL	1483	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Operations Counter AF	1483	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Maintenance Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	General Comments	Wooden farm fence is close and around most of the sub	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations Ground	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations C Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations B Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AF	829	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AL	829	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AL	129	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AF	129	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Leaks	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations Ground	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations C Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations B Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Min Tap Position	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Max Tap Position	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC As Left Counter	56913	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Counter Readings	LTC As Found Counter	56913	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	LTCMechanism	P-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	9 Month Operations	3	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty A Ph V	5	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty B Ph V	11.67	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty C Ph V	13.33	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps A Ø	78.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps B Ø	93.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps C Ø	59.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations B Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations C Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Oil Temp Present	35	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	WithLTC Trn Dynamic Health	445.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	X2 Winding Temp Max	80	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Ambient Temp	24	°F
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	General Comments	DNO	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Maintenance Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AF	1342	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AL	1342	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Unknown Operations	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Switching Operations	1	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations This Read Vac	1	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AL	38	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Operations Counter AF	38	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Maintenance Operations	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations This Read AM	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Switching Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Unknown Operations	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	General Comments	Needs Nitro	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	WithLTC	P-TRANS 4A	LTC Transformer Readings	Oil Temp Max	120	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	PT Free of Leaks?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002280	PT	WH-12KV TR 2 POT	PT Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PF001301	PowerFuse	WH-12KV TR 3 POTS	Disconnect Powerfuse Inspection	General Comments	ok	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AF	5492	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Vegetation	None	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 2 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Leaks	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Number of Ops last 9 Months	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AF	721	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000290	PowerFuse	P-STA SER 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000290	PowerFuse	P-STA SER 1	Disconnect Powerfuse Inspection	General Comments	OK	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AL	721	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations This Read Oil	3	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Switching Operations	3	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AL	581	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AF	581	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps C Ø	153.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps B Ø	142.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps A Ø	170.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty C Ph V	.29	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty B Ph V	1.47	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty A Ph V	1.47	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTC000091	LTCControl	P-TRANS 4A	LTC Control Insp	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTC000091	LTCControl	P-TRANS 4A	LTC Control Insp	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTC000091	LTCControl	P-TRANS 4A	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	9 Month Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty A Ph V	6.19	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty B Ph V	6.78	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty C Ph V	5.3	%
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Switching Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	9 Month Operations	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps A Ø	5.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AL	194	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AF	194	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps B Ø	5.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps C Ø	5.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AL	187	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations This Read Vac	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AF	1313	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Switching Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AL	5492	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AF	112	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AL	112	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps B Ø	0.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000294	PowerFuse	P-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000294	PowerFuse	P-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps A Ø	118.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps B Ø	129.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps C Ø	131.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PF001302	PowerFuse	WH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AF	187	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Operations Since Last Insp	578	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Max Tap Position	2R	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Left Counter	115536	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Found Counter	115536	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AL	1492	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations Counter AF	95	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations Counter AL	95	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AL	1313	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AF	1492	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Number of Ops last 9 Months	2	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Maintenance Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps C Ø	93.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations Counter AF	41	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations Counter AL	41	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Switching Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000121	LTCMechanism	830-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC As Found Counter	50612	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC As Left Counter	50612	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	104	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations A Ø	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Operations B Ø	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	9 Month Operations	2	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps A Ø	321.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps B Ø	322.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps C Ø	320.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	9 Months Operations	21	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	4.82	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps A Ø	60.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Readings	Amps B Ø	65.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Number of Ops last 9 Months	2	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AF	3255	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AL	3255	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	PT Free of Leaks?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	PT002279	PT	WH-12KV TR 3 POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps B Ø	0.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	9 Month Operations	19	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	9 Month Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	9 Months Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps A Ø	290.0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps B Ø	288.0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps C Ø	295.0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000285	WithLTC	830-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	General Comments	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Ambient Temperature	37	*F
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	SF6 Pressure	5	psi
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	9 Month Operations	3	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps A Ø	260.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations A Ø	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations B Ø	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations C Ø	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations Ground	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	General Comments	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Maintenance Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Present	20	°C
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Max	45	°C
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps B Ø	150.0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps C Ø	195.0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AL	1063	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AL	1085	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AF	1085	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Number of Ops last 9 Months	11	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AL	1343	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AF	1343	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Number of Ops last 9 Months	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank 1	chg 1st quarter
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	SF6 Pressure	5	psi
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001886	BreakerSF6	830-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Number of Ops last 9 Months	2	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AF	1993	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AL	1993	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations This Read Vac	1	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Switching Operations	1	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Unknown Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Switching Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001154	PowerFuse	P-1387 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001154	PowerFuse	P-1387 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001155	PowerFuse	P-1391 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001155	PowerFuse	P-1391 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps C Ø	40.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps B Ø	40.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps A Ø	40.0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	27	°F
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001885	BreakerSF6	830-618	GCB Patrol Inspection	Ambient Temperature	37	*F
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Operations Since Last Insp	2836	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Min Tap Position	3	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Max Tap Position	8	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC Current Tap Position	6	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC As Left Counter	36863	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC As Found Counter	36863	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Found Counter	32381	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Left Counter	32381	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Current Tap Position	4L	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1R	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Min Tap Position	7L	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	320	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps A Ø	90.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps B Ø	90.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps C Ø	90.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Fault Operations	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	24	*F
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AL	1199	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AF	1199	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	General Comments	Unable to read vc. Counter needs to be replaced	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Follow-up Action Required?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AF	849	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AL	849	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	9 Month Operations	1	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AF	194	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AL	194	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations C Ø	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations Ground	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Maintenance Operations	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AF	177	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AL	177	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations This Read Vac	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Switching Operations	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Unknown Operations	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LTC000182	LTCControl	WH-TRANS 3	LTC Control Insp	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LTC000182	LTCControl	WH-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LTC000182	LTCControl	WH-TRANS 3	LTC Control Insp	All Connections OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AF	1178	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Number of Ops last 9 Months	31	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Maintenance Operations	17	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AL	122	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AF	122	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Ambient Temperature	37	*F
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	General Comments	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	SF6 Pressure	5	psi
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001965	BreakerSF6	805-618	GCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	135.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AF	843	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AL	843	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	All Connections OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Overall Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AF	6240	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AL	6240	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps A Ø	375.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps B Ø	405.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Ambient Temperature	37	°F
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Present	35	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Max	50	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Vegetation	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0430	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Maintenance Operations	8	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations Counter AF	99947	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations Counter AL	99947	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Operations This Read Vac	9	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Switching Operations	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Unknown Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	9 Month Operations	11	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	9 Month Operations	2	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps A Ø	52.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps B Ø	52.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps C Ø	52.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Left Counter	240256	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Current Tap Position	4L	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Max Tap Position	1R	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Min Tap Position	11L	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Operations Since Last Insp	398	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Unknown Operations	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Switching Operations	1	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations This Read Vac	1	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AL	180	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AF	180	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Maintenance Operations	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations Ground	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations C Ø	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations B Ø	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations A Ø	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps C Ø	126.0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps B Ø	120.0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps A Ø	133.0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	9 Month Operations	2	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Number of Ops last 9 Months	20	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AF	1505	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AL	1505	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AF	3858	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AL	3858	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps A Ø	40.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps B Ø	40.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps C Ø	40.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	60	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	60	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	60	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	40	°C
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	15	°C
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank Leaks	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps A Ø	360.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps B Ø	420.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps C Ø	400.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps B Ø	75.0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps C Ø	77.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Number of Ops last 9 Months	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AF	2078	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AL	2078	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 2 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0041	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	General Comments	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	SF6 Pressure	5	psi
1/18/2022 13:38	Distribution	Loudon Avenue Storage Lot Quarterly Inspection	BK001966	BreakerSF6	805-628	GCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps C Ø	378.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Fault Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Number of Ops last 9 Months	4	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations Counter AF	1170	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations Counter AL	1170	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Operations This Read Oil	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Switching Operations	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AF	1716	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AL	1716	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations B Ø	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations C Ø	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations Ground	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Maintenance Operations	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AF	172	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AL	172	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	LTC As Found Counter	240252	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BAT000021	Battery	P-Battery Bank Sec 1 Swgr	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AF	1636	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AL	1636	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AL	994	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AF	994	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Number of Ops last 9 Months	2	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Maintenance Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AL	19	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AF	19	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Maintenance Operations	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AL	915	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AF	915	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Number of Ops last 9 Months	3	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Maintenance Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	9 Month Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0984	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCCControl	660-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AL	131	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AF	131	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Number of Ops last 9 Months	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps C Ø	98.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps B Ø	95.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps A Ø	100.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Ground Lights	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	All Connections OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Operation Checked?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AL	747	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AF	747	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations B Ø	0	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Structuring Horns Good Condition?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AL	1943	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AF	1943	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Fault Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps B Ø	0.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	*C
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	*C
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	9 Month Operations	2	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AL	1143	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AF	1143	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Maintenance Operations	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Number of Ops last 9 Months	3	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AF	1197	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AL	1197	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 2 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Reading	.6912	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps A Ø	320.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps B Ø	400.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps C Ø	360.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Fault Operations	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Maintenance Operations	0	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Number of Ops last 9 Months	4	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AF	1185	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AL	1185	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations This Read Oil	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Switching Operations	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	General Comments		
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	LTC Totalizer Reading	2211.84	kw
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Max	55	°C
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Present	40	°C
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 10:11	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	9 Month Operations	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	206.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 2 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	General Comments		
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	LTC Totalizer Reading	9004.80	kw
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Max	45	°C
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Reading	.9380	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AL	677	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AF	677	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	9 Month Operations	4	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Vegetation	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps C Ø	10.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps B Ø	10.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps A Ø	10.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps C Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Amps B Ø	0.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	YD000870	Yard	932-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Number of Ops last 9 Months	30	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AF	1846	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AL	1846	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations This Read Oil	15	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	0949	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Pressure OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations This Read Oil	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AL	1283	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AF	1283	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Number of Ops last 9 Months	16	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Maintenance Operations	15	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps C Ø	0.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001283	PowerFuse	P-1392 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AF	159	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations B Ø	0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001283	PowerFuse	P-1392 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001284	PowerFuse	P-14KV GEN 13 AUX POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001284	PowerFuse	P-14KV GEN 13 AUX POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Operations Since Last Insp	425	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps C Ø	104.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps B Ø	104.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps A Ø	105.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Min Tap Position	16L	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Max Tap Position	4L	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Current Tap Position	11L	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Left Counter	181083	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Found Counter	181080	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Reading	.6590	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	General Comments	OK	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	LTC Totalizer Reading	6326.40	kw
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AL	159	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps B Ø	325.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps A Ø	325.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	9 Month Operations	2	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Pressure OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps A Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps B Ø	0.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs Nitro	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Number of Ops last 9 Months	16	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AF	1257	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AL	1257	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Switching Operations	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	General Comments		
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	9 Month Operations	3	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Number of Ops last 9 Months	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AF	646	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AL	646	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations This Read Oil	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Fault Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Unknown Operations	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Switching Operations	1	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations This Read Vac	1	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AL	225	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AF	225	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	9 Month Operations	3	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps A Ø	14.0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Maintenance Operations	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Grounds in Place?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps B Ø	13.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps C Ø	13.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations Ground	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps C Ø	322.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Follow-up Action Required?	n	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Maintenance Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AF	99964	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AL	99964	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations This Read Vac	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Switching Operations	1	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Unknown Operations	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Foundation Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations Ground	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations C Ø	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations B Ø	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations A Ø	0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushing Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps C Ø	10.0	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps B Ø	10.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Found Counter	18437	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Left Counter	18437	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	721	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Unknown Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Switching Operations	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations This Read Vac	0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations Counter AL	141	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Operations Counter AF	141	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	General Comments		
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/18/2022 12:59	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	LTC Operation Checked?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	LTCC000287	LTCControl	404-1	LTC Control Insp	All Connections OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	W0242	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps C Ø	223.0	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/18/2022 13:13	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps B Ø	223.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps A Ø	223.0	
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 14:30	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	9 Month Operations	1	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	9 Month Operations	20	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Vegetation	None	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	General Comments		
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/18/2022 9:03	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps A Ø	10.0	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:06	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Leaks	None	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC As Found Counter	77991	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC As Left Counter	78002	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Current Tap Position	1R	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Max Tap Position	5R	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Min Tap Position	3L	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Operations Since Last Insp	165	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Current Tap Position	2R	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Vegetation	None	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	260	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	General Comments	ok	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	205	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	265	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	General Comments	ok	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	General Comments	ok	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Min Tap Position	5L	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Regulator As Left Counter	61921	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	General Comments	Right gate needs attention.	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	LTC Totalizer Reading	12579.84	kw
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Max	70	*C
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Vegetation	None	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations A Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations B Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations C Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations Ground	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Maintenance Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AF	235	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AL	235	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations This Read Vac	3	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Switching Operations	3	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps C Ø	260	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Unknown Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps B Ø	205	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps A Ø	265	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty C Ph V	7.48	%
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty B Ph V	6.48	%
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty A Ph V	2.49	%
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	9 Month Operations	9	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	General Comments	ok	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Vegetation	None	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Totalizer Meter Reading	.4296	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Oil Temp Max	35	°C
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	LTC Totalizer Reading	4124.16	kw
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	General Comments	Bus could use additional wildlife protection.	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	General Comments	ok	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	General Comments	ok	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.5	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Operations Counter	41	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Reading	.8736	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Max	70	°C
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Present	40	°C
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	53	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	53	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	General Comments	ok	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Vegetation	None	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	26	*F
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	9 Month Operations	2	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	9 Month Operations	2	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty A Ph V	1.99	%
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty B Ph V	1.99	%
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty C Ph V	1.99	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps A Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps B Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Found Counter	276583	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Left Counter	276583	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Current Tap Position	4L	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Unknown Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Switching Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations This Read Vac	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations Counter AL	201	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations Ground	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations C Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations B Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations A Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Regulator As Left Counter	59459	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	General Comments	ok	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Found Counter	90560	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Left Counter	90560	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Max Tap Position	4R	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Operations Since Last Insp	298	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	R1369	Regulator	635-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps C Ø	0.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps B Ø	0.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps A Ø	0.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations Ground	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations C Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations B Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations A Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps C Ø	125.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps B Ø	120.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps A Ø	130.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	9 Month Operations	2	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.0	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	200	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	All Connections OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Operation Checked?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations Counter AF	201	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Maintenance Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations Ground	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations C Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations B Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations A Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps C Ø	165.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps B Ø	155.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps A Ø	175.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	9 Month Operations	2	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.6	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Operations Counter	294	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Unknown Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Switching Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations This Read Vac	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations Counter AL	175	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations Counter AF	175	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Maintenance Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Operations Since Last Insp	362	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	9 Month Operations	13	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations Ground	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations C Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations B Ø	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Operations A Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps C Ø	550.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps B Ø	550.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Amps A Ø	555.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	9 Month Operations	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Unknown Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Ambient Temp	26	*F
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	General Comments		
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Unknown Operations	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Switching Operations	1	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations This Read Vac	1	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AL	211	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AF	211	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Maintenance Operations	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	General Comments	ok	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	General Comments	1 switching op to repace high side insulator.	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations Ground	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations C Ø	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations B Ø	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations A Ø	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Vegetation	None	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps C Ø	95.0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps B Ø	94.0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps A Ø	102.0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Unknown Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Switching Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations This Read Vac	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations Counter AL	141	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Operations Counter AF	141	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	Maintenance Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001604	BreakerVacuum	807-1	VCB Readings	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	General Comments	ok	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Vegetation	None	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/17/2022 12:40	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/17/2022 12:40	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	All Connections OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	General Comments	ok	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	LTC Operation Checked?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/17/2022 12:40	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Time Delay	40	Seconds
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Unknown Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Switching Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations This Read Vac	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations Counter AL	173	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations Counter AF	173	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Maintenance Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	General Comments		
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Switching Operations	4	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations This Read Vac	4	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AL	156	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AF	156	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Maintenance Operations	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	General Comments	ok	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	General Comments	1 switching op to replace high side insulator. 3 switching to replace A&B phase line side disconnects.	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations Ground	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations C Ø	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations B Ø	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations A Ø	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps C Ø	20.0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps B Ø	15.0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps A Ø	25.0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	9 Month Operations	4	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	°F
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	General Comments	ok	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	General Comments	ok	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Reading	.421	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Max	45	°C
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Winding Temp Present	20	°C
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	General Comments	Could use a new spare fuse barrel for xfmr. Need additional wildlife protection in bus.	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	348.30	kw
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	General Comments	ok	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Unknown Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Operation Checked?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	All Connections OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations This Read Vac	0	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Unknown Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Switching Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations This Read Vac	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Switching Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations This Read Vac	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AL	249	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AF	249	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	General Comments	Fiberglass is started to be exposed on xfmr fuse barrel. Bus needs wildlife protection.	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	1.1610	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Unknown Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Switching Operations	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	LTC Totalizer Reading	6062.4	kw
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Present	16	°C
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Max	24	°C
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/17/2022 14:29	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations Ground	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps C Ø	150.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps B Ø	165.0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	LTC Totalizer Reading	585.60	kw
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Max	45	°C
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps A Ø	170.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Reading	.1830	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations C Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations B Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations A Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	9 Month Operations	2	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Maintenance Operations	0	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AL	240	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AF	240	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Maintenance Operations	0	
1/17/2022 9:41	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations Counter AL	181	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations Counter AF	181	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Maintenance Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	General Comments		
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations Ground	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations C Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations B Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations A Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations Ground	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations C Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations B Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations A Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps C Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps B Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps A Ø	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty A Ph V	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	9 Month Operations	4	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Operation Checked?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	All Connections OK?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Operations Since Last Insp	932	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Max Tap Position	5R	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Left Counter	40420	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Found Counter	40420	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations A Ø	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps C Ø	110.0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps B Ø	30.0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps A Ø	140.0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations A Ø	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations B Ø	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations C Ø	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations Ground	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Follow-up Action Required?	n	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	9 Month Operations	4	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	General Comments		
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Maintenance Operations	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AF	186	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AL	186	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations This Read Vac	1	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps A Ø	170.0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Unknown Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps B Ø	165.0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps C Ø	150.0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	227.68	kw
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Present	0	°C
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2846	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushing Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/17/2022 14:58	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps C Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations Counter AF	181	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations Counter AL	181	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations This Read Vac	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Switching Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Tank Paint Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Unknown Operations	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Foundation Condition	Good	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Follow-up Action Required?	n	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations Ground	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations C Ø	0	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations B Ø	0	
1/17/2022 11:05	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	9 Month Operations	5	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	General Comments		
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Grounds in Place?	y	
1/17/2022 11:29	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Maintenance Operations	0	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	General Comments	Xfmr oil temp gauge doesn't work.	
1/17/2022 12:13	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	992	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	992	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0966	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	710.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	780.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	710.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	506	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	506	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LTCC000117	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	300	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC As Found Counter	2412	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC As Left Counter	2412	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Current Tap Position	16L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000101	LTCMechanism	SW-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Unknown Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	1	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Left Counter	83399	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Found Counter	83399	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	400.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Switching Operations	1	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Operations This Read Vac	15	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Operations Counter AL	25	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Operations Counter AF	25	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Maintenance Operations	14	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	400.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	400.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H1 Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H1 Winding Temp Present	0	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	HV Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	HV Winding Temp Present	0	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Oil Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Oil Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BAT001591	Battery	SY-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.2	psi
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	*C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	*C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	*C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	*C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	*C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	*C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	62	*C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	34	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	0	*C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Max	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Present	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Max	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Present	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Max	0	*C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Present	0	*C
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	57	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	27	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	TV Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	TV Winding Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	Winding Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000250	WithLTC	SW-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Unknown Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Switching Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Operations This Read Vac	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Operations Counter AL	39	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Operations Counter AF	39	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Maintenance Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Operations Ground	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Operations C Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Operations A Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Amps C Ø	0.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Amps B Ø	0.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Amps A Ø	0.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Unknown Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Switching Operations	1	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Operations This Read Vac	17	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Operations Counter AL	41	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Operations Counter AF	41	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Maintenance Operations	16	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Operations Ground	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Operations C Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Operations B Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Operations A Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Amps C Ø	400.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Amps B Ø	420.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Amps A Ø	380.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001903	BreakerVacuum	DX-1222	VCB Readings	9 Month Operations	17	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Present	31	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Max	42	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Vegetation	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001902	BreakerVacuum	DX-1223	VCB Readings	9 Month Operations	19	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	9 Months Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps A Ø	260.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps B Ø	250.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps C Ø	100.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations A Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations B Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AF	419	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AL	419	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations This Read AM	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Switching Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Trash Emptied?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	48	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	39	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	48	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	39	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	48	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	39	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-12KV TR 1	VCB Readings	9 Month Operations	15	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Unknown Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Switching Operations	1	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Operations This Read Vac	1	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Operations Counter AL	40	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Operations Counter AF	40	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Maintenance Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Operations Ground	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Operations C Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Operations B Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Operations A Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Amps C Ø	420.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Amps B Ø	430.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Amps A Ø	420.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	120	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	107	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	107	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000846	LTCControl	SW-TRANS 2	LTC Control Insp	VRR Time Delay	0	Seconds
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Operations Ground	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Fault Adjusted Amps A Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Amps C Ø	400.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Amps B Ø	400.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Amps A Ø	400.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001906	BreakerVacuum	DX-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Amps C Ø	310.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Amps B Ø	210.0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Amps A Ø	210.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	9 Month Operations	20	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC As Found Counter	10167	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC As Left Counter	10167	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCM000082	LTCMechanism	SW-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	8	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001905	BreakerVacuum	DX-1220	VCB Readings	9 Month Operations	20	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Unknown Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Switching Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Operations This Read Vac	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Operations Counter AL	58	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Operations Counter AF	58	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Maintenance Operations	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Operations Ground	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Operations C Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Operations B Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Operations A Ø	0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	BK001904	BreakerVacuum	DX-1221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	20	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10774	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Ambient Temp	29	*F
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	*F
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Found Counter	252450	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Left Counter	252450	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Present	25	°C
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps A Ø	0.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps B Ø	0.0	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Switching Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations This Read AM	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AL	232	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AF	232	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations B Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Vegetation	None	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AF	86	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AL	86	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10969	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	heater fan needs to be replaced	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	9 Months Operations	11	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Switching Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations This Read AM	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AL	234	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AF	234	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations B Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations A Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps C Ø	350.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps B Ø	250.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps A Ø	290.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	9 Months Operations	2	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AF	133	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Maintenance Operations	1	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	General Comments	Counter not working	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations C Ø	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations B Ø	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations A Ø	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	0	°C
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AF	536	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AL	536	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations This Read AM	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Unknown Operations	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Switching Operations	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations This Read Vac	1	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AL	133	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Switching Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations This Read Vac	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AL	194	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AF	194	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Maintenance Operations	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps C Ø	421.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps B Ø	461.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps A Ø	440.0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	9 Month Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF001262	PowerFuse	SW-B 14KV GND RLY POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF001262	PowerFuse	SW-B 14KV GND RLY POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	9 Month Operations	1	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Vegetation	None	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Positive DC Ground	2.2	VDC
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Negative DC Ground	2.2	VDC
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps C Ø	116.0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps B Ø	116.0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps A Ø	116.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	140	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Left Counter	80974	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Found Counter	80974	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	9 Month Operations	14	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps C Ø	0.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps B Ø	0.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps A Ø	0.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	9 Months Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps A Ø	43.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps B Ø	42.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Amps C Ø	43.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations A Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations B Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	141091	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	141091	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Min Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	9 Months Operations	18	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations Ground	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations C Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations B Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations A Ø	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Regulator As Left Counter	9167	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Found Counter	6806	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Left Counter	6806	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	143	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Maintenance Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations Counter AF	198	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations Counter AL	198	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Operations This Read Vac	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Switching Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BK001475	BreakerVacuum	SW-1451	VCB Readings	Unknown Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	Neutral	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	General Comments		
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Vegetation	None	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/14/2022 17:54	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	9 Month Operations	5	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	VCB Patrol Inspection	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Maintenance Operations	1	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AF	251	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps B Ø	100.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps C Ø	100.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps A Ø	86.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AL	252	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps B Ø	79.0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps C Ø	43.0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations This Read Vac	1	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Unknown Operations	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Switching Operations	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps A Ø	100.0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations A Ø	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	General Comments		
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations B Ø	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations C Ø	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations Ground	0	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 9:01	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Follow-up Action Required?	n	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Switching Operations	0	
1/14/2022 19:06	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/19/2022 9:03	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	*F
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Regulator As Left Counter	29252	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Present	30	*C
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Max	25	*C
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Reading	1.2222	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps A Ø	130.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps B Ø	80.0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Adjusted Amps A Phase V	12.55	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	9 Month Operations	3	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Amps C Ø	130.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CO456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Regulator As Left Counter	64764	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Max Tap Position	1L	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps C Ø	145.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps B Ø	140.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Amps A Ø	140.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	9 Month Operations	13	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Left Counter	76032	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Found Counter	76032	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Maintenance Operations	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Operations Counter AF	171	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Operations Counter AL	172	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Operations This Read Vac	1	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Switching Operations	1	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Unknown Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations A Ø	1	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Operations Since Last Insp	414	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Fault Operations B Ø	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Found Counter	11627	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Left Counter	11632	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Max Tap Position	4R	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Min Tap Position	11L	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Operations Since Last Insp	749	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Max	29	°C
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps A Ø	89.0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps B Ø	154.0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps C Ø	161.0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Found Counter	6544	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Left Counter	6544	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Max Tap Position	3R	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Min Tap Position	7L	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Operations Since Last Insp	705	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	8799.84	kw
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Reading	.6500	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/13/2022 9:34	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/13/2022 9:34	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
1/13/2022 9:34	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/13/2022 9:34	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/13/2022 9:34	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Min Tap Position	12L	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Max Tap Position	1L	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	All Connections OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	9 Month Operations	14	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	LTC Totalizer Reading	3900.00	kw
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps C Phase V	8.76	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations A Ø	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations B Ø	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations C Ø	1	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Maintenance Operations	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations Counter AF	172	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations Counter AL	172	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations This Read Vac	1	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Switching Operations	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Oil Temp Max	41	°C
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Oil Temp Present	31	°C
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Unknown Operations	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	9 Month Operations	7	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps A Ø	420.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps B Ø	420.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps C Ø	420.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	General Comments		
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Found Counter	213634	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Left Counter	213634	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Current Tap Position	2L	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Max Tap Position	2R	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Operations Since Last Insp	469	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	All Connections OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Regulator As Left Counter	9370	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	9 Month Operations	2	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps A Ø	158.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps B Ø	150.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps C Ø	168.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	LTC Totalizer Reading	13992.00	kw
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Reading	.5830	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Max	55	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Present	35	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	LTC Totalizer Reading	11424.00	kw
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Found Counter	38412	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Left Counter	38412	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Max Tap Position	5R	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Operations Since Last Insp	598	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Reading	1.1900	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AF	291	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AL	291	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations This Read Vac	1	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Switching Operations	1	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Unknown Operations	0	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps B Ø	48.0	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps C Ø	45.0	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	General Comments		
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Operations Counter	23	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps C Ø	220.0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps B Ø	230.0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps A Ø	220.0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	9 Month Operations	6	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	All Connections OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	9 Month Operations	5	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps A Ø	268.0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps B Ø	234.0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps C Ø	208.0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps B Phase V	8.76	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Reading	.9204	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	General Comments		
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	LTC Totalizer Reading	8835.84	kw
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Oil Temp Max	55	°C
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Unknown Operations	0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Switching Operations	4	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations This Read Vac	4	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AL	161	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AF	160	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Maintenance Operations	0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	General Comments	1- replaced insulator, 3 - Tornado	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations Ground	0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations C Ø	0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations B Ø	0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations A Ø	0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps C Phase V	8.76	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations A Ø	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations B Ø	1	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations C Ø	1	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations Ground	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Maintenance Operations	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations Counter AF	167	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations Counter AL	167	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations This Read Vac	2	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Found Counter	142250	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Max	55	*C
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Present	25	*C
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Left Counter	142259	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Current Tap Position	3L	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Max Tap Position	1L	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Min Tap Position	11L	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Operations Since Last Insp	601	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Switching Operations	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Unknown Operations	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8819	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	General Comments		
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Found Counter	407686	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Left Counter	407686	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Current Tap Position	9L	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Max Tap Position	1L	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Min Tap Position	16L	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Time Delay	60	Seconds
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Unknown Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Maintenance Operations	6	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AF	193	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AL	193	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations This Read Vac	8	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Switching Operations	2	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Unknown Operations	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	180.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	180.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	192.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps A Ø	37.0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps B Ø	38.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	7508	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	7508	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.2	VDC
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.2	VDC
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps C Ø	41.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps C Phase V	1.66	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations A Ø	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations C Ø	1	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations Ground	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Maintenance Operations	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AF	234	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AL	236	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations This Read Vac	3	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Switching Operations	2	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	LTC000824	LTCControl	691-1	LTC Control Insp	All Connections OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	LTC000824	LTCControl	691-1	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Surge Arrester Condition	Blown	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Maintenance Operations	2	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AF	189	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations Counter AL	189	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Operations This Read Vac	3	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Switching Operations	1	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Unknown Operations	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	General Comments		
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Operations Counter	432	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.6	VDC
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	chg 1st quarter
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps A Ø	140.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	9 Month Operations	14	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7914	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	9 Month Operations	3	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps A Ø	385.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps B Ø	415.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps C Ø	385.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	General Comments		
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations A Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations B Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	General Comments		
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations B Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations A Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps C Ø	150.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Amps B Ø	145.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2532.48	kw
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Current Tap Position	8L	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Left Counter	19652	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Found Counter	19652	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	General Comments		
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps C Ø	145.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps B Ø	140.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Amps A Ø	145.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000972	BreakerVacuum	621-0115	VCB Readings	9 Month Operations	15	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	General Comments	BFTC	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations Ground	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations C Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations B Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps C Ø	124.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps B Ø	128.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Amps A Ø	121.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Readings	9 Month Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Switching Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations This Read Vac	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AL	288	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Operations Counter AF	288	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Maintenance Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Operations Since Last Insp	258	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Min Tap Position	13L	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Max Tap Position	2L	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	76	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	76	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	9 Month Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	All Connections OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	LTC Operation Checked?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000960	LTCControl	664-3	LTC Control Insp	VRR Time Delay	30	Seconds
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	LTCC000961	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	LTCC000961	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	LTCC000961	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	LTCC000961	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	LTCC000961	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	LTCC000961	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	LTCC000961	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	LTCC000961	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps A Ø	0.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps B Ø	0.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Amps C Ø	0.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AF	193	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Maintenance Operations	6	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Fault Operations C Ø	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	9 Month Operations	5	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Operations Counter	237	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	General Comments	Tornado	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps C Ø	35.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	9 Month Operations	13	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations B Ø	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations A Ø	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps C Ø	0.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps B Ø	0.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Amps A Ø	0.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps C Ø	0.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps B Ø	0.0	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	General Comments		
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	All Connections OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps A Ø	0.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Unknown Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Switching Operations	3	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations This Read Vac	9	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000971	BreakerVacuum	621-0041	VCB Readings	Operations Counter AL	195	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	9 Month Operations	5	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations B Ø	1	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Operations A Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps B Phase V	12.55	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Switching Operations	2	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Amps A Ø	137.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Amps B Ø	134.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Amps C Ø	151.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Operations A Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Operations B Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Operations C Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Fault Operations Ground	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Maintenance Operations	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Operations Counter AF	149	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Operations Counter AL	150	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Operations This Read Vac	1	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Switching Operations	1	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AL	217	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations Counter AF	215	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Maintenance Operations	6	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	General Comments	Bottom insulators for C and B phase fuse holders have broken skirts. Replaced Insulator 1514 Bypass	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations B Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Operations A Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	9 Month Operations	0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	9 Month Operations	25	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Reading	.4650	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Unknown Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Switching Operations	3	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps C Ø	65.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps B Ø	110.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Amps A Ø	60.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	9 Month Operations	12	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations This Read Vac	16	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AL	221	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Operations Counter AF	219	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Maintenance Operations	12	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Max Tap Position	3R	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Min Tap Position	11L	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-5	psi
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Operations Since Last Insp	46	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Found Counter	101878	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Left Counter	101878	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	194	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Amps B Ø	125.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Amps C Ø	120.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Operations A Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Operations B Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Operations C Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Fault Operations Ground	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Unknown Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Switching Operations	3	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations This Read Vac	10	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AL	199	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Operations Counter AF	197	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Maintenance Operations	7	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations B Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Operations A Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Unknown Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Switching Operations	4	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations This Read Vac	11	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AL	195	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Operations Counter AF	193	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	Maintenance Operations	6	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001822	BreakerVacuum	860-2128	VCB Readings	Unknown Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations This Read Vac	2	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AL	118	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Operations Counter AF	118	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Maintenance Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations Ground	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations C Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations B Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps C Ø	57.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps B Ø	57.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Amps A Ø	57.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Readings	9 Month Operations	7	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps C Ø	100.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps B Ø	120.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Amps A Ø	110.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001041	BreakerVacuum	621-0190	VCB Readings	9 Month Operations	16	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC As Found Counter	9434	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC As Left Counter	9434	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	9 Month Operations	31	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	BK001823	BreakerVacuum	860-2129	VCB Readings	Amps A Ø	115.0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Current Tap Position	3L	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Switching Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Unknown Operations	1	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1150	psi
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	LTC Totalizer Reading	3450.24	kw
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	230.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	20	°C
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	15	°C
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	9 Month Operations	13	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps A Ø	233.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps B Ø	238.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps C Ø	228.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations A Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations B Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AF	583	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AL	583	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations This Read Vac	1	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	9 Month Operations	6	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	LTC Totalizer Reading	7140.00	kw
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Reading	1.1900	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	LTC Totalizer Reading	4464.00	kw
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Oil Temp Max	50	°C
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Oil Temp Present	40	°C
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps B Ø	117.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps A Ø	117.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Unknown Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Switching Operations	3	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Operations This Read Vac	9	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations Ground	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps C Ø	118.0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Unknown Operations	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Switching Operations	1	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations This Read Vac	6	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AL	150	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AF	150	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Maintenance Operations	5	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations B Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Operations A Ø	0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps C Ø	400.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps B Ø	370.0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Regulator As Left Counter	55308	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Amps A Ø	410.0	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps C Ø	36.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps B Ø	39.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Amps A Ø	36.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations B Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations C Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations Ground	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Maintenance Operations	12	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AF	50	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AL	66	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations This Read Vac	16	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Switching Operations	4	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Unknown Operations	0	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Swept?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Trash Emptied?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Present	24	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Max	52	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Reading	.6710	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Present	23	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Max	51	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	LTC Totalizer Reading	16104.00	kw
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations A Ø	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations B Ø	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Maintenance Operations	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AF	223	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AL	223	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallePAR	Position
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations This Read Vac	1	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Switching Operations	1	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Unknown Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	9 Month Operations	4	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Maintenance Operations	24	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations Ground	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations C Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations B Ø	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations A Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps A Ø	50.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps B Ø	59.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps C Ø	53.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	9 Month Operations	5	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	General Comments	BFTC	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Maintenance Operations	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AF	461	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Switching Operations	4	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations This Read Vac	28	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AL	327	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AF	299	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	9 Month Operations	6	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps A Ø	159.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps B Ø	237.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps C Ø	168.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	General Comments		
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6270	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Operations Since Last Insp	479	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	39	°C
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Min Tap Position	14L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Max Tap Position	2L	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Current Tap Position	7L	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Left Counter	9967	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	General Comments		
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations Ground	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations C Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations B Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations A Ø	0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushing Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations B Ø	0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Unknown Operations	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	9 Month Operations	26	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps A Ø	140.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps B Ø	110.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps C Ø	120.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations C Ø	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations Ground	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Found Counter	9967	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1504.80	kw
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	General Comments	Can not read nitrogen guage	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	CO275	NonLTC	822-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Vegetation	None	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	87	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	All Connections OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Left Counter	55155	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Found Counter	55155	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations B Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations C Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Operations Ground	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Left Counter	209777	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	569	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	39	°F
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps A Ø	0.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps B Ø	0.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Amps C Ø	0.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Found Counter	144572	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Left Counter	144576	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Current Tap Position	8L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Max Tap Position	1L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Min Tap Position	12L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Operations Since Last Insp	392	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Found Counter	209777	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	General Comments	nitrogen btl needs nitrogen	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	General Comments		
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps B Phase V	5.33	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	1.0062	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Unknown Operations	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Switching Operations	1	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	55	°C
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations This Read Vac	2	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AL	237	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AF	237	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Maintenance Operations	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	General Comments		
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations C Ø	0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations B Ø	1	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations A Ø	0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	9 Month Operations	3	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps A Ø	114.0	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	General Comments		
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1207.44	kw
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps B Ø	94.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps C Ø	109.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AF	140	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations Counter AL	140	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Operations This Read Vac	5	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Switching Operations	5	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 11:19	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations A Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations B Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations C Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations Ground	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AL	461	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations This Read Vac	4	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Switching Operations	4	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	45	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Present	32	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Cylinder needs to be filled	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps C Ø	120.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps B Ø	120.0	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	General Comments		
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps A Ø	120.0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	9 Month Operations	35	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Max	45	°C
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Present	22	°C
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Multiplier	2800	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	8.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	7.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	9.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	9 Month Operations	9	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Maintenance Operations	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations Counter AF	211	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations Counter AL	213	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations This Read Vac	2	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Switching Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Unknown Operations	0	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Current Tap Position	6R	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	General Comments		
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Regulator As Left Counter	44752	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 10:27	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Unknown Operations	0	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	9 Month Operations	6	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations Counter AL	192	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations This Read Vac	2	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Unknown Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Switching Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations This Read Vac	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AL	150	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps B Ø	59.0	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps A Ø	69.0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AF	150	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations Ground	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations C Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations B Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations A Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Maintenance Operations	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations Counter AF	190	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps C Ø	89.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps B Ø	46.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps A Ø	40.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCCControl	032-6	LTC Control Insp	VRR Time Delay	60	Seconds
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCCControl	032-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCCControl	032-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCCControl	032-6	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCCControl	032-6	LTC Control Insp	LTC Operation Checked?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCCControl	032-6	LTC Control Insp	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCCControl	032-6	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCCControl	032-6	LTC Control Insp	All Connections OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps C Ø	53.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps B Ø	50.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Switching Operations	1	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations This Read Vac	1	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AL	106	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	General Comments		
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Operations Counter AF	106	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Current Tap Position	1L	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Min Tap Position	10L	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	General Comments		
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Maintenance Operations	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Switching Operations	2	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Unknown Operations	0	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7635	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations B Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations A Ø	0	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	All Connections OK?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Operations Counter	33	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	General Comments		
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps C Ø	60.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps B Ø	80.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps A Ø	40.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Operations Counter	27	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps C Ø	143.0	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps B Ø	144.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps A Ø	156.0	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	9 Month Operations	4	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations A Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations B Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations C Ø	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps C Ø	166.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps B Ø	176.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps A Ø	193.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations Ground	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Follow-up Action Required?	n	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 12:16	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	9 Month Operations	5	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 13:57	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Foundation Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	9 Month Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps A Ø	0.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps B Ø	0.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps C Ø	0.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations A Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations B Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AF	151	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Regulator As Left Counter	29718	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AL	151	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations This Read Vac	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Switching Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Unknown Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	49.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	66.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	65.0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Unknown Operations	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Switching Operations	2	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations This Read Vac	2	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations Counter AL	189	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations Counter AF	187	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Maintenance Operations	0	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Grounds in Place?	y	
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	General Comments		
1/13/2022 9:34	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	30.0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Unknown Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Switching Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations This Read Vac	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AL	261	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AF	261	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations B Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations A Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps C Ø	91.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps B Ø	90.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Amps A Ø	87.0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	9 Month Operations	7	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	9 Month Operations	1	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	173	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	173	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99895	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99895	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0714	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Present	20	°C
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Max	40	°C
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Broom on Site?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Switching Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations This Read Vac	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AL	125	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Operations Counter AF	125	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	LTC Totalizer Reading	1564.80	kw
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Maintenance Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Readings	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	General Comments		
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Connection/Risers	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/13/2022 10:30	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Reading	.3260	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	All Connections OK?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	General Comments	LTC is off	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Operation Checked?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	423	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	419	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps A Ø	52.0	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations This Read Vac	1	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AL	104	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Operations Counter AF	104	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Maintenance Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	General Comments		
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Regulator As Left Counter	33538	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Leaks	None	
1/13/2022 11:33	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	General Comments		
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/13/2022 9:46	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Vegetation	None	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Maintenance Operations	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations Ground	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations C Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations B Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	General Comments		
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Foundation Condition	Good	
1/14/2022 5:17	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps A Ø	53.0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps B Ø	55.0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B80251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Readings	Amps C Ø	54.0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B80251	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Time Delay	60	Seconds
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/13/2022 11:25	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushing Condition	Good	
1/13/2022 14:26	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	9 Month Operations	2	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations B Ø	0	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B80251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/13/2022 10:46	Distribution	Spindletop Quarterly Inspection	B80251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:59	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Readings	Fault Operations C Ø	0	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	LTCC000945	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Maintenance Operations	11	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Regulator As Left Counter	13244	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations Ground	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations B Ø	1	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations A Ø	0	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Ambient Temp	28	*F
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps B Phase V	6.27	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AF	223	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	leaking from top of transformer	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps C Ø	155	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps B Ø	150	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps A Ø	140	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty C Ph V	2.34	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty B Ph V	3.74	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	9 Month Operations	17	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AL	223	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations This Read Vac	12	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Switching Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Unknown Operations	0	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	LTC Totalizer Reading	6566.4	kw
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations This Read Vac	7	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AL	235	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AF	235	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	666.96	kw
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Maintenance Operations	6	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	General Comments		
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	General Comments		
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	9 Month Operations	11	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Maintenance Operations	12	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AF	186	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AL	186	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations This Read Vac	12	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Switching Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Unknown Operations	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	General Comments	bushings low side 1 and 3 show signs of seepage	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Unknown Operations	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	General Comments	High side bushing has large chip in skirt.	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Switching Operations	1	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Vegetation	None	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps A Ø	270	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps B Ø	260	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	9 Month Operations	8	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Unknown Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Switching Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations This Read Vac	7	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AL	175	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AF	175	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Maintenance Operations	7	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Max	60	°C
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Present	30	°C
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations A Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations B Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations Ground	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Maintenance Operations	7	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AF	169	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AL	169	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations This Read Vac	7	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Switching Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	9 Month Operations	11	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps A Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps B Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	245.00	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	Fault Operations A Ø	0	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5558	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	Fault Operations B Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	Fault Operations C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	Fault Operations Ground	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Max	68	°C
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BTS-6	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Unknown Operations	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Reading	.456	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.9	volts
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	178771	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	9 Month Operations	16	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps A Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps B Ø	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Present	25	°C
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Maintenance Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AF	181	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AL	181	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations This Read Vac	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Switching Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Unknown Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	All Connections OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	Follow-up Action Required?	n	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Unknown Operations	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Switching Operations	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	LTC Operation Checked?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCControl	196-5	LTC Control Insp	VRR Time Delay	30	Seconds
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	9 Month Operations	2	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps A Ø	30.0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps B Ø	7.0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations This Read Vac	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AL	164	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AF	164	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Maintenance Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AL	210	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AF	210	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Maintenance Operations	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations Ground	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations C Ø	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations B Ø	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations A Ø	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps C Ø	62.0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps B Ø	51.0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps A Ø	72.0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	9 Month Operations	2	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations A Ø	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations B Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations C Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations Ground	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps C Ø	110.0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps B Ø	34.0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps A Ø	55.0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	9 Month Operations	2	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps A Ø	89.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps B Ø	102.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps C Ø	106.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps A Phase V	16.97	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps B Phase V	16.97	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps C Phase V	16.97	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations A Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations B Ø	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Installed winter blanks	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations A Ø	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations B Ø	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations C Ø	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations Ground	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations Ground	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations C Ø	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations B Ø	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations A Ø	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Regulator As Left Counter	292719	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Maintenance Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AF	188	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AL	188	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations This Read Vac	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Switching Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Unknown Operations	0	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	9 Month Operations	39	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations A Ø	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations B Ø	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations This Read Vac	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Operations Since Last Insp	420	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Min Tap Position	11L	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Max Tap Position	4L	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Current Tap Position	6L	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations C Ø	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations Ground	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Left Counter	44012	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Found Counter	44012	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Switching Operations	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Maintenance Operations	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AF	271	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AL	271	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations This Read Vac	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Unknown Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Switching Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations This Read Vac	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AL	177	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AF	177	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Maintenance Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Reading	.5580	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Max	54	°C
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	LTC Totalizer Reading	4017.60	kw
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	9 Month Operations	2	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps A Ø	310.0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps B Ø	320.0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps C Ø	300.0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Unknown Operations	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Switching Operations	0	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations This Read Vac	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps C Ø	0.0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps B Ø	3.0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps A Ø	3.0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	9 Month Operations	2	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Switching Operations	0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps B Ø	11.0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Unknown Operations	0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Operations Counter	166	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Ambient Temp	48	°F
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Vegetation	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	177	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps A Ø	19.6	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.4	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps C Ø	23.9	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	210	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	195	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps A Ø	7	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps B Ø	12	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps C Ø	8	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations A Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	General Comments	Entrance drive washout at culvert.	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Vegetation	None	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations B Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Maintenance Operations	6	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	General Comments	meter wouldnt read ripple	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations A Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations B Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations Ground	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	General Comments		
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Maintenance Operations	6	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AF	216	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AL	216	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations This Read Vac	6	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Switching Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Unknown Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	9 Month Operations	10	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty B Ph V	1.4	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty C Ph V	1.4	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations A Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations B Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Fault Operations Ground	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Maintenance Operations	11	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AF	206	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AL	206	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations This Read Vac	11	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Switching Operations	0	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Vegetation	None	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Unknown Operations	0	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	BCH001494	Charger	879-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AF	222	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AL	222	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations This Read Vac	6	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Switching Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Unknown Operations	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3528	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Present	37	°C
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	335.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	361.67	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1270.08	kw
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	9 Month Operations	16	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty A Ph V	1.4	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty B Ph V	1.4	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Accumulated Fault Duty C Ph V	1.4	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps A Ø	135	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps B Ø	105	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps C Ø	90	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	General Comments	ok	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	9 Month Operations	12	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	9 Month Operations	12	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps A Ø	75.0	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps B Ø	42.0	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps C Ø	37.0	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	Bushing oil on A and C phases turning red	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations A Ø	0	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations B Ø	0	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations C Ø	0	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations Ground	0	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Follow-up Action Required?	n	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	General Comments		
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	General Comments		
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Maintenance Operations	9	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps A Ø	110	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps B Ø	120	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps C Ø	120	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations C Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations Ground	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	General Comments	9 ops for relay test, 1 op to verify supervisory control, 6 unknown	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Maintenance Operations	10	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AF	52	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AL	52	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations This Read Vac	16	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Switching Operations	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Unknown Operations	6	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Found Counter	72663	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Left Counter	72672	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Max Tap Position	1L	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Min Tap Position	12L	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Operations Since Last Insp	667	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Unknown Operations	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Switching Operations	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations This Read Vac	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AL	182	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AF	182	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Maintenance Operations	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps C Ø	8.0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps B Ø	8.0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps A Ø	9.0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Glass for the oil Temp is cracked	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	9 Month Operations	2	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	General Comments	Fiberglass is exposed on single phase xfmr fuse barrels. Whole station needs additional wildlife protection.	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	9 Month Operations	8	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps A Ø	13	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps B Ø	28	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps C Ø	11	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations A Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations B Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations C Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations Ground	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AF	235	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AL	235	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations This Read Vac	10	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Maintenance Operations	8	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AF	223	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Switching Operations	1	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Unknown Operations	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations Ground	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations C Ø	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations B Ø	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations A Ø	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AL	223	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations This Read Vac	8	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Switching Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Unknown Operations	0	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	195	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Left Counter	28349	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Found Counter	28349	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.7	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.7	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps C Ø	29.8	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Operations Counter	394	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Unknown Operations	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Switching Operations	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations This Read Vac	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AL	292	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AF	292	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Maintenance Operations	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations Ground	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations C Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations B Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations A Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps C Ø	74.0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Unknown Operations	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Operations Counter	88	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Switching Operations	6	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations This Read Vac	8	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AL	248	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AF	248	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Maintenance Operations	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations Ground	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations C Ø	1	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations B Ø	1	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations A Ø	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps C Ø	85	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps B Ø	85	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps A Ø	80	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty C Ph V	1.51	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Maintenance Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AF	129	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AL	129	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations This Read Vac	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Unknown Operations	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps A Ø	0.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps B Ø	0.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps C Ø	0.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations A Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations B Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations C Ø	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations Ground	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	General Comments	Bkr is open	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Maintenance Operations	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AF	241	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AL	241	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations This Read Vac	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Switching Operations	0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Unknown Operations	0	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	Filter Dirty	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.7	VDC
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Installed winter blanks	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Found Counter	33403	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Left Counter	33403	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	4	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	9 Month Operations	24	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps C Ø	84.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps B Ø	87.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps A Ø	86.0	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	9 Month Operations	19	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps A Ø	730.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps B Ø	750.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps C Ø	675.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Glass for the oil temp is cracked	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0200	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Found Counter	49292	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Left Counter	49295	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Current Tap Position	6L	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Max Tap Position	16R	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Min Tap Position	9L	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Operations Since Last Insp	1135	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.4	VDC
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.5	VDC
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	55393	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Regulator As Left Counter	312146	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	113	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Amps A Ø	39.0	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Amps B Ø	44.0	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Amps C Ø	34.0	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	34	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	55	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	DX0130	RecloserHydraulic	564-0495	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps B Ø	72.0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Regulator As Left Counter	280414	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	General Comments	Barbed wire very rusty	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Found Counter	68507	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Left Counter	68507	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Current Tap Position	11L	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Max Tap Position	8L	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Min Tap Position	16L	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Operations Since Last Insp	395	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	139.0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	33	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	31	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	34	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	General Comments		
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Regulator As Left Counter	66228	volts
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Found Counter	11847	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Left Counter	11847	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Current Tap Position	7L	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Max Tap Position	6L	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Min Tap Position	14L	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	18	°C
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Operations Since Last Insp	319	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	LTCM000063	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	All Connections OK?	y	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	Follow-up Action Required?	n	
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	General Comments		
1/12/2022 14:51	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Operation Checked?	y	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Operations Since Last Insp	887	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Min Tap Position	11L	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Max Tap Position	6R	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Current Tap Position	1L	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Left Counter	77020	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Found Counter	77008	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	General Comments		
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	General Comments		
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Regulator As Left Counter	63086	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Regulator As Left Counter	60067	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Present	18	°C
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Max	35	°C
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	LTC Totalizer Reading	2668.80	kw
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	770.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	776.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	770.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	862-Battery Charger Current	1.2	amps
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.3	VDC
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.3	VDC
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	550	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	550	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Reading	.8340	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18547	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Regulator As Left Counter	19371	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Time Delay	45	Seconds
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Operation Checked?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Follow-up Action Required?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	All Connections OK?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0930	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Max Tap Position	9R	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Regulator As Left Counter	18295	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Vegetation	None	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	General Comments	ok	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
1/12/2022 12:38	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Reading	.5830	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Present	25	°C
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Max	30	°C
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	LTC Totalizer Reading	8395.20	kw
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	183	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps A Ø	21.1	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.2	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.7	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	307	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps C Ø	188.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps B Ø	170.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps A Ø	204.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	9 Month Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	1219	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	804	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.0	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps B Ø	25.1	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.1	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	877	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Regulator As Left Counter	117691	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Present	24	°C
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Max	30	°C
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Unknown Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Switching Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations This Read Vac	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AL	66	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AF	66	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Maintenance Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations C Ø	0	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Maintenance Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations C Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations B Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations A Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps C Ø	140.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps B Ø	164.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps A Ø	147.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	9 Month Operations	5	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Unknown Operations	0	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	20.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Switching Operations	1	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations This Read Vac	1	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AL	217	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AF	217	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Maintenance Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	General Comments		
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:33	Distribution	Evarts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	151	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	151	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations A Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations B Ø	1	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations C Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Unknown Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Switching Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations This Read Vac	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Reading	.5836	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Present	33	°C
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Max	50	°C
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	LTC Totalizer Reading	5602.56	kw
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	General Comments		
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AL	215	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AF	215	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Maintenance Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations C Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations B Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations A Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations	1	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps C Ø	163.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps B Ø	161.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps A Ø	110.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	9 Month Operations	2	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Unknown Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Switching Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations This Read Vac	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AL	193	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps A Ø	22.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps B Ø	24.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps C Ø	21.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 15:33	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AF	193	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Unknown Operations	0	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	n
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations C Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations B Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations A Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps C Ø	191.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps B Ø	235.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Follow-up Action Required?	n	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	General Comments		
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	General Comments	HB-1149 B Phase IOC	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Maintenance Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AF	169	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AL	169	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations This Read Vac	1	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Switching Operations	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5058	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Present	28	°C
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Max	39	°C
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	606.96	kw
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps A Ø	268.0	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	9 Month Operations	1	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Undetermined	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 18:02	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Max	30	°C
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2409.12	kw
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Switching Operations	4	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations This Read Vac	4	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AL	125	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AF	125	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Maintenance Operations	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	9 Month Operations	5	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Regulator As Left Counter	182272	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Grounds in Place?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:22	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0284	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	All Connections OK?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations B Ø	0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations C Ø	0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations Ground	0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Follow-up Action Required?	n	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations A Ø	0	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Operation Checked?	y	
1/12/2022 14:57	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	General Comments		
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0038	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	Busted Glass	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/12/2022 9:55	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
1/12/2022 11:12	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Unknown Operations	0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
1/12/2022 10:50	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/12/2022 15:26	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	General Comments		
1/12/2022 11:05	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	1	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	728	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	729	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	1	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	1	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Pressure Indicator	good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Ambient Temperature	24	°F
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Unknown Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AF	123.7	VAC
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AL	93	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AL	124.5	VAC
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps C Ø	121.0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps B Ø	120.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Maintenance Operations	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps A Ø	101.0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AF	93	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Time Delay	60	Seconds
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	9 Month Operations	1	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Maintenance Operations	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AF	78	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	9 Months Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps A Ø	0.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps B Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	9 Months Operations	5	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AF	184	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps A Ø	100.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps B Ø	100.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps C Ø	70.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps C Ø	0.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Switching Operations	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations This Read AM	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AL	6	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AF	6	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Negative DC Ground	132.5	VDC
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Operations Ground	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Maintenance Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AF	536	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations Counter AL	536	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Operations This Read AM	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Switching Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Unknown Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	9 Month Operations	2	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps A Ø	153.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps B Ø	146.0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	*F
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps C Ø	168.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps C Ø	363.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps A Ø	80.0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps B Ø	120.0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps C Ø	110.0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations Ground	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Maintenance Operations	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AF	546	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AL	546	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Switching Operations	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	7	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps A Ø	25.0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps B Ø	25.0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps C Ø	100.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Operations Counter	37	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	9 Month Operations	2	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AF	157	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations Counter AL	157	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Operations This Read Vac	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Switching Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations Ground	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	All Connections OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	General Comments		
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Maintenance Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AF	327	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AL	327	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Switching Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Unknown Operations	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	9 Month Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps A Ø	490.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps B Ø	480.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps C Ø	500.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps C Ø	0.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps B Ø	0.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps A Ø	0.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	9 Month Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AL	980	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AF	67	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	285	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	285	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AL	67	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps C Ø	168.0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps B Ø	132.0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps A Ø	216.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Switching Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Pressure	65	psi
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations This Read SF6	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AL	72	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AF	72	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	General Comments	Whole station needs wildlife protection and fiberglass is exposed on all xfmr fuse barrels including spare.	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Num Operations Last 9 Months	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Unknown Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Switching Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AL	234	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AF	234	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Maintenance Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Maintenance Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	286	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Ambient Temperature	32	*F
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations This Read AM	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	9 Month Operations	1	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	3	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	239	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	239	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps A Ø	60.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	15.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	15.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	14.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps C Ø	60.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps B Ø	80.0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Ambient Temp	19	*F
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations Counter AL	184	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	170.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	165.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	177.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Fault Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	286	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	0.0	VDC
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	9 Months Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AL	259	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AF	259	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps A Ø	0.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps B Ø	0.0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps C Ø	0.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps A Ø	580.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	9 Month Operations	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations A Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations Ground	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AL	78	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations This Read Vac	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Switching Operations	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Unknown Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Unknown Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations This Read Vac	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AL	189	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AF	189	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps C Ø	50.0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps B Ø	50.0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Amps A Ø	50.0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	9 Months Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	GR-1124 "B" Battery bank has been removed.Please remove from inspection	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Switching Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AF	244	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AL	244	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations This Read Vac	1	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Switching Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Unknown Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Unknown Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Switching Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps B Ø	53.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps A Ø	54.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	9 Month Operations	3	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AL	77	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AF	77	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Maintenance Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	3	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Maintenance Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations Ground	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations C Ø	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations B Ø	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations A Ø	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PF001303	PowerFuse	EI-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations A Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations C Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations A Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	9 Month Operations	5	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps A Ø	270.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps B Ø	285.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps C Ø	230.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps A Phase V	13.97	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations A Ø	1	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations C Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations Ground	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps C Ø	52.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Maintenance Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Maintenance Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AF	980	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps C Ø	313.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps B Ø	311.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps A Ø	232.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	5	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	5	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	353	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	353	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	73	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	126.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	108.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	109.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	320	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	320	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	9 Months Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps B Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps C Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AF	41	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AL	41	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Unknown Operations	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	73	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	General Comments		storm trouble 12-11-21
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Operations Counter	13	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Regulator As Left Counter	73195	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.6	volts
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Unknown Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Switching Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations This Read Vac	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AL	298	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AF	298	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Maintenance Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Unknown Operations	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Switching Operations	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations This Read Vac	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AL	255	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AF	255	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Maintenance Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Maintenance Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AF	92	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AL	92	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Switching Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Unknown Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps C Ø	1110.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps B Ø	1040.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps A Ø	1010.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	9 Month Operations	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty A Ph V	2.94	%
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty B Ph V	3.73	%
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty C Ph V	3.5	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps B Ø	86.0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps A Ø	83.0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	480.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	9 Months Operations	2	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps C Ø	420.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps B Ø	480.0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Operations Counter	231	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps A Ø	540.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	9 Month Operations	7	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps C Ø	500.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps B Ø	580.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	0	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	48	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	48	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Switching Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AL	93	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AF	93	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Unknown Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Switching Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.2	amps
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Unknown Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Switching Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations This Read AM	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AL	505	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	9 Months Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps A Ø	50.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps B Ø	60.0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Readings	Amps C Ø	100.0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0277	BreakerAirMagnetic	DU-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	354	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	354	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	325.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations This Read Vac	1	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	1	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	332.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	337.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	2	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	General Comments	towe leg foundations are crumbling	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations Counter AF	293	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations Counter AL	293	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Operations This Read AM	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Switching Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Unknown Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.5	VDC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.7	VDC
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations This Read Vac	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AL	166	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AF	166	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Maintenance Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	152	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	152	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	97.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	67.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	77.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	718.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	666.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	718.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	319	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	7	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	1	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	1	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations This Read Vac	1	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	179	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	179	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	185.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	157.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	153.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PF001300	PowerFuse	DU-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps C Ø	85.0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps B Ø	80.0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps A Ø	75.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pop-off Valve Tested Date	2021-10-13 00:00:00.000000	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	425	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	425	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	4	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations This Read AM	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	126.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Ambient Temp	20	*F
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PF001309	PowerFuse	GI-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PF001309	PowerFuse	GI-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF001312	PowerFuse	HC-1431 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	9 Months Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AF	152	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AL	152	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	9 Month Operations	2	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps A Ø	355.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps B Ø	321.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Unknown Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Switching Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Pressure	67	psi
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations This Read SF6	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AL	52	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AF	52	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Num Operations Last 9 Months	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Maintenance Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	9 Months Operations	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Fault Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Ambient Temperature	32	°F
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	874	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	874	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0989	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1071	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1071	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	9 Month Operations	3	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps A Ø	56.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps B Ø	55.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps C Ø	65.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	173.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	118.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.200	millivolts
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations This Read AM	3	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AL	1327	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AF	1327	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations Ground	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations C Ø	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations B Ø	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations A Ø	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	9 Month Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps A Ø	180.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps B Ø	180.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps C Ø	190.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	95.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	98.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	95.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Operations C Ø	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	277.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	212.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	208.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps A Phase V	2.12	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations A Ø	1	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations B Ø	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations C Ø	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations Ground	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	General Comments	1- Tornado	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Maintenance Operations	1	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AF	238	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AL	238	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations This Read Vac	2	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Switching Operations	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	10	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	9 Month Operations	6	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Amps A Ø	23.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Amps B Ø	17.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Amps C Ø	18.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	21	*F
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	161	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	161	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Unknown Operations	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Switching Operations	3	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	62.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	87.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	63.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Ambient Temp	20	*F
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AF	497	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AL	497	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Switching Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	18	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	93	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	93	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	4	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	151.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	169.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	228.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Maintenance Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Operations Counter AF	16	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Operations Counter AL	16	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Operations This Read Vac	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Switching Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001909	BreakerVacuum	GR-1124	VCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Maintenance Operations	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps C Ø	179.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps B Ø	182.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps A Ø	178.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	9 Months Operations	4	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	425	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	425	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	General Comments	barbed wire top broke in places	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCCControl	127-5	LTC Control Insp	All Connections OK?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCCControl	127-5	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCCControl	127-5	LTC Control Insp	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCCControl	127-5	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCCControl	127-5	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCCControl	127-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCCControl	127-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCCControl	127-5	LTC Control Insp	VRR Time Delay	30	Seconds
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations This Read AM	3	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AL	154	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AF	154	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	General Comments	Target A Phase	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations Ground	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations C Ø	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations B Ø	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Operations A Ø	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps C Ø	100.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps B Ø	50.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Amps A Ø	50.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	9 Months Operations	5	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Water coming in from Exhaust fan	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Operations Since Last Insp	1031	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Min Tap Position	12L	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Max Tap Position	1L	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Current Tap Position	6L	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Left Counter	10763	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Found Counter	10756	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Ambient Temp	23	°F
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Main tank low oil	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	45	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	20	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Operations Since Last Insp	310	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	163	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	163	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Unknown Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Switching Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AL	16	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AF	16	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps C Ø	200.0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps B Ø	150.0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps A Ø	150.0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	9 Months Operations	6	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Unknown Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Switching Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations This Read AM	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AL	665	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AF	665	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Fault Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	General Comments	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Maintenance Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Num Operations Last 9 Months	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AF	84	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AL	84	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations This Read SF6	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Compressor Belt Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Pressure	64	psi
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Switching Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Unknown Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	9 Months Operations	2	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps A Ø	40.0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps B Ø	50.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	*C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	*C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Maintenance Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations Counter AF	332	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations Counter AL	332	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations This Read Vac	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Switching Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps C Ø	50.0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AF	591	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AL	591	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Switching Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	General Comments	SPR has been removed	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Cabinet has 2 strip heaters. Neither are working.	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Max	40	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	9 Month Operations	1	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps A Ø	230.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps B Ø	230.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps C Ø	240.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Left Counter	51438	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Found Counter	51438	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Max	75	°C
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1950	psi
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	General Comments	Winding Temp guage reset	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	9 Months Operations	1	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps A Ø	48.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps B Ø	81.0	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	General Comments	LTC is very low on oil	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	LTC Totalizer Reading	24444.00	kw
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Max	70	°C
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Present	45	°C
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Reading	1.3580	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Max	70	°C
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Present	45	°C
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Present	21	°C
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Max	61	°C
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Present	20	°C
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Operations Since Last Insp	865	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Min Tap Position	6L	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Max Tap Position	11R	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Current Tap Position	3R	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	55	°C
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	°C
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.0	psi
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	General Comments	WORKERS WORKING IN SUB COULD NOT PULL IN SUB TO GET LADDER OFF TRUCK SO I DIDNT RESET	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO ASAP	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	General Comments	barb wire rusty and top rail is rusty back left corner posts need replaced, multiple bayonets loose on fence	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Regulator As Left Counter	356472	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Present	40	°C
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Max	70	°C
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps C Ø	82.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AF	864	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AL	864	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations This Read AM	1	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Switching Operations	1	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Unknown Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	14	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Ambient Temp	21	*F
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Trash Emptied?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	243	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	243	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	133	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	133	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	257.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	230.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	234.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	16	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps A Ø	4.2	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps B Ø	3.1	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps C Ø	.6	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	20	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Found Counter	59311	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	General Comments	added 2 pounds of nitrogen	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	General Comments		
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Min Tap Position	12L	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Max Tap Position	5L	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Current Tap Position	8L	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Left Counter	2539	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Found Counter	2539	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	General Comments	Counter not working.	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	All Connections OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Ambient Temp	22	*F
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Operations Since Last Insp	495	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Min Tap Position	2L	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Max Tap Position	2L	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Current Tap Position	2L	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Left Counter	53252	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Found Counter	53252	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Operations Since Last Insp	1366	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Min Tap Position	16L	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Max Tap Position	7L	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Current Tap Position	12L	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Left Counter	59318	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	General Comments	Storm trouble 12-11-21	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Maintenance Operations	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AF	199	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AL	199	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations This Read Vac	5	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Switching Operations	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Unknown Operations	5	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000337	LTCControl	TA-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000336	LTCControl	TA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations This Read AM	2	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AL	859	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AF	859	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	General Comments	IOC A and B phase	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	9 Month Operations	5	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps A Ø	36.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps B Ø	37.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps C Ø	29.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps A Phase V	8.81	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps B Phase V	8.81	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps C Phase V	8.81	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	General Comments	storm trouble 12-11-21	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Maintenance Operations	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AF	199	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AL	199	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations This Read Vac	3	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Switching Operations	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Unknown Operations	3	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	9 Month Operations	7	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps A Ø	5.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps B Ø	7.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps C Ø	2.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCC000335	LTCControl	TA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Found Counter	70522	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Left Counter	70522	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	16R	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	15L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	306	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Found Counter	27740	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Left Counter	27740	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	434	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Operations Since Last Insp	638	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Unknown Operations	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Switching Operations	8	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations This Read AM	8	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AL	925	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AF	925	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	800.16	kw
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0002	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Time Delay	60	Seconds
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AL	124.3	VAC
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AF	124.8	VAC
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	All Connections OK?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	372	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2L	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Left Counter	11267	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Found Counter	11267	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps C Ø	136.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps B Ø	146.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps A Ø	156.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	9 Months Operations	9	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Unknown Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Switching Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AL	559	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AF	559	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Maintenance Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps C Ø	0.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps B Ø	0.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps A Ø	0.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	9 Month Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Present	22	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	55	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	50	°C
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	9 Months Operations	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps A Ø	180.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	45	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	4	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	34	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	5	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	42	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	16	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	40	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	16	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations C Ø	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps C Ø	255.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps B Ø	245.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps A Ø	290.0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	9 Month Operations	3	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps B Ø	160.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps C Ø	155.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Unknown Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Switching Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations This Read Vac	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AL	657	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AF	657	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Maintenance Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations Ground	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations C Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations B Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations A Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps C Ø	249.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps B Ø	262.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps A Ø	256.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations C Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations Ground	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AF	898	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AL	898	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations This Read AM	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Unknown Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	9 Month Operations	1	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Unknown Operations	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Switching Operations	1	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations This Read Vac	1	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AL	202	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AF	202	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Maintenance Operations	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Found Counter	272399	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Left Counter	272399	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16R	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3585	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	check oil cup
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	-60	°C
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	-60	°C
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Present	20	°C
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Max	45	°C
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Reading	.1602	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations Ground	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	General Comments	OK	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Maintenance Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AF	57	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AL	57	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations This Read AM	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Switching Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Unknown Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Left Counter	60300	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	736	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	736	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	261	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Present	40	°C
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Max	40	°C
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Reading	.9000	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Present	40	°C
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Max	55	°C
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	LTC Totalizer Reading	12960.00	kw
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Reading	.6480	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Max	65	°C
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Present	25	°C
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	9 Month Operations	2	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps A Ø	0.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps B Ø	0.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps C Ø	0.0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Present	20	°C
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Max	45	°C
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	LTC Totalizer Reading	2306.88	kw
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	LTC Totalizer Reading	11664.00	kw
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Present	20	°C
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2587	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	225	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Left Counter	105067	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Found Counter	105067	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	740	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	740	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	9 Month Operations	2	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps A Ø	307.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps B Ø	309.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps C Ø	317.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Switching Operations	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations This Read Vac	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AL	476	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AF	476	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Maintenance Operations	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations Ground	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations C Ø	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations B Ø	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations A Ø	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps C Ø	166.0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps B Ø	155.0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps A Ø	145.0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	9 Month Operations	20	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	11	°C
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	4768	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	239563	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Left Counter	239563	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	General Comments	pver hanging trees and vegetation growing through fence in multiple sposts	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	9 Months Operations	1	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	15.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	14.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	13.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Found Counter	60300	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps A Ø	240.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps B Ø	240.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps C Ø	240.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Found Counter	101311	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Left Counter	101311	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	406	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Maintenance Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations Counter AF	390	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations Counter AL	390	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations This Read Vac	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Switching Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Unknown Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	LTC low oil/ desiccant needs to be replaced	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Found Counter	26807	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Left Counter	26807	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	169	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Present	25	°C
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Max	40	°C
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	LTC Totalizer Reading	3265.20	kw
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Found Counter	71976	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Left Counter	71976	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	El-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EL-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	202	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Present	35	°C
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Max	55	°C
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Reading	.1814	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Reading	.8220	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Present	32	°C
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Max	38	°C
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	LTC Totalizer Reading	7891.20	kw
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Operations Since Last Insp	410	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Min Tap Position	1L	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Max Tap Position	16R	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Current Tap Position	2R	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Left Counter	39661	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Found Counter	39659	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	General Comments	bathroom is out of order	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	7.000	millivolts
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	All Connections OK?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps B Ø	500.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps C Ø	500.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	General Comments	OK	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Maintenance Operations	3	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AF	57	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AL	57	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations This Read AM	4	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Switching Operations	1	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	9 Months Operations	5	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps A Ø	170.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps B Ø	150.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps C Ø	170.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations A Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations C Ø	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations Ground	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	General Comments		IOC C Phase
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AF	150	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AL	150	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations This Read AM	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Unknown Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Maintenance Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations Counter AF	160	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations Counter AL	160	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations This Read Vac	2	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Switching Operations	2	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Unknown Operations	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.278	millivolts
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	9 Months Operations	7	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps A Ø	500.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	175	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	106.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	105.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Regulator As Left Counter	194216	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	R0885	Regulator	810-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Max	55	°C
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Present	20	°C
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	22	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	15	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Maintenance Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AF	377	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	42	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	15	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AL	377	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations This Read Vac	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Switching Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Unknown Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Operations Since Last Insp	327	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Min Tap Position	14L	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Current Tap Position	9L	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Left Counter	128293	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Found Counter	128293	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	55	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	40	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	50	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Maintenance Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AF	384	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AL	384	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations This Read Vac	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Switching Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Unknown Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Switching Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations This Read Oil	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AL	2776	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AF	2776	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Number of Ops last 9 Months	1	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Maintenance Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Fault Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99989	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99989	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	9 Month Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps A Ø	2.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps B Ø	3.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps C Ø	2.0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AF	155	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AL	155	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations This Read Vac	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Switching Operations	0	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Unknown Operations	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	All Connections OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	9 Month Operations	2	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps A Ø	478.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps B Ø	480.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps C Ø	467.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	9 Month Operations	17	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps A Ø	101.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps B Ø	108.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps C Ø	102.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Maintenance Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AF	410	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AL	410	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	60	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	25	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	55	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	25	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	55	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	25	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps A Ø	221.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps B Ø	223.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps C Ø	225.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations This Read Vac	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Switching Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	22	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	44	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	9 Month Operations	1	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps A Ø	125.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps B Ø	128.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps C Ø	125.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations A Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations B Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations C Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations Ground	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Maintenance Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AF	350	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AL	350	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations This Read Vac	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Switching Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	General Comments	Counter not working	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Found Counter	54479	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Left Counter	54479	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Current Tap Position	10L	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Max Tap Position	3L	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps B Ø	50.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps C Ø	40.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Maintenance Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AF	326	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AL	326	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations This Read Vac	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Switching Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Unknown Operations	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Min Tap Position	15L	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	2	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	130	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	130	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	3	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	°F
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	General Comments	ok	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	9 Month Operations	2	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps A Ø	40.0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Found Counter	12357	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Retired Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1357	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1357	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Left Counter	12357	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Max Tap Position	4L	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Operations Since Last Insp	428	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Found Counter	86595	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Left Counter	86595	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	29	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	175.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	160.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	174.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	2	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	4	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Unknown Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	General Comments	Station needs additional wildlife protection.	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AL	896	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AF	896	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps C Ø	38.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps B Ø	58.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps A Ø	72.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	9 Months Operations	10	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Present	5	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Max	46	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen, 138kv A and C phase bushing skirt broken.	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	426.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	487.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	424.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3090	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3090	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	10	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	10	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	10	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	58.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	58.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Unknown Operations	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Switching Operations	6	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations This Read AM	6	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Unknown Operations	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Switching Operations	0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.9	VDC
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.9	VDC
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BCH001277	Charger	574-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations This Read Vac	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AL	309	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AF	309	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Maintenance Operations	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations Ground	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations C Ø	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations B Ø	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations A Ø	0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps C Ø	0.0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps B Ø	0.0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps A Ø	0.0	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	9 Month Operations	2	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	495	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	495	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Broken skirts	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	General Comments	trans needs nitrogen	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	General Comments	guage reset is frozen	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps A Ø	56.0	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps B Ø	3.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Unknown Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Switching Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations This Read Vac	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations Counter AL	172	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Operations Counter AF	172	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Maintenance Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps C Ø	63.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps B Ø	65.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps A Ø	100.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	9 Month Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	°C
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Ambient Temp	19	°F
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Max	36	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Present	24	*C
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	20	*C
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	All Connections OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Output Voltage Level	113.2	VAC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Time Delay	45	Seconds
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	All Connections OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Output Voltage Level	112.8	VAC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Time Delay	45	Seconds
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	General Comments	station work and switching 12-2-21	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Operations Counter	20	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	All Connections OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps C Ø	398.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps B Ø	392.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps A Ø	388.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	9 Month Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LTCC000020	LTCControl	LY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	LTCC000020	LTCControl	LY-TRANS 2	LTC Control Insp	General Comments	OK	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps C Ø	675.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps B Ø	660.0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	9 Month Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps A Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps B Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps C Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AF	176	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AL	176	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Unknown Operations	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AF	216	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Maintenance Operations	3	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps C Ø	163.0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps B Ø	199.0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps A Ø	160.0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations Ground	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Ambient Temp	22	*F
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:48	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Unknown Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Switching Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations This Read Vac	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations Counter AL	186	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations Counter AF	186	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Maintenance Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations A Ø	0	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Fault Operations B Ø	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps C Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps B Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps A Ø	0.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	9 Months Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	388	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	446	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCControl	AB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	9 Month Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AF	120	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AL	120	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Unknown Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	548	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps A Ø	24.5	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.9	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Reading	.5088	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps C Ø	34.8	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	LTC Totalizer Reading	3663.36	kw
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	General Comments	added nitrogen from 0-1psi	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AF	95	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCCControl	526-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCCControl	526-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCCControl	526-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCCControl	526-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCCControl	526-1	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCCControl	526-1	LTC Control Insp	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCCControl	526-1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCCControl	526-1	LTC Control Insp	All Connections OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	35	°C
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	10	°C
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Present	10	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps A Ø	154.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps B Ø	120.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps C Ø	178.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Max	35	°C
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Unknown Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Switching Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations This Read Vac	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AL	208	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AF	208	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Maintenance Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Reading	.8994	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCCControl	535-3	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCCControl	535-3	LTC Control Insp	LTC Output Voltage Level	112.8	VAC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCCControl	535-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCCControl	535-3	LTC Control Insp	VRR Base Voltage AF	113.5	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Time Delay	45	Seconds
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Operations Counter	71	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	leaking from previous repair	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	84.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	101.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	158	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	158	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Amps A Ø	770.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	9 Month Operations	4	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Maintenance Operations	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AF	362	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AL	362	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations This Read AM	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Switching Operations	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps A Ø	166.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps B Ø	195.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps C Ø	168.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps C Ø	300.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps B Ø	275.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps A Ø	255.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	9 Month Operations	3	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Present	10	°C
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	All Connections OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Present	46	°C
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	LTC Totalizer Reading	2878.08	kw
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	9 Month Operations	1	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Max	53	°C
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	755.28	kw
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen from 0-1psi	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	General Comments		
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6294	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps A Ø	435.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps B Ø	465.0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps C Ø	428.0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	General Comments		
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	LTC Totalizer Reading	936.00	kw
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Max	48	°C
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Present	37	°C
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AF	540	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AL	540	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations This Read AM	1	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Switching Operations	1	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Unknown Operations	0	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	9 Months Operations	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Ambient Temp	22	*F
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Vegetation	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	General Comments		
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Maintenance Operations	5	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AF	197	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AL	197	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations This Read Vac	6	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Switching Operations	1	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	El-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations Ground	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps C Ø	190.0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps B Ø	170.0	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps A Ø	130.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	9 Months Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	9 Month Operations	6	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps A Ø	580.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps B Ø	480.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps C Ø	460.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Present	48	°C
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Max	65	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Operations Since Last Insp	216	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Min Tap Position	6L	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Left Counter	39031	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Found Counter	39031	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	General Comments		
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:33	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Present	42	°C
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Max	85	°C
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	220.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	170.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	204.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Switching Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations This Read Vac	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AL	469	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AF	469	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Maintenance Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	General Comments		
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations Ground	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations C Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations B Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations A Ø	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps C Ø	340.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps B Ø	320.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps A Ø	320.0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	330.00	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Operations Counter	157	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Unknown Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	9 Month Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps A Ø	232.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps B Ø	236.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps C Ø	234.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AF	338	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AL	338	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	2	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	224	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	224	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	1	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	1	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps B Ø	43.0	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps A Ø	73.0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Unknown Operations	0	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 13:25	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Switching Operations	1	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations This Read Vac	4	
1/11/2022 11:11	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Operations Counter AL	216	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Unknown Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AL	429	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AF	429	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Maintenance Operations	0	
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 11:23	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	9 Month Operations	1	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Unknown Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Switching Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations This Read Vac	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AL	173	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AF	173	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Maintenance Operations	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	General Comments	ok	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations Ground	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations C Ø	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations B Ø	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations A Ø	0	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps C Ø	58.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Present	10	°C
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Max	24	°C
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	LTC Totalizer Reading	624.00	kw
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	General Comments	added one pound of nitrogen	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	General Comments		
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 10:54	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Reading	.0650	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 13:24	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Reading	.1300	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	9 Month Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	104.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	141.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	113.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	228	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	228	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/11/2022 11:50	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	8	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	545.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	529.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	540.0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	260	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	260	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations This Read Vac	8	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	8	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Unknown Operations	0	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:53	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	65	°C
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	30	°C
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps C Ø	55.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps B Ø	46.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Amps A Ø	57.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	9 Month Operations	6	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	1	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	159	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	111	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	159	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Unknown Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Switching Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AL	660	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AF	660	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Maintenance Operations	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC As Found Counter	188936	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Left Counter	188936	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8L	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	138	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Found Counter	96090	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Left Counter	96090	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Switching Operations	1	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations This Read Vac	1	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AL	57	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Operations Counter AF	57	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	111	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations Ground	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations C Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations B Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.1	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps B Ø	48.5	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps C Ø	33.1	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps C Ø	164.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps B Ø	151.0	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps A Ø	158.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	27.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	27.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	9 Month Operations	2	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	TA-Swgr Grounds in Place?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	157	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AF	124	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AL	124	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations This Read AM	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Unknown Operations	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Left Counter	302906	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Found Counter	302906	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Found Counter	48558	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Left Counter	48558	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	9 Months Operations	1	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Max Tap Position	3R	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Unknown Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Switching Operations	0	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps A Ø	450.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps B Ø	400.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps C Ø	475.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	4	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	2755	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Current Tap Position	12L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Max Tap Position	9L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Min Tap Position	16L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	402	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PNS7	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 12:25	Distribution	Grady Quarterly Inspection	PNS7	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	32	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Found Counter	405026	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Left Counter	405026	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	196	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 9:27	Distribution	Gilligan Quarterly Inspection	PNS6	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations This Read Vac	1	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AL	127	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AF	127	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	9.0	amps
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Left Counter	233678	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Found Counter	233678	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 13:58	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1110	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1110	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Unknown Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Switching Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations This Read AM	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AL	686	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Ambient Temp	26	°F
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Left Counter	21766	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Found Counter	21766	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AF	686	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Maintenance Operations	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	General Comments	HSI A and B Phase	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	General Comments		
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Operations Counter	421	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	General Comments		
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	10	°C
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	10	°C
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	15	°C
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	35	°C
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 12:15	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.4	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	General Comments	ok	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Left Counter	415103	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Found Counter	415103	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/11/2022 13:05	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 9:15	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Unknown Operations	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Switching Operations	0	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	General Comments		
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations This Read Vac	0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Operations Counter AL	95	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/11/2022 13:21	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps C Ø	380.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps B Ø	460.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps A Ø	410.0	
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/24/2022 7:57	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	9 Months Operations	1	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps B Ø	24.1	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.1	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Operations Counter	485	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	122	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6	
1/11/2022 14:07	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.9	VDC
1/11/2022 10:57	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Negative DC Ground	29.1	VDC
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	General Comments		
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Vegetation	None	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	165.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	146.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	166.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps A Ø	377.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps B Ø	366.0	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Amps C Ø	401.0	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
1/11/2022 14:45	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
1/11/2022 17:17	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/11/2022 13:42	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Readings	9 Month Operations	1	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
1/11/2022 13:24	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.5	VDC
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BCH000422	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	58	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	3	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.0	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.0	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	29	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Unknown Operations	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	9 Month Operations	1	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	General Comments		
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	326	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	326	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations This Read AM	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	General Comments		
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Regulator As Left Counter	190744	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps A Ø	8.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps B Ø	21.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps C Ø	9.0	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps A Phase V	45.60	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps B Phase V	45.60	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps C Phase V	10.13	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations A Ø	9	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations B Ø	9	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations C Ø	2	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations Ground	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Maintenance Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations Counter AF	196	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations Counter AL	196	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations This Read Vac	20	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Switching Operations	0	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	192.60	kw
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Max	35	°C
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Oil Temp Present	18	°C
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.8	volts
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1825	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations A Ø	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations B Ø	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations C Ø	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations Ground	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	General Comments	1 trip check	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Maintenance Operations	1	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AF	177	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AL	177	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations This Read Vac	1	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Switching Operations	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Unknown Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.3210	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCCControl	557-1	LTC Control Insp	All Connections OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCCControl	557-1	LTC Control Insp	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCCControl	557-1	LTC Control Insp	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Regulator As Left Counter	164243	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps A Ø	178.0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Present	29	°C
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Max	45	°C
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	LTC Totalizer Reading	3314.88	kw
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps B Ø	151.0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps C Ø	129.0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Max Tap Position	13R	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37625	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	LTC Totalizer Reading	482.40	kw
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Max	47	°C
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Present	35	°C
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Reading	.2010	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	General Comments	ok	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	Oil Temp Present	18	°C
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0990	NonLTC	342-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Regulator As Left Counter	124821	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Operations Counter	95	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Reading	.6906	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	9.1	VDC
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	9 Month Operations	25	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	25.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	100.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	25.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PF001304	PowerFuse	FC-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	25.1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PF001305	PowerFuse	FC-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	General Comments	Neighbors fence within 6 inches of station fence (on right side of fence). Noted in previous insp.	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Ambient Temp	29	*F
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	9.1	VDC
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0991	NonLTC	342-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Min Tap Position	1R	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.8	VDC
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Regulator As Left Counter	144477	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Min Tap Position	4L	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Max Tap Position	6R	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2382	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	571.68	kw
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Regulator As Left Counter	34839	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps A Ø	31.0	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps B Ø	29.0	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps C Ø	49.0	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Pressure OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Oil Status	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Ambient Temp	28	*F
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	General Comments	Washout under fence back left.	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	General Comments	ok	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	General Comments	Road leqasding to station needs tree trimming	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps B Ø	46.0	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps C Ø	47.0	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Operations Counter	12	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	General Comments	Berm needs some gravel. Needs new ODL.	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Unknown Operations	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 3 Oil Level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 2 Oil level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 1 Oil Level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Switching Operations	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pop-off Valve Tested Date	2022-01-10 00:00:00.000000	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations This Read Oil	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AL	99991	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AF	99991	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Number of Ops last 9 Months	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Maintenance Operations	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Fault Operations	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	General Comments	TC operation	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Unknown Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Switching Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations This Read Vac	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Broom on Site?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Present	29	°C
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Floor Swept?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Panels Dusted?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Trash Emptied?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations Counter AL	183	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations Counter AF	183	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Maintenance Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Regulator As Left Counter	378133	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Negative DC Ground	29.5	VDC
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps C Ø	34.0	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Broken skirts	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	445	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Min Tap Position	1R	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Regulator As Left Counter	72306	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations Ground	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Operations Counter	268	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations C Ø	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations B Ø	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations A Ø	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps C Ø	0.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps B Ø	0.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps A Ø	0.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	9 Month Operations	2	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Regulator As Left Counter	34192	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	127	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	199	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Current Tap Position	9L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	General Comments	ok	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	General Comments	Barb wire and fabric is rusted in some spots.	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	General Comments	1- Trip Check	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Operations Counter	115	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Regulator As Left Counter	67080	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Max Tap Position	5R	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Min Tap Position	5L	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Regulator As Left Counter	161260	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Time Delay	60	Seconds
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Operations Since Last Insp	633	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Min Tap Position	7L	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Max Tap Position	3L	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Left Counter	374124	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Found Counter	374116	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Operation Checked?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Regulator As Left Counter	116652	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	General Comments	Meter has been removed.	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	517.50	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	500.00	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Max	100	°C
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Present	18	°C
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	438.00	kw
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	170.00	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	155.00	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Max	90	°C
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Present	23	°C
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Unknown Operations	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Time Delay	60	Seconds
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	LTC Operation Checked?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	All Connections OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Switching Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations This Read Vac	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AL	209	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AF	209	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Maintenance Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations Ground	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations C Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	YD000189	Yard	560-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Operations Since Last Insp	258	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Left Counter	9040	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Found Counter	9033	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	77	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps B Ø	26.0	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	80	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations A Ø	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps C Ø	168.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps B Ø	136.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps A Ø	205.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	9 Month Operations	0	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	137.12	kw
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.6856	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations B Ø	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Switching Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations This Read Vac	5	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Vegetation	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Unknown Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Switching Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations This Read AM	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AL	1302	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AF	1302	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Maintenance Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations Ground	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps C Ø	170.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps B Ø	160.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps A Ø	150.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Months Operations	1	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	General Comments	Top of containment is exposed by the control house.	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Present	55	°C
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	General Comments	No meter	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations Counter AL	175	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations Counter AF	175	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Maintenance Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations Ground	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations C Ø	1	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations B Ø	2	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations A Ø	2	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps B Phase V	10.13	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps A Phase V	10.13	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps C Ø	135.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps B Ø	177.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps A Ø	181.0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	9 Month Operations	6	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Reading	.4330	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/10/2022 12:15	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Present	17	°C
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Max	42	°C
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	LTC Totalizer Reading	2078.40	kw
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Trash Emptied?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Unknown Operations	0	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Regulator As Left Counter	116264	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Regulator As Left Counter	118473	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.6	volts
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Regulator As Left Counter	17891	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	374662	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BCH001407	Charger	310-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	511	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Left Counter	419197	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Found Counter	419197	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	3	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	2	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	All Connections OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Operation Checked?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	57	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	10	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	General Comments	ok	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.1	VDC
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	BAT001473	Battery	310-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.2	VDC
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.0	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	MX0259	RecloserHydraulic	383-0932	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	4	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Left Counter	76672	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Found Counter	76672	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.8810	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	1057.20	kw
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	General Comments	ok	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Current Tap Position	3L	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Max Tap Position	2R	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Regulator As Left Counter	821627	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	LTCC00785	LTCControl	673-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	9 Month Operations	4	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps A Ø	10.0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps B Ø	10.0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps C Ø	10.0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations A Ø	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations B Ø	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations C Ø	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations Ground	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Maintenance Operations	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AF	31	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Unknown Operations	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Switching Operations	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations This Read Vac	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AL	139	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AF	139	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Maintenance Operations	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations Ground	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations C Ø	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations B Ø	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations A Ø	0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Present	29	°C
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Oil Temp Max	41	°C
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Regulator As Left Counter	233588	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	M0025	NonLTC	555-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations Ground	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps C Ø	210.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps B Ø	200.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps A Ø	130.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Months Operations	5	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24272	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Max Tap Position	7L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps C Ø	252.0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps B Ø	192.0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Amps A Ø	168.0	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	9 Month Operations	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AL	31	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations This Read Vac	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Unknown Operations	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Switching Operations	0	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Unknown Operations	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28732	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Switching Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations This Read AM	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	General Comments	ok	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 14:29	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AL	34895	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AF	34895	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Switching Operations	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations This Read Vac	1	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AL	171	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AF	170	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Maintenance Operations	1	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	General Comments	TC	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations Ground	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations C Ø	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations B Ø	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations A Ø	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps C Ø	52.0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps B Ø	60.0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps A Ø	36.0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	9 Month Operations	6	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.7	VDC
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.7	VDC
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Maintenance Operations	1	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	General Comments	TC	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	General Comments		
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations Ground	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Regulator As Left Counter	37581	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	General Comments	operation controls sluggish, had to raise and lower twice to get proper auto operation.	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations C Ø	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations B Ø	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations A Ø	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps C Ø	33.0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps B Ø	33.0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps A Ø	50.0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	9 Month Operations	10	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Unknown Operations	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Current Tap Position	8L	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Max Tap Position	4L	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Min Tap Position	13L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Operations Since Last Insp	570	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	3	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	PT/CT/CVVT Visible Condition	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	General Comments	ok	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	F
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
1/10/2022 10:25	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	General Comments	ok	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 12:21	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations This Read AM	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	408	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	408	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	90.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	25.0	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	50.0	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6174	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2222.64	kw
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 13:59	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:58	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Found Counter	432252	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Left Counter	432262	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Present	15	°C
1/10/2022 10:24	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Max	32	°C
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	General Comments	ok	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	General Comments		
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
1/10/2022 12:43	Distribution	Turtle Creek Quarterly Inspection	BAT001559	Battery	859-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Present	20	°C
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Max	20	°C
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Present	15	°C
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Max	26	°C
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	General Comments	No equipment only switches	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	n	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	n	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	ST000195	Structure	560-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusted and some lower sections broken	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 12:20	Distribution	Cerro-Salem Quarterly Inspection	FE000191	Fence	560-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Regulator As Left Counter	59051	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Max	60	°C
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	General Comments		
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Vegetation	None	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7339.68	kw
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	General Comments		
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/12/2022 11:02	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Regulator As Left Counter	164941	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	General Comments		
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	General Comments		
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/10/2022 15:49	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0194	
1/10/2022 13:16	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:04	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AF	219	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AL	220	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations This Read Vac	1	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Switching Operations	0	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 11:59	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Unknown Operations	0	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 11:28	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Regulator As Left Counter	243062	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations Ground	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations A Ø	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AF	191	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AL	191	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Switching Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations This Read Vac	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Switching Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	9 Month Operations	3	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Maintenance Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AF	161	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AL	161	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations This Read Vac	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Switching Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps C Ø	213.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps B Ø	233.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps A Ø	207.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty A Ph V	49.42	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty B Ph V	42.25	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty C Ph V	27.1	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations This Read Vac	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AL	148	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AF	148	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Maintenance Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps B Ø	74.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps C Ø	78.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps A Ø	33.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty C Ph V	18.33	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	9 Month Operations	7	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations A Ø	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations B Ø	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations C Ø	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Tank Paint Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Switching Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Pressure Indicator	good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations This Read SF6	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AL	61	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations Ground	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AF	61	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Maintenance Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps B Ø	0.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps A Ø	0.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	9 Month Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Switching Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations This Read Vac	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AL	148	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AF	148	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Maintenance Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations Ground	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations C Ø	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations B Ø	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Maintenance Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps C Ø	0.0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Ambient Temp	12	*F
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Present	11	*C
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	56	°C
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	8	°C
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	63	°C
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	12	°C
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	63	°C
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	12	°C
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Ambient Temperature	12	°F
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Fault Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	12	°F
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Follow-up Action Required?	n	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Foundation Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	General Comments		
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Grounds in Place?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Maintenance Operations	0	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Num Operations Last 9 Months	3	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.1	VDC
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.1	VDC
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Vegetation	None	
1/7/2022 10:31	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0259	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0257	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0256	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0255	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0254	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0261	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0253	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0252	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0251	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0250	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LB0260	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LTCC000116	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BAT000111	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Found Counter	93864	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Left Counter	93868	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Operations Since Last Insp	534	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Max Tap Position	4R	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Min Tap Position	5L	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Operations Since Last Insp	538	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Min Tap Position	9L	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Max Tap Position	1L	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Current Tap Position	3L	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Left Counter	81849	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Found Counter	81844	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Operations Counter	8	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations A Ø	0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Found Counter	53171	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	9 Months Operations	5	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty A Ph AM	2.41	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	9 Month Operations	10	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps A Ø	100.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps B Ø	80.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps C Ø	140.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations A Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations B Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations C Ø	2	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Amps A Ø	110.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Amps B Ø	136.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Amps C Ø	143.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCControl	LTCControl	369-1	LTC Control Insp	All Connections OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps B Ø	80.0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	9 Month Operations	23	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty A Ph V	3.64	%
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Regulator As Left Counter	32867	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty B Ph V	3.64	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps A Ø	480	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps B Ø	500	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps C Ø	500	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps A Ø	100.0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Left Counter	53171	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Current Tap Position	4R	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Max Tap Position	6R	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Min Tap Position	4L	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Operations Since Last Insp	398	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Switching Operations	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	9 Month Operations	8	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Unknown Operations	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps A Ø	1005	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps B Ø	1120	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Amps C Ø	1115	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Operations Counter AF	189	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Operations Counter AL	189	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Switching Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001289	BreakerVacuum	158-0661	VCB Readings	Unknown Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	VRR Base Voltage AL	118.0	VAC
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps C Ø	90.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	VRR Base Voltage AF	118.0	VAC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	LTC Output Voltage Level	118.1	VAC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	LTC Operation Checked?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000850	LTCControl	158-2	LTC Control Insp	All Connections OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AF	213	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations Counter AL	213	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations This Read Vac	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Base Voltage AL	120.9	VAC
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Base Voltage AF	120.9	VAC
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	LTC Output Voltage Level	120.9	VAC
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	LTC Operation Checked?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	70	"F
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	9 Month Operations	1	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps C Ø	134.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	All Connections OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	LTC Operation Checked?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	LTC Output Voltage Level	0	VAC
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Base Voltage AF	0	VAC
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Base Voltage AL	0	VAC
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Eyewash Solution	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	General Comments		
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps B Ø	.1	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps A Ø	.6	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	256	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Switching Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AL	255	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AF	255	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Maintenance Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps C Ph V	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps C Ø	160.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps B Ø	180.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps A Ø	180.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty C Ph V	4.82	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty B Ph V	4.82	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty A Ph V	6.42	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps B Ø	210.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps A Ø	154.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	General Comments		
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10748	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	oil level low alarm found isolated. "needs oil"	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Found Counter	74267	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Left Counter	74267	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	9 Month Operations	0	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	nitro cyl at 0 psi needs refilling.	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Present	21	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Max	35	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Present	20	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Max	35	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1750	psi
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.8	psi
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations A Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Max	39	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Present	25	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Max	39	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Present	22	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	Ground Lights	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	134.6	VDC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	134.6	VDC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BCH001481	Charger	158-Battery Charger 1	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.800	millivolts
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps C Ø	26.0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	67.2	VDC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	67.1	VDC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BAT001550	Battery	158-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations Counter AF	175	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations Counter AL	175	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Switching Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Unknown Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	9 Month Operations	4	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty A Ph V	4.99	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty B Ph V	4.49	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty C Ph V	6.98	%
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps C Ø	240	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps B Ø	240	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Amps A Ø	240	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2558	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Switching Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations This Read Vac	1	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AL	465	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AF	465	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Maintenance Operations	0	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Amps C Ø	155.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Amps B Ø	147.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Amps A Ø	153.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	9 Month Operations	1	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Switching Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations This Read AM	2	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AL	1416	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AF	1416	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Maintenance Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	General Comments	CO-1192 C Phase IOC	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Unknown Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations Ground	0	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Unknown Operations	0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Switching Operations	0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations This Read Vac	0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AL	189	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AF	189	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Maintenance Operations	0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps B Ø	100.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations A Ø	1	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	9 Month Operations	14	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	9 Month Operations	3	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty A Ph V	2.36	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty B Ph V	3.54	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty C Ph V	.88	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps A Ø	100.0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Operations Since Last Insp	937	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Max Tap Position	3L	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Left Counter	66710	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Found Counter	66702	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations Ground	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	9 Month Operations	6	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps A Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps B Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	Need size info and qty
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations B Ø	0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations C Ø	0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations Ground	0	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps A Ø	26.0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Unknown Operations	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Switching Operations	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations This Read Vac	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AL	1661	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AF	1661	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Maintenance Operations	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations Ground	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Operations A Ø	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Maintenance Operations	3	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AF	742	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AL	742	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations This Read Vac	5	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Switching Operations	2	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Unknown Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Unknown Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Switching Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Operations Counter AL	170	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Operations Counter AF	170	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK001403	BreakerVacuum	158-0662	VCB Readings	Fault Operations A Ø	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Amps C Ø	120.0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Amps B Ø	120.0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Amps A Ø	120.0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	9 Month Operations	4	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Maintenance Operations	0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AF	246	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AL	246	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations This Read Vac	0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Switching Operations	0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations A Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations Ground	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations This Read Vac	4	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AL	190	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AF	190	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Maintenance Operations	3	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Maintenance Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AF	175	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AL	175	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Switching Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Installed winter filter blanks. Center light is not working	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Left Counter	123281	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Found Counter	123281	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	LTC Totalizer Reading	9580.80	kw
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Max	38	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Present	28	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Reading	.9980	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Max	25	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Present	18	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	467	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Unknown Operations	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Switching Operations	1	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Operations Counter AF	661	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Maintenance Operations	5	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations Ground	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Fault Operations A Ø	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations Ground	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Operations A Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations Ground	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	General Comments	CO-1196 C Phase IOC	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Maintenance Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AF	149	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AL	149	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations This Read Vac	1	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Switching Operations	0	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3013.92	kw
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Operations Since Last Insp	414	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations Ground	0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Unknown Operations	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Switching Operations	2	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations This Read Vac	3	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AL	180	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Operations Counter AF	180	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Regulator As Left Counter	89741	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AL	202	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AF	202	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Maintenance Operations	6	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	9 Month Operations	1	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	.71	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps A Ø	111.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps B Ø	116.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps C Ø	118.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps C Ø	260.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps B Ø	250.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps A Ø	250.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty C Ph V	4.82	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty B Ph V	18.47	%
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps C Ø	860.0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps B Ø	880.0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps A Ø	865.0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty A Ph V	15.26	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Left Counter	12252	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Found Counter	12249	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	9 Month Operations	7	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	9 Month Operations	8	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations This Read Vac	7	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Switching Operations	1	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	9 Month Operations	4	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	All Connections OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	LTC Operation Checked?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	LTC Output Voltage Level	125	VAC
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCCControl	716-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps B Ø	7.1	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps A Ø	7.7	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	9 Month Operations	1	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Ambient Temp	23	*F
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Found Counter	65528	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Left Counter	65532	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Current Tap Position	1L	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Max Tap Position	3R	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Min Tap Position	5L	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Operations Since Last Insp	328	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Unknown Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Switching Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AL	96	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AF	96	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations C Ø	0	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AF	787	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Maintenance Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations Ground	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations C Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations B Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations A Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps C Ø	200.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps B Ø	180.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps A Ø	200.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty C Ph AM	8.43	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty A Ph AM	4.82	%
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34317	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	9 Months Operations	13	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Unknown Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Switching Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AL	128	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AF	128	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps C Ø	5.1	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	9 Months Operations	1	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps A Ø	0.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps B Ø	0.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps C Ø	0.0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	LTC Totalizer Reading	22824	kw
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Reading	.951	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Max	55	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Winding Temp Present	45	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps C Ø	18.2	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps B Ø	26.5	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps A Ø	26.2	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	9 Month Operations	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.800	millivolts
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	General Comments	oil temp guage will not reset	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AF	186	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AL	186	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Switching Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Unknown Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Unknown Operations	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Operations Counter	0	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	General Comments		
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps C Ø	2.9	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps B Ø	3.2	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps A Ø	2.8	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Switching Operations	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Regulator As Left Counter	123762	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Foundation Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	9 Month Operations	1	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps A Ø	320.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps B Ø	375.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps C Ø	320.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	General Comments		
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Regulator As Left Counter	851663	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3057.60	kw
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6370	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Switching Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations This Read AM	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AL	787	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations This Read Vac	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AL	427	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AF	427	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Maintenance Operations	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations Ground	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations A Ø	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps C Ø	180.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps B Ø	180.0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps A Ø	180.0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	9 Month Operations	22	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Max	30	°C
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	LTC Totalizer Reading	8242.56	kw
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	All Connections OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	LTC Operation Checked?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Time Delay	60	Seconds
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	LTC Operation Checked?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Time Delay	60	Seconds
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AF	54	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AL	54	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Switching Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	9 Months Operations	3	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps A Ø	300.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps B Ø	280.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps C Ø	280.0	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps C Ø	0.0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps B Ø	43.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps A Ø	72.0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	9 Month Operations	2	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	LTC Totalizer Reading	5145.60	kw
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Max	35	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Present	18	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Reading	.5360	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Max	25	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Present	20	°C
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps C Ø	0.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Reading	.8586	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps C Ø	130.0	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps B Ø	120.0	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps A Ø	122.0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	9 Month Operations	19	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps A Ø	160	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps B Ø	180	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps C Ø	180	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations A Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations Ground	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Maintenance Operations	12	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AF	381	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AL	381	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations This Read Vac	14	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Switching Operations	2	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Unknown Operations	0	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Tank Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Grounds in Place?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	General Comments		
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BTS-6	VCB Readings	Unknown Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Maintenance Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AF	553	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AL	553	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations This Read AM	1	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Switching Operations	1	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.3	VDC
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	23	*F
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BAT001477	Battery	369-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	BCH001411	Charger	369-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Operations Counter	20	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	General Comments	Barbed wire needs replaced	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	9 Month Operations	18	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps A Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps B Ø	0	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Amps C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B80394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B80394	BreakerVacuum	716-0107	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B80394	BreakerVacuum	716-0107	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B80394	BreakerVacuum	716-0107	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	LTC Totalizer Reading	0	kw
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Oil Temp Max	30	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Oil Temp Present	0	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Totalizer Meter Reading	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Max	30	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	Winding Temp Present	0	°C
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations A Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations B Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations C Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations Ground	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Maintenance Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AF	8320	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AL	832	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations This Read AM	1	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Switching Operations	1	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Regulator As Left Counter	424336	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	General Comments		
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	General Comments		
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Swept?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Trash Emptied?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations B Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations C Ø	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Fault Operations Ground	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Maintenance Operations	17	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AF	867	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations Counter AL	867	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Operations This Read Vac	18	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Switching Operations	1	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	BB0394	BreakerVacuum	716-0107	VCB Readings	Unknown Operations	0	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushing Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/24/2022 17:05	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Reading	1.3152	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Present	34	°C
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Max	64	°C
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	LTC Totalizer Reading	6312.96	kw
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	General Comments	nitrogen at 0	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	2	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Operations Counter	0	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	806	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	806	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments	OK	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Operation Checked?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	General Comments		
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	Follow-up Action Required?	n	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	All Connections OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	General Comments	No yard light at this station	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Vegetation	None	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Left Counter	25920	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Found Counter	25920	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Present	10	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	12	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	46	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	12	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	46	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	13	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	47	°C
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusting	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	460	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/6/2022 14:12	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Ambient Temp	23	*F
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Unknown Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Switching Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations This Read Vac	1	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AL	71	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AF	71	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations Ground	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations C Ø	1	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations A Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps C Ø	16.7	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps B Ø	20.6	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps A Ø	21.5	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	9 Month Operations	2	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.5	VDC
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.5	VDC
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	General Comments		
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/6/2022 10:19	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	9 Month Operations	1	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps A Ø	150.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps B Ø	137.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps C Ø	131.0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Regulator As Left Counter	92590	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	General Comments		
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	General Comments		
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Found Counter	13897	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Left Counter	13897	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Regulator As Left Counter	107497	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	n	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/6/2022 14:22	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	General Comments	Trees have been removed	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	96.48	kw
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Max	52	°C
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0804	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	General Comments		
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	General Comments		
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps A Ø	.3	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps B Ø	.2	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps C Ø	.3	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	General Comments		
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:57	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Grounds in Place?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Maintenance Operations	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AF	206	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AL	206	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations This Read Vac	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Tank Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Unknown Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
1/6/2022 13:48	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	General Comments		
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/6/2022 11:36	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:58	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	General Comments		
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	General Comments		
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/6/2022 11:59	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Follow-up Action Required?	n	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations Ground	0	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	General Comments		
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations C Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations B Ø	0	
1/6/2022 13:05	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations A Ø	0	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/6/2022 10:47	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Maintenance Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AF	278	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AL	278	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Switching Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	9 Month Operations	6	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps A Ø	33.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps B Ø	50.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps C Ø	33.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps A Ø	160.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps B Ø	205.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	9 Month Operations	18	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps C Ø	155.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Unknown Operations	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Unknown Operations	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Unknown Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Switching Operations	1	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations This Read Vac	1	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AL	356	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AF	356	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Maintenance Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	9 Month Operations	11	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps C Ø	97.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps B Ø	108.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps A Ø	86.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps A Ø	98.0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps B Ø	109.0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps C Ø	114.0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	*C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Max	20	*C
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	*C
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	9 Month Operations	21	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Vent fan not working	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	*C
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	*C
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Maintenance Operations	15	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AF	362	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AL	362	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations This Read Vac	17	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Switching Operations	2	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps B Ø	129.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps A Ø	105.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	9 Months Operations	4	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Unknown Operations	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Switching Operations	1	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations This Read Vac	1	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AL	189	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AF	189	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Maintenance Operations	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	General Comments	One switching op during storm outage.	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations Ground	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations C Ø	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations B Ø	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations A Ø	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	525	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	521	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	28	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.6	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.8	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps C Ø	6.8	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	General Comments	ok	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Operations Counter	797	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps C Ø	140.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps B Ø	190.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps A Ø	180.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty B Ph AM	7.47	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99994	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99994	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	9 Months Operations	1	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps C Ø	104.0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps B Ø	110.0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps A Ø	87.0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	9 Month Operations	2	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	350.0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	350.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	350.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations Ground	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	Need size info and qty
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	General Comments	Trees hitting barbed wire and barbed wire is broken. Pic sent to Stinson	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations A Ø	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Maintenance Operations	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Operations Since Last Insp	437	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Min Tap Position	12L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Current Tap Position	6L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC As Left Counter	263205	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Unknown Operations	0	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	81	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps A Ø	3.3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps B Ø	3.2	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps C Ø	4.5	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	92	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	462	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC As Found Counter	263205	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Unknown Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Switching Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations This Read AM	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AL	486	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AF	486	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Maintenance Operations	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AF	380	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AL	380	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Switching Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	General Comments		
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Regulator As Left Counter	100292	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	22.3	VDC
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusty and drooping in areas.	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	*C
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	*C
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	3	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	3	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	283	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	283	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Switching Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AL	304	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Operations Counter AF	304	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Maintenance Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps C Ø	321.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps B Ø	334.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Amps A Ø	329.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	9 Month Operations	11	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	9 Month Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps A Ø	0.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps B Ø	0.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps C Ø	0.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	General Comments	Brush growing into fence in front of breaker at lower station	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Unknown Operations	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Maintenance Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AF	1167	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AL	1167	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Switching Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Unknown Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	General Comments	Under frequency has been disabled	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations B Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	General Comments		
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/10/2022 10:49	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	General Comments		
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	General Comments	Could use additional wildlife protection in bus.	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps C Ø	111.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Oil Temp Max	50	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Unknown Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Switching Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations This Read AM	1	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AL	1216	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AF	1216	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	General Comments	Fabric is rusty and barb wire.	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations C Ø	1	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Switching Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Unknown Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	56.5	VDC
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	56.5	VDC
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.7	If no, which cells in comments
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.0	VDC
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	62	*F
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Regulator As Left Counter	128054	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AF	683	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AL	683	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Maintenance Operations	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AF	273	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AL	273	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations This Read Vac	1	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations This Read AM	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Switching Operations	1	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Unknown Operations	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	9 Months Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps A Ø	73.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps B Ø	55.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps C Ø	66.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	9 Month Operations	2	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps A Ø	100.0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps B Ø	100.0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps C Ø	100.0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations A Ø	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations B Ø	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations C Ø	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations Ground	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	General Comments	One switching op during storm outage.	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1128	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Unknown Operations	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	General Comments	Needs wildlife protection in bus.	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5832	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	General Comments	Low oil	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	General Comments	ok	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1399.68	kw
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	9 Month Operations	2	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps A Ø	75.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps B Ø	70.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps C Ø	75.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Maintenance Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AF	188	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AL	188	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations This Read Vac	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Switching Operations	0	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	67.68	kw
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Oil Temp Present	24	°C
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AL	222	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Switching Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Unknown Operations	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	9 Month Operations	6	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps A Ø	23.0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps B Ø	43.0	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3088.80	kw
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps C Ø	39.0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Oil Temp Max	46	°C
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps A Ø	155.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps B Ø	145.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps C Ø	140.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4290	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	General Comments	ok	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	9 Month Operations	4	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	9 Month Operations	2	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps A Ø	0.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps B Ø	0.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps C Ø	0.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Maintenance Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AF	222	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps A Ø	0.0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps B Ø	0.0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps C Ø	0.0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations A Ø	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations B Ø	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations C Ø	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations Ground	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	General Comments	BFTC	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Maintenance Operations	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AF	263	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AL	264	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations This Read Vac	1	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Switching Operations	1	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	297	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	297	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps A Ø	100.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps B Ø	110.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps C Ø	120.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Maintenance Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AF	673	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AL	673	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	165.0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CVVT Visible Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	General Comments	barbed wire rusty	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	General Comments	Will not go into EQ	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	General Comments	Multiple insulators have chipped and broken skirts above transformers	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.400	millivolts
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	49.8	VDC
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	9 Month Operations	14	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps B Ø	19.5	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps C Ø	23.5	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	87	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	94	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	60	°C
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	410.00	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Reading	.8376	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	679	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Max	52	°C
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	LTC Totalizer Reading	4020.48	kw
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	310	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	153.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	180.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Switching Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AL	99968	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AF	99968	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps C Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps B Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps A Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	9 Months Operations	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5424	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3905.28	kw
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	General Comments	OK	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	105	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.6	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Switching Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Unknown Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Operations Since Last Insp	330	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Min Tap Position	9L	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Current Tap Position	3L	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Left Counter	10983	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Found Counter	10983	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	9 Month Operations	1	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps A Ø	125.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps B Ø	145.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps C Ø	185.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Present	20	°C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Max	30	°C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Reading	.3690	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Max	30	°C
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Maintenance Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AF	151	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AL	151	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations This Read Vac	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Switching Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Unknown Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	9 Month Operations	3	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps A Ø	0.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps B Ø	0.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps C Ø	0.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Fault Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Ambient Temperature	45	*F
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Maintenance Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AF	185	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AL	185	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations This Read Vac	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	All Connections OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	22	*C
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	*C
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	210.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	813.60	kw
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	General Comments	found at negative 1.7, added to positive 1.5	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	General Comments		
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Present	28	°C
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments	No longer in station. Has been removed.	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	LTC Totalizer Reading	5313.60	kw
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Maintenance Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AF	159	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AL	159	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations This Read Vac	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Switching Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Unknown Operations	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.6780	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations Ground	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Maintenance Operations	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AF	288	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AL	288	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations This Read Vac	3	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Switching Operations	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Unknown Operations	2	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	0.0	VDC
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	0.0	VDC
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Maintenance Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AF	276	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AL	276	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations This Read AM	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Switching Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Unknown Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	9 Month Operations	2	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps A Ø	60.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps B Ø	95.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps C Ø	110.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Unknown Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Maintenance Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AF	151	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Switching Operations	1	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations This Read Vac	1	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Maintenance Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AF	195	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AL	195	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations This Read Vac	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Switching Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Unknown Operations	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations A Ø	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations B Ø	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations C Ø	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Fault Operations Ground	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Maintenance Operations	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AF	513	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations Counter AL	514	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Operations This Read Vac	1	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Switching Operations	1	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Months Operations	2	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty A Ph AM	8.54	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty B Ph AM	2.14	%
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Unknown Operations	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	9 Month Operations	6	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps A Ø	62.0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps B Ø	48.0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps C Ø	32.0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps A Phase V	15.11	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps B Phase V	15.11	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps C Phase V	22.66	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations A Ø	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations B Ø	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations C Ø	1	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations Ground	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	General Comments	1 51C, 1 51N, 2 unknown ops	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	General Comments	ok	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps A Ø	180.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps B Ø	190.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps C Ø	140.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	General Comments	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	9 Month Operations	2	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	114	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	15	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps A Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Left Counter	258272	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Found Counter	258272	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps B Ø	0.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps C Ø	0.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PF001296	PowerFuse	CB-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PF001296	PowerFuse	CB-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PF001297	PowerFuse	CB-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PF001297	PowerFuse	CB-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Maintenance Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AF	196	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AL	196	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations This Read Vac	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Ambient Temperature	45	*F
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Switching Operations	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations This Read SF6	0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AL	66	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AF	66	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Num Operations Last 9 Months	1	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Maintenance Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Switching Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Unknown Operations	0	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Present	28	*C
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Max	48	*C
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Trash Emptied?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	17	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	39	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	9 Month Operations	1	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps A Ø	90.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps B Ø	100.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps C Ø	90.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Maintenance Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AF	81	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AL	81	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	General Comments		
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps C Ø	55.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps B Ø	80.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps A Ø	70.0	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	9 Month Operations	3	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	726	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	726	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Ambient Temp	45	°F
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Unknown Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Switching Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AL	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AF	296	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Maintenance Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Max	37	°C
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	General Comments	Needs new nitro gauge	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	573.12	kw
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Present	15	°C
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AL	433	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AF	433	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps C Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps B Ø	0.0	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	CO205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	CO205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	CO205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	CO205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps A Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	9 Months Operations	0	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	CO205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	CO205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	CO205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4776	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	9 Month Operations	3	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps A Ø	170.0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps B Ø	130.0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps C Ø	120.0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	25.0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	25.0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	25.0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	General Comments		
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations A Ø	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations B Ø	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations C Ø	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations Ground	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AF	196	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AL	196	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations This Read Vac	1	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Switching Operations	1	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Unknown Operations	0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Operations Since Last Insp	912	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Max Tap Position	7R	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Left Counter	440274	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Found Counter	440270	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps A Phase V	10.52	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations A Ø	1	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations B Ø	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations C Ø	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations Ground	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Maintenance Operations	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AF	198	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AL	198	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations This Read Vac	1	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Switching Operations	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Unknown Operations	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	9 Month Operations	3	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps A Ø	30.0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	42	°C
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps B Ø	25.0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps C Ø	20.0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	All Connections OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Operations Since Last Insp	319	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Min Tap Position	3L	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Max Tap Position	12R	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Current Tap Position	3R	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Left Counter	295763	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Found Counter	295757	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	General Comments	Tap gauge leaking	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.6	VDC
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.6	VDC
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	If no, which cells in comments
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Unknown Operations	0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Switching Operations	4	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations This Read Vac	4	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AL	740	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AF	736	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Maintenance Operations	0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.8	VDC
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.8	VDC
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	8.800	millivolts
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Maintenance Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AF	362	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AL	362	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Switching Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	General Comments	corner of foundation next to house is crumbling, multiple insulators are cracked and chipped in the steel	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Operations Since Last Insp	755	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Min Tap Position	14L	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Max Tap Position	1R	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Current Tap Position	6L	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Left Counter	18585	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Found Counter	5120	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	General Comments	adjusted the as found counter since LTC control was replaced in December 2021	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	294	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	6L	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4R	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	2R	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	48845	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	48845	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps A Ø	142.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps B Ø	118.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps C Ø	153.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations B Ø	1	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	General Comments		IOC B Phase
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AF	984	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AL	984	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations This Read AM	1	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Switching Operations	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Unknown Operations	0	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	General Comments		Whole station needs wildlife protection.
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	9 Month Operations	12	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		Meter wouldnt read ac ripple

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	9 Month Operations	17	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps A Ø	211.0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps B Ø	168.0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps C Ø	212.0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Maintenance Operations	15	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AF	219	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AL	219	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations This Read Vac	16	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Switching Operations	1	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Unknown Operations	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps C Ø	100.0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps B Ø	100.0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps A Ø	100.0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	9 Month Operations	10	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.700	millivolts
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	9 Months Operations	4	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	264	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	264	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Max	57	°C
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2839.68	kw
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.0	psi
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Unknown Operations	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Switching Operations	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations This Read Vac	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AL	99943	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AF	99943	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Maintenance Operations	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Follow-up Action Required?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations Ground	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations C Ø	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations B Ø	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations A Ø	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	All Connections OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5916	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	General Comments	ok	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	General Comments	ok	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	General Comments	Fiberglass is exposed on two xfmr fuses. Metering equip needs additional wildlife protection and so does bus.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	499	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	499	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	9 Month Operations	4	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps A Ø	70.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps B Ø	90.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps C Ø	90.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps C Ø	160.0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps B Ø	130.0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps A Ø	100.0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	9 Month Operations	2	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	General Comments	Top rail is rusty and fabric	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 12:25	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Unknown Operations	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Switching Operations	1	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations This Read Vac	2	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AL	216	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AF	216	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Maintenance Operations	1	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	General Comments	ok	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	General Comments	1 switching op for tornado, 1 trip check	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps C Ø	40.0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps B Ø	40.0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps A Ø	25.0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Unknown Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Switching Operations	0	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Oil Level	Low	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Regulator As Left Counter	208097	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps B Ø	76.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Operations Counter	940	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	9 Month Operations	1	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps A Ø	106.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps B Ø	86.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps C Ø	74.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations A Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations B Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations C Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations Ground	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Maintenance Operations	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AF	215	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AL	215	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations This Read Vac	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Switching Operations	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Unknown Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	773	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	773	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AL	355	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Operations Counter AF	355	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Maintenance Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps C Ø	225.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps B Ø	190.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps A Ø	220.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	9 Month Operations	2	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	22	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Regulator As Left Counter	134790	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Unknown Operations	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Switching Operations	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations This Read Vac	1	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AL	165	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AF	165	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	General Comments	1 51C T op	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations Ground	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations C Ø	1	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations B Ø	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations A Ø	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps C Ø	138.0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps B Ø	102.0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps A Ø	108.0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	9 Month Operations	6	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	General Comments	BFTC	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Maintenance Operations	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AF	322	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AL	323	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations This Read Vac	1	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Switching Operations	1	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Unknown Operations	0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps A Ø	94.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps B Ø	67.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps C Ø	106.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Operations Counter	103	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Max Tap Position	11R	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32245	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	General Comments	ok	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	General Comments	One switching op during tornado outage. One trip check.	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Maintenance Operations	1	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AF	357	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AL	357	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations This Read Vac	2	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Switching Operations	1	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Unknown Operations	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	9 Month Operations	3	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps A Ø	65.0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps B Ø	70.0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps C Ø	65.0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations C Ø	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations Ground	0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Regulator As Left Counter	133249	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps C Ø	420.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps B Ø	400.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Amps A Ø	410.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	9 Month Operations	1	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Unknown Operations	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Switching Operations	1	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations This Read Vac	2	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AL	197	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AF	197	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Maintenance Operations	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	General Comments	1 switching op for tornado, 1 CG T op	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations C Ø	1	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Max	52	°C
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	30	°C
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	70	°C
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Unknown Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Switching Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AL	186	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AF	186	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Maintenance Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Regulator As Left Counter	149447	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Current Tap Position	5L	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	9 Month Operations	2	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Max Tap Position	2L	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Reading	.7300	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Max	51	°C
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps C Ø	14.0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps B Ø	15.0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps A Ø	8.0	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	1752.00	kw
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	9 Month Operations	3	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Current Tap Position	4L	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Regulator As Left Counter	152701	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Oil Temp Present	70	°C
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6892.80	kw
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	142091	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	12R	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0290	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Present	47	°C
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps A Ø	22.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps B Ø	16.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps C Ø	19.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Left Counter	608353	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Found Counter	60353	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	9 Month Operations	1	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps A Ø	345.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps B Ø	420.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps C Ø	400.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Maintenance Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AF	174	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AL	174	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Switching Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Unknown Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AL	336	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Operations Counter	39	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	General Comments		
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50873	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Operations Since Last Insp	682	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Min Tap Position	6L	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Max Tap Position	4R	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Current Tap Position	2R	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Left Counter	65019	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Found Counter	65019	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Operations Since Last Insp	301	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Min Tap Position	6L	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Max Tap Position	2R	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Maintenance Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AF	504	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AL	504	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations This Read AM	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Switching Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Unknown Operations	0	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	237	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Left Counter	201286	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Found Counter	201286	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Regulator As Left Counter	167278	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	588	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Left Counter	112680	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Regulator As Left Counter	97809	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Max Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Found Counter	112680	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Operations Since Last Insp	808	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Max Tap Position	3R	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Left Counter	256624	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Found Counter	256615	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Maintenance Operations	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AF	204	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AL	204	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations This Read Vac	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Switching Operations	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Unknown Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Present	30	°C
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Max	60	°C
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Reading	.8010	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Present	25	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Max	25	°C
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	LTC Totalizer Reading	11534.40	kw
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Regulator As Left Counter	208712	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	9 Month Operations	2	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps A Ø	120.0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps B Ø	84.0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps C Ø	84.0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations A Ø	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations B Ø	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations C Ø	0	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations Ground	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Max Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Regulator As Left Counter	29923	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	9 Month Operations	14	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps A Ø	0.0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps B Ø	0.0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps C Ø	0.0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations A Ø	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations B Ø	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations C Ø	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations Ground	0	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6696	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2142.72	kw
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 14:39	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Left Counter	529306	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Found Counter	529300	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Unknown Operations	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Switching Operations	1	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations This Read Vac	1	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AL	168	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AF	168	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Maintenance Operations	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	General Comments	1 op for tornado outage	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AF	336	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	General Comments	no spare fuses	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Operations Since Last Insp	173	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Min Tap Position	5L	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Max Tap Position	3R	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1094.40	kw
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps C Ø	56.0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps B Ø	21.0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps A Ø	42.0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	9 Month Operations	2	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9120	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59084	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Regulator As Left Counter	47051	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	60	°C
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	All Connections OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45333	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	9 Month Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps A Ø	425.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps B Ø	425.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps C Ø	425.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Maintenance Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AF	223	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AL	223	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Switching Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Unknown Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Regulator As Left Counter	45082	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Oil Temp Present	10	*C
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Oil Temp Max	30	*C
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Present	22	*C
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Max	50	*C
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Regulator As Left Counter	131327	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	9 Month Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Regulator As Left Counter	126650	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Regulator As Left Counter	71296	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.6	VDC
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.8	VDC
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	3.2	VDC
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.6	VDC
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps A Ø	120.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps B Ø	120.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps C Ø	120.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Maintenance Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AF	387	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AL	387	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Switching Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Unknown Operations	0	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	General Comments	Needs new nitro gauge	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	25	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Max Tap Position	16R	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32754	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Unknown Operations	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Switching Operations	1	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations This Read Vac	1	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AL	338	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AF	337	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Maintenance Operations	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	General Comments		
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations Ground	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations C Ø	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	General Comments		
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Operations Counter	16	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps C Ø	72.0	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
1/5/2022 10:08	Distribution	Clinton 12KV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps A Ø	88.0	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Reading	.3198	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Present	50	°C
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Max	30	°C
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	LTC Totalizer Reading	2302.56	kw
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.7	amps
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AF	326	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AL	326	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations A Ø	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps C Ø	360.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	All Connections OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	All Connections OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	14R	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	317278	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Operations Counter	100	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	General Comments		
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps A Ø	37.0	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps C Ø	24.0	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	892.08	kw
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4956	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	General Comments	Containment berm is washed out behind xfmr.	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	No longer in station. Has been removed.	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3302	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9577.44	kw
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps C Ø	135.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps B Ø	110.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps A Ø	115.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps B Ø	0.0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps C Ø	0.0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations A Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations B Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations C Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations Ground	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Maintenance Operations	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations Counter AF	177	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations Counter AL	178	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations This Read Vac	1	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Switching Operations	1	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Unknown Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Unknown Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Switching Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AL	400	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AF	400	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Maintenance Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations A Ø	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations Ground	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Follow-up Action Required?	n	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	General Comments		
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Maintenance Operations	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AF	171	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AL	171	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Switching Operations	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Unknown Operations	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Reading	.4110	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Present	50	°C
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Max	58	°C
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	LTC Totalizer Reading	2959.20	kw
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	9 Month Operations	5	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	9 Month Operations	2	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps A Ø	9.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps B Ø	9.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps C Ø	17.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations A Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations B Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations C Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations Ground	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Maintenance Operations	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AF	162	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AL	162	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations This Read Vac	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Switching Operations	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Unknown Operations	0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	9 Month Operations	5	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps A Ø	20.0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps B Ø	30.0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps C Ø	20.0	
1/5/2022 10:08	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Unknown Operations	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Present	32	°C
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2726	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Max	31	°C
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4581.36	kw
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	General Comments	ok	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Regulator As Left Counter	160431	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	14R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	181093	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps A Ø	138.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps B Ø	115.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps C Ø	129.0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Maintenance Operations	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AF	99980	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AL	99980	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Switching Operations	0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	General Comments	ok	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 11:54	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	9 Month Operations	2	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps A Ø	0.0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Vegetation	None	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 12:41	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Max	20	*C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Reading	.5570	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Present	20	*C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Max	20	*C
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	LTC Totalizer Reading	8020.80	kw
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Found Counter	23890	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Left Counter	23890	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	General Comments		
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Current Tap Position	2R	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BCH001452	Charger	794-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	General Comments	ok	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	*F
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	BAT001526	Battery	794-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Unknown Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Switching Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations This Read AM	3	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AL	410	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AF	410	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Maintenance Operations	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations Ground	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations C Ø	1	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations B Ø	1	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations A Ø	1	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps C Phase AM	9.55	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Present	20	*C
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Regulator As Left Counter	198	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Regulator As Left Counter	120220	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps C Ø	30.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps A Ø	55.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps B Ø	45.0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty C Ph AM	6.4	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty B Ph AM	7.47	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty A Ph AM	7.47	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Months Operations	5	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Reading	.7100	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Present	5	°C
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Max	5	°C
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	268	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 8:57	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	LTC Totalizer Reading	6816.00	kw
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Regulator As Left Counter	52230	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	General Comments		
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Regulator As Left Counter	58431	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Reading	.4428	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Max	52	°C
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100.00	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	2125.44	kw
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	General Comments		
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:00	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Present	35	°C
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Max	35	°C
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Reading	.7030	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Present	30	°C
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Max	30	°C
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	LTC Totalizer Reading	12654.00	kw
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Min Tap Position	16L	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Max Tap Position	8R	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	General Comments	needs guage reset yes or no to report	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations C Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Unknown Operations	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Switching Operations	1	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations This Read Vac	1	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations Counter AL	218	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations Counter AF	217	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Regulator As Left Counter	33405	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BAT001543	Battery	848-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Maintenance Operations	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	General Comments		
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	General Comments		
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	155	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32486	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.9	VDC
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.9	VDC
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations Ground	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations C Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations B Ø	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations Ground	0	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	12R	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	9 Month Operations	2	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Found Counter	536930	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Left Counter	536930	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps C Ø	12.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps B Ø	23.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps A Ø	37.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	9 Month Operations	0	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 11:19	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	All Connections OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	All Connections OK?	y	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	390	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations C Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations B Ø	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations A Ø	0	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Max Tap Position	11R	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps A Ø	181.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps B Ø	194.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps C Ø	192.0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	General Comments		
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps C Ø	160.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps B Ø	125.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps A Ø	120.0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	LTC Totalizer Reading	2764.80	kw
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Unknown Operations	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Oil Temp Present	40	°C
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Reading	1.1520	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	9 Month Operations	2	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps A Ø	18.0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps B Ø	37.0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations C Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations Ground	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Maintenance Operations	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AF	179	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AL	179	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations This Read Vac	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Switching Operations	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Unknown Operations	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps C Ø	37.0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Regulator As Left Counter	17178	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	9 Month Operations	2	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations A Ø	0	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 16:11	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Max Tap Position	16R	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	General Comments	vines growing from the abandoned sub, getting closer to the bus work	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	688	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	1 op because of storm	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Vegetation	Light	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	41.0	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	29.6	
1/5/2022 11:25	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.5	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	General Comments		
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Maintenance Operations	0	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	79454	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AF	206	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AL	206	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations This Read Vac	1	
1/10/2022 8:55	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Switching Operations	1	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:57	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations A Ø	0	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCCControl	CY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCCControl	CY-TRANS 1	LTC Control Insp	General Comments		
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCCControl	CY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations A Ø	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations B Ø	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations C Ø	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations Ground	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Follow-up Action Required?	n	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Max	49	°C
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	122.4	VAC
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Maintenance Operations	0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Operations Counter	1835	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	General Comments		
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Found Counter	69589	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Left Counter	69589	
1/5/2022 13:01	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	9 Month Operations	2	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	LTCC000944	LTCControl	846-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	All Connections OK?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	General Comments		
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps A Ø	65.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
1/5/2022 9:16	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
1/5/2022 13:46	Distribution	West Hickman Quarterly Inspection	LTCC000933	LTCControl	507-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps C Ø	59.0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps B Ø	64.0	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps A Ø	61.0	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	General Comments		
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Regulator As Left Counter	264956	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 13:22	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AF	236	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.1	VDC
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.7	VDC
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Max	58	*C
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Present	30	*C
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	General Comments		
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	Follow-up Action Required?	n	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	All Connections OK?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Maintenance Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	General Comments		
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 9:48	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 13:34	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 10:57	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	General Comments		
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	13R	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 13:33	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	281719	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Unknown Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Switching Operations	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations This Read Vac	0	
1/5/2022 10:15	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AL	236	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
1/5/2022 10:40	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations Counter AF	181	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations Counter AL	182	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Switching Operations	1	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 14:01	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	General Comments	ok	
1/5/2022 8:29	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 10:29	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 11:10	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Unknown Operations	0	
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 12:50	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	949	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	949	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	848	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	848	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0355	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0353	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	264	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	264	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	600.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	600.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	600.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	60.4	VDC
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	65.5	VDC
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps B Ø	46.0	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps A Ø	36.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps C Ø	60.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps B Ø	55.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps A Ø	70.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	9 Month Operations	2	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	9 Month Operations	4	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps A Ø	62.0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps B Ø	53.0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	All Connections OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps C Ø	70.0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Present	40	°C
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Max	75	°C
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	LTC Totalizer Reading	19440	kw
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Unknown Operations	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Switching Operations	1	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations This Read Vac	1	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AL	221	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2040.96	kw
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Max	38	°C
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6378	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Maintenance Operations	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Present	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Max	85	°C
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Reading	1.08	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations	2	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AF	290	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AL	294	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations This Read Vac	4	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Switching Operations	4	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Unknown Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Unknown Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Switching Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AL	184	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AF	184	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps C Ø	120.0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps B Ø	90.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Maintenance Operations	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps A Ø	130.0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	9 Month Operations	13	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.8	VDC
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.8	VDC
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AF	220	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Maintenance Operations	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	44	°F
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.5	VDC
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.3	VDC
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps C Ø	198.0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps B Ø	180.0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps A Ø	184.0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations Counter AF	182	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations Counter AL	183	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Operations This Read Vac	1	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Switching Operations	1	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Unknown Operations	0	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Reading	1.1520	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Regulator As Left Counter	482578	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Regulator As Left Counter	380690	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	General Comments		
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	General Comments	added 2 pounds nitrogen	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	LTC Totalizer Reading	5529.60	kw
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Max	56	°C
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	9 Month Operations	2	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps A Ø	195.0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps B Ø	153.0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Amps C Ø	141.0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations A Ø	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations B Ø	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations C Ø	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Fault Operations Ground	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001766	BreakerVacuum	784-0209	VCB Readings	Maintenance Operations	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Reading	.8530	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations A Ø	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations B Ø	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations C Ø	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Fault Operations Ground	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Maintenance Operations	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations Counter AF	166	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations Counter AL	167	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Operations This Read Vac	1	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Switching Operations	1	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Unknown Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Present	29	°C
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Max	49	°C
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	LTC Totalizer Reading	4094.40	kw
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Regulator As Left Counter	48724	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	9 Month Operations	41	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps A Ø	29.0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps B Ø	33.0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Readings	Amps C Ø	10.0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001767	BreakerVacuum	784-2210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations Ground	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Maintenance Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AF	619	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AL	619	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations This Read AM	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Switching Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Unknown Operations	0	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AF	240	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Maintenance Operations	5	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps C Ø	179	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps B Ø	182	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps A Ø	141	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty C Ph V	4.94	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty B Ph V	4.94	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty A Ph V	5.93	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	9 Month Operations	13	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	9 Months Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps A Ø	40.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps B Ø	40.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps C Ø	50.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations B Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations C Ø	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Vegetation	None	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Ambient Temp	28	°F
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Present	10	°C
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Operations Since Last Insp	464	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Min Tap Position	3L	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Max Tap Position	11R	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Current Tap Position	1R	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Left Counter	25361	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Found Counter	24359	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Broom on Site?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Trash Emptied?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Regulator As Left Counter	117367	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	General Comments	ok	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Min Tap Position	4R	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	267	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	267	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BAT001604	Battery	529-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	58.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	59.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	57.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Regulator As Left Counter	34136	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	70	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	70	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	General Comments	added 1 pound of nitrogen	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	25	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	849.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	810.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	714.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Regulator As Left Counter	42220	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	1245.0	volts
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28240	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	General Comments	Need Enhanced Wildlife protection	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Trash Emptied?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	950	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	230.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	250.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments	Actual counter	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	390	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	390	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations This Read Vac	25	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	25	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Present	16	°C
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Max	16	°C
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	LTC Totalizer Reading	4832.64	kw
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Max	50	°C
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Present	30	°C
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	LTC Totalizer Reading	3448	kw
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Present	16	°C
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Max	30	°C
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Reading	.5034	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps C Ø	380	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps B Ø	380	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps A Ø	340	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	9 Months Operations	11	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps A Ø	80.0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps B Ø	75.0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps C Ø	75.0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations B Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations C Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations Ground	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Maintenance Operations	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AF	280	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AL	280	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations This Read AM	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Switching Operations	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Unknown Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	9 Month Operations	5	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	9 Month Operations	2	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps A Ø	274.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps B Ø	250.0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.5	VDC
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Reading	.431	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Unknown Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Switching Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AL	546	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AF	546	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Maintenance Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps C Ø	65.0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps B Ø	70.0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps A Ø	70.0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	9 Month Operations	2	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Unknown Operations	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Switching Operations	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations This Read Vac	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AL	241	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AF	241	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Maintenance Operations	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Present	25	°C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Max	40	°C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	LTC Totalizer Reading	14040.00	kw
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Min Tap Position	11L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Max Tap Position	3R	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Regulator As Left Counter	50629	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	*F
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations	4	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	9 Month Operations	3	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations A Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations B Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations C Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations Ground	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty A Ph V	5.79	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty B Ph V	3.86	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty C Ph V	3.86	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps A Ø	218	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps B Ø	212	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps C Ø	235	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Maintenance Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AF	274	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AL	275	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations This Read Vac	1	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Switching Operations	1	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Unknown Operations	0	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	9 Month Operations	2	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Switching Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AL	156	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AF	156	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps C Ø	0.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps B Ø	0.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps A Ø	0.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps A Ø	92.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps B Ø	82.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps C Ø	100.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Unknown Operations	0	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	9 Month Operations	9	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Unknown Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Switching Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations This Read Vac	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AL	190	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AF	190	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Maintenance Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps B Ø	835.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps B Ø	850.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps C Ø	855.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps C Ø	263.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	All Connections OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCControl	717-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations B Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations C Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations Ground	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Maintenance Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AF	349	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AL	350	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations This Read Vac	1	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Switching Operations	1	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Unknown Operations	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Switching Operations	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations This Read AM	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AL	328	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AF	328	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Maintenance Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	9 Month Operations	1	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Maintenance Operations	7	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AF	143	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AL	152	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations This Read Vac	9	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Switching Operations	2	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Unknown Operations	0	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations Ground	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations C Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations B Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps C Ø	240.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps B Ø	280.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps A Ø	300.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Maintenance Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AF	297	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AL	297	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations This Read AM	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Switching Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Unknown Operations	0	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	General Comments	Counter not working	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Found Counter	3300	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Left Counter	3300	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Current Tap Position	10L	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Max Tap Position	5L	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Min Tap Position	15L	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Unknown Operations	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Switching Operations	2	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations This Read Vac	2	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AL	248	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AF	246	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Found Counter	51737	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Left Counter	51740	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Max Tap Position	4R	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Min Tap Position	6L	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Operations Since Last Insp	405	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	9 Months Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps A Ø	50.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps B Ø	20.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps C Ø	50.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations B Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations C Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations Ground	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations Ground	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations C Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations B Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps C Ø	200.0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps B Ø	190.0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps A Ø	200.0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	9 Months Operations	8	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations C Ø	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations B Ø	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations A Ø	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps C Ø	85	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps B Ø	47	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps A Ø	24	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty C Ph V	2.89	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Found Counter	31951	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Left Counter	31954	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Current Tap Position	6L	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Max Tap Position	4L	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Maintenance Operations	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	LTC Totalizer Reading	8530.56	kw
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Max	40	°C
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Present	26	°C
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Reading	.8886	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Unknown Operations	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Switching Operations	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations This Read AM	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AL	320	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AF	320	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Maintenance Operations	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Max	33	°C
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	General Comments		
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	General Comments	Tornado	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Maintenance Operations	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AF	214	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AL	214	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations This Read Vac	3	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Switching Operations	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Unknown Operations	0	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	9 Month Operations	4	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps C Phase V	3.94	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations C Ø	3	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations Ground	0	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Operations Counter	41	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps A Ø	13.0	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps B Ø	9.0	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	General Comments	28/25.5 BFTC	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Operations Counter	18	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Present	10	°C
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Left Counter	172244	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Found Counter	172240	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Found Counter	126181	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Left Counter	126181	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Current Tap Position	6L	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Max Tap Position	3L	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Min Tap Position	13L	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Operations Since Last Insp	509	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Max	39	°C
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	General Comments		
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps A Ø	36.0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps B Ø	37.0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps C Ø	29.0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps B Phase V	3.94	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations B Ø	3	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	General Comments	Tornado	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Maintenance Operations	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AF	189	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AL	189	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations This Read Vac	3	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Switching Operations	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Unknown Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Operations Since Last Insp	244	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Min Tap Position	5L	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Max Tap Position	2R	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2426.40	kw
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3370	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46378	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	9912.96	kw
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Max	37	°C
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Present	32	°C
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0326	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Max	42	°C
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Present	40	°C
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps C Ø	440	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps B Ø	440	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps A Ø	380	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	9 Month Operations	5	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Present	25	°C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Max	40	°C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Reading	.5850	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Operations Since Last Insp	268	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Min Tap Position	9L	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Current Tap Position	1L	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Left Counter	29876	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Found Counter	29876	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Unknown Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Switching Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AL	85	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AF	85	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Maintenance Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Found Counter	163032	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Left Counter	163032	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Current Tap Position	4L	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Max Tap Position	2L	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Min Tap Position	12L	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Operations Since Last Insp	436	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	9 Month Operations	20	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps A Ø	120.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps B Ø	120.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Amps C Ø	120.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Grounds in Place?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PT000854	PT	ML-12KV TR 3 POT	PT Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Min Tap Position	13L	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Operations Since Last Insp	288	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	30	*F
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty B Ph V	2.89	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty A Ph V	2.89	%
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	9 Month Operations	6	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Found Counter	160131	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Left Counter	160131	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Current Tap Position	6L	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Max Tap Position	5L	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Min Tap Position	15L	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Operations Since Last Insp	336	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	107702	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0876	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Operations Counter	12	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations This Read Vac	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	383	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	383	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	69.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	109.0	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Ambient Temp	41	°F
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	B ∅ Operations Counter	235	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps C ∅	0.0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps B ∅	0.0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps A ∅	0.0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	A ∅ Operations Counter	201	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps A ∅	130.0	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps B ∅	174.0	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps C ∅	139.0	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	General Comments		
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Max	53	°C
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3019.68	kw
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	General Comments	Needs new psi guage	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	210.24	kw
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8388	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Present	18	°C
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Vegetation	None	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Regulator As Left Counter	64343	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Max	55	*C
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Present	25	*C
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Max	52	*C
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Present	35	*C
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Switching Operations	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	9 Month Operations	1	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps A Ø	55.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps B Ø	160.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps C Ø	76.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations A Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations B Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations C Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations Ground	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Unknown Operations	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Switching Operations	2	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations This Read Vac	17	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	General Comments	2 small washouts under fence. One to the left of gate entrance and one in back	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Operations Counter	183	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	General Comments		
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	114.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	2	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Months Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps A Ø	814.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps B Ø	815.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps C Ø	884.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AF	577	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AL	577	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations This Read AM	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	General Comments		
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	107.5	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	100	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps C Ø	0.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps B Ø	0.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps A Ø	0.0	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	General Comments	Vegetation needs cut back around fence	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AL	281	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	General Comments	Small washout under fence behind xfms.	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AF	281	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Maintenance Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps B Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps C Ø	348	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps B Ø	354	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps A Ø	349	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty B Ph V	2.11	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty A Ph V	10.55	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	9 Month Operations	17	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Operations Counter	17	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	General Comments		
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	9 Months Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps A Ø	50.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps B Ø	50.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps C Ø	40.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations B Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations C Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations Ground	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	9 Month Operations	3	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	580	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	580	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Unknown Operations	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Switching Operations	2	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations This Read Vac	9	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AL	232	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AF	232	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Maintenance Operations	7	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AF	1242.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Found Counter	81379	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Left Counter	81379	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Time Delay	60	Seconds
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	1	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6L	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Max Tap Position	3L	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Min Tap Position	10L	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	228	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	260.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	210.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	194.0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Unknown Operations	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Switching Operations	4	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations This Read Vac	4	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AL	221	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AF	217	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Maintenance Operations	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps C Ø	10.0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps B Ø	10.0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps A Ø	10.0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	9 Month Operations	14	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	All Connections OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Present	16	°C
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Max	32	°C
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	140.00	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Ambient Temp	25	°F
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Unknown Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Switching Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.0	VDC
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Negative DC Ground	24.0	VDC
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	31	°F
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	All Connections OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	General Comments		
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCControl	883-1	LTC Control Insp	VRR Time Delay	40	Seconds
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Instal/Remove?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	All Connections OK?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	All Connections OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	General Comments		
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/11/2022 9:32	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	194	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	General Comments		
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	LTC Totalizer Reading	1585.44	kw
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Max	46	°C
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Present	27	°C
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Reading	.2202	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps C Ø	45.0	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps C Ø	182	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps B Ø	198	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps A Ø	218	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty C Ph V	.99	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty B Ph V	2.96	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty A Ph V	2.96	%
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Vegetation	None	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	4	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Maintenance Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AF	327	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AL	327	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations This Read AM	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Switching Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Unknown Operations	0	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Unknown Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	282.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	263.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	244.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	416	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	416	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Switching Operations	2	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations This Read Vac	7	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AL	202	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AF	202	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Maintenance Operations	5	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	General Comments	fence connected onsite	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	235.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	235.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	242.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	81	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	81	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations This Read AM	1	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	1	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Ambient Temp	28	*F
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	9 Month Operations	9	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Ambient Temp	24	*F
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	28	*F
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	LTC Totalizer Reading	5935.68	kw
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Max	40	°C
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Present	32	°C
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Regulator As Left Counter	11043	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	107	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1R	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Left Counter	426985	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Found Counter	426985	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Positive DC Ground	8.2	VDC
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Negative DC Ground	8.4	VDC
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT001613	Battery	421-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Reading	.7450	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Regulator As Left Counter	51876	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Min Tap Position	4R	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Max Tap Position	10L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Current Tap Position	1L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Reading	.6183	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	LTC Totalizer Reading	4470.00	kw
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Max	60	°C
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Present	25	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	9 Month Operations	7	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12843	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	9 Month Operations	10	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps A Ø	180.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps B Ø	200.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps C Ø	190.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Maintenance Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AF	193	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AL	193	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations This Read Vac	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Switching Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Unknown Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Switching Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations This Read Vac	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations Counter AL	155	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Operations Counter AF	155	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Maintenance Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations Ground	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations C Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations B Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Operations A Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps C Ø	67.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps B Ø	19.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Amps A Ø	45.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	28	°F
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT001525	Battery	764-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Regulator As Left Counter	68064	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH001451	Charger	764-Battery Charger	Battery Charger Patrol Insp	General Comments	.8 A	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Maintenance Operations	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AF	406	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AL	410	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations This Read Vac	4	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Switching Operations	4	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Unknown Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps A Ø	20.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps B Ø	20.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps C Ø	20.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations A Ø	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations B Ø	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations C Ø	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations Ground	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Maintenance Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AF	663	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AL	663	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations This Read Vac	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Switching Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Unknown Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations C Ø	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations B Ø	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations A Ø	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps C Phase V	13.43	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Operations Counter	88	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12709	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	General Comments	open/BFTC	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	9 Month Operations	5	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Unknown Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Switching Operations	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations This Read Vac	4	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AL	216	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AF	216	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Maintenance Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Unknown Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Switching Operations	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations This Read Vac	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AL	197	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AF	197	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Maintenance Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps C Ø	245.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps B Ø	280.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps A Ø	300.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	9 Month Operations	3	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Unknown Operations	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Switching Operations	2	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations This Read Vac	7	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AL	240	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps B Phase V	13.43	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps A Phase V	13.43	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps C Ø	190.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps B Ø	135.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps A Ø	150.0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	9 Month Operations	6	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5112	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Present	14	°C
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	155.00	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	160.00	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	306.72	kw
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Present	40	*C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Max	60	*C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Reading	1.0200	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Present	35	*C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Max	60	*C
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	9 Month Operations	2	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps A Ø	240.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps B Ø	220.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps C Ø	255.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Maintenance Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations Counter AF	170	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations Counter AL	170	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Switching Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	LTC Totalizer Reading	18360.00	kw
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Present	25	*C
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Max	40	*C
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Reading	.6930	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Multiplier	14440	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Present	25	°C
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Max	40	°C
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	LTC Totalizer Reading	10006.92	kw
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AF	194	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Maintenance Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps C Ø	200.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps B Ø	180.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps A Ø	140.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	9 Month Operations	3	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps A Ø	250.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps B Ø	280.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps C Ø	240.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Maintenance Operations	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AF	512	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AL	516	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations This Read Vac	4	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Switching Operations	4	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Unknown Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Unknown Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Switching Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AL	194	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps C Ø	240	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps B Ø	240	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps A Ø	240	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty C Ph V	6.91	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty B Ph V	3.95	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty A Ph V	1.98	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	9 Month Operations	16	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	LTC Totalizer Reading	22914.00	kw
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Oil Temp Present	45	°C
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Unknown Operations	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Switching Operations	2	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations This Read Vac	8	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AL	337	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AF	337	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Maintenance Operations	6	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Maintenance Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AF	169	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AL	169	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations This Read Vac	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Switching Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Unknown Operations	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	All Connections OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AL	308	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AF	308	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Maintenance Operations	15	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps C Ø	259	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps B Ø	185	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps A Ø	114	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	9 Month Operations	25	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	27	*F
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Time Delay	60	Seconds
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0740	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Unknown Operations	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Switching Operations	2	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations This Read Vac	2	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AL	245	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AF	243	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Maintenance Operations	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	9 Month Operations	11	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	General Comments		
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	General Comments	Nitro guage broke	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	644.40	kw
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 11:28	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Regulator As Left Counter	122180	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Min Tap Position	5R	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	All Connections OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Ambient Temp	29	*F
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	79	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	56	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	24.5	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	.4	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	52	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations B Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations A Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps C Ø	202.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps B Ø	249.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Amps A Ø	236.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	9 Month Operations	4	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Regulator As Left Counter	31287	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Maintenance Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	9 Month Operations	2	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps A Ø	400.0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps B Ø	420.0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps C Ø	415.0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations Ground	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations Ground	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Fault Operations C Ø	0	
1/4/2022 9:32	Distribution	Dawson Springs 4KV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Readings	Unknown Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001584	BreakerVacuum	116-0687	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	9 Month Operations	1	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps A Ø	180.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps B Ø	183.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps C Ø	183.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations A Ø	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations B Ø	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations C Ø	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations Ground	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Maintenance Operations	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AF	241	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AL	241	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations This Read Vac	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Switching Operations	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Unknown Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	318	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	318	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations This Read AM	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Present	15	°C
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps C Ø	335.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps B Ø	260.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps A Ø	320.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Reading	1.2730	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Max	70	°C
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Present	50	°C
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	146.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	110.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	185.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Maintenance Operations	0	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AF	182	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AL	182	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations This Read Vac	4	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Switching Operations	0	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Unknown Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Readings	Switching Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BK001585	BreakerVacuum	116-0688	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Switching Operations	1	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Unknown Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	1	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	1	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	352	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	352	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	2	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Found Counter	502525	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Left Counter	502525	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	227	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	60	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	60	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	60	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	1	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations This Read AM	1	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	620	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	620	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	156.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	185.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	174.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	9	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AF	224	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AL	224	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations This Read Vac	1	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Operations Since Last Insp	204	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Min Tap Position	9L	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Max Tap Position	2L	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Current Tap Position	2L	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Left Counter	9981	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Found Counter	9981	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	48	*F
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Negative DC Ground	-66.8	VDC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Positive DC Ground	66.8	VDC
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	9 Month Operations	29	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	9 Month Operations	2	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty A Ph V	10.3	%
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty B Ph V	10.04	%
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty C Ph V	10.04	%
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps A Ø	156	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps B Ø	160	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps C Ø	162	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Amps A Ø	215	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Amps B Ø	360	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Amps C Ø	235	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Current Tap Position	9R	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Found Counter	492216	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Left Counter	492216	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	214	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Max Tap Position	9R	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Regulator As Left Counter	22876	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R1541	Regulator	448-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Unknown Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Switching Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations This Read Vac	4	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AL	717	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AF	717	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Maintenance Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations Ground	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations C Ø	2	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations B Ø	2	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations A Ø	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps C Phase V	6.09	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps B Phase V	6.09	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps C Ø	100.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps B Ø	120.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps A Ø	60.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	9 Month Operations	11	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Maintenance Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AF	664	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AL	668	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations This Read Vac	4	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Switching Operations	4	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Unknown Operations	0	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Regulator As Left Counter	60664	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Operations A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Amps C Ø	245	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Amps B Ø	275	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Amps A Ø	281	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	9 Month Operations	16	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.0	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Operations Counter	41	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Reading	.6300	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Max Tap Position	7L	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps A Ø	80.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps B Ø	80.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps C Ø	90.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AF	220	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AL	220	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations This Read Vac	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Switching Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Unknown Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	9 Month Operations	8	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps A Ø	60.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps B Ø	60.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps C Ø	60.0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Fault Operations Ground	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations A Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations B Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations C Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations Ground	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	9 Months Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps A Ø	60.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps B Ø	100.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps C Ø	80.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations B Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations C Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations Ground	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134	VDC
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134	VDC
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Maintenance Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AF	525	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AL	525	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations This Read AM	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Switching Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Unknown Operations	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	9 Month Operations	4	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps A Ø	165.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps B Ø	155.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps C Ø	150.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	LTC Totalizer Reading	5040.00	kw
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	General Comments	Switch gear heater is cycling	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	6	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	795	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	795	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	7	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Maintenance Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations Counter AF	169	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations Counter AL	169	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Switching Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Unknown Operations	0	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Min Tap Position	2L	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Max Tap Position	5L	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Left Counter	14044	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Found Counter	14037	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Reading	.5720	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	General Comments		
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Found Counter	283491	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Left Counter	283501	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Current Tap Position	9L	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Max Tap Position	5L	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Operations Since Last Insp	646	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	45	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	10	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Max	35	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Present	15	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	10	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	10	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	20	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	20	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	30	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	30	°C
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Maintenance Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AF	675	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AL	680	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations This Read Vac	5	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Switching Operations	5	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Unknown Operations	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Negative DC Ground	-27.9	VDC
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Current Tap Position	1L	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Max Tap Position	1L	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Min Tap Position	9L	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Operations Since Last Insp	317	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Ambient Temperature	38	°F
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Reading	.4480	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	LTC Totalizer Reading	3584.00	kw
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Fault Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	General Comments	upper fence post washing out, large tree limbs growing into station over fence	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Found Counter	32704	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Left Counter	32708	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Current Tap Position	6L	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Max Tap Position	4L	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Min Tap Position	12L	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Operations Since Last Insp	347	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Found Counter	116058	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Left Counter	116058	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	9 Month Operations	10	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps A Ø	10.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps B Ø	10.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps C Ø	10.0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations A Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations B Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations C Ø	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations Ground	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Follow-up Action Required?	n	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Found Counter	10651	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Left Counter	10660	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Current Tap Position	5L	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Min Tap Position	9L	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Operations Since Last Insp	652	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	All Connections OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	VRR Base Voltage AF	125.1	VAC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	VRR Base Voltage AL	125.1	VAC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	LTCC000947	LTCControl	116-6	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.500	millivolts
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps A Ø	390.0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps B Ø	490.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps C Ø	380.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations A Ø	2	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations B Ø	0	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations C Ø	0	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations Ground	0	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Found Counter	216985	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Left Counter	216990	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Current Tap Position	4L	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Max Tap Position	2R	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Min Tap Position	13L	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Operations Since Last Insp	838	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Maintenance Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Operations Counter AF	174	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Operations Counter AL	174	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Switching Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001825	BreakerVacuum	028-0004	VCB Readings	Unknown Operations	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Unknown Operations	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Switching Operations	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations This Read Vac	1	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations Counter AL	188	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations Counter AF	188	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Maintenance Operations	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	General Comments	Tornado	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Operations Since Last Insp	375	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	9 Month Operations	9	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations A Ø	1	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps A Phase V	1.93	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps C Ø	35.0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps B Ø	42.0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps A Ø	31.0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	9 Month Operations	3	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps A Phase V	4.83	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Max	45	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Present	30	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	62	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	40	°C
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Present	45	°C
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Max	65	°C
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	62	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	40	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	55	°C
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	36	°C
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	LTC Totalizer Reading	7648	kw
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Found Counter	16254	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Left Counter	16254	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Current Tap Position	2L	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Max Tap Position	1L	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Min Tap Position	10L	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Operations Since Last Insp	257	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Follow-up Action Required?	n	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	General Comments		
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	General Comments	Two fault operations from tornado. Not sure what targets dropped.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Maintenance Operations	0	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	All Connections OK?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	General Comments		
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AF	124.3	VAC
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 11:01	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Time Delay	60	Seconds
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AF	191	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AL	191	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations This Read Vac	2	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Switching Operations	0	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:19	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Unknown Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Reading	.956	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Operations Counter	2336	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	9 Months Operations	2	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps A Ø	100.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps B Ø	50.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps C Ø	70.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations B Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations C Ø	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations Ground	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps A Ø	0.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Maintenance Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AF	379	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AL	379	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations This Read AM	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Switching Operations	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Unknown Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps B Ø	0.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps C Ø	0.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Operations Counter	15	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Regulator As Left Counter	308019	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Operations Since Last Insp	742	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Min Tap Position	5L	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Max Tap Position	5R	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Left Counter	31737	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Found Counter	31727	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Current Tap Position	11R	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	13.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	9 Month Operations	2	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	General Comments	28.4/25.9	BFTC
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PF001299	PowerFuse	CT-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Present	35	°C
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Max	45	°C
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Reading	.836	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Unknown Operations	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Switching Operations	2	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Operations This Read Vac	9	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Operations Counter AL	167	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Operations Counter AF	167	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Maintenance Operations	7	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Operations A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Amps C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Amps B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Amps A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Unknown Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Switching Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations This Read Vac	1	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AL	240	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Operations Counter AF	240	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Maintenance Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations Ground	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations C Ø	1	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations B Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Operations A Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps C Ø	102.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps B Ø	91.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Amps A Ø	101.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Readings	9 Month Operations	8	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PF001298	PowerFuse	CT-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Max Tap Position	16R	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Min Tap Position	3R	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55430	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCCControl	060-5	LTC Control Insp	All Connections OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCCControl	060-5	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCCControl	060-5	LTC Control Insp	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCCControl	060-5	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCCControl	060-5	LTC Control Insp	LTC Output Voltage Level	124	VAC
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCCControl	060-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCCControl	060-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCCControl	060-5	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PF001290	PowerFuse	CK-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	PF001290	PowerFuse	CK-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	All Connections OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Switching Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations This Read SF6	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AL	48	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	LTC Output Voltage Level	124	VAC
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AF	124	VAC
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Base Voltage AL	124	VAC
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCControl	060-6	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AF	48	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Num Operations Last 9 Months	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	General Comments	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Fault Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Ambient Temperature	38	*F
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Operations Since Last Insp	315	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.0	psi
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Min Tap Position	10L	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Max Tap Position	1L	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Left Counter	29290	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Found Counter	29290	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R0996	Regulator	764-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Regulator As Left Counter	47669	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1285.92	kw
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Max	35	*C
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Present	20	*C
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Regulator As Left Counter	345740	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Operations Counter	294	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0716	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Regulator As Left Counter	156731	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Regulator As Left Counter	23970	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	General Comments	Drag hands do not work	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Min Tap Position	2L	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Regulator As Left Counter	40404	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Present	40	°C
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Max	55	°C
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	LTC Totalizer Reading	3981.60	kw
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	General Comments		
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Switching Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Unknown Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	9 Month Operations	2	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTC000942	LTCControl	717-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps A Ø	185.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps B Ø	250.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps C Ø	220.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations C Ø	0	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Regulator As Left Counter	92299	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AF	197	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AL	197	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations This Read Vac	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Switching Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Unknown Operations	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 13:52	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Reading	.8295	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Present	30	*C
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Max	40	*C
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4389.12	kw
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Ambient Temp	23	*F
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Unknown Operations	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Switching Operations	2	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Operations This Read Vac	16	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Operations Counter AL	164	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Operations Counter AF	164	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Readings	Maintenance Operations	14	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001806	BreakerVacuum	060-0024	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	9 Month Operations	2	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	General Comments		
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Regulator As Left Counter	124234	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4572	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 9:56	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AF	196	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AL	196	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations This Read Vac	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps C Ø	0.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps A Ø	0.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	9 Month Operations	19	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Switching Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Unknown Operations	0	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Ambient Temp	29	°F
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Regulator As Left Counter	74941	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK001287	BreakerVacuum	060-BT5-6	VCB Readings	9 Month Operations	9	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Unknown Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Switching Operations	0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Regulator As Left Counter	177630	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations This Read Vac	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AL	273	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AF	273	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Maintenance Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Present	55	°C
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Max	55	°C
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	LTC Totalizer Reading	15048	kw
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations Ground	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations C Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations B Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations A Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCCControl	717-1	LTC Control Insp	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCCControl	717-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps B Ø	450.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps C Ø	400.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCCControl	717-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCCControl	717-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCCControl	717-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AF	169	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AL	169	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations This Read Vac	0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Max Tap Position	10R	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	General Comments		
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Current Tap Position	8R	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Unknown Operations	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Switching Operations	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations This Read Vac	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations Counter AL	168	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations Counter AF	168	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Maintenance Operations	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps C Ø	7.0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps B Ø	3.0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps A Ø	2.0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	9 Month Operations	4	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	All Connections OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	9 Month Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps A Ø	400.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	LTCC000942	LTCControl	717-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Unknown Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps A Ø	44.0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	9 Month Operations	2	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Unknown Operations	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Switching Operations	1	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations This Read Vac	1	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations Counter AL	175	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations Counter AF	174	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Maintenance Operations	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	General Comments		
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Regulator As Left Counter	16117	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	General Comments		
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 12:35	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	All Connections OK?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Unknown Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Switching Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations This Read Vac	0	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AL	409	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AF	409	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Maintenance Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations Ground	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations C Ø	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations B Ø	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations A Ø	0	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps A Phase V	3.00	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations A Ø	3	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	General Comments		
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	General Comments	Tornado	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps A Ø	250.0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	9 Month Operations	4	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	49	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	49	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Maintenance Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AF	192	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AL	192	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations This Read Vac	3	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Switching Operations	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Unknown Operations	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	General Comments		
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	9 Month Operations	4	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps A Ø	75.0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps B Ø	85.0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps C Ø	87.0	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushing Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Found Counter	156789	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps C Ø	210.0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps B Ø	210.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC As Left Counter	156793	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Current Tap Position	1L	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Max Tap Position	1R	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Min Tap Position	6L	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	LTC Operations Since Last Insp	378	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Unknown Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Switching Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations Counter AL	187	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:42	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations Counter AF	187	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Maintenance Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	9 Month Operations	6	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty A Ph V	2.17	%
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty B Ph V	1.45	%
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty C Ph V	1.45	%
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps A Ø	159	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps B Ø	119	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps C Ø	114	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations A Ø	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations B Ø	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations C Ø	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations Ground	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations A Ø	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps C Ø	30.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps B Ø	75.0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.500	millivolts
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	All Connections OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	2	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Regulator As Left Counter	96062	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5718	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AL	125	VAC
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AF	125	VAC
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	85.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	95.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	105.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	General Comments	des breather	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	17	°C
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	17	°C
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations A Ø	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations B Ø	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations C Ø	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations Ground	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Maintenance Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AF	209	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AL	209	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations This Read Vac	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Switching Operations	0	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:07	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps A Ø	70.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Maintenance Operations	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AF	384	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AL	386	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations This Read Vac	2	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Switching Operations	2	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Unknown Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
1/4/2022 10:56	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Regulator As Left Counter	92424	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	9 Month Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps A Ø	120.0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps B Ø	105.0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps C Ø	115.0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	All Connections OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	9 Month Operations	3	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps A Ø	230.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	9 Month Operations	1	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations This Read Vac	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Switching Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Unknown Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Current Tap Position	1L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Max Tap Position	4R	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	9 Month Operations	8	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Regulator As Left Counter	53738	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps A Ø	180.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps B Ø	180.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps C Ø	120.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations C Ø	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations Ground	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Maintenance Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AF	209	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AL	209	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations This Read Vac	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	619	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	619	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	157.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	148.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	155.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	3	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations A Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps C Ø	240.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps B Ø	280.0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Switching Operations	2	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Unknown Operations	0	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Negative DC Ground	9.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations This Read AM	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	409	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	409	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Maintenance Operations	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AF	461	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AL	465	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations This Read Vac	4	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Maintenance Operations	9	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Switching Operations	4	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Unknown Operations	0	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AF	180	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AL	180	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations This Read Vac	11	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps A Ø	120.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Present	18	°C
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Max	30	°C
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Reading	.8028	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTC000289	LTCControl	784-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	6	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	General Comments		
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps B Ø	120.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Found Counter	21095	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Left Counter	21095	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Current Tap Position	9L	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Max Tap Position	5L	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Min Tap Position	11L	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	258	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps C Ø	120.0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations B Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations C Ø	0	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations Ground	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Unknown Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Switching Operations	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	167.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	196.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	190.0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Operations Counter AL	207	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Operations Counter AF	207	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Maintenance Operations	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps C Ø	24.0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	General Comments	added 1 gall water	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations This Read AM	1	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	1	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1372.32	kw
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps C Ø	170.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps B Ø	220.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps A Ø	190.0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	BCH001469	Charger	784-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	9 Month Operations	5	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	All Connections OK?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps B Ø	17.0	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	General Comments		
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/5/2022 5:27	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps A Ø	16.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	9 Month Operations	3	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	9 Months Operations	7	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations This Read Vac	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps A Ø	0.0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps B Ø	0.0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Amps C Ø	215	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Amps B Ø	160	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Amps A Ø	170	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	9 Month Operations	42	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	9 Month Operations	15	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps C Ø	0.0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AL	237	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AF	237	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Maintenance Operations	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations C Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps A Ø	622	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps B Ø	591	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps C Ø	587	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations B Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations A Ø	0	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations A Ø	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	General Comments		
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Present	23	°C
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Max	23	°C
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Unknown Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	BK001423	BreakerVacuum	028-0001	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	LTC Totalizer Reading	7706.88	kw
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	General Comments		
1/4/2022 15:31	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Switching Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	9 Month Operations	2	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations This Read Vac	1	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Switching Operations	1	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Unknown Operations	0	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Regulator As Left Counter	61885	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Max Tap Position	5R	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AF	67	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Num Operations Last 9 Months	0	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Maintenance Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations This Read SF6	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AL	67	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	General Comments	Gate side fence is not grounded. Every other side is just grounded in one spot.	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations B Ø	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations C Ø	0	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps C Ø	280.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	General Comments	BFTC	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Maintenance Operations	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AF	9	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AL	9	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	All Connections OK?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations A Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations C Ø	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Maintenance Operations	0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AF	93	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AL	97	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations This Read Vac	4	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Switching Operations	4	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Unknown Operations	0	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Unknown Operations	0	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps C Ø	20.0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps B Ø	20.0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps A Ø	20.0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	9 Month Operations	18	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	9 Month Operations	9	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty A Ph V	0	%
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty B Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty C Ph V	0	%
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps A Ø	836	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps B Ø	789	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps C Ø	835	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	93.0	amps
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Tank Paint Condition	Good	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	9 Month Operations	5	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps A Ø	60.0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps B Ø	60.0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps C Ø	60.0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Max Tap Position	11L	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
1/4/2022 8:58	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	General Comments		
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Min Tap Position	3R	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Regulator As Left Counter	117288	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:45	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Unknown Operations	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	General Comments		
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	General Comments		
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	9 Month Operations	11	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps A Ø	280.0	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps B Ø	280.0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Switching Operations	1	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations This Read Vac	1	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AL	1315	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AF	1315	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations Counter AF	151	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations Counter AL	152	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Maintenance Operations	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	General Comments	BFTC	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations This Read Vac	1	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Switching Operations	1	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Unknown Operations	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	General Comments		
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	LTC Operation Checked?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/4/2022 10:20	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations Ground	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations C Ø	0	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/10/2022 8:52	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27263	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	General Comments	above breaker 4427 on line side, insulator has a large chip in skirt on bottom of line side disconnect	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 12:04	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	All Connections OK?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Switching Operations	0	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 12:01	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Maintenance Operations	0	
1/4/2022 13:13	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	General Comments	2 arresters blown on cir 414 and one blown on cir 415, center bushing on transfer buss has chipped skirt	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Present	18	°C
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	General Comments		
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Max	47	°C
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps B Ø	76.0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps C Ø	60.0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations A Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations B Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations C Ø	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations Ground	0	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Follow-up Action Required?	n	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:19	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	280.29	kw
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps A Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations A Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations B Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations Ground	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Follow-up Action Required?	n	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.7382	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Unknown Operations	0	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Present	35	°C
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Max	55	°C
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	LTC Totalizer Reading	4118.40	kw
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Switching Operations	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations Counter AL	180	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 14:29	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations Counter AF	180	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Maintenance Operations	0	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	LTC Totalizer Reading	7200.00	kw
1/4/2022 13:50	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/4/2022 13:30	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	General Comments	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 10:49	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Max	50	°C
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Present	50	°C
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.9343	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Reading	1.0000	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Unknown Operations	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Switching Operations	2	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations This Read Vac	9	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AL	213	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	General Comments		
1/4/2022 14:26	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Maintenance Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AF	250	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AL	250	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations This Read Vac	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Switching Operations	0	
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AF	204	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Maintenance Operations	7	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Grounds in Place?	y	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Foundation Condition	Good	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	General Comments		
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
1/4/2022 9:32	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations Ground	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations C Ø	0	
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	General Comments		
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	General Comments		
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations B Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations A Ø	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps C Phase V	0	
1/4/2022 8:04	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps B Phase V	0	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	General Comments		
1/4/2022 11:59	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	General Comments		
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/4/2022 12:52	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Max	37	°C
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4171.68	kw
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
1/4/2022 11:28	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 12:42	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/4/2022 13:49	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	6825.60	kw
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.7110	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCC000909	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations This Read AM	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Switching Operations	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations C Ø	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations B Ø	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps C Ø	100.0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps B Ø	100.0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps A Ø	25.0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty B Ph AM	1.07	%
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty A Ph AM	1.07	%
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	9 Months Operations	29	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps C Ø	0.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps B Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Maintenance Operations	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AF	450	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AL	450	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Min Tap Position	6R	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Overall Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Found Counter	65927	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Left Counter	65927	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	991	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6976	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Maintenance Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations Counter AF	157	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Kwh Reading	78107	KwH
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	LTC Totalizer Reading	474.30	kw
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaVar Demand Meter Max	39110.00	MegaVars
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaWatt Demand Meter Max	4.52	MegaWatts
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	500	psi
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Max	35	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Present	30	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations Counter AL	156	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Operations This Read Vac	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Switching Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Unknown Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Amps A Ø	0.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	9 Month Operations	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations A Ø	0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1674.24	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Regulator As Left Counter	39119	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Unknown Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations Counter AF	171	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations Counter AL	171	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Operations This Read Vac	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Switching Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Ambient Temp	31	°F
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Unknown Operations	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps C Ø	160.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations C Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations Counter AF	55	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations Counter AL	55	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Found Counter	11102	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Left Counter	11102	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Current Tap Position	6L	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	31	*F
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Operations Since Last Insp	459	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	*C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	10	*C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Min Tap Position	14L	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	LTC Totalizer Reading	7641.60	kw
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Max	60	°C
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Present	40	°C
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Reading	.9552	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations Counter AF	142	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations Counter AL	142	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Kwh Reading	12988	Kwh
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	LTC Totalizer Reading	10368.00	kw
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Max	19	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Present	19	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Switching Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Unknown Operations	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations Counter AF	54	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations Counter AL	54	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	All Connections OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations C Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001598	BreakerVacuum	898-0087	VCB Readings	Maintenance Operations	0	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Ground Connections Intact?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	All Connections OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Rosettes Clean and Lubed?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Vacuum and Clean Breaker?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	9 Month Operations	3	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps A Ø	258.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps B Ø	302.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Readings	Amps C Ø	297.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001647	BreakerVacuum	BR-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Battery Charger Current	9.5	amps
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Left Float Voltage	54.4	VDC
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Found Float Voltage	54.4	VDC
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	9 Month Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps A Ø	145.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001599	BreakerVacuum	898-0088	VCB Readings	Amps B Ø	175.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Reading	.4320	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Max	19	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Present	19	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Regulator As Left Counter	13517	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	All Connections OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Bearings lubricated?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps B Ø	212.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps A Ø	248.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	9 Month Operations	14	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps C Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps B Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Amps A Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Found Counter	36768	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Left Counter	36770	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Max Tap Position	3L	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Min Tap Position	13L	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Operations Since Last Insp	274	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	9 Month Operations	7	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations This Read SF6	0	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AL	52	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AF	52	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Num Operations Last 9 Months	0	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Maintenance Operations	0	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps A Ø	132.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps B Ø	146.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Amps C Ø	156.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	9 Month Operations	5	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations Counter AL	51	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Operations Counter AF	51	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps C Ø	165.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps B Ø	145.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Amps A Ø	170.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001638	BreakerVacuum	BR-1180	VCB Readings	9 Month Operations	3	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations Counter AL	132	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Operations Counter AF	132	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001637	BreakerVacuum	BR-1176	VCB Readings	Amps C Ø	236.0	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Switching Operations	0	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2292.00	kw
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations Counter AF	50	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	All Connections OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	All Connections OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Max	15	*C
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Present	15	*C
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9550	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations Counter AL	50	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Unknown Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Fault Operations	0	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Ambient Temperature	30	*F
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	LTC Totalizer Reading	6452.16	kw
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Operations Since Last Insp	248	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	*C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	*C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Min Tap Position	14L	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Current Tap Position	5L	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Left Counter	25286	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Found Counter	25286	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Max	50	*C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Present	20	*C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Reading	.6721	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Max	55	*C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Present	20	*C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	77	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	77	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTC000611	LTCControl	459-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTC000611	LTCControl	459-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTC000611	LTCControl	459-1	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTC000611	LTCControl	459-1	LTC Control Insp	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTC000611	LTCControl	459-1	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	LTC000611	LTCControl	459-1	LTC Control Insp	All Connections OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Found Counter	20107	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Left Counter	20109	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Current Tap Position	6L	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Found Counter	25306	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps C Ø	119.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps B Ø	136.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Amps A Ø	108.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001643	BreakerVacuum	BR-1177	VCB Readings	9 Month Operations	12	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001672	BreakerVacuum	BR-14KV BUS TIE	VCB Readings	9 Month Operations	21	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations Counter AL	134	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Operations Counter AF	134	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps C Ø	149.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps B Ø	99.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Amps A Ø	139.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001639	BreakerVacuum	BR-1179	VCB Readings	9 Month Operations	4	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001671	BreakerVacuum	BR-14KV TRANSFER	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001642	BreakerVacuum	BR-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	15	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Max Tap Position	3L	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Min Tap Position	12L	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Operations Since Last Insp	256	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001644	BreakerVacuum	BR-1181	VCB Readings	9 Month Operations	6	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations Counter AL	56	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Operations Counter AF	56	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps C Ø	540.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps B Ø	448.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Amps A Ø	556.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001640	BreakerVacuum	BR-12KV TR 3	VCB Readings	9 Month Operations	3	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	400.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	360.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Min Tap Position	8L	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Operations Since Last Insp	607	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Regulator As Left Counter	186341	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Found Counter	55553	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Left Counter	5557	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Current Tap Position	6L	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Max Tap Position	4L	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Min Tap Position	12L	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Operations Since Last Insp	261	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Found Counter	48921	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Left Counter	48925	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Max Tap Position	2R	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Min Tap Position	12L	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Operations Since Last Insp	328	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC00857	LTCControl	176-5	LTC Control Insp	All Connections OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Found Counter	22878	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Left Counter	22881	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Max Tap Position	1R	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Min Tap Position	8L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	28	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	57	°C
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	12	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	35	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	25	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	54	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Vegetation	None	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AL	179	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Operations Counter AF	179	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps C Ø	231.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps B Ø	226.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Amps A Ø	236.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	9 Month Operations	5	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Found Counter	199688	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Left Counter	199688	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Current Tap Position	3L	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Max Tap Position	3R	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps C Ø	195.0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps B Ø	215.0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps A Ø	180.0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	9 Month Operations	6	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Operations Since Last Insp	343	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Present	25	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Max	70	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Regulator As Left Counter	12344	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	9 Month Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Present	30	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Max	35	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Reading	.4743	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps A Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps B Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Readings	Amps C Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001646	BreakerVacuum	BR-1183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Unknown Operations	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Switching Operations	1	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations This Read Vac	1	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AL	290	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AF	289	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Maintenance Operations	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Ambient Temp	31	°F
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations Ground	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations C Ø	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations B Ø	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations A Ø	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Maintenance Operations	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations Counter AF	17	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations Counter AL	17	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Unknown Operations	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps C Ø	167.0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps B Ø	185.0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps A Ø	176.0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	9 Month Operations	2	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Found Counter	154896	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Left Counter	154896	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Current Tap Position	2L	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Max Tap Position	4R	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Min Tap Position	9L	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Operations Since Last Insp	340	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	284	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	284	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Unknown Operations	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Switching Operations	1	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations This Read Vac	1	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AL	196	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AF	195	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	9 Month Operations	4	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps A Ø	17.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps B Ø	11.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Readings	Amps C Ø	21.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001645	BreakerVacuum	BR-1182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	LTC Totalizer Reading	9676.80	kw
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1550	psi
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Oil Temp Max	40	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Oil Temp Present	25	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Reading	.6720	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Max	40	°C
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Present	25	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PF001288	PowerFuse	BK-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PF001288	PowerFuse	BK-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panels Dusted?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Swept?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	323	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Min Tap Position	13L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Current Tap Position	10L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Left Counter	183991	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Found Counter	183991	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations C Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Maintenance Operations	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations Counter AF	227	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations Counter AL	229	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations This Read Vac	2	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Switching Operations	2	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Unknown Operations	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps C Ø	65.0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps B Ø	65.0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps A Ø	25.0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	9 Month Operations	7	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Unknown Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Unknown Operations	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Switching Operations	1	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations This Read Vac	1	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AL	212	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AF	211	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Maintenance Operations	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations Ground	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations C Ø	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations B Ø	0	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	9 Month Operations	4	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Amps A Ø	540.0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Amps B Ø	535.0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Amps C Ø	560.0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps A Ø	230.0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps B Ø	220.0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps C Ø	230.0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	LTC Totalizer Reading	2502.40	kw
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Max	45	°C
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	Totalizer Meter Reading	.7820	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	9 Month Operations	4	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps A Ø	220.0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps B Ø	230.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps C Ø	225.0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Switching Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AL	247	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AF	247	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Maintenance Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps C Ø	700.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps B Ø	800.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps A Ø	700.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	9 Month Operations	1	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	WithLTC	735-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	9 Month Operations	6	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5644.80	kw
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Present	37	°C
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5880	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps C Ø	129.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps B Ø	132.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps A Ø	134.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	9 Month Operations	5	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	840	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	840	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	721	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	721	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	LTC Totalizer Reading	6060.96	kw
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Max	40	°C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Present	15	°C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Reading	.4209	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Max	50	°C
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Present	25	°C
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations A Ø	2	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Maintenance Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations C Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Maintenance Operations	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AF	184	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AL	186	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations This Read Vac	2	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Switching Operations	2	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Unknown Operations	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Max Tap Position	11L	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Regulator As Left Counter	83738	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Leaks	None	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	9 Month Operations	6	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps C Ø	120.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps B Ø	190.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps A Ø	125.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	9 Month Operations	8	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations C Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Maintenance Operations	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations Counter AF	176	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations Counter AL	3178	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Operations This Read Vac	2	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Switching Operations	2	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001259	BreakerVacuum	875-0068	VCB Readings	Unknown Operations	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	9 Month Operations	4	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps A Ø	105.0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps B Ø	140.0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Amps C Ø	70.0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations C Ø	0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	All Lights Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps B Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps A Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps C Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps B Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps A Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	9 Month Operations	6	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Unknown Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Switching Operations	1	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations This Read Vac	1	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AL	183	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AF	183	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Maintenance Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps C Ø	375.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps B Ø	440.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps A Ø	310.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	9 Month Operations	5	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Unknown Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Switching Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AL	160	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AF	160	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Maintenance Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Max	48	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Present	21	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	58	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	22	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	56	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	22	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	57	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	22	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	All Connections OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps B Ø	424.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps A Ø	372.0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	9 Month Operations	5	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Unknown Operations	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1856.00	kw
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	142.50	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	135.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Leaks	None	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Switching Operations	0	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations This Read Oil	0	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AL	31	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AF	31	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Number of Ops last 9 Months	1	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12145	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Operational?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	All Connections OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCCControl	896-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Leaks	None	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Fault Operations	0	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	37	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	37	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001948	BreakerVacuum	BR-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Maintenance Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AF	193	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AL	193	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	2	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	420.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	425.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	450.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	*F
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	536	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	2	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	2	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Found Counter	154990	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Left Counter	154990	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Current Tap Position	1L	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Max Tap Position	1R	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Min Tap Position	9L	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Operations Since Last Insp	323	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations This Read Vac	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Switching Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Unknown Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations C Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps C Ø	360.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	536	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	General Comments		
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/3/2022 10:23	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	9 Month Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps A Ø	90.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps B Ø	85.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps C Ø	95.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AL	224	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AF	224	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AL	224	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AF	224	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Maintenance Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AF	232	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations Counter AL	232	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Switching Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps C Ø	45.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps B Ø	42.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps A Ø	44.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	9 Month Operations	14	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Maintenance Operations	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations Ground	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations C Ø	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations B Ø	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Operations A Ø	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Unknown Operations	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Switching Operations	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations This Read AM	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AL	678	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AF	678	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Maintenance Operations	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations Ground	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations C Ø	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations B Ø	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5800	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Unknown Operations	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Switching Operations	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations This Read Vac	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AL	239	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Operations Counter AF	239	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps C Ø	130.0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps B Ø	50.0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps A Ø	75.0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	9 Months Operations	2	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Ambient Temp	27	°F
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Patrol Inspection	Bushing Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps C Ø	260.0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps B Ø	250.0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Amps A Ø	300.0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	9 Month Operations	6	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Switching Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Unknown Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations This Read Vac	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AL	504	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AF	504	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations Counter AL	48	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Operations Counter AF	48	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations C Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Maintenance Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AF	510	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AL	510	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000049	PowerFuse	BR-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000046	PowerFuse	BR-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps A Ø	120.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps B Ø	140.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps C Ø	120.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Unknown Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Switching Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.3	amps
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Maintenance Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AF	254	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AL	254	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTC000496	LTCControl	BR-TRANS 4	LTC Control Insp	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LTC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	LTC Totalizer Reading	7766.40	kw
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Oil Temp Max	32	°C
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Oil Temp Present	14	°C
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Switching Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps C Ø	124.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps B Ø	107.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Amps A Ø	103.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001850	BreakerVacuum	BR-1186	VCB Readings	9 Month Operations	1	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000045	PowerFuse	BR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000044	PowerFuse	BR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000043	PowerFuse	BR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000041	PowerFuse	BR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000040	PowerFuse	BR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Maintenance Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	All Connections OK?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	30	*F
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	BAT001468	Battery	475-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	9 Month Operations	7	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps A Ø	75.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps B Ø	110.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps C Ø	75.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Maintenance Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AF	220	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AL	220	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Switching Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000050	PowerFuse	BR-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations Counter AL	77	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Operations Counter AF	77	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AF	178	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AL	178	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	9 Month Operations	3	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps A Ø	141.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps B Ø	135.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps C Ø	141.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Found Counter	43759	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AL	236	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Unknown Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Left Counter	43759	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Current Tap Position	7L	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Max Tap Position	3L	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Min Tap Position	13L	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Operations Since Last Insp	457	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps A Ø	66.0	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Operations Counter	10	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	9 Month Operations	8	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps C Ø	85.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps B Ø	85.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Amps A Ø	84.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	9 Month Operations	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AF	236	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	9 Month Operations	4	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps A Ø	25.0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps B Ø	16.0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps C Ø	5.0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations A Ø	0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations B Ø	0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations C Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Present	30	°C
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations Ground	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Max	40	°C
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Reading	.3720	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps C Ø	198.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps B Ø	195.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Amps A Ø	195.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	9 Month Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Unknown Operations	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Trash?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Operations Counter	135	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps C Ø	84.0	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps B Ø	76.0	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	9 Month Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Amps A Ø	170.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Amps B Ø	170.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Readings	Amps C Ø	145.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BK001597	BreakerVacuum	898-0079	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Present	15	*C
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Max	40	*C
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	LTC Totalizer Reading	8928.00	kw
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Maintenance Operations	0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AF	169	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AL	170	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations This Read Vac	1	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Switching Operations	1	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Vegetation	None	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps C Ø	88.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps B Ø	87.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Amps A Ø	98.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	9 Month Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps C Ø	340.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps B Ø	300.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps A Ø	240.0	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	General Comments	substation gate post on the right has been hit, post is leaning over to the left	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Grounds in Place?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	General Comments		
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Reading	.3236	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Max	30	°C
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Present	25	°C
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 13:56	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	9 Month Operations	5	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps A Ø	234.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps B Ø	222.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Amps C Ø	229.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations Ground	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations C Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations B Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations A Ø	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations Counter AL	21	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Operations Counter AF	21	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001849	BreakerVacuum	BR-1185	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Reading	.6230	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Max	55	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Present	40	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations Counter AL	19	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Operations Counter AF	19	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001848	BreakerVacuum	BR-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gates Aligned?	n	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/4/2022 7:12	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AF	141	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000713	BreakerVacuum	BR-14KV TR 1	VCB Readings	Operations Counter AL	141	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	VRR Time Delay	30	Seconds
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	LTC Operation Checked?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	LTC Totalizer Reading	14952.00	kw
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Max	50	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Present	40	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	LTCC000937	LTCControl	735-2	LTC Control Insp	All Connections OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	General Comments		
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	LTC Totalizer Reading	3672.00	kw
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Max	40	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Present	20	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Reading	.4590	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	155.00	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	9 Month Operations	10	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Leaks	None	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2614	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	9 Month Operations	6	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	All Connections OK?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	General Comments		
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Operations Counter	8	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Leaks	None	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Operations Since Last Insp	542	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Min Tap Position	9L	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Max Tap Position	2R	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Current Tap Position	1L	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Left Counter	67087	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Found Counter	67087	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	General Comments		
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:37	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Unknown Operations	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Switching Operations	1	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations This Read Vac	1	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AL	279	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AF	278	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Maintenance Operations	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	438	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Min Tap Position	16L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Max Tap Position	16R	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Left Counter	172527	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Found Counter	172527	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	59	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3	
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 13:05	Distribution	UK West Quarterly Inspection	LTCC000962	LTCControl	412-1	LTC Control Insp	VRR Time Delay	30	Seconds
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps A Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps B Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps C Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	74	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Left Counter	335752	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Found Counter	335752	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	352	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Min Tap Position	6L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Max Tap Position	Neutral	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Current Tap Position	2L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Left Counter	181716	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Found Counter	181716	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Maintenance Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AF	124	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AL	124	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations A Ø	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations A Ø	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations B Ø	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations C Ø	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations Ground	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Follow-up Action Required?	n	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Foundation Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Grounds in Place?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Maintenance Operations	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AF	188	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AL	188	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps C Ø	0.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps B Ø	0.0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps A Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps B Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps C Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations B Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Unknown Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Switching Operations	1	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations This Read Vac	1	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AL	543	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Maintenance Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AF	121	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AL	121	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AF	543	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Maintenance Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Switching Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Unknown Operations	0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps A Ø	72.0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps B Ø	89.0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps C Ø	67.0	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Present	28	°C
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Max	28	°C
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	LTC Totalizer Reading	302.40	kw
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps C Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps B Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Amps A Ø	0.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	9 Month Operations	0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps A Ø	0.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations This Read Vac	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations Counter AL	25	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Operations Counter AF	25	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	Maintenance Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001853	BreakerVacuum	BR-12KV TR 5	VCB Patrol Inspection	General Comments		
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations This Read Vac	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Switching Operations	0	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Tank Paint Condition	Good	
1/5/2022 5:28	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Unknown Operations	0	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	29	*F
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	General Comments		
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Reading	.0630	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 14:58	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	9 Month Operations	5	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps A Ø	0.0	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	LTC Totalizer Reading	16536.00	kw
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Oil Temp Max	40	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Oil Temp Present	20	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Reading	.6890	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Max	45	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Present	25	°C
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps B Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps C Ø	0.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Neighboring Fence within 6'?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCCControl	896-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	LTC Operation Checked?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	All Connections OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 12:46	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	General Comments		
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Regulator As Left Counter	40874	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations Ground	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	62	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	62	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
1/3/2022 11:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations A Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations C Ø	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations Ground	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Follow-up Action Required?	n	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	General Comments		
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Heaters (All) Functioning?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Maintenance Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AF	184	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AL	184	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations This Read Vac	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Switching Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Unknown Operations	0	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK001852	BreakerVacuum	BR-1187	VCB Readings	Switching Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	9 Month Operations	2	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps A Ø	155.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps B Ø	142.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps C Ø	152.0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations B Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations C Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	40	°C
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps C Ø	80.0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps B Ø	86.0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps A Ø	110.0	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	9 Month Operations	5	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	9 Month Operations	19	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	General Comments		
1/3/2022 14:26	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps A Ø	205.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps B Ø	260.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps C Ø	200.0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations A Ø	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Left Counter	103437	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Found Counter	103437	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 12:34	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Switching Operations	0	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Unknown Operations	0	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	General Comments		
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Present	30	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	40	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	40	°C
1/3/2022 13:09	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AL	166	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations This Read Vac	1	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Switching Operations	1	
1/3/2022 12:48	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Unknown Operations	0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	9 Month Operations	5	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps A Ø	60.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps B Ø	100.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps C Ø	60.0	
1/3/2022 14:32	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushing Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Leaks	None	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
1/3/2022 10:29	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Regulator As Left Counter	69730	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
2/2/2022 10:58	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	